Deep Multi-State Dynamic Recurrent Neural Networks Operating on Wavelet Based Neural Features for Robust Brain Machine Interfaces

Benyamin Haghi[1*], Spencer Kellis[2], Sahil Shah[1],Maitreyi Ashok[1], Luke Bashford[2], Daniel Kramer[3], Brian Lee[3], Charles Liu[3], Richard Andersen[2], and Azita Emami[1]

1. Electrical Engineering, Caltech, Pasadena, CA, USA

2. Biology and Biological Engineering, Caltech, Pasadena, CA, USA

3. Neurorestoration Center and Neurosurgery, Keck School of Medicine, USC, L.A., USA

benyamin.a.haghi@caltech.edu

NeurIPS poster session: Dec. 8 – Dec 14 2019

Applications of BMI



A Sci-Fi Becomes Reality



Implantable Wireless Medical Devices



Intra-Ocular Pressure Sensor



Injectable Glucose Sensor

External Reader



1mm x 0.5mm classifier CMOS chip for seizure prediction



ATOMS, Smart Pill

Goals

- Minimize Treatment Cost
- Low Power/Area Chip
- Robustness
- High Performance

Challenges

- Achieving High Speed Design
- Non-Stationarity of Neural Data
- Noise
- Limited Data

Deep Multi-state DRNN Architecture



$$
\begin{cases}
s_k = W_{ss}s_{k-1} + W_{sr}r_{k-1} + W_{si}u_k + W_{sf}z_k + b_s \\
r_k = \tanh(s_k) \\
h_k^{(1)} = \tanh\left(W_{h^{(1)}h^{(1)}}h_{k-1}^{(1)} + W_{h^{(1)}r}r_k + b_{h^{(1)}}\right) \\
h_k^{(i)} = \tanh\left(W_{h^{(i)}h^{(i)}}h_{k-1}^{(i)} + W_{h^{(i)}h^{(i-1)}}h_k^{(i-1)} + b_{h^{(i)}}\right) \\
\hat{y}_k = W_{yh^{(l)}}h_k^{(l)} + b_y \\
\hat{y}_k = tanh(\hat{y}_k) \quad |\hat{y}_k| > 1 \\
z_k \leftarrow \hat{y}_k \ or \ y_k \ (Scheduled\ Sampling)
\end{cases}
$$

Architecture of BMI System

- 32 year-old tetraplegic (C5-C6) human
- FDA- and IRB-approved
- Sampling Rate: 30 KHz
- Utah electrode arrays

192 Channels



AIP: Anterior Intraparietal
BA5: Broadman's Area 5

Features	Frequency Range
HWT, HFT, HPF	> 3.75KHz
TCs, LFADS	250Hz – 5KHz
MWT, MFT, MUA	234Hz – 3.75KHz
LWT, LFT, LPF	< 234HZ

Single-day Analysis with Mid-Wavelet Feature



Fig.1. Regression of different algorithms on test data from the same day 2018-04-23: true target motion (black) and reconstruction (red)

Multi-Day Performance of the Decoders



Fig.2. The DRNN operating on different features.

Multi-Day Performance of the Decoders



Fig.3. Multi-day performance of the decoders.

Multi-Day Performance of the Decoders



Fig.4. (Left) Effect of number of training days on the performance of the decoders. (Right) The DRNN operating in different training scenarios.

Summary

- Neural networks for BMI: promising
- Hardware requirements of NN: challenges toward implantable devices
- Algorithms that can translate to energy-efficient hardware
- Need to deal with significant variations and non-stationary conditions

Team Members



Azita Emami

Benyamin Haghi

Sahil Shah



Maitreyi Ashok

Spencer Kellis



Richard Andersen

Luke Bashford

Thank you!

- **Paper:**

  https://www.biorxiv.org/content/biorxiv/early/2019/08/30/710327.full.pdf

- **Codes, Poster, and Slides:**

  https://github.com/BenyaminHaghi/DRNN-NeurIPS2019

TIANQIAO & CHRISSY CHEN INSTITUTE