

Alpilla Enerji Üretim A.Ş.

Alpilla 600 MW Combined Cycle Power Plant

Positive EIA Decision: Conditions Binding the Project

Document number	ALP-OWN-ENV-001
Revision	0
Date	2026-09-09
Status	Issued for tender / contract
Confidentiality	Restricted - Contract ALP-EPC-001 parties only

	Prepared	Checked	Approved
Function	Owner's Engineer (discipline lead)	Owner's Engineer (project engineer)	Owner's Project Director
Signature / date	signed 2026-09-09	signed 2026-09-09	signed 2026-09-09

Rev	Date	Description
0	2026-09-09	Issued for tender / contract

CASE STUDY - all organisations, data and signatures are fictional.

1. Air emissions (dry, 15 % O₂, 70–100 % load unless stated)

Pollutant	Natural gas	Light diesel oil (≤ 500 h/year)
NO _x (as NO ₂)	30 mg/Nm ³	50 mg/Nm ³
CO	30 mg/Nm ³	50 mg/Nm ³
NH ₃ slip	5 mg/Nm ³	5 mg/Nm ³
SO ₂	—	10 mg/Nm ³
Dust	—	5 mg/Nm ³

- **Stack height: 65 m** (result of the approved dispersion study; the Owner's draft contract states 60 m).
- CEMS per EN 14181 with on-line reporting.

2. Water

- Cooling water temperature rise across the condenser ≤ 7 K; temperature excess ≤ 3 K at 100 m from the diffuser.
- Residual oxidant (as Cl₂) at the outfall ≤ 0.1 mg/l.
- Process and sanitary effluents treated to the Water Pollution Control Regulation sea-discharge limits.
- No discharge of brine from the SWRO at more than 5 % above ambient salinity at 50 m from the diffuser.

3. Noise

- Operation: 45 dB(A) night / 55 dB(A) day at the nearest residential receptor.
- Construction: 07:00–19:00 on weekdays and 08:00–17:00 on Saturdays for noisy works (piling, blasting, steam blowing); steam blowing requires 7 days' notice to the village and silencers.

4. Marine and ecology

- No marine works (dredging, trenching, pipe laying) between **1 May and 30 September** (fish spawning).
- Fish return system at the screens; intake velocity ≤ 0.15 m/s.
- Marine monitoring programme during construction and for 3 years of operation (Owner's obligation; the Contractor provides data).

5. Other

- Traffic: heavy vehicles avoid the village road between 07:30–09:00 and 16:00–18:00.
- Archaeological chance-find procedure applies to all excavations.