

Instruction Manual

COMPACT -RF-ADMITTANCE POINT LEVEL SWITCH

FUNCTION:

RF-Admittance Level Switch comprises of a specially designed electronics and sensing probe using DRIVEN SHIELD COAT GUARD circuit and corresponding 3-Element Probe. The Electro-mechanical combination of the COAT GUARD technique makes the system immune to the material build-up on the probe and material bridging between the probe and the hopper wall.

The unique feature of the system is that the measured signal does not flow to the hopper wall through the probe in the backward direction but flows only through the material (actual material level) to the hopper wall.

MEASURING SYSTEM:

The complete system consists of: -

The sensing probe and

The Electronic Switching unit

The sensing probe consists of three sections, (1) Measuring section, (2) Coat Guard section and (3) ground section. The Coat Guard section guards the system against the transmission of RF signal through any coating on the sensing element from the measuring section to the ground. The only available path to the ground for the RF signal is through the service material in the hopper.

PRIMARY AREA OF APPLICATION

Building industry materials, cement, sand, lime, etc

Foodstuff industry, milk powder, flour, salt, foodgrains, pharmaceutical etc

Plastic industry, powder, granular etc.

Timber industry, chemical and mining etc.

TECHNICAL SPECIFICATIONS:

SWITCHING UNIT:

Housing	Cast Aluminum, weatherproof, powder coated
	Remote Electronics or Integral
Cable entry	2 nos. for Integral Type.
Ambient temperature	0 ° C to +60° C For Electronics
Power consumption	1.8 VA
Mains Voltage	20V AC/ DC to 265V AC/DC
Output	2 sets of potential free c/o contacts rated at 5 amps, 230 V AC for non-inductive loads.

Switching delay	Continuously adjustable from 0.5 to 26 sec. probe free or Probe covered.
Safety operation (FSL/FSH)	Field selected switch over for minimum or maximum switching points.
Switch status display	Green LED shows Normal and Red LED shows Alarm Conditions. LED Arrays shows Probe Sensitivity.

COAT GUARD SENSING PROBE:

Mounting	Screwed – 1 ½” BSP (standard) Flanged (as per requirement)
Sense rod	Stainless steel
Coat Guard Shield	Stainless steel
Insulation	PTFE (standard) / CERAMIC (Optional)
Operating temperature	:100 ° C max. with insulation as PTFE (Inside vessel) for integral electronic model. :250 ° C max. with insulation as CERAMIC (Inside vessel) for integral electronic model.

INSTALLATION OF RE-ADMITTANCE SWITCH :

Mounting of the probe would depend upon its construction and may differ from application to application. Depending upon the application, the rigid Probe can be mounted vertically, either from the top or horizontally, from the hopper side.

The standard unit has screwed, 1-1/2” BSP mounting, which can be mounted laterally on the container wall at the desired level of the material to be controlled. The probe rod should be horizontally or pointed slightly downward.

For installing the probe vertically from the top, sufficient clearance (equal to the probe length minimum) should be available above the hopper top to facilitate to hoist the probe over the hopper top for insertion into the hopper.

Following precautions should be taken during installations -

The probe should not be bent or position distorted.

In case of flat strip probe, the edge of the strip should face the ground so that the strip surface remain perpendicular to the ground plane.

The shield element of the probe (standard probe) should extend at least 50 mm into the vessel. The extended probe should be mounted in such a way that it does not extend further than necessary in the vessel. (For the boot level probe the mounting socket length should not be more than 25 mm)

During filling operation, the material should not fall directly onto the probe. Otherwise protection shield should be provided over the probe.

During installation of probe with screwed mounting, turn the hexagonal mounting bush of the probe and not the housing.

SWITCHING UNIT INSTALLATION:

The standard unit has electronics integral with the probe. For remote mounting of the Switching unit, Off the probe, the housing is suitable for back panel mounting.

For wiring and connection, refer the enclosed drawing. For remote unit only the supplied THREE TERMINAL connecting cable should be used for interconnecting probe with the Switching Unit.

The Switching unit should not be mounted at the location where the ambient temperature is not more than 60° C.

Precaution should be taken to avoid fall of Sunrays on to the Switching Unit housing. In case it is not possible to avoid, a suitable Sun protection cover should be provided over the housing.

FAIL SAFE MODE SELECTION:

Depending upon the process requirement, the minimum or maximum fail-safe mode can be selected in RF-ADMITTANCE SWITCH.

In SWITCH the Relay is in energized (Relay-ON) condition. When level changes state the relay de-energizes (Relay-OFF). Thus, besides level alarm condition, the operator gets an alarm even in case of mains failure or the instrument failure. This imparts a better overall reliability of operation.

Maximum fail-safe mode means the relay de-energizes when the level exceeds the desired or when mains supply fails.

Minimum fail-safe mode means the relay de-energizes when the level drops below the desired level or when mains supply fails.

NOTE: The contacts shown in the connection drawing are for Fail Safe LOW condition. The contacts will reverse when the FS Switch is changed to HI position.

ELECTRICAL CONNECTION TO RF-ADMITTANCE SWITCH:

Please refer the connection diagram for the electrical connection. Appropriate mains voltage should be connected to the terminals of the instruments as specified. The connectors are suitable for 1.5 sq.mm cable cross section.

SETPOINT SWITCHING CALIBRATION

There is single adjustment in the Switching Unit and is accessible from the top. There are three LEDs on top of the Switching Unit. The Green LED indicates the relay is in the energized state. The red LED indicates the alarm condition and relay in de-energized state. The Sensitivity adjustment is done by **Sensitivity Selector**.

Select the Fail Safe mode.

Keep the time delay pot at minimum.

Turn the Sensitivity Knob turn clockwise will increase the sensitivity and turn Anti- clockwise will decrease the sensitivity.

Do not turn the Sensitivity Knob beyond its limits, as it would damage the same.

Hopper should be empty or the level should be more than 300 mm below the probe.

Adjust the time delay pots, as per your requirement.

CALIBRATION FOR ROPE PROBE

Set the instrument as stated in the page no 3 under heading Calibration.

The probes with flexible rope oscillate with the material movement or with inflow pressure. If the mounting of the probe is also very near to the hopper wall the oscillation brings the sensing weight of the probe very close to the hopper wall, which gives rise to false alarm even if the probe does not touch the wall.

The slight insensitive setting makes the detection stable and the sensor would respond only to the touch with the hopper wall.

This also could be eliminated if the off-time delay is set to 4-5 sec. (The timer setting has to be as per the oscillation time period.)

In this case even if the probe oscillates the time period will be less than set time and the sensor will detect the wall but the relay will not change over. This gives the trouble-free performance.

MAINTENANCE

In normal conditions the RF-ADMITTANCE SWITCH need no maintenance.

However, if the material has built up tendency, over a period of time, probe should be cleaned whenever need occurs.

Ensure that the cable glands and the housing lid are sealed to prevent ingress of moisture.

