

	INSTALLATION CHECKLIST FOR HT CABLE	IMS/FOR/PR/054
		Rev.00
		Date. 14.03.2024

Drawing / Specification No.:	
Site Location / Area:	

Sr. No.	CHECK POINTS	Status (✓) (x)			Remarks
		Yes	No	N/A	
1	Check the IR value of cable before laying				
2	Check for physical damage of the cables				
3	Check cable make, size, voltage grade, conductor & insulation type as per design/specifications				
4	Check Cable route as per drawing				
5	Check spacing between cables is as per approved drawing				
6	No twists, knots or kinks				
7	Check for proper Dressing of the cables				
8	Check that cable bending radius is as per IS standards				
9	Check the Blocks alignment & distance between blocks				
10	Adequate looping at the termination ends				
11	Check for Hume Pipes at road crossing as per drawing				
12	Check the tightness of cable terminations at connection points				
13	Check for Phase sequence identification				
14	Check for Earthing Connections provided				
15	Cable identification tags at termination ends				

Comments/ Remarks:

	Checked By	Witnessed By	Witnessed By	Witnessed By
Signature				
Name				
Date				
Company				