LINE / EQUIPMENT OPENING - ISOLATION LIST

List no.: LO-5561

Line / equipment: L-230

Unit: Gas line

Step	Valve	Action	Isolation category	Lock #
1	XV-204	CLOSE	Proved	G-1
2	XV-231	CLOSE	Non-proved	G-2

Vent / drain point: none

Hold before sign-on: 10 min

Prepared by: _____ Issued by: _____ Received by: _____