




LAKE ALBERT WATER LEVEL REFERENCE

WATER SOURCE MANAGEMENT FRAMEWORK

LAKE LEVEL POST



POST MARKER	MANAGEMENT LEVEL	LAKE LEVEL (AHD)	MAX EXTRACTION	WHAT IT MEANS	REQUIRED ACTION
3	LEVEL 1 NORMAL OPERATIONS	RL 190.25 m	1.50 ML/day	Plenty of water available.	Normal irrigation operations. Monthly monitoring.
2	LEVEL 2 INCREASED MONITORING	RL 190.05 m	1.00 ML/day	Water levels starting to decline.	Increase monitoring frequency. Review irrigation demand and usage.
1	LEVEL 3 WATER CONSERVATION PLANNING	RL 189.85 m	0.75 ML/day	Water conservation planning required.	Implement water conservation measures. Review irrigation priorities.
.....	LEVEL 4 CRITICAL WARNING	RL 189.75 m MID MARKER BETWEEN 1 & 0	0.50 ML/day	Critical warning. Prepare for potential changeover to town water.	Activate Level 4 Procedure. Notify Management and Greens Committee. Prepare town water strategy.
0	LEVEL 5 SHUTDOWN VERIFICATION	RL 189.65 m	0 ML/day NO EXTRACTION	Minimum allowable level, verification required.	Activate Level 5 Procedure. Verify level and obtain approval. Cease extraction if approved. Change over to town water.

Maximum extraction steps down as the lake falls. No extraction is permitted below RL 189.65 m AHD.

LEVEL 4 - CRITICAL WARNING

TRIGGER: WATER LEVEL REACHES MID MARKER (RL 189.75 m AHD)

- ✓ FarmBot alert received
- ✓ Superintendent verification
- ✓ Internal notification
- ✓ Forecast assessment
- ✓ Board notification
- ✓ Town water preparation

LEVEL 5 - SHUTDOWN VERIFICATION

TRIGGER: WATER LEVEL REACHES MARKER 0 (RL 189.65 m AHD)

- ✓ Verification process
- ✓ Shutdown recommendation
- ✓ Secondary approval
- ✓ Pump shutdown
- ✓ Changeover to town water
- ✓ Board notification



IMPORTANT

- Marker 0 DOES NOT automatically trigger pump shutdown. All Level 5 verification steps must be completed before extraction ceases.
- No lake extraction is permitted below RL 189.65 m AHD in accordance with WaterNSW licence conditions.

Water Access Licence WAL 33232 (Ref 40AL413687) · Water Supply Works and Use Approval 40CA413688 · Water Management Act 2000.
Extraction limits per Approval condition DK3659-00001, Murrumbidgee Unregulated River Water Sources 2012.

💧 EVERY DROP COUNTS - MONITOR, PLAN, CONSERVE.