Water Supply Service Charter

Sahyadripur Municipal Corporation

1. Service commitments

The Water Supply Department commits to supply of at least 2 hours twice daily in every ward, minimum residual pressure at the tap, and resolution of supply complaints within 48 hours.

2. Water quality

Samples are tested at least weekly at source points and monthly at consumer taps in every ward. Residual chlorine must be maintained above 0.2 mg per litre. Results are published on the corporation website.

3. Contamination response protocol

When three or more complaints about discoloured, foul-smelling or contaminated water arrive from the same locality within 48 hours, the Ward Officer must alert the Public Health Department, issue a boil-water advisory within 12 hours, arrange alternate supply by tanker and complete a pipeline inspection within 24 hours.

4. Summer demand

Water complaints increase 40 to 70 percent in April, May and June. Tanker capacity must be increased in outer wards, where piped coverage is lower than in central wards.