PID Control

Classical feedback control

John Bagterp Jørgensen

Department of Applied Mathematics and Computer Science Technical University of Denmark

02619 Model Predictive Control

Closed-loop continuous-time system in the Laplace domain

► Linear process represented by transfer function

$$Y(s) = G(s)U(s) + H(s)D(s)$$

▶ Controller

$$U(s) = C(s)E(s)$$
 $E(s) = \bar{Y}(s) - Y(s)$

► Closed-loop system

$$Y(s) = G(s)U(s) + H(s)D(s)$$

$$= G(s)C(s)E(s) + H(s)D(s)$$

$$= G(s)C(s)(\bar{Y}(s) - Y(s)) + H(s)D(s)$$

$$[I + G(s)C(s)]Y(s) = G(s)C(s)\bar{Y}(s) + H(s)D(s)$$

$$\begin{split} Y(s) &= [I + G(s)C(s)]^{-1} \, G(s)C(s)\bar{Y}(s) + [I + G(s)C(s)]^{-1} \, H(s)D(s) \\ &= G_{cl,\bar{Y}}(s)\bar{Y}(s) + G_{cl,D}(s)D(s) \end{split}$$

$$\begin{split} G_{cl,\bar{Y}}(s) &= [I + G(s)C(s)]^{-1} \, G(s)C(s) \\ G_{cl,D}(s) &= [I + G(s)C(s)]^{-1} \, H(s) \end{split}$$

Ideal PID controller

► Laplace domain

$$U(s) = C(s)E(s)$$
 $C(s) = K_c \left(1 + \frac{1}{T_i s} + T_d s\right)$

► Time domain

$$u(t) = K_c e(t) + \int_0^t \frac{K_c}{T_i} e(\tau) d\tau + K_c T_d \frac{de}{dt}(t)$$

Ideal PID controller - different parametrization Standard parametrization:

► Laplace domain

$$U(s) = C(s)E(s)$$
 $C(s) = K_c \left(1 + \frac{1}{T_i s} + T_d s\right)$

Time domain

$$u(t) = K_c e(t) + \int_0^t \frac{K_c}{T_i} e(\tau) d\tau + K_c T_d \frac{de}{dt}(t)$$

Alternative parametrization:

► Laplace domain

$$U(s) = C(s)E(s)$$
 $C(s) = K_P + K_I \frac{1}{s} + K_D s$

► Time domain

$$u(t) = K_P e(t) + \int_0^t K_I e(\tau) d\tau + K_D \frac{de}{dt}(t)$$

Parameter relation

$$K_P = K_c$$
 $K_I = \frac{K_c}{T_i}$ $K_D = K_c T_d$

► Ideal PID controller with general parametrization

$$u(t) = K_P e(t) + \int_0^t K_I e(\tau) d\tau + K_D \frac{de}{dt}(t)$$

► Practical PID controller (continuous time)

$$u(t) = K_P e(t) + \int_0^t K_I e(\tau) d\tau - K_D \frac{dy}{dt}(t)$$

▶ Discrete time equivalent practical PID controller

$$u_k = K_P e_k + \sum_{i=0}^{k-1} K_I e_i \Delta t - K_D \frac{y_k - y_{k-1}}{\Delta t}$$

Discrete time practical PID controller - implementation

► Discrete time practical PID controller

$$u_k = K_P e_k + \sum_{i=0}^{k-1} K_I e_i \Delta t - K_D \frac{y_k - y_{k-1}}{\Delta t}$$

▶ Implementation (start with k = 0, $I_0 = 0$, $y_{-1} = y_0$)

Given:
$$\bar{y}_k, y_k, y_{k-1}, I_k, K_P, K_I, K_D, \Delta t$$

$$e_k = \bar{y}_k - y_k$$

$$P_k = K_P e_k$$

$$D_k = -K_D \frac{y_k - y_{k-1}}{\Delta t}$$

$$u_k = P_k + I_k + D_k$$

$$I_{k+1} = I_k + K_I e_k \Delta t$$
Return: u_k, I_{k+1}

Remember that the above equations are for deviation variables

Discrete time practical PID controller - implementation

lacktriangle Physical variables (u_k, y_k) and deviation variables (U_k, Y_k)

$$U_k = u_k - \bar{u}_k \qquad Y_k = y_k - \bar{y}_k$$

▶ Discrete time practical PID controller - physical variables

$$u_k = \bar{u}_k + K_P e_k + \sum_{i=0}^{k-1} K_I e_i \Delta t - K_D \frac{y_k - y_{k-1}}{\Delta t}$$

▶ Implementation (start with k = 0, $I_0 = 0$, $y_{-1} = y_0$)

Given:
$$\bar{u}_k, \bar{y}_k, y_k, y_{k-1}, I_k, K_P, K_I, K_D, \Delta t$$

$$e_k = \bar{y}_k - y_k$$

$$P_k = K_P e_k$$

$$D_k = -K_D \frac{y_k - y_{k-1}}{\Delta t}$$

$$u_k = \bar{u}_k + P_k + I_k + D_k$$

$$I_{k+1} = I_k + K_I e_k \Delta t$$
Return: u_k, I_{k+1}

lacktriangle Notice that $ar u_k+I_k$ may be interpreted as an update ar u that will give ar y

Constraints and anti-windup

► Input constraints

$$u_{\min} \le u_k \le u_{\max}$$

- ► Anti-windup: Only update the integrator when the constraints are not active
- ▶ Implementation (start with k = 0, $I_0 = 0$, $y_{-1} = y_0$)

Given:
$$\bar{u}_k, \bar{y}_k, y_k, y_{k-1}, I_k, K_P, K_I, K_D, \Delta t, u_{\min}, u_{\max}$$
 $e_k = \bar{y}_k - y_k$ $P_k = K_P e_k$
$$D_k = -K_D \frac{y_k - y_{k-1}}{\Delta t}$$
 $v_k = \bar{u}_k + P_k + I_k + D_k$ if $u_{\min} < v_k < u_{\max}$ then $I_{k+1} = I_k + K_I e_k \Delta t, \quad u_k = v_k$ else $u_k = \max\{u_{\min}, \min\{u_{\max}, v_k\}\}$ Return: u_k, I_{k+1}

SISO PID