



SCHEDULE			
Symbol	Description	Symbol	Description
	TV system.		1200mm, 18W LED bare batten flourescent fitting
	Nurse call panel.		600mm, 18W LED bare batten flourescent fitting
	Nurse call.		9W LED surface mounted day light down light
	45A Cooker control unit.		8W Emergency exit sign
	Isolator switched flame-proof socket.		Mirror light
	13A twin switched socket outlet 300mm/1400mm a.f.f.l.		Chargeable Emergency light
	20A D.P switch outlet.		meter box (as specified in BoQ)
	sounder.		Loop box (as specified in BoQ)
	Fire alarm panel.		Consumer Unit
	Smoke detector		Photocell
	Break glass .		
	CCTV Camera (specified in BoQ)		
	CCTV Camera (specified in BoQ)		
	1 gang 1 way switch		
	1 gang 2 way switch		
	Intermediate switch		
	1200mm, 18W flourescent fitting with difuser		

GENERAL NOTES:

- All electrical installation shall comply with the requirement of IEE regulations .
- Internal wiring shall be carried out in PVC insulated single core cables as East African cables or approved equivalent .
- All Electrical instructions shall come from PEE .
- All conduits to be done before plaster .

REVISION HISTORY

RevID	ChID	Change Name	Date

CONSULTANT



COUNTY GOVERNMENT OF NAKURU
DEPARTMENT OF PUBLIC WORKS .
P.O BOX 2870-20100 , NAKURU

CLIENT

DEPARTMENT OF HEALTH SERVICES

PROJECT

PROPOSED CONSTRUCTION OF KIPTANGWANY
MATERNITY AT ELEMEINTAITA WARD

DRAWING TITLE

ELECTRICAL DRAWING
- POWER LAYOUT

DRAWING STATUS .

TENDERING DRAWINGS

DRAWN BY

B.B.N.

DATE .

JAN, 2024

CHECKED BY

J.W.G.

DATE

JAN, 2024

DRAWING SCALE (@ A2)

1:25, 1:50, 1:75

DRAWING NO .

REVISION

0