

FICTIONAL PROCESS ENGINEERING TRAINING CENTER

Illustrative SOP & Incident Review

Document ID	SOP-CDU-215-REV2 (Training Example)
Title	Controlled Startup Procedure for Crude Unit Feed Heater (H-215)
Facility	Crude Distillation Training Unit
Effective Date	March 5, 2025

Purpose

Fictional document for engineering training and formatting practice only.

Parameter	Value
Equipment	H-215 Crude Feed Heater
Pump	P-215A Feed Transfer Pump
Outlet Temperature	295 C
Fuel Gas Pressure	5.4 bar
High Temp Alarm	310 C
Emergency Shutoff	ESDV-215

Illustrative Procedure

- Verify permits and instrumentation.
- Complete burner purge.
- Establish circulation.
- Ignite burners sequentially.
- Increase firing gradually.
- Record operating data.

Illustrative LOTO

- Stop pump.
- Isolate power.
- Close fuel gas valves.
- Verify zero energy.

Illustrative Incident

Incident ID: TRN-2025-062

Scenario: Simulated high outlet temperature following reduced combustion airflow.

Illustrative Root Cause: Fouled combustion air filters reduced airflow.

Illustrative CAPA: Replace filters, inspect instrumentation, shorten inspection intervals, update training.

Notice

Entirely fictional. For educational use only.