Weishaupt CanApiJson / CAPI / CAN Api – Parsed telegrams:

https://github.com/BorgNumberOne/Weishaupt_CanApiJson

Weishaupt CanApiJson / Weishaupt CAPI side of a Weishaupt Gateway WEM-Modbus | **Modbus TCP side of a Weishaupt Gateway WEM-Modbus** | **RAW CanApiJson telegram**

SRC: --> requesting device: DDC
--> responding device: SYS

CM:
0x01 (1) = request reading / **GET** numeric value
0x02 (2) = **Response** reading
0x03 (3) = request writing / **SET** numeric value
0x04 (4) = **Response** writing / **ACK**nowledge
0x05 (5) = error
0x11 (17) = request string / **GETS**
0x12 (18) = **Response** string
0x13 (19) = request writing string / **SETS**
0x14 (20) = **Response** writing string / **ACK**nowledge

HEX to DEC (**OX**)

Cycle Time (in s) between DDC telegrams

Modbus TCP register on the Modbus TCP side of Weishaupt Gateway WEM-Modbus

SRC	CM	MI	MX	OX	OS	VS	VA	HEX to DEC (OX)	Cycle Time (in s)			Reg.	Registername	Funktion	Datentyp	Auflösg.	Länge	S/Cov	Aktualis.	RAW CanApiJson telegram
												7.5.1	**EM-KA**							
												0	Temperaturfühler an Anschluss T1	Kaskadengerät	Temperatur	0,1 °C	2 Bytes		m/≥60s	No "**EM-KA**" device/participant available during the research work
												1	Temperaturfühler an Anschluss T2	Kaskadengerät	Temperatur	0,1 °C	2 Bytes		m/≥60s	No "**EM-KA**" device/participant available during the research work
												2	PWM-Signal an Umwälzpumpe	Kaskadengerät	Prozent	1,00 %	1 Byte		m/≥60s	No "**EM-KA**" device/participant available during the research work
												7.5.2	**EM-Sol**							
DDC	01	04	00	2501	00	0002	00	9473	10	Sol	SOL1	20	20 Kollektortemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010400250100000200"}}}
SYS	02	04	00	2501	00	0002	8000	9473												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020400250100000028000"}}}
DDC	01	04	00	2502	00	0002	00	9474	30	Sol	SOL1	21	21 Speichertemperatur unten	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010400250200000200"}}}
SYS	02	04	00	2502	00	0002	0207	9474												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020400250200000020207"}}}
DDC	01	04	00	252b	02	0004	00	9515	60	Sol	SOL1	22 23	22, Solarertrag Gesamtzähler 23	Solarertrag	Wirkarbeit	0,01 kWh	4 Bytes		l/≥10min	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010400252b02000400"}}}
SYS	02	04	00	252b	02	0004	00000000	9515												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020400252b02000400000000"}}}
DDC	01	04	00	252a	02	0004	00	9514	30	Sol	SOL1	24 25	24, Solarertrag (heute) 25	Solarertrag	Wirkarbeit	0,01 kWh	4 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010400252a02000400"}}}
SYS	02	04	00	252a	02	0004	00000000	9514												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020400252a02000400000000"}}}
DDC	01	04	00	2529	02	0004	00	9513	60	Sol	SOL1	26 27	26, Solarertrag (Vortag) 27	Solarertrag	Wirkarbeit	0,01 kWh	4 Bytes		l/≥10min	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010400252902000400"}}}
SYS	02	04	00	2529	02	0004	00000000	9513												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020400252902000400000000"}}}
												7.5.3	**SG**							
DDC	01	02	00	2533	02	0001	00	9523	30	SG	SG1	100	100 Betriebsart Heizkreis 1 Vorgabe	1: Standby 2: Zeitprogramm 1 3: Zeitprogramm 2 4: Zeitprogramm 3 5: Sommer 6: Komfort 7: Normal 8: Absenk	Schalten		1 Byte	S	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200253302000100"}}}
SYS	02	02	00	2533	02	0001	02	9523												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200253302000102"}}}
DDC	01	02	00	2582	02	0001	00	9602	30	SG	SG1	101	101 So/Wi Umschaltung Heizkreis 1	0: Aus 1: Ein	Boolesch		1 Byte	S	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200258202000100"}}}
SYS	02	02	00	2582	02	0001	01	9602												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200258202000101"}}}
DDC	01	02	00	257e	04	0001	00	9598	30	SG	SG1	102	102 Betriebsart Heizkreis 1 aktuell	1: System Standby 2: System Sommer 3: Estrich: Funktionsheizen 4: Estrich: Belegreifheizen 5: Urlaub 6: Zeitprogramm 1 7: Zeitprogramm 2 8: Zeitprogramm 3 9: Sommer 10: Absenk 11: Normal 12: Komfort 13: Standby	Schalten		1 Byte		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200257e04000100"}}}
SYS	02	02	00	257e	04	0001	06	9598												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200257e04000106"}}}
DDC	01	02	00	257e	05	0001	00	9598	30	SG	SG1	103	103 Status Heizkreis 1	1: Raumfrostschutz 2: Anlagenfrostschutz 16: Eingang H1: Sonder 17: Eingang H1: Komfort 18: Eingang H1: Normal 19: Eingang H1: Absenk 20: Eingang H1: Standby 21: Eingang H1: Not-Aus 24: Party 32: Optimierung 33: Niveauanhebung Außentemperatur 48: ext. Notabnahme 49: ext. Überangebot 50: ext. Heizvorgabe 51: Warmwasser-vorrang 64: Sommerbetrieb witterungsgeführt 65: Heizgrenze Raum 66: Heizgrenze VL 67: Raumthermostat 80: Komfort 81: Normal 82: Absenken 83: Frost 84: Frostschutz aktiv	Schalten		1 Byte		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200257e05000100"}}}
SYS	02	02	00	257e	05	0001	54	9598												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200257e05000154"}}}

Weishaupt CanApiJson / CAPI / CAN Api – Parsed telegrams: https://github.com/BorgNumberOne/Weishaupt_CanApiJson

SRC: --> requesting device: DDC
--> responding device: SYS

CM:
0x01 (1) = request reading / **GET** numeric value
0x02 (2) = **Response** reading
0x03 (3) = request writing / **SET** numeric value
0x04 (4) = **Response** writing / **ACK**nowledge
0x05 (5) = error
0x11 (17) = request string / **GETS**
0x12 (18) = **Response** string
0x13 (19) = request writing string / **SETS**
0x14 (20) = **Response** writing string / **ACK**nowledge

Weishaupt CanApiJson / Weishaupt CAPI side of a Weishaupt Gateway WEM-Modbus												Modbus TCP side of a Weishaupt Gateway WEM-Modbus								RAW CanApiJson telegram
SRC	CM	MI	MX	OX	OS	VS	VA	HEX to DEC (OX)	Cycle Time (in s) between DDC telegrams			Modbus TCP register on the Modbus TCP side of Weishaupt Gateway WEM-Modbus								
DDC	01	02	00	253b	02	0002	00	9531	30	SG	SG1	106	106 Raumsolltemperatur	Komfort	Temperatur	0,1 °C	2 Bytes	S: 0,5K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200253b02000200"}}}
SYS	02	02	00	253b	02	0002	00dc	9531												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200253b02000200dc"}}}
DDC	01	02	00	253a	02	0002	00	9530	30	SG	SG1	107	107 Raumsolltemperatur	Normal	Temperatur	0,1 °C	2 Bytes	S: 0,5K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200253a02000200"}}}
SYS	02	02	00	253a	02	0002	00d2	9530												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200253a02000200d2"}}}
DDC	01	02	00	2539	02	0002	00	9529	30	SG	SG1	108	108 Raumsolltemperatur	Absenk	Temperatur	0,1 °C	2 Bytes	S: 0,5K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200253902000200"}}}
SYS	02	02	00	2539	02	0002	00a0	9529												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200253902000200a0"}}}
DDC	01	02	00	2558	02	0002	00	9560	30	SG	SG1	109	109 Raumsolltemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200255802000200"}}}
SYS	02	02	00	2558	02	0002	0000	9560												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200255802000200000"}}}
DDC	01	02	00	256b	02	0002	00	9579	30	SG	SG1	110	110 Vorlaufsolltemperatur	Komfort	Temperatur	0,1 °C	2 Bytes	S: 1K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200256b02000200"}}}
SYS	02	02	00	256b	02	0002	02bc	9579												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200256b02000202bc"}}}
DDC	01	02	00	256a	02	0002	00	9578	30	SG	SG1	111	111 Vorlaufsolltemperatur	Normal	Temperatur	0,1 °C	2 Bytes	S: 1K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200256a02000200"}}}
SYS	02	02	00	256a	02	0002	0258	9578												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200256a0200020258"}}}
DDC	01	02	00	2569	02	0002	00	9577	30	SG	SG1	112	112 Vorlaufsolltemperatur	Absenk	Temperatur	0,1 °C	2 Bytes	S: 1K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200256902000200"}}}
SYS	02	02	00	2569	02	0002	01c2	9577												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200256902000201c2"}}}
DDC	01	02	00	252c	02	0002	00	9516	10	SG	SG1	113	113 Vorlaufsolltemperatur	Sonderniveau	Temperatur	0,1 °C	2 Bytes	S: 1K	s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200252c02000200"}}}
SYS	02	02	00	252c	02	0002	0190	9516												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200252c0200020190"}}}
DDC	01	01	00	27f9	02	0002	00	10233	10	SG	SG1	114	114 N1-Vorgabe über Ethernet		Prozent (0...100%)	0,01 %	2 Bytes	S: 0,1%	s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"01010027f902000200"}}}
SYS	05	01	00	27f9	02	0002	0001	10233												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"05010027f90200020001"}}}
DDC	01	02	00	2559	02	0002	00	9561	30	SG	SG1	115	115 Vorlaufsolltemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200255902000200"}}}
SYS	02	02	00	2559	02	0002	0000	9561												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200255902000200000"}}}
DDC	01	02	00	2507	02	0002	00	9479	10	SG	SG1	116	116 Vorlaufisttemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010200250702000200"}}}
SYS	02	02	00	2507	02	0002	0232	9479												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020200250702000202 32"}}}
DDC	01	01	00	261f	02	0002	00	9759	10	SG	SG1	117	117 Plattenwärmetauschertemperatur (B2)	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100261f02000200"}}}
SYS	02	01	00	261f	02	0002	8000	9759												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100261f0200028000"}}}
DDC	01	01	00	2560	02	0002	00	9568	30	SG	SG1	118	118 Pufferspeicher Temperatur oben	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100256002000200"}}}
SYS	02	01	00	2560	02	0002	0235	9568												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100256002000202 35"}}}
DDC	01	01	00	2561	02	0002	00	9569	30	SG	SG1	119	119 Pufferspeicher Temperatur unten	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100256102000200"}}}
SYS	02	01	00	2561	02	0002	0213	9569												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100256102000202 13"}}}
DDC	01	01	00	263f	00	0008	00	9791	30	SG	SG1	120 121 122 123	120 Can Open spezifisch				2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100263f00000800"}}}
													121 Fehler/Warnung anstehend (Bit7…5 frei)	Bit15…8: >0 Fehler aktiv 0 Fehler inaktiv Bit4: 0 Modulfehler 1 Systemfehler Bit3...0: Fehlerart: 1 Fehler 2 Warnung 3 Info			2 Bytes		m/≥60s	
													122 Fehlernummer	Aktuelle Fehlernummer			2 Bytes		m/≥60s	
													123 Modul	Bit15…8: Modul-ID Bit7…0: Modul-Index			2 Bytes		m/≥60s	
SYS	02	01	00	263f	00	0008	0000000000000000	9791												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100263f0000080000000000000000"}}}
DDC	01	01	00	261e	00	0001	00	9758	30	SG	SG1	124	124 Systembetriebsart	1: Standby 2: Sommer 3: Automatik	Schalten		1 Byte	S	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100261e00000100"}}}
SYS	02	01	00	261e	00	0001	03	9758												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100261e00000103"}}}
DDC	01	01	00	26b1	02	0002	00	9905	30	SG	SG1	125	125 Außentemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"01010026b102000200"}}}
SYS	02	01	00	26b1	02	0002	0058	9905												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"02010026b10200020058"}}}
DDC	01	01	00	259c	01	0002	00	9628	10	SG	SG1	126	126 Wärmeanforderung Heizung	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100259c01000200"}}}
SYS	02	01	00	259c	01	0002	01b7	9628												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100259c01000201b7"}}}

Weishaupt CanApiJson / CAPI / CAN Api – Parsed telegrams:

https://github.com/BorgNumberOne/Weishaupt_CanApiJson

Weishaupt CanApiJson / Weishaupt CAPI side of a Weishaupt Gateway WEM-Modbus | **Modbus TCP side of a Weishaupt Gateway WEM-Modbus** | **RAW CanApiJson telegram**

SRC: --> requesting device: DDC
--> responding device: SYS

CM:
0x01 (1) = request reading / **GET** numeric value
0x02 (2) = **Response** reading
0x03 (3) = request writing / **SET** numeric value
0x04 (4) = **Response** writing / **ACK**nowledge
0x05 (5) = error
0x11 (17) = request string / **GETS**
0x12 (18) = **Response** string
0x13 (19) = request writing string / **SETS**
0x14 (20) = **Response** writing string / **ACK**nowledge

SRC	CM	MI	MX	OX	OS	VS	VA	HEX to DEC (OX)	Cycle Time (in s) between DDC telegrams			Modbus TCP register on the Modbus TCP side of Weishaupt Gateway WEM-Modbus								RAW CanApiJson telegram
DDC	01	01	00	259d	01	0002	00	9629	10	SG	SG1	127	127 Wärmeanforderung Warmwasser	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100259d01000200"}}}
SYS	02	01	00	259d	01	0002	0000	9629												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100259d01000020000"}}}
DDC	01	03	00	2569	02	0001	00	9577	30	SG	SG1	130	130 Status Warmwasser	0: Warnung anstehend 1: Fehler anstehend	Boolesch		1 Byte		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010300256902000100"}}}
SYS	02	03	00	2569	02	0001	01	9577												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020300256902000101"}}}
DDC	01	03	00	2549	02	0001	00	9545	10	SG	SG1	131	131 Warmwasser-Push	Starten	Boolesch		1 Byte	S	s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010300254902000100"}}}
SYS	02	03	00	2549	02	0001	00	9545												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020300254902000100"}}}
DDC	01	03	00	2539	02	0002	00	9529	30	SG	SG1	132	132 WWsolltemperatur Vorgabe	Normal	Temperatur	0,1 °C	2 Bytes	S: 1K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010300253902000200"}}}
SYS	02	03	00	2539	02	0002	0190	9529												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020300253902000020190"}}}
DDC	01	03	00	2538	02	0002	00	9528	30	SG	SG1	133	133 WWsolltemperatur Vorgabe	Absenk	Temperatur	0,1 °C	2 Bytes	S: 1K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010300253802000200"}}}
SYS	02	03	00	2538	02	0002	0190	9528												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020300253802000020190"}}}
DDC	01	03	00	252c	02	0002	00	9516	30	SG	SG1	134	134 WWsolltemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010300252c02000200"}}}
SYS	02	03	00	252c	02	0002	0190	9516												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020300252c0200020190"}}}
DDC	01	03	00	2529	02	0002	00	9513	10	SG	SG1	135	135 Warmwassertemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010300252902000200"}}}
SYS	02	03	00	2529	02	0002	0242	9513												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020300252902000020242"}}}
DDC	01	03	00	2557	02	0002	00	9559	30	SG	SG1	136	136 Rücklauftemperatur Zirkulation	Aktueller Wert	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010300255702000200"}}}
SYS	02	03	00	2557	02	0002	8000	9559												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020300255702000028000"}}}
DDC	01	03	00	2551	02	0001	00	9553	10	SG	SG1	137	137 Pumpe Warmwasser	0: Aus 1: Ein	Boolesch		1 Byte		s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010300255102000100"}}}
SYS	02	03	00	2551	02	0001	00	9553												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020300255102000100"}}}
DDC	01	01	00	26e4	02	0001	00	9956	60	SG	SG1	140	140 Folgewechsel	0: normal 1: invertiert 2: zeitlich 3: Betriebsstunden	Schalten		1 Byte	S	l/≥10min	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"01010026e402000100"}}}
SYS	02	01	00	26e4	02	0001	02	9956												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"02010026e402000102"}}}
DDC	01	01	00	26e6	02	0002	00	9958	60	SG	SG1	141	141 Wechselzeit	Aktueller Wert	Zeit	1 h	2 Bytes	S: 1h	l/≥10min	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"01010026e602000200"}}}
SYS	02	01	00	26e6	02	0002	0032	9958												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"02010026e60200020032"}}}
DDC	01	01	00	26fe	02	0002	00	9982	10	SG	SG1	142	142 Kaskade	Abgleichtemperatur	Temperatur	0,1 °C	2 Bytes		s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"01010026fe02000200"}}}
SYS	02	01	00	26fe	02	0002	8000	9982												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"02010026fe0200028000"}}}
DDC	01	01	00	261c	00	0002	00	9756	30	SG	SG1	143	143 Kaskade	Soll-Modulation System HZ	Prozent (0...255%)	0,01 %	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100261c00000200"}}}
SYS	02	01	00	261c	00	0002	0000	9756												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100261c0000020000"}}}
DDC	01	01	00	261d	00	0002	00	9757	30	SG	SG1	144	144 Kaskade	Soll-Modulation System WW	Prozent (0...255%)	0,01 %	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100261d00000200"}}}
SYS	02	01	00	261d	00	0002	0000	9757												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100261d0000020000"}}}
DDC	01	01	00	2612	00	0002	00	9746	30	SG	SG1	145	145 Kaskade	Sollwert System HZ	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100261200000200"}}}
SYS	02	01	00	2612	00	0002	01bd	9746												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100261200000201bd"}}}
DDC	01	01	00	2613	00	0002	00	9747	30	SG	SG1	146	146 Kaskade	Sollwert System WW	Temperatur	0,1 °C	2 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100261300000200"}}}
SYS	02	01	00	2613	00	0002	0000	9747												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100261300000020000"}}}
DDC	01	01	00	2562	02	0001	00	9570	10	SG	SG1	150	150, Uhrzeit 151	Aktuelle Uhrzeit	Tageszeit		2 Bytes		s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100256202000100"}}}
SYS	02	01	00	2562	02	0001	14	9570												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100256202000114"}}}
DDC	01	01	00	2562	03	0001	00	9570	10	SG	SG1	151								{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100256203000100"}}}
SYS	02	01	00	2562	03	0001	37	9570												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100256203000137"}}}
DDC	01	01	00	2563	02	0001	00	9571	30	SG	SG1	153	153, Datum 154, 155	Aktuelles Datum	Datum		3 Bytes		m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100256302000100"}}}
SYS	02	01	00	2563	02	0001	1a	9571												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100256302000011a"}}}
DDC	01	01	00	2563	03	0001	00	9571	30	SG	SG1	154								{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100256303000100"}}}
SYS	02	01	00	2563	03	0001	02	9571												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100256303000102"}}}
DDC	01	01	00	2563	04	0001	00	9571	30	SG	SG1	155								{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010100256304000100"}}}
SYS	02	01	00	2563	04	0001	17	9571												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020100256304000117"}}}

7.5.4 WTC

Weishaupt CanApiJson / CAPI / CAN Api – Parsed telegrams:

https://github.com/BorgNumberOne/Weishaupt_CanApiJson

SRC:
-->
requesting device:
DDC
-->
responding device:
SYS

CM:
0x01 (1) = request reading / **GET** numeric value
0x02 (2) = **Response** reading
0x03 (3) = request writing / **SET** numeric value
0x04 (4) = **Response** writing / **ACK**nowledge
0x05 (5) = error
0x11 (17) = request string / **GETS**
0x12 (18) = **Response** string
0x13 (19) = request writing string / **SETS**
0x14 (20) = **Response** writing string / **ACK**nowledge

Weishaupt CanApiJson / Weishaupt CAPI side of a Weishaupt Gateway WEM-Modbus												Modbus TCP side of a Weishaupt Gateway WEM-Modbus							RAW CanApiJson telegram
SRC	CM	MI	MX	OX	OS	VS	VA	HEX to DEC (OX)	Cycle Time (in s) between DDC telegrams			Modbus TCP register on the Modbus TCP side of Weishaupt Gateway WEM-Modbus							
DDC	01	09	01	2639	00	0001	00	9785	10	WTC	WTC1	160	160	Betriebsphase WTC	0: Normalbetrieb 10: Pumpennachlauf 15: Brennertaktsperre Heizen 20: Sperre Mindest-heizleistung 24: Adaption Gasstell-glied läuft 25: Verzögerter Heizbetrieb 30: Softstart Warm-wasser 35: Abregelfunktion Fernsteuerung 40: Spreizung Vorlauf/Abgas 45: Spreizung Vorlauf/Rücklauf 50: Abregelfunktion Abgastemperatur 55: Abschaltung Fernsteuerung 60: Abschaltung Mindestumlauf 70: SCOT Kalibration läuft	Schalten		1 Byte	s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010901263900000100"}}}
SYS	02	09	01	2639	00	0001	00	9785											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020901263900000100"}}}
DDC	01	07	00	2541	00	0001	00	9537	10	WTC	WTC1	161	161	Betriebsphase Brenner	0: Brenner aus 1: Vorbelüftung 2: Brenner ein: Steuerbetrieb 3: Brenner ein: Regelbetrieb 4: Nachbelüftung	Schalten		1 Byte	s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010700254100000100"}}}
SYS	02	07	00	2541	00	0001	00	9537											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020700254100000100"}}}
DDC	01	07	00	2545	00	0002	00	9541	30	WTC	WTC1	163	163	Vorlaufsolltemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010700254500000200"}}}
SYS	02	07	00	2545	00	0002	0050	9541												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020700254500000020050"}}}
DDC	01	07	00	2532	00	0002	00	9522	10	WTC	WTC1	164	164	Kesseltemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes	s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010700253200000200"}}}
SYS	02	07	00	2532	00	0002	00aa	9522												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020700253200000200aa"}}}
DDC	01	09	01	2613	02	0002	00	9747	30	WTC	WTC1	165	165	Volumenstrom VPT	Aktueller Wert	Durchfluss-menge	1 l/h	2 Bytes	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010901261302000200"}}}
SYS	02	09	01	2613	02	0002	0000	9747												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020901261302000020000"}}}
DDC	01	09	01	2614	02	0002	00	9748	30	WTC	WTC1	166	166	Anlagendruck	Aktueller Wert	Druck	0,01 bar	2 Bytes	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010901261402000200"}}}
SYS	02	09	01	2614	02	0002	007a	9748												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020901261402000207a"}}}
DDC	01	07	00	2533	02	0002	00	9523	10	WTC	WTC1	167		nicht dokumentiert						{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010700253302000200"}}}
SYS	02	07	00	2533	02	0002	00ad	9523												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020700253302000200ad"}}}
DDC	01	07	00	2537	00	0002	00	9527	10	WTC	WTC1	168		nicht dokumentiert						{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010700253700000200"}}}
SYS	02	07	00	2537	00	0002	00c4	9527												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020700253700000200c4"}}}
DDC	01	09	01	2631	02	0004	00	9777	30	WTC	WTC1	170 171	170, 171	Wärmeleistung VPT	Aktueller Wert	Leistung	0,01 kW	4 Bytes	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010901263102000400"}}}
SYS	02	09	01	2631	02	0002	0000	9777												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020901263102000020000"}}}
DDC	01	09	01	2628	02	0004	00	9768	60	WTC	WTC1	172 173	172, 173	Tageswärmemenge (Vortag)	Gesamt	Wirkarbeit	0,01 kWh	4 Bytes	l/≥10min	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010901262802000400"}}}
SYS	02	09	01	2628	02	0004	0000058e	9768												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020901262802000400000058e"}}}
DDC	01	09	01	2626	02	0004	00	9766	60	WTC	WTC1	174 175	174, 175	Tageswärmemenge (Vortag)	Heizbetrieb	Wirkarbeit	0,01 kWh	4 Bytes	l/≥10min	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010901262602000400"}}}
SYS	02	09	01	2626	02	0004	00000436	9766												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020901262602000400000436"}}}
DDC	01	09	01	2627	02	0004	00	9767	60	WTC	WTC1	176 177	176, 177	Tageswärmemenge (Vortag)	Warmwasserbetrieb	Wirkarbeit	0,01 kWh	4 Bytes	l/≥10min	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010901262702000400"}}}
SYS	02	09	01	2627	02	0004	00000158	9767												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020901262702000400000158"}}}
												7.5.6		**EM-WW**						
DDC	01	02	01	2533	02	0001	00	9523	30	HK	HK2	1030	1030	Betriebsart Vorgabe	1: Standby 2: Zeitprogramm 1 3: Zeitprogramm 2 4: Zeitprogramm 3 5: Sommer 6: Komfort 7: Normal 8: Absenk	Schalten		1 Byte	S m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201253302000100"}}}
SYS	02	02	01	2533	02	0001	02	9523												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201253302000102"}}}
DDC	01	02	01	2582	02	0001	00	9602	30	HK	HK2	1031	1031	So/Wi Umschaltung	0: Aus 1: Ein	Boolesch		1 Byte	S m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201258202000100"}}}
SYS	02	02	01	2582	02	0001	01	9602												{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201258202000101"}}}

Weishaupt CanApiJson / CAPI / CAN Api – Parsed telegrams: https://github.com/BorgNumberOne/Weishaupt_CanApiJson

SRC: --> requesting device: DDC
--> responding device: SYS

CM:
0x01 (1) = request reading / **GET** numeric value
0x02 (2) = **Response** reading
0x03 (3) = request writing / **SET** numeric value
0x04 (4) = **Response** writing / **ACK**nowledge
0x05 (5) = error
0x11 (17) = request string / **GETS**
0x12 (18) = **Response** string
0x13 (19) = request writing string / **SETS**
0x14 (20) = **Response** writing string / **ACK**nowledge

Weishaupt CanApiJson / Weishaupt CAPI side of a Weishaupt Gateway WEM-Modbus												Modbus TCP side of a Weishaupt Gateway WEM-Modbus							RAW CanApiJson telegram
SRC	CM	MI	MX	OX	OS	VS	VA	HEX to DEC (OX)	Cycle Time (in s) between DDC telegrams			Modbus TCP register on the Modbus TCP side of Weishaupt Gateway WEM-Modbus							
DDC	01	02	01	257e	04	0001	00	9598	30	HK	HK2	1032	1032 Betriebsart aktuell	1: System Standby 2: System Sommer 3: Estrich: Funktionsheizen 4: Estrich: Belegreifheizen 5: Urlaub 6: Zeitprogramm 1 7: Zeitprogramm 2 8: Zeitprogramm 3 9: Sommer 10: Absenk 11: Normal 12: Komfort 13: Standby	Schalten	1 Bit	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201257e04000100"}}}
SYS	02	02	01	257e	04	0001	06	9598											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201257e04000106"}}}
DDC	01	02	01	257e	05	0001	00	9598	30	HK	HK2	1033	1033 Status	1: Raumfrostschutz 2: Anlagenfrostschutz 16: Eingang H1: Sonder 17: Eingang H1: Komfort 18: Eingang H1: Normal 19: Eingang H1: Absenk 20: Eingang H1: Standby 21: Eingang H1: Not-Aus 24: Party 32: Optimierung 33: Niveauanhebung Außentemperatur 48: ext. Notabnahme 49: ext. Überangebot 50: ext. Heizvorgabe 51: Warmwasser-vorrang 64: Sommerbetrieb witterungsgeführt 65: Heizgrenze Raum 66: Heizgrenze VL 67: Raumthermostat 80: Komfort 81: Normal 82: Absenken 83: Frost 84: Frostschutz aktiv	Schalten	1 Byte	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201257e05000100"}}}
SYS	02	02	01	257e	05	0001	51	9598											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201257e05000151"}}}
DDC	01	02	01	253b	02	0002	00	9531	30	HK	HK2	1036	1036 Raumsolltemperatur	Komfort	Temperatur	0,1 °C	2 Bytes S: 0,5K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201253b02000200"}}}
SYS	02	02	01	253b	02	0002	015e	9531											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201253b020002015e"}}}
DDC	01	02	01	253a	02	0002	00	9530	30	HK	HK2	1037	1037 Raumsolltemperatur	Normal	Temperatur	0,1 °C	2 Bytes S: 0,5K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201253a02000200"}}}
SYS	02	02	01	253a	02	0002	00d2	9530											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201253a02000200d2"}}}
												7.5.5 EM-HK							
DDC	01	02	01	2539	02	0002	00	9529	30	HK	HK2	1038	1038 Raumsolltemperatur	Absenk	Temperatur	0,1 °C	2 Bytes S: 0,5K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201253902000200"}}}
SYS	02	02	01	2539	02	0002	00a0	9529											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201253902000200a0"}}}
DDC	01	02	01	2558	02	0002	00	9560	30	HK	HK2	1039	1039 Raumsolltemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201255802000200"}}}
SYS	02	02	01	2558	02	0002	00d2	9560											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201255802000200d2"}}}
DDC	01	02	01	256b	02	0002	00	9579	30	HK	HK2	1040	1040 Vorlaufsolltemperatur	Komfort	Temperatur	0,1 °C	2 Bytes S: 1K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201256b02000200"}}}
SYS	02	02	01	256b	02	0002	02bc	9579											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201256b02000202bc"}}}
DDC	01	02	01	256a	02	0002	00	9578	30	HK	HK2	1041	1041 Vorlaufsolltemperatur	Normal	Temperatur	0,1 °C	2 Bytes S: 1K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201256a02000200"}}}
SYS	02	02	01	256a	02	0002	0258	9578											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201256a0200020258"}}}
DDC	01	02	01	2569	02	0002	00	9577	30	HK	HK2	1042	1042 Vorlaufsolltemperatur	Absenk	Temperatur	0,1 °C	2 Bytes S: 1K	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201256902000200"}}}
SYS	02	02	01	2569	02	0002	01c2	9577											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201256902000201c2"}}}
DDC	01	02	01	252c	02	0002	00	9516	10	HK	HK2	1043	1043 Vorlaufsolltemperatur	Sonderniveau	Temperatur	0,1 °C	2 Bytes S: 1K	s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201252c02000200"}}}
SYS	02	02	01	252c	02	0002	0190	9516											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201252c0200020190"}}}
DDC	01	02	01	2559	02	0002	00	9561	30	HK	HK2	1045	1045 Vorlaufsolltemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes	m/≥60s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201255902000200"}}}
SYS	02	02	01	2559	02	0002	01b4	9561											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201255902000201b4"}}}
DDC	01	02	01	2507	02	0002	00	9479	10	HK	HK2	1046	1046 Vorlaufisttemperatur	Aktueller Wert	Temperatur	0,1 °C	2 Bytes	s/≥30s	{"ID":"12345678","SRC":"DDC","CAPI":{"NN":1,"N01":{"VG":"010201250702000200"}}}
SYS	02	02	01	2507	02	0002	01b6	9479											{"ID":"12345678","SRC":"SYS","CAPI":{"NN":1,"N01":{"VG":"020201250702000201b6"}}}