

Highlights

Reducing RES Droughts through the integration of wind and [solar](#) PV

Boris Morin, Aina Maimó Far, Damian Flynn, Conor Sweeney

- RES droughts are analysed using 45 years of hourly wind and [solar](#) PV generation data
- RES droughts from C3S-Energy and ERA5-Atlite datasets are compared
- Adding [solar](#) PV to a wind-dominated system reduces RES drought frequency and duration
- Validated RES datasets are crucial to accurately identify RES drought extremes

Reducing RES Droughts through the integration of wind and solar PV

Boris Morin^{a,*}, Aina Maimó Far^a, Damian Flynn^b, Conor Sweeney^a

*^aSchool of Mathematics and Statistics, University College Dublin, Belfield, Dublin
4, Dublin, D04 V1W8, Ireland*

*^bSchool of Electrical and Electronic Engineering, University College Dublin, Belfield,
Dublin 4, Dublin, D04 V1W8, Ireland*

*Corresponding author

Email addresses: `boris.morin@ucdconnect.ie` (Boris Morin),
`aina.maimofar@ucd.ie` (Aina Maimó Far), `damian.flynn@ucd.ie` (Damian Flynn),
`conor.sweeney@ucd.ie` (Conor Sweeney)

Abstract

Increasing the share of electricity produced from renewable energy sources (RES), combined with RES dependence on weather, poses a critical challenge for energy systems. This study investigates the importance of the balance between wind and [solar](#) photovoltaic (PV) capacity on periods of low renewable generation, known as RES droughts. Three different RES ~~models~~ [datasets](#) are used to estimate the capacity factors for different scenarios of installed capacities for wind and [solar](#) PV power. The skill of the RES models is quantified by comparing capacity factor time series to observed hourly data and by assessing their representation of observed RES droughts. The RES models are used to generate a 45-year hourly time series of RES capacity factor, enabling analysis of the frequency, duration and return periods of RES droughts at a climatological scale. Results show the importance of using an accurate, validated RES model for RES drought risk assessment. The addition of [solar](#) PV capacity to a wind-dominated system results in a significant reduction in the frequency and duration of RES droughts, while also reducing extremes and seasonal [RES](#) drought patterns. These findings underscore the importance of diversification in RES capacity to enhance energy security and resilience.

Keywords: RES Drought, Wind Power, Solar PV Power, Renewable Energy Sources, Return Periods

1. Introduction

The EU aims to generate at least 69% of its electricity from renewable energy sources (RES) by 2030, up from 41% in 2022 [1]. While this transition is essential for reducing greenhouse gas emissions, it also highlights the challenge of managing the variability of weather-dependent energy sources such as wind and [solar](#) photovoltaic (PV) power. This challenge is ~~compounded~~ [amplified](#) by the increasing electrification of energy sectors, which places greater demand on the power system and makes it more sensitive to meteorological conditions ~~[2, 3, 4]~~ [both in historical \[2\] and future climates \[3\]](#). Periods of low renewable generation, known as *Dunkelflaute* or RES droughts, pose significant risks to system adequacy and energy security, emphasising the need for a resilient energy system to meet both growing electricity demand and decarbonisation targets.

This study focuses on Ireland, a region with a strong reliance on wind power, which has ambitious targets for PV power expansion. This case study provides valuable insights into the potential benefits of diversifying the renewable energy mix on RES droughts. The performance of different RES models are compared, and a 45-year time series of RES generation is produced. The results highlight the role of increased PV capacity in reducing RES drought risks, offering insights for policymakers and energy planners.

For this study, RES drought events do not have a fixed definition, with various approaches present in the literature. One common method defines a RES drought event as occurring when as a period during which the average capacity factor (CF) remains below a fixed threshold for a given duration, following the methodology used in other research [5, 6, 7, 8]. Alternative methods exist for defining specified duration. For example, Kaspar et al. [5] used this method to investigate the shortfall risks of low wind and solar PV generation in Europe, with a focus on Germany, testing multiple CF thresholds and durations. Similarly, Mockert et al. [7] examined the link between weather regimes and RES droughts in Germany using a 48-hour rolling window under a threshold to define RES droughts. One approach uses relative CF thresholds that change. Similar fixed-threshold approaches have also been applied using CF series reconstructed through machine learning in regions such as Japan [6] and Hungary [8].

Alternative methods adjust the CF threshold dynamically over the year to account for seasonal variations in renewable energy generation [9, 10, 11, 12, 13]. Another common method relies on percentile-based thresholds, where drought events are defined by identifying periods of unusually low generation relative to historical production levels, typically based on the lowest production percentiles [12, 15]. Additionally, some studies combine these definitions with metrics that incorporate the demand side of energy consumption, analysing the balance between supply and demand during drought periods [9, 10, 12, 15]. production. Raynaud et al. [9] defined RES droughts as sequences of days with renewable electricity generation below a threshold that varies seasonally, a methodology later adapted for India [11]. Building on this, Kapica et al. [13] compared the likelihood of increased RES droughts in Europe under different climate models. Other studies have defined RES droughts based on deviations from daily mean production: Rinaldi et al. [10] applied these in the U.S. Western Interconnection to quantify the benefits of long-term storage, while Brown et al. [14] examined weekly timescales to explore meteorological influences on the most severe RES drought events. Another method defines RES drought indices based on

metrics commonly used in hydro-meteorology to characterise RES droughts [12]. This index was also applied to the U.S. by Bracken et al. [15], revealing a consistent increase in the RES drought magnitude when load is considered, despite showing differing results across regions. The consideration of demand introduces a completely different factor to generation: weather is not the only driver, as the societal component plays a large role.

In addition to examining periods of low renewable electricity generation, several studies also explore the periods when the imbalance between renewable generation and electricity demand (residual load) is high. Raynaud et al. [9] showed the difference between RES droughts and high residual load events in a hypothetical fully renewable system composed of wind, solar PV and run-of-the-river hydropower. Similarly, Allen and Otero [12] also defined a standardised index based on meteorological droughts to address residual load, whose correlation to the electricity generation index is mostly negative (as expected, although quite low anticorrelations and even small positive correlations appear for some European countries). This index was also applied to the U.S. by Bracken et al. [15], revealing a consistent increase in the RES drought magnitude when load is considered, despite showing differing results across regions.

In this paper, the focus is exclusively on ~~energy generation, and a renewable~~ electricity generation, which allows us to maintain physical models that do not consider the behavioural influence of demand. A fixed threshold approach is used to define RES droughts, which facilitates consistent inter-comparison between scenarios with different installed wind and solar PV capacities. The case study used in this paper is Ireland, a region where most RES generation comes from wind power and with ambitious targets for solar PV power expansion. This provides valuable insights into the potential benefits of adding solar PV installations in wind-dominated countries.

RES droughts are identified using onshore wind and solar PV CF time series. In this study, three different datasets are used and compared, all of which are driven by the ERA5 data reanalysis [17]. Two of the datasets are part of C3S Energy (~~C3S-E~~C3SE), an energy-based operational dataset produced by the EU Copernicus Climate Change Service [18, 19][18]. One of the ~~C3S-E~~C3SE datasets provides CF time series aggregated at the national scale, while the other provides the CF time series at each grid point, at the ERA5 resolution of 0.25°. The third dataset produced by the authors was generated using the Atlite model [20], which converts the ERA5 atmospheric data to a generation time series using specified wind turbine and PV panel

models. Atlite is an open-source tool developed by PyPSA [20] and ~~is widely~~
~~has been~~ used for estimating wind and ~~PV generation~~ [7, 21, 22, 23] solar PV
generation in order to study RES droughts in Germany [7].

Generic datasets for wind and solar PV CF are often used for the quantification
of RES droughts. Despite undergoing a validation process, they are often not
fully representative of each geographical location, and can show differences
in the number of RES drought events [24]. This study evaluates the skill of a
dataset developed for the European region (C3SE) when applied to a specific
country (Ireland). In particular, the analysis explores the impact of using a
generic versus a tailored dataset on RES drought assessments, in the context
of a transition from a wind-dominated system to one with a greater share of
solar PV.

The aim of this study is to answer three questions which are relevant for
systems with a large share of RES generation:

- Do generic datasets have sufficient skill to reliably quantify extreme
RES drought events?
- What is the importance of using accurate RES farm locations, and
regionally-validated wind and solar PV models, when analysing of RES
droughts?
- How does the integration of solar PV into a predominantly wind-based
system alter the characteristics of RES drought events?

The datasets used in this study are detailed in section ~~??~~2, which de-
scribes their characteristics and relevance for evaluating RES droughts. Sec-
tion ~~??~~3 outlines the RES ~~models~~ datasets used to simulate wind and solar
PV generation and provides the methodology for defining and identifying
RES drought events, including the thresholds and metrics applied. In sec-
tion ~~??~~, ~~the models~~ 4, the datasets are first verified against observed energy
data to assess their accuracy, followed by an analysis of RES drought occur-
rences for two scenarios with different ratios of installed wind to solar PV
capacities. Finally, section ~~??~~5 offers a discussion of the results in the context
of energy reliability and future planning, followed by the main conclusions
and recommendations for further research.

2. Data

This study uses publicly available datasets to construct and validate the ~~models-datasets~~ for estimating the CF of wind and ~~PV-energy~~solar PV power. The primary data sources include: EirGrid and SONI, the transmission system operators (TSO) for the Republic of Ireland and Northern Ireland, respectively; the ERA5 reanalysis dataset; and the ~~C3S-E-datasets~~C3SE dataset.

2.1. Wind and solar PV Capacity and Availability

EirGrid, the TSO for the Republic of Ireland, and SONI, the Northern Ireland TSO, provide detailed datasets on all wind and solar PV farms across the island of Ireland (Republic of Ireland and Northern Ireland) from 1990 to the present [25]. These datasets include information such as each farm’s installed capacity, name, and connection date. To enhance the accuracy of this data, the longitude and latitude for each farm were manually determined through online searches. For simplicity, this data will be referred to as originating from EirGrid, as all-island data was directly obtained from EirGrid, and the combined regions of the Republic of Ireland and Northern Ireland will be referred to as Ireland throughout the remainder of this document.

The spreadsheet available from the EirGrid website contains two key variables: generation and availability. Generation is the energy that a RES farm actually contributed to the grid, which may include limitations introduced by the TSO to maintain grid stability, such as constraints and curtailment. Availability represents the energy that would have been generated from a RES farm if no grid constraints had been applied, making it representative of the weather-related response. Generation and availability values are available from 2014 onward for wind power and from 2018 onward for solar PV power, although solar PV availability data only became present in the Republic of Ireland in 2023. This study focuses on availability for all analyses.

2.2. Atmospheric Variables

~~Atlite and C3S-E datasets~~All of the datasets used in this study are driven by data from the ERA5 reanalysis [17], produced by the European Centre for Medium-Range Weather Forecasts (ECMWF). This global gridded dataset provides hourly atmospheric variables from 1940 to the present at a horizontal resolution of 0.25°. ~~It is widely used for estimating PV and wind energy [7, 18, 14, 26].~~ Table 1 lists the relevant ERA5 variables ~~used by Atlite and C3S-Energy~~.

Table 1: ERA5 variables used to calculate wind and [solar](#) PV generation

ERA5 name	variable
100 metre zonal and meridional wind speed	u_{100}, v_{100}
2 metre temperature	$t2m$
Surface net solar radiation	ssr
Surface solar radiation downwards	$ssrd$
Top of atmosphere incident radiation	$tisr$
Total sky direct solar radiation at surface	$fdir$

2.3. C3S Energy

The EU Copernicus Climate Change Service developed the ~~C3S-E~~ [C3S-Energy](#) ([C3SE](#)) renewable energy dataset for Europe [18], using ERA5 atmospheric variables and weather-to-energy models. This dataset provides hourly CF for wind and ~~PV-energy-solar~~ [PV power](#) from 1979 to the present. The data are available on the same grid as the ERA5 data, which has a horizontal resolution of 0.25° . The time series are also available for download at two aggregated scales: regional (NUTS 2) and national.

The ~~C3S-E dataset estimates wind energy~~ [wind CF in C3SE was calculated](#) using wind speeds at 100 metres (u_{100}, v_{100}) and a standard turbine model, the Vestas V136/3450, with a fixed hub height of 100 meters. ~~This choice is based on expert advice and the trend in wind turbine installation. The PV-generation model used by C3S-E uses two~~ [As data on wind turbine fleet locations and specifications are difficult to obtain across Europe, C3SE assumes a homogeneous distribution of wind turbines across the ERA5 variables: grid. While this approach does not capture the precise capacity factors reported by grid operators, it provides a well-correlated time series that effectively represents the impact of climate variability on wind power generation. The C3SE solar PV CF was also calculated for the ERA5 grid. It is derived from meteorological data, including surface solar radiation downwards \(\$ssrd\$ \) and air temperature \(\$t2m\$ \). PV-generation is calculated multiple times, using the same model with different azimuth and tilt angles. The results are aggregated based on a statistical distribution of the module angles based on the geographical, using a reference solar PV plant model. This model incorporates empirical calculations for key system components such as optical losses, module efficiency, and inverters. The final CF accounts for a mix of module orientations typical for each](#) location [27].

3. Methods

This study ~~uses three datasets to analyse~~ analyses RES droughts across the island of Ireland. ~~Data downloaded from C3S-E were used to obtain two datasets: one using onshore wind and solar PV CF time series from three datasets: two from C3SE, based on national-level data (C3S-E-N), and another on C3S NAT) and grid-level data (C3S-E-G). The third dataset was computed using C3S GRD), and one derived from the Atlite model (Atlite).~~ ATL). Fig. 1 presents the statistics of the three datasets in violin plots for wind and solar PV. These plots illustrate the density of CF values over time, highlighting differences between the datasets and their alignment with observed data.

3.1. *C3S-Energy National*




Figure 1: Violin plots of CF distributions for wind a) and solar PV b) datasets. Each violin represents the distribution of CF over time for different datasets: Observations (black), ATL (red), C3S GRD (blue), and C3S NAT (purple). The mean value for each dataset is marked with a green horizontal line. The red line indicates the threshold of 0.1 used in the study to identify RES droughts

3.1. *C3S Energy National: C3S NAT*

~~For national-level analyses, the aggregated CF time series provided by C3S-E were used at two~~ The C3S NAT dataset is created by combining two

inputs provided by C3SE at the corresponding NUTS levels: Republic of Ireland (NUTS0: IE) and Northern Ireland (NUTS2: UKN0). ~~These are based on the assumption by C3S-E~~ The two inputs are combined, using the actual installed capacity as weights. This dataset assumes that RES generation occurs at every ERA5 grid point in Ireland. ~~We computed a weighted average of these, based on the installed capacity of each one, to represent the total CF for Ireland.~~

3.2. ~~C3S-E~~ C3S Energy Gridded: C3S GRD

The ~~gridded dataset from C3S-E was used to create CF datasets which account for the location of RES farms in Ireland.~~ A list C3S GRD dataset uses, as inputs, the actual locations of the RES farms in Ireland ~~was compiled, including each farm's latitude, longitude and installed capacity.~~ Using these coordinates, the nearest grid point on the C3S-E grid ~~was identified for each farm.~~ The CF values from the C3S-E dataset corresponding to these grid points ~~were retrieved,~~ and the CF from C3SE over the ERA5 grid. For each farm, the CF from the nearest grid point on the C3SE dataset was selected. A weighted average of the CF ~~values was calculated, with the installed capacity of each farm serving as the weight, to construct the~~ associated with each farm, using the farm's installed capacities, was used to produce the total CF time series for Ireland. This process resulted in a time series of RES generation for each energy source (wind and PV) for Ireland, which takes the location of the RES farms into account.

3.3. *Atlite*: ATL

~~Atlite transforms weather data into energy data using the gridded ERA5 data and~~ The ATL dataset is produced using the Atlite model. Atlite allows the user to define the wind turbine power curve and PV panel model to use when converting weather variables to wind and solar PV generation. The Atlite model takes as inputs the locations of ~~existing RES farms, as described in C3S-E G.~~ RES farms and ERA5 ~~data for weather variables:~~ wind speed at 100 metres (u_{100} , v_{100}) ~~are used to calculate for~~ wind generation, ~~while the ERA5 and~~ radiation variables (ssr , $ssrd$, $tisr$, and $fdir$) ~~and along with~~ air temperature ($t2m$) ~~are used to calculate for solar~~ PV generation. A key distinction between C3S-E and Atlite lies in their representation of wind turbines and PV panels ~~The output of the Atlite model is a generation time series, which is divided by the total capacity to transform it back into CF.~~ The selection of the wind turbine power curve and PV panel model

236 represents the key difference between this dataset and C3S GRD. This study
237 identifies the most appropriate wind turbine power curve to use from the 121
238 power curves, each at five different levels of smoothing, made available by
239 Renewables.ninja [28]. ~~The selection of a specific wind turbine and PV panel~~
240 ~~characteristics is further discussed and explained in section 4.1,~~ and selects
241 the PV panel model out of the options available within Atlite.

242 3.4. Energy Scenarios

243 The three datasets provide CF time series for both wind and solar PV.
244 In addition to analysing ~~wind and PV generation~~ the CF of wind and solar
245 PV separately, a combined CF was computed for each ~~model-dataset~~ by
246 averaging wind and ~~PV-generation~~ solar PV CF, weighted by their installed
247 capacities at the end of 2023 (5.9 GW for wind power and 0.6 GW for solar PV
248 power). This configuration is referred to as the 91W-9PV scenario, reflecting
249 the distribution of 91% wind and 9% solar PV capacity. Given that solar
250 PV capacity in Ireland is low in 2023, and to explore how a more balanced
251 distribution of wind and solar PV capacities might impact RES droughts, this
252 study also considered a second scenario, referred to as 57W-43PV, where the
253 installed solar PV capacity is assumed to increase to 8.6 GW, while wind
254 capacity rises to 11.45 GW. These values are based on targets outlined in
255 the roadmap published by the 2024 Climate Action Plan [29]. This study
256 does not include offshore wind in the analysis. Recent reports suggest that
257 even by 2030, Ireland is unlikely to have any significant new offshore wind
258 farms, with projected offshore capacity expected to remain near zero using
259 realistic scenarios [30].

260 New time series were generated for both the ~~Atlite and C3S-E-G PV~~
261 ~~models~~ ATL and C3S GRD solar PV datasets, incorporating a revised distri-
262 bution of installed capacity across Ireland as specified in the roadmap. For
263 wind power, the CF time series remains unchanged, as significant shifts in
264 the location of wind farms are not expected. In total, twelve CF time series
265 were analysed in this study, six for individual wind and solar PV CF (three
266 ~~models-datasets~~ for each source) in the 91W-9PV scenario, and an additional
267 six time series that include the combined CF for 91W-9PV and 57W-43PV
268 scenarios across the different ~~models~~ datasets.

269 It is important to note that the specific capacity values used in this study
270 are illustrative and are not intended to reflect precise future realities. Instead,
271 they serve to explore the impact of transitioning from a wind-dominated sys-
272 tem (91W-9PV) to a more evenly distributed system (57W-43PV). This ap-

273 proach allows for a comparative analysis between the two scenarios, assessing
274 how the balance of RES capacity affects the occurrence of RES droughts.

275 For each dataset (ATL, C3S GRD, and C3S NAT), four distinct scenarios
276 are examined, as summarised below:

- 277 • Wind Power - based on the actual capacity at the end of 2023
- 278 • Solar PV Power - based on the actual capacity at the end of 2023
- 279 • Combined RES / 91W-9PV - based on the actual capacity at the end
280 of 2023
- 281 • Combined RES / 57W-43PV - based on the projected capacity for 2030
282

283 3.5. RES Drought Definition

284 In this study, a RES drought event was defined as occurring when the
285 24-hour moving average of CF remains below a fixed threshold of 0.1 for
286 a period of longer than 24 hours. ~~The choice of this threshold is somewhat~~
287 ~~arbitrary, but aligns with similar studies on low renewable energy production~~
288 ~~[5, 6, 8].~~ By using a 24-hour moving average, fewer but longer-lasting events
289 were captured compared to using the raw CF time series, which can be more
290 sensitive to short-term fluctuations. The 24-hour rolling average also avoids
291 potential masking of day-long events due to their start time. A fixed thresh-
292 old approach was chosen in this study to enable consistent inter-comparison
293 between datasets.

294 The moving average approach smooths out short-term fluctuations, so
295 that brief periods above the threshold do not interrupt an otherwise continu-
296 ous low-CF period (Fig. 2). This means that a single hour above the threshold
297 does not "break" a RES drought event if it is surrounded by prolonged low-
298 generation hours. As a result, fewer but longer-lasting RES drought events
299 are identified, which may better reflect real-world conditions where energy
300 supply constraints persist over extended periods.

301 4. Results

302 4.1. Verification

303 The accuracy of the datasets used in this study was verified, before con-
304 tinuing to the analysis of RES droughts. For the verification process, time-
305 varying values of installed capacity were used to account for changes in RES




Figure 2: Wind time series of CF (green) and its 24-hour moving average (pink) from the 7th to the 15th of July 2021. The black dashed line indicates the CF threshold. The grey bar shows the period identified as a wind drought under our definition

306 development over the verification period. This step allowed us to assess how
 307 well the datasets represent the production of renewable energy by comparing
 308 them against observed data.

309 4.1.1. Wind Energy

310 The ~~C3S-E~~ C3S datasets use the Vestas V136/3450 wind turbine power
 311 curve ~~;~~ (Fig. 3a). The Atlite model allows the user to specify the power
 312 curve. We considered the 121 power curves available for download from
 313 Renewables.ninja [28]. For each power curve, Renewables.ninja also provides
 314 four associated smoothed power curves. The smoothing is done using a Gaus-
 315 sian filter with different standard deviations that depend on the wind speed.
 316 A separate wind CF time series for Ireland was generated for each of the
 317 wind turbine power curves and smoothing levels.

318 The performance of each CF time series is then assessed based on four skill
 319 scores: correlation coefficient (CC), root mean square error (RMSE), mean
 320 bias error (MBE), and the percentage of overlap. The percentage of overlap
 321 quantifies the similarity between the observed and modelled distributions. It
 322 is a positively oriented skill score, where 100% shows full agreement between

the two distributions, and 0% indicates no overlap. The histograms of hourly CF values for the most recent decade (2014-2023) are used to calculate this skill score.




Figure 3: a) Power curves of the Enercon E112.4500 with a $0.3w$ smoothing filter used by ~~Atlite~~-ATL (orange) and the Vestas V136/3450 used by ~~C3S-E~~-C3SE (blue) b) Histograms of wind CF for Ireland from ~~Atlite~~-ATL (orange), ~~C3S-E~~-C3SE (blue) and Observed (shaded)

Based on these metrics, the most representative power curve for Ireland is the Enercon E112.4500 power curve with the $0.3w$ smoothing filter. The smoothing of the wind turbine power curve represents losses associated with each turbine, as well as losses such as wake effects between turbines, which are important when modelling wind energy on larger spatial scales. The histogram in Fig. 3b shows that the ~~C3S-E~~-C3SE power curve tends to underestimate low CF values and overestimate higher ones, whereas the smoothed ~~Atlite~~-ATL power curve more closely follows the observed wind availability data. This is further supported by the percentage of overlap which is higher for ~~Atlite~~-ATL (97.2%) than for ~~C3S-E~~-C3SE (83.2%), indicating better agreement with observed data.

The effect of the difference between the power curves is also visible in Fig. 4, which shows a density plot of wind CF values. The two ~~C3S-E~~-C3S datasets are shown to overestimate the observed CF, whereas the ~~Atlite~~ model-ATL dataset is in good agreement with the observed data. The skill




Figure 4: Wind CF density plot of the observed CF (vertical axes) and modelled (horizontal axes) CF data for the a) AtliteATL, b) C3S-E-G C3S GRD and c) C3S-E-N-models C3S NAT datasets

341 scores presented in Table 2 show that AtliteATL performs better than the
 342 C3S-E-two C3S datasets for all of the skill scores.

	<u>AtliteATL</u>	<u>C3S-E-G C3S GRD</u>	<u>C3S-E-N C3S NAT</u>
CC	0.981	0.972	0.970
RMSE	0.045	0.177	0.162
MBE	-0.003	0.137	0.121

Table 2: Skill scores for wind power for the three datasets compared to observed data

343 Fig. 5 shows the average annual number of wind drought events during the
 344 2014 to 2023 validation period. The figure reveals that AtliteATL presents
 345 the best overall agreement with the observed frequency and duration of wind
 346 drought events. This pattern is particularly evident for shorter-duration
 347 events, which are the most frequent.

348 This verification for wind generation data highlights the importance of
 349 selecting a representative wind turbine power curve for the region being
 350 analysed. The ATL dataset, which uses a representative wind turbine power
 351 curve, is skilled at reproducing wind CF and RES droughts over Ireland.
 352 On the other hand, the power curve used for both C3S GRD and C3S
 353 NAT is not representative for Ireland, as it severely overestimates generation,
 354 underestimating the occurrence of RES droughts. This highlights a problem
 355 with using generalised datasets for analysing RES droughts: biases severely
 356 affect their ability to accurately reproduce RES drought events. The skill
 357 scores for the three datasets (Tab. 2) show only a small difference in their




Figure 5: Average annual number of wind drought events for ~~Atlite~~-ATL (red), ~~C3S-E~~
~~G~~-C3S GRD (blue), ~~C3S-E-N~~-C3S NAT (purple), and the observed data (black outline).
The wind droughts are identified from 2014 to 2023, considering the actual capacity of the
system at any given time

ability to reproduce the changes in CF, as seen by their similar CC scores.
However, their ability to reproduce the actual CF values is much lower than
that of ATL, with RMSE scores almost four times bigger for the two C3S
datasets. There is a clear bias towards an overestimation of CF, seen in
the MBE values, which leads to the underestimation of RES droughts. This
highlights the need to use regionally verified models to assess RES droughts.

4.1.2. Solar PV Energy

The Atlite model allows the user to select certain PV panel characteristics.
In this study, the three PV panel types available in the Atlite model were
considered (CSi, CdTe, Kaneka). Following the same methodology as in the
previous section, the three available models were compared using four skill
scores (CC, RMSE, MBE, and the percentage of overlap). Based on the
best-performing metrics, the ~~Breyer~~-Beyer PV panel model was selected [31],
using the Kaneka Hybrid panel option. For all solar PV farm locations, the

azimuth angle is fixed at 180° (due south), and the optimal tilt angle option is applied.

The [solar](#) PV installed capacity available on the spreadsheets from EirGrid represents the Maximum Export Capacity (MEC) and does not accurately reflect the installed [solar](#) PV capacity. To enable actual [solar](#) PV generation potential to be modelled correctly, installed capacities were set at 1.4 times the MEC values. This scaling factor was estimated by analysing proprietary data from individual [solar](#) PV farms provided by EirGrid, which showed that, on average, assuming that the installed capacities of farms exceed their MEC values by 40% yields the best agreement with the observed availability.




Figure 6: [Solar](#) PV CF density plot of the observed (vertical axes) and modelled (horizontal axes) CF series for the a) [AtliteATL](#), b) [C3S-E-G-C3S GRD](#) and c) [C3S-E-N-modelsC3S NAT datasets](#)

[Figure-Fig. 6](#) shows that the three datasets have a similar tendency to overestimate the CF compared to the observed values, especially for high CF values. The skill scores presented in Table 3 indicate that [C3S-E-G-performs best overall, with the lowest RMSE and a high correlation coefficient, suggesting a closer match to observed data. All models show a slight positive bias, with Atlite exhibiting a slightly lower correlation and higher RMSEC3S GRD and C3S NAT perform better than ATL for solar PV CF, with lower RMSE and MBE, and higher CC scores. This may be due to the statistical approach taken by C3SE for the orientation of the PV panels.](#)

Fig. 7 shows the number of [solar](#) PV drought events during the 2023 validation period across different duration ranges. The figure reveals partial agreement between the three datasets and the observed data, with consistent results noticed for duration ranges of 1-2, 3-4, 7-8, and 8+ days. However,

	At lite <u>ATL</u>	C3S-E-G <u>C3S GRD</u>	C3S-E-N <u>C3S NAT</u>
CC	0.921	0.931	0.931
RMSE	0.119	0.090	0.113
MBE	0.046	0.027	0.021

Table 3: Skill scores for solar PV CF for the three datasets compared to observed data

discrepancies appear in the other ranges, where the models diverge from the observed data. The main challenge in validating solar PV data stems from the recent installation of a large share of Ireland’s solar PV capacity, with over 65% of the total solar PV capacity installed in 2023. This results in uncertainties in solar PV generation data and the actual generating capacity in the first few months after each farm is connected.

~~As the goal of this analysis is to assess the combination of wind and PV generation, the complementary nature of these energy sources mitigates the limitations in PV-only results~~Overall, C3S GRD performs slightly better than the other datasets in reproducing observed solar PV drought events.

4.2. Analysis

In this section, RES droughts are analysed by calculating the frequency and duration of RES drought events, the return periods for different RES drought durations, and the seasonality of RES drought events. Understanding the characteristics and timing of RES drought events enables system operators to optimally plan for reserve capacity requirements, ensuring grid stability and security of supply. Results are presented for the three datasets, allowing their differences on the characterisation of RES droughts to be clearly identified.

RES drought events are evaluated under two different scenarios with fixed installed capacities: the 91W-9PV scenario, with 5.9 GW of wind capacity and 0.6 GW of solar PV capacity; and the 57W-43PV scenario, where wind capacity comprises 11.45 GW and solar PV capacity increases to 8.6 GW. Both scenarios were driven by 45 years of ERA5 data. Using the RES drought identification process described in Section 3.5, wind and solar PV droughts are first analysed separately before presenting the results for combined (wind + solar PV) RES droughts under both scenarios.




Figure 7: Number of solar PV drought events for ~~Atlite~~-ATL (red), ~~C3S-E-G~~-C3S GRD (blue), and ~~C3S-E-N~~-C3S NAT (purple) and the observed data (black outline). The solar PV droughts are identified for 2023, considering the actual capacity of the system at any given time

4.2.1. Annual Number of RES Droughts

The first part of the analysis examines the annual number of RES drought events ~~across the three datasets~~. When only wind energy is considered (Fig. 8a), the number of RES drought events decreases as the duration range increases, with very few events lasting more than seven days. In ~~the case of only~~ contrast, for solar PV energy (Fig. 8b), ~~the number of events also declines as the duration range extends~~ RES drought frequency declines from one to eight days, ~~followed by a slight increase and then slightly increases~~ for longer durations. This ~~increase occurs because Ireland, being located above the 50° parallel, experiences reduced sunlight during the winter months. From~~ behaviour is attributable to Ireland's high-latitude location, where reduced sunlight in winter (from November to March, PV output often remains consistently low, leading to extended periods where generation stays below the CF threshold) leads to consistently low solar PV output.

When comparing wind and PV results (Fig. 8a & b), Moreover, the comparison between wind and solar PV results indicates that the median, first, and third quartiles for solar PV are consistently higher than or equal to those for wind, across all duration ranges and datasets. This is due to the typically lower CF of PV power compared to wind power, especially in a region such as Ireland where solar potential is limited. expected, given that solar PV generation is also inherently lower, zero at night and constrained by the daily solar cycle, leading to a naturally higher frequency of drought events in PV compared to wind.

Fig. 8e & d show the combination of wind and PV under the two capacity scenarios. In the , and limited by the solar cycle. When wind and solar PV are combined under the 91W-9PV scenario (Fig. 8c), the identified RES droughts closely match those for results closely mirror those of wind alone, which is expected due to the dominance of installed wind capacity. In contrast, wind power in the current energy mix. However, in the 57W-43PV scenario (Fig. 8d) shows a clear reduction in the number of drought events, a marked reduction in RES drought events is observed across all datasets and durations, with a decrease of the total number of events of 56% for AtliteATL, 52% for C3S-E-GC3S GRD, and 50% for C3S-E-N. This reduction is attributed to the anti-correlation between wind and PV generationC3S NAT, demonstrating the beneficial effects of a more balanced energy mix.

The median, first, and third quartiles for the Atlite dataset are consistently greater than or equal to those of the other two datasets, regardless of the duration range or type of renewable energy considered. This difference arises from the consistently higher RES drought counts reported by the ATL dataset, compared to the C3S datasets, underscore the importance of wind turbine power curve model used in the C3S-E datasets, which tends to overestimate the wind CF (Fig. 4). As a result, the overall number of RES droughts is underestimated in the C3S-E datasets compared to Atliterepresentation when quantifying RES droughts. Whereas the three datasets agree on the overall effect of balancing the share of wind and solar PV generation, they differ at a quantitative level, which has crucial implications for energy planning.

4.2.2. Return Periods of RES Drought Duration

The RES drought events identified over the 45-year period were used to calculate the return periods for different RES drought durations. A return period is the estimated average time interval between events of a specified




Figure 8: Average annual number of RES droughts (from 1979 to 2023) for a) Wind, b) solar PV, c) 91W-9PV and d) 57W-43PV for Atlite-ATL (red), C3S-E-G-C3S GRD (blue), and C3S-E-N-C3S NAT (purple). The x-axis represents duration ranges in days (lower bound included), while the y-axis indicates the annual number of events. The boxes display the first and third quartiles and the median is marked by a black line. The whiskers indicate the 5th and 95th percentiles

475 duration ~~or intensity~~ (not to be confused with the frequency of their oc-
 476 currence within a fixed time frame). Fig. 9 ~~illustrates~~ shows the return
 477 periods for ~~varying different~~ RES drought durations, ~~highlighting how often~~
 478 ~~different drought lengths are likely to occur across the datasets. This analysis~~
 479 ~~provides insight into the frequency and likelihood of prolonged low-generation~~
 480 ~~periods, which is crucial for evaluating the potential impact of RES droughts~~
 481 ~~on energy reliability and which can be used to capture the most extreme~~
 482 ~~events affecting the system. Understanding their return periods is crucial, as~~
 483 ~~extreme yet rare RES droughts pose the toughest challenge to energy security~~
 484 ~~by placing significant strain on the conventional backup sources necessary to~~
 485 ~~maintain security of supply during these events.~~

486 The duration of wind droughts (Fig. 9a) increases in a log-linear fashion
 487 across the three datasets. The log-linear trend indicates a predictable rela-

488 tionship between wind drought duration and occurrence, with longer wind
489 droughts becoming exponentially less likely as duration increases.

490 In the case of solar PV droughts (Fig. 9b), Atlite behaves differently than
491 the two ~~C3S-E-C3S~~ datasets. The ~~Atlite results~~ ATL dataset show a generally
492 log-linear increase. For ~~C3S-E-G and C3S-E-N~~ C3S GRD and C3S NAT, the
493 duration of PV droughts increases in a log-linear pattern for events lasting
494 less than 16 days. Beyond this duration, there is a sharp rise in solar PV
495 drought duration for events up to a one-year return period. This sudden
496 increase again reflects the impact of extended periods of low PV generation
497 during winter in Ireland.

498 The difference between ~~Atlite and the C3S-E~~ the ATL and the C3S results
499 arises from differences in the datasets near the threshold of 0.1 CF. ~~Atlite~~
500 ATL remains slightly above the threshold more frequently during these condi-
501 tions, leading to shorter, more fragmented RES drought events. In contrast,
502 ~~C3S-E-G and C3S-E-N~~ C3S GRD and C3S NAT tend to fall below the thresh-
503 old in similar conditions, resulting in longer continuous RES drought periods,
504 especially during winter.

505 ~~For Under~~ the 91W-9PV scenario (Fig. 9c), the combined RES drought
506 return periods mirror those ~~of Fig. 9a, due to the low levels of installed PV~~
507 ~~capacity. In for wind alone, reflecting the dominance of wind in the current~~
508 ~~energy mix. In contrast,~~ the 57W-43PV scenario (Fig. 9d) ~~, the return periods~~
509 ~~for RES droughts increase shows a dramatic increase in return periods~~ across
510 all durations, suggesting that a more diversified energy mix can substantially
511 mitigate the frequency of prolonged RES drought events. For example, the
512 return period for a five-day RES drought event (shown by the vertical dashed
513 lines in Fig. 9) extends from roughly six months for the 91W-9PV scenario,
514 to four years for the 57W-43PV scenario in the ~~Atlite-ATL~~ dataset, and from
515 about fifteen months to around five years in the two ~~C3S-E~~ datasets. C3S
516 datasets. Despite the lower wind share in the 57W-43PV scenario, typically
517 known for its relative stability, the balanced share with solar PV leads to
518 extended return periods for RES droughts. This result indicates that the
519 complementarity between wind and solar PV plays a crucial role in reducing
520 the occurrence of RES drought events in a diversified energy portfolio.

521 Across Fig. 9a, c, and, d, the return periods in the ~~Atlite-ATL~~ dataset are
522 consistently higher than those in the two ~~C3S-E-C3S~~ datasets. For instance,
523 in the 91W-9PV scenario (Fig. 9c), an event with a one-year return period
524 lasts six days in the ~~Atlite-ATL~~ dataset, compared to only five days in the
525 ~~C3S-E-C3S~~ datasets. This difference underscores the importance of model se-




Figure 9: Return periods of the duration of RES droughts (from 1979 to 2023) for a) Wind, b) Solar PV, c) 91W-9PV and d) 57W-43PV for Atlite-ATL (red triangle), C3S-E-G-C3S GRD (blue circle), and C3S-E-N-C3S NAT (purple square). The x-axis represents the return period time in a log-scale and the y-axis indicates the duration of RES drought associated with it. The horizontal dashed line marks the 5-day return period, with coloured vertical dashed marking its return period for each dataset

lection when quantifying RES droughts, as each model dataset's assumptions and parametrisations significantly influence drought RES droughts duration estimates. Additionally, in all four graphs, the similarity between results from the two C3S-E-C3S datasets suggests that assumptions in the Atlite model—ATL dataset, such as wind turbine power curve selection and PV panel specifications—, have a greater impact on RES drought duration estimates than the precise geographic distribution of RES farms when studying the return periods of RES droughts.

The return periods calculated from the three datasets show large differences, in particular for the more extreme events with longer return periods. The C3S datasets produce shorter RES drought durations for these events, which would have the largest impact on the power system. This shows that system planning based on the wrong datasets could yield an underestimation of the

duration of extreme RES droughts, potentially leading to shortages linked to undersized reserve capacity.

4.2.3. Seasonal Distribution of RES Droughts

The ~~seasonality~~ seasonal analysis of RES droughts ~~was analysed by comparing~~ is based on the percentage of hours in each month classified as part of a RES drought event. Wind droughts tend to be more frequent during summer, whereas solar PV droughts are more common in winter due to reduced sunlight. By comparing these seasonal patterns across different datasets and energy scenarios, this study examines how model-specific assumptions and variations in capacity mix affect the overall characterisation of RES drought events.

For ~~wind-dominated scenarios~~ the wind-only scenario (Fig. 10a & e), the percentage of hours that are part of a drought is higher in summer than in winter. In the Atlite dataset, for instance, an average of ATL dataset exhibits a pronounced seasonal pattern, with about 24% of hours in summer (June-July-August) are identified as wind droughts, summer hours (June, July, August) identified as RES droughts compared to only 4% in winter (December-January-February December, January, February). This seasonal variation is less prominent for the two C3S-E datasets compared to the Atlite one. This difference can be linked to the shape of the two power curves (Fig. 3). CFs near or under strong seasonal signal is less evident in the C3S datasets, which suggests that the differences in the underlying wind power curves play a significant role. In ATL, CF near or below the 0.1 threshold occur at occurs at relatively higher wind speeds for the Atlite power curve than for the C3S-E one, resulting in a higher count of RES drought hours during the summer months. In contrast, the results for solar PV droughts (Fig. 10b) show a higher percentage in winter, with PV droughts occurring display an opposite seasonal trend. Across all datasets, over 60% of the time regardless of the dataset. The Atlite results show a winter hours are classified as solar PV droughts, reflecting the naturally low solar irradiance in Ireland during winter.

ATL tends to record a slightly higher percentage of ~~PV-RES~~ drought hours for wind, and a slightly and a marginally lower percentage for PV, compared to the two C3S-E datasets.

Percentage of hours in a month which are part of a RES drought (from 1979 to 2023) for a) Wind, b) PV, c) 91W-9PV and d) 57W-43PV for Atlite (red dotted), C3S-E G (blue dashed), and C3S-E N (purple solid). The x-axis

represents the month of the year, and the y-axis indicates the percentage of hours. Lines correspond to the median values and the area between the first and third quartiles is shaded. Note the different y-axis scale for b). solar PV relative to the C3S datasets. These differences highlight how dataset-specific assumptions, such as the treatment of wind turbine power curves and PV panel characteristics, significantly influences the apparent seasonal dynamics of RES droughts.

The 91W-9PV scenario (Fig. 10c) shows patterns comparable to the ones for wind droughts (Fig. 10a). However, in the 91W/9PV scenario, the number of hours classified as RES droughts in summer decreases slightly compared to the wind-only scenario. This reduction can be explained by the contribution of solar PV generation during the summer months in the 91W-9PV scenario, even though it constitutes only 11% of total capacity. Since the number of RES drought hours for solar PV in summer is near zero, this small contribution has a noticeable impact on reducing overall RES drought hours. In the 57W-43PV scenario (Fig. 10d), all three datasets show a reduction in monthly RES drought frequency. Annual reductions in median RES drought frequency are observed across the datasets, dropping from 14% to 5% for AtliteATL, from 8% to 3% for C3S-E-GC3S GRD, and from 9% to 4% for C3S-E-NC3S NAT. The balanced mix of wind and solar PV power in this scenario reduces the seasonal signal overall and significantly decreases the percentage of RES drought hours in the summer.

5. Discussion and Conclusions

This study has investigated the ability of three RES models to represent RES droughts : Atlite, C3S-E-G, and C3S-E-N. One of the most evident differences is how each dataset incorporates the specific locations of RES farms. Both Atlite and C3S-E-G consider the locations of wind and PV farms, which one would expect to result in a more accurate representation of RES generation. While this approach slightly improves PV models, our analysis indicates that for wind energy , the Atlite dataset performs better overall, especially in its close alignment with observed data for wind generation estimates. This finding suggests that, although the inclusion of RES farm locations is beneficial, the accuracy of the RES model is more strongly influenced by underlying model assumptions, such as selecting an appropriate wind power curve. The seasonal variations of RES droughts observed in this study have important implications for energy planning. Energy demand




Figure 10: Percentage of hours in a month which are part of a RES drought (from 1979 to 2023) for a) Wind, b) Solar PV, c) 91W-9PV and d) 57W-43PV for ATL (red dotted), C3S GRD (blue dashed), and C3S NAT (purple solid). The x-axis represents the month of the year, and the y-axis indicates the percentage of hours. Lines correspond to the median values and the area between the first and third quartiles is shaded. Note the different y-axis scale for b).

peaks in winter for Northern European countries, making the seasonality of RES droughts critical for the sizing of reserve capacity. Our results show that selecting the wrong dataset could severely underestimate RES droughts during winter months, thereby affecting the reliability of the energy system during critical periods. Additionally, the integration of large shares of solar PV in the system leads to a generalised reduction of RES droughts, yet winter months present a slight increase. The natural limitations of solar PV lead to inevitably higher reserve capacity needs during winter months as reliance on RES increases. These types of insights are essential to develop targeted strategies that enhance grid resilience and ensure a stable energy supply throughout the year.

Atlite shows the best alignment with observed data for wind generation. Differences between the models are smaller for PV, with C3S-G performing

marginally better than the other two. The results show that the two C3S-E datasets (C3S-E G and C3S-E N) consistently yield similar outcomes, indicating that their methodological differences have minimal impact in this case. This distinction is also evident in the analysis, where Atlite reports higher return periods and a greater number of RES droughts, especially in scenarios with a balanced share of RES. Again, the results from RES drought modelling rely more on the precision of

5. Conclusions

This study has explored the characterisation of RES droughts in the transition from a wind-dominated system to a more balanced system with integrated solar PV, based on the real case of Ireland. Three different datasets were compared over a 45-year period: one created using a regionally validated model and two derived from a generic dataset for Europe, C3S-Energy. The two datasets derived from C3S-Energy present different approaches, with one using large-scale aggregated information only, and the other one including the locations of farms as well. The regionally validated model considered the locations of farms as well as tailored wind and solar PV models selected to best represent the actual generation in Ireland.

Our results show the wind power curve and limitations in the quantification of RES droughts present in datasets that have not undergone regional validation. The three datasets used in this study are able to capture overall trends in RES drought occurrence such as the seasonal cycle or the effect of increasing the share of solar PV. However, significant differences in the quantitative values, particularly the extremes, emerge when using non-validated datasets for the study of RES droughts. This finding highlights that using a non-validated dataset can lead to undersized reserve capacity, with the associated negative consequences for grid stability and security of supply.

This study has also revealed that differences in the wind turbine power curves and solar PV panel models than on the specific locations of RES farms. Atlite's superior performance highlights the importance of selecting validated models for assessing RES drought risks. This careful model selection can better quantify risks, support effective planning, and avoid the potential underestimation of capacity needs, which is essential for ensuring energy security have a stronger influence on the estimation of RES droughts than the consideration of RES farm locations. The two datasets derived from C3S-Energy consistently underestimated the number of wind drought events

and the frequency of extremes when compared to the regionally validated dataset with a specifically selected wind turbine power curve. This suggests that a meticulous selection of the wind turbine power curve to match observed data is crucial for accurately quantifying RES drought risks, thereby supporting more effective energy system planning.

~~Looking at the 57W-43PV scenario, the analysis showed a significant improvement in the management of RES droughts due to the complementary nature~~ Finally, the effect of the integration of solar PV in a wind-dominated system on RES droughts has been explored in a real-case setting based on Ireland. Our analysis has demonstrated that transitioning to a system with similar amounts of wind and PV generation. ~~Wind and PV together perform better in terms of reducing drought frequency and duration than either would individually, largely because of the seasonal anti-correlation between the two energy sources. This diversification reduces the seasonal impact on RES droughts, as PV generation peaks in the summer and solar PV reduces the frequency, duration, and seasonal variability of RES drought events. This improvement is attributed to the complementary nature of wind and solar PV generation, as solar PV typically peaks in summer while wind generation is more consistent in winter. Ireland currently has a highly wind-dependent energy system, but with ambitious targets for PV installations in the coming years.~~ However, this integration is unable to counter the critical winter RES droughts, which coincide with the strongest electricity demand in Northern European countries like Ireland. Still, a more diversified renewable energy mix mitigates extreme RES drought conditions and enhances overall system resilience.

The results presented in this study have four main limitations. First, the presented study uses a fixed threshold to define RES drought events, but other methods could yield different results, even though the main takeaways would be expected to be the same. Second, the definition of RES droughts based on generation does not consider the mismatch between renewable generation and demand, which may be of interest to system operators, as these events put large amounts of strain on the system. Third, the ~~energy mix is expected to approach a balance between wind and PV capacity. While this balanced approach offers a more stable and secure energy supply by mitigating RES drought risks, it is important to note that having similar wind and PV capacities may not optimise other aspects, such as annual energy production or meeting nighttime loads. For policymakers, these findings underscore the importance of meeting these capacity targets to enhance~~

~~energy security through diversification. Additionally, the choice of model for RES drought assessment becomes increasingly critical as more renewable capacity is integrated into the system~~availability of solar PV data is limited to a relatively short time period, as recent expansions in installed capacity have significantly changed the generation landscape. Lastly, the source for weather data is ERA5, which is among the best reanalysis datasets for renewable energy applications, but still comes in a limited spatial resolution.

Future work is planned to extend the current analysis. First, climate projection data will be integrated with different energy scenarios, incorporating the addition of offshore wind, to better understand how climate change might affect RES droughts. Second, expanding the geographic domain of the study to include the rest of Europe would provide a more comprehensive understanding of RES droughts in an interconnected ~~energy~~-electricity grid. This would require extensive verification across other European countries, making it a more complex but highly relevant challenge.

Data Availability

The ERA5 data can be obtained from the Climate Data Store (<https://doi.org/10.24381/cds.adbb2d47>). The ~~C3S-E~~-C3SE dataset is also available from the Climate Data Store (<https://doi.org/10.24381/cds.4bd77450>). Information on wind and solar PV farms in Ireland can be obtained from the EirGrid website (<https://www.eirgrid.ie/grid/system-and-renewable-data-reports>). The Atlite model used in this study is open-source and can be found on GitHub (<https://github.com/pypsa/atlite>). The data and code required to reproduce the analysis in this article will be made available upon acceptance of the manuscript in a public GitHub repository.

Acknowledgments

The research conducted in this publication was funded by Science Foundation Ireland and co-funding partners under grant number 21/SPP/3756 through the NexSys Strategic Partnership Programme.

References

- [1] EuroStat, Renewable Energy Statistics, 2023. URL: https://ec.europa.eu/eurostat/statistics-explained/index.php?title=Renewable_energy_statistics, Accessed: 2024-11-06.
- [2] H. C. Bloomfield, D. J. Brayshaw, L. C. Shaffrey, P. J. Coker, H. E. Thornton, Quantifying the increasing sensitivity of power systems to climate variability, *Environmental Research Letters* 11 (2016) 124025. doi:10.1088/1748-9326/11/12/124025.
- [3] H. C. Bloomfield, D. J. Brayshaw, A. Troccoli, C. M. Goodess, M. De Felice, L. Dubus, P. E. Bett, Y.-M. Saint-Drenan, Quantifying the sensitivity of european power systems to energy scenarios and climate change projections, *Renewable Energy* 164 (2021) 1062–1075. doi:10.1016/j.renene.2020.09.125.
- [4] K. van der Wiel, L. P. Stoop, B. R. H. Van Zuijlen, R. Blackport, M. A. Van den Broek, F. M. Selten, Meteorological conditions leading to extreme low variable renewable energy production and extreme high energy shortfall, *Renewable and Sustainable Energy Reviews* 111 (2019) 261–275. doi:10.1016/j.rser.2019.04.065.
- [5] F. Kaspar, M. Borsche, U. Pfeifroth, J. Trentmann, J. Drücke, P. Becker, A climatological assessment of balancing effects and shortfall risks of photovoltaics and wind energy in germany and europe, *Advances in Science and Research* 16 (2019) 119–128. doi:10.5194/asr-16-119-2019.
- [6] M. Ohba, Y. Kanno, D. Nohara, Climatology of dark doldrums in japan, *Renewable and Sustainable Energy Reviews* 155 (2022) 111927. doi:10.1016/j.rser.2021.111927.
- [7] F. Mockert, C. M. Grams, T. Brown, F. Neumann, Meteorological conditions during periods of low wind speed and insolation in Germany: The role of weather regimes, *Meteorological Applications* 30 (2023) e2141. doi:10.1002/met.2141.
- [8] M. J. Mayer, B. Biró, B. Szücs, A. Aszódi, Probabilistic modeling of future electricity systems with high renewable energy penetration using

- 761 machine learning, *Applied Energy* 336 (2023) 120801. doi:10.1016/j.
762 apenergy.2023.120801.
- 763 [9] D. Raynaud, B. Hingray, B. François, J. Creutin, Energy droughts from
764 variable renewable energy sources in European climates, *Renewable*
765 *Energy* 125 (2018) 578–589. doi:https://doi.org/10.1016/j.renene
766 .2018.02.130.
- 767 [10] K. Z. Rinaldi, J. A. Dowling, T. H. Ruggles, K. Caldeira, N. S. Lewis,
768 Wind and Solar Resource Droughts in California Highlight the Benefits
769 of Long-Term Storage and Integration with the Western Interconnect,
770 *Environmental Science and Technology* 55 (2021) 6214–6226. doi:10.1
771 021/acs.est.0c07848.
- 772 [11] A. Gangopadhyay, A. K. Seshadri, N. J. Sparks, R. Toumi, The role
773 of wind-solar hybrid plants in mitigating renewable energy-droughts,
774 *Renewable Energy* 194 (2022) 926–937. doi:10.1016/j.renene.2022.
775 05.122.
- 776 [12] S. Allen, N. Otero, Standardised indices to monitor energy droughts,
777 *Renewable Energy* 217 (2023) 119206. doi:10.1016/j.renene.2023.11
778 9206.
- 779 [13] J. Kapica, J. Jurasz, F. A. Canales, H. Bloomfield, M. Guezgouz,
780 M. De Felice, Z. Kobus, The potential impact of climate change on
781 european renewable energy droughts, *Renewable and Sustainable En-*
782 *ergy Reviews* 189 (2024) 114011. doi:10.1016/j.rser.2023.114011.
- 783 [14] P. T. Brown, D. J. Farnham, K. Caldeira, Meteorology and climatology
784 of historical weekly wind and solar power resource droughts over western
785 North America in ERA5, *SN Applied Sciences* 3 (2021) 814. doi:10.1
786 007/s42452-021-04794-z.
- 787 [15] C. Bracken, N. Voisin, C. D. Burleyson, A. M. Campbell, Z. J. Hou,
788 D. Broman, Standardized benchmark of historical compound wind and
789 solar energy droughts across the Continental United States, *Renewable*
790 *Energy* 220 (2024) 119550. doi:https://doi.org/10.1016/j.renene
791 .2023.119550.
- 792 [16] H. Lei, P. Liu, Q. Cheng, H. Xu, W. Liu, Y. Zheng, X. Chen, Y. Zhou,
793 Frequency, duration, severity of energy drought and its propagation in

- hydro-wind-photovoltaic complementary systems, *Renewable Energy* (2024) 120845. doi:10.1016/j.renene.2024.120845, 2.
- [17] H. Hersbach, B. Bell, P. Berrisford, S. Hirahara, A. Horányi, J. Muñoz-Sabater, J. Nicolas, C. Peubey, R. Radu, D. Schepers, et al., The ERA5 global reanalysis, *Quarterly Journal of the Royal Meteorological Society* 146 (2020) 1999–2049. doi:10.1002/qj.3803.
- [18] L. Dubus, Y. Saint-Drenan, A. Troccoli, M. De Felice, Y. Moreau, L. Ho-Tran, C. Goodess, R. Amaro E Silva, L. Sanger, C3S Energy: A climate service for the provision of power supply and demand indicators for Europe based on the ERA5 reanalysis and ENTSO-E data, *Meteorological Applications* 30 (2023) e2145. doi:10.1002/met.2145.
- [19] Copernicus Climate Change Service (C3S), Climate and energy indicators for Europe from 1979 to present derived from reanalysis., 2020. doi:10.24381/cds.4bd77450, accessed on 28-11-2024.
- [20] F. Hofmann, J. Hampp, F. Neumann, T. Brown, J. Hörsch, Atlite: a lightweight Python package for calculating renewable power potentials and time series, *Journal of Open Source Software* 6 (2021) 3294. doi:10.21105/joss.03294.
- [21] J. Li, Z. Zhao, D. Xu, P. Li, Y. Liu, M. A. Mahmud, D. Chen, The potential assessment of pump hydro energy storage to reduce renewable curtailment and CO2 emissions in Northwest China, *Renewable Energy* 212 (2023) 82–96. doi:10.1016/j.renene.2023.04.132.
- [22] M. Parzen, H. Abdel-Khalek, E. Fedotova, M. Mahmood, M. M. Frysztacki, J. Hampp, L. Franken, L. Schumm, F. Neumann, D. Poli, et al., Pypsa-earth. a new global open energy system optimization model demonstrated in africa, *Applied Energy* 341 (2023) 121096. doi:10.1016/j.apenergy.2023.121096.
- [23] K. Ali Khan Niazi, M. Victoria, Comparative analysis of photovoltaic configurations for agrivoltaic systems in europe, *Progress in Photovoltaics: Research and Applications* 31 (2023) 1101–1113. doi:10.1002/pip.3727.
- [24] A. Kies, B. U. Schyska, M. Bilousova, O. El Sayed, J. Jurasz, H. Stoecker, Critical review of renewable generation datasets and their

827 implications for european power system models, *Renewable and Sus-*
828 *tainable Energy Reviews* 152 (2021) 111614. doi:10.1016/j.rser.202
829 1.111614.

830 [25] EirGrid & SONI, System and Renewable Data Reports, 2023. URL:
831 [https://www.eirgrid.ie/grid/system-and-renewable-data-rep](https://www.eirgrid.ie/grid/system-and-renewable-data-reports)
832 [orts](https://www.eirgrid.ie/grid/system-and-renewable-data-reports), Accessed: 2024-11-06.

833 [26] N. Otero, O. Martius, S. Allen, H. Bloomfield, B. Schaeffli, Character-
834 izing renewable energy compound events across Europe using a logistic
835 regression-based approach, *Meteorological Applications* 29 (2022) e2089.
836 doi:10.1002/met.2089, 13.

837 [27] Y.-M. Saint-Drenan, L. Wald, T. Ranchin, L. Dubus, A. Troccoli, An
838 approach for the estimation of the aggregated photovoltaic power gener-
839 ated in several European countries from meteorological data, *Advances*
840 *in Science and Research* 15 (2018) 51–62. doi:10.5194/asr-15-51-201
841 8.

842 [28] I. Staffell, S. Pfenninger, Using bias-corrected reanalysis to simulate
843 current and future wind power output, *Energy* 114 (2016) 1224–1239.
844 doi:10.1016/j.energy.2016.08.068.

845 [29] Government of Ireland, Climate Action Plan 2024, Technical Report 3,
846 Department of the Environment, Climate and Communications, 2023.
847 URL: [https://www.gov.ie/pdf/?file=https://assets.gov.ie/](https://www.gov.ie/pdf/?file=https://assets.gov.ie/284675/70922dc5-1480-4c2e-830e-295afd0b5356.pdf)
848 [284675/70922dc5-1480-4c2e-830e-295afd0b5356.pdf](https://www.gov.ie/pdf/?file=https://assets.gov.ie/284675/70922dc5-1480-4c2e-830e-295afd0b5356.pdf), Accessed:
849 2024-11-06.

850 [30] Sustainable Energy Authority Ireland, National Energy Projections
851 2024, Technical Report, Sustainability Energy Authority of Ireland,
852 2024. URL: [https://www.seai.ie/news-and-events/news/energ](https://www.seai.ie/news-and-events/news/energy-projections-report)
853 [y-projections-report](https://www.seai.ie/news-and-events/news/energy-projections-report), Accessed: 2024-11-06.

854 [31] H. G. Beyer, G. Heilscher, S. Bofinger, A robust model for the mpp
855 performance of different types of pv-modules applied for the performance
856 check of grid connected systems, *Eurosun* (2004) 8.