

COLDPROOF

DIGITAL PHARMACOVIGILANCE REPORT . . .

COLDPROOF EXCURSION REPORT

Fridge ID Domestic/Bar Fridge (Non-Compliant)
Date Range Analysed Not specified

GEYER Classification	GEYER RED
Outcome Status	CRITICAL

Clinical Summary

Fridge Name	Domestic/Bar Fridge (Non-Compliant)
Model	Model not specified
Date Range	Not specified
Total Data Points	156980
Number of Excursions	94
Longest Excursion	2983.2 minutes
Time Above 8°C	7802.2 minutes
Time Below 2°C	0.0 minutes
Classification Rule Triggered	REPORTABLE BREACH

GEYER Classification

GEYER RED
Reason: Critical breach

Pharmacist Review

Summary Interpretation: The refrigerator demonstrated temperature behaviour that may be inconsistent with Strive-for-5 guidelines. A risk-based assessment is indicated.


Action:

- Quarantine stock where appropriate.
- Supervisor pharmacist review required.
- Document the outcome in the local clinical governance system.

Fridge Signature

Mean temperature	N/A
Min / max	5.8 °C / 38.7 °C
Drift	N/A
Spike frequency	N/A
Cooling return slope	N/A
Power-cycle detection	N/A
Sensor noise index	N/A

Fridge Signature Trace



Interpretation Notes

- Wide range and/or high variability suggests domestic/non-compliant fridge.

Excursions (Audit Record)

Start Time	End Time	Duration (min)	Peak Temp (°C)	GEYER Rule	Notes
02-09-2024 09:26	02-09-2024 21:14	707.7	22.2	Reportable	
02-09-2024 21:14	02-09-2024 21:14	0.2	8.1	Non-reportable	
02-09-2024 21:14	02-09-2024 21:14	0.1	8.1	Non-reportable	
02-09-2024 21:16	02-09-2024 21:16	0.0	8.1	Non-reportable	
02-09-2024 21:16	02-09-2024 21:16	0.0	8.1	Non-reportable	
02-09-2024 21:22	02-09-2024 21:22	0.0	8.1	Non-reportable	
02-09-2024 21:22	02-09-2024 23:19	116.8	9.6	Reportable	
02-09-2024 23:19	02-09-2024 23:19	0.2	8.1	Non-reportable	
02-09-2024 23:26	02-09-2024 23:27	0.1	8.1	Non-reportable	
02-09-2024 23:27	02-09-2024 23:27	0.0	8.1	Non-reportable	
02-09-2024 23:27	02-09-2024 23:27	0.1	8.1	Non-reportable	
02-09-2024 23:28	02-09-2024 23:28	0.0	8.1	Non-reportable	
02-09-2024 23:28	02-09-2024 23:28	0.0	8.1	Non-reportable	
02-09-2024 23:28	02-09-2024 23:28	0.0	8.1	Non-reportable	
02-09-2024 23:29	02-09-2024 23:29	0.0	8.1	Non-reportable	
02-09-2024 23:29	02-09-2024 23:29	0.0	8.1	Non-reportable	
02-09-2024 23:29	02-09-2024 23:29	0.0	8.1	Non-reportable	
02-09-2024 23:48	03-09-2024 19:58	1210.0	24.6	Reportable	
03-09-2024 19:58	03-09-2024 19:58	0.0	8.1	Non-reportable	
03-09-2024 19:58	03-09-2024 19:58	0.0	8.1	Non-reportable	
03-09-2024 19:59	03-09-2024 19:59	0.0	8.1	Non-reportable	
03-09-2024 19:59	03-09-2024 19:59	0.0	8.1	Non-reportable	
03-09-2024 19:59	03-09-2024 19:59	0.1	8.1	Non-reportable	
03-09-2024 19:59	03-09-2024 19:59	0.0	8.1	Non-reportable	
03-09-2024 20:00	03-09-2024 20:00	0.0	8.1	Non-reportable	
03-09-2024 20:00	03-09-2024 20:04	4.1	8.1	Non-reportable	
03-09-2024 20:04	03-09-2024 20:04	0.0	8.1	Non-reportable	
03-09-2024 20:11	04-09-2024 00:11	239.2	10.0	Reportable	
04-09-2024 00:11	04-09-2024 00:11	0.0	8.1	Non-reportable	
04-09-2024 00:12	04-09-2024 00:12	0.1	8.1	Non-reportable	
04-09-2024 00:13	04-09-2024 07:43	450.0	11.6	Reportable	
04-09-2024 07:43	04-09-2024 07:43	0.1	8.1	Non-reportable	
04-09-2024 07:43	04-09-2024 07:43	0.0	8.1	Non-reportable	
04-09-2024 07:43	04-09-2024 07:43	0.0	8.1	Non-reportable	
04-09-2024 07:43	04-09-2024 07:43	0.0	8.1	Non-reportable	

Clinical Interpretation

The recorded excursions indicate periods where product temperatures may have been outside the recommended 2–8°C range. The pattern and duration of excursions should be interpreted in the context of vaccine stability data, storage conditions, and local policy.

Final Recommendation: Review Required

ColdProof recommends that stock stored during the flagged excursions be quarantined and assessed by a supervising pharmacist, with outcomes documented in accordance with Strive-for-5 and local clinical governance.