





CONCEPT, NOT FOR FABRICATION

EmberGuard · github.com/BoujeeEnjinia1701/emberguard

REV	DESCRIPTION	DATE	BY
P1	Concept sheet	2026-09-26	AC



KEY FIGURES

- Two 32 x 24 px thermal arrays in gutter-corner pods look along each gutter
- Open gutter in view 1.25 to 12.95 m; hanger straps hide deep debris beyond 7.8 m
- Leeward zone only in wind: 4 L/min steady draw
- About 965 L per 4 h ember event
- 67.5 Wh needed against 115 Wh usable (10 Ah battery)
- Kit parts \$605 within the \$605 budget (TRL 3 estimate)

EMBERGUARD

github.com/BoujeeEnjinia1701/emberguard

Ember watch mast and eave spray concept

DRAWING NO. EGD-DWG-010		REV P1	SHEET 1 of 1	SIZE ANSI B
SCALE 1:100	UNITS mm	PROJECTION 	DATE 2026-09-26	DRAWN Amish Chadha
MATERIAL / NOTES Massing model for concept communication				
Licensed CERN-OHL-S-2.0 · Design Molecule Lab · designmolecule.com			Generated from cad/src; do not edit by hand	