


CONCEPT, NOT FOR FABRICATION


EmberGuard · github.com/BoujeeEnjinia1701/emberguard

REV	DESCRIPTION	DATE	BY
P1	Concept sheet	2026-09-26	AC




TOP VIEW

Scale 1:100; looking down (along -Z)




FRONT VIEW

Scale 1:100; looking at the front (along +Y)



RIGHT VIEW

Scale 1:100; looking at the right side (along -X)



ISOMETRIC VIEW

Not to scale; figure is a 1.75 m person; seen from the front right and above, about 30 deg elevation

KEY FIGURES

- Two 32 x 24 px thermal arrays in gutter-corner pods look along each gutter
- Open gutter in view 1.25 to 12.95 m; hanger straps hide deep debris beyond 7.8 m
- Leeward zone only in wind: 4 L/min steady draw
- About 965 L per 4 h ember event
- 67.5 Wh needed against 115 Wh usable (10 Ah battery)
- Kit parts \$605 within the \$605 budget (TRL 3 estimate)

EMBERGUARD

github.com/BoujeeEnjinia1701/emberguard

Ember watch mast and eave spray concept

DRAWING NO. EGD-DWG-010			REV P1	SHEET 1 of 1	SIZE ANSI B
SCALE 1:100	UNITS mm	PROJECTION 	DATE 2026-09-26	DRAWN Amish Chadha	

MATERIAL / NOTES
Massing model for concept communication