

HEATMAP NODE · CALCULATION

HeatMap Node sizing calculations

Design Molecule Lab · designmolecule.com

DOCUMENT CONTROL

Document ID	HMN-CAL-001	Version	0.2
Status	Draft	Date	2026-09-25
Author	Amish Chadha	License	CERN-OHL-S-2.0
Project TRL	TRL 3 Proof of concept		
Repository	github.com/BoujeeEnjinia1701/heatmap-node		
Source	docs/04-calcs/01-sizing.md @ bcf6063		

REVISION HISTORY

Version	Date	Author	Change
0.2	2026-09-25	Amish Chadha	Recommendations accepted by Amish (DDR-002)
0.1	2026-09-25	Amish Chadha	First issue for TRL 3 (mean radiant temperature, natural wet bulb and WBGT error budget, shield error, globe response and probe, height and shading, power, data, wind and clamp, outdoor temperatures, fit and installation, mass, cost)

HeatMap Node sizing calculations

On paper, HeatMap Node now meets or is on track for thirteen of its fifteen requirements; two are not met. Version 0.2 applies the decisions Amish accepted on 2026-09-25 (HMN-DDR-002): a small fan aspirates the radiation shield before each air reading, R4, R8, R13 and R15 are restated, the saddle is formed from sheet, the arm points toward the equator with the FieldNode core below it, and the FieldNode core carries FieldNode's hot-climate sun shield. The heat stress method is unchanged: in the worked example (35 °C air, 40 %RH, 50 °C globe, 1 m/s wind) mean radiant temperature is 74.8 °C and WBGT is 31.7 °C, and with the fan the input errors add up to ± 0.30 °C of WBGT (root sum square), against ± 0.59 °C with the passive shield. The two misses are R9, because the sensors sit at about 2.7 m, where the air is 0.2 to 0.8 °C cooler than at pedestrian height on a sunny afternoon, and R13, because the sensor head costs \$127 against the \$120 budget: the \$7 fan and cowl outweigh the \$3 saved on the saddle once the pole adapter is counted against FieldNode. The new orientation raises one new problem: the shield, globe and arm shade 16 to 44 % of the FieldNode panel near noon (section E). Every number in this note is printed by `docs/04-calcs/sizing.py`; the tag in brackets, for example [A1], is the line of that script's output that carries it.

Safety: These are first-principles estimates for a paper proof of concept. They do not show that a place is safe or unsafe for people, and HeatMap Node data must not be used to decide whether a particular person may work or exercise. Pole mounting, the pole's added wind load and the FieldNode cell are safety matters; see HMN-PRC-001, Safety.

■ Scope and method

The note checks every requirement in HMN-REQ-001 v0.4 against the design in HMN-PRC-001 v0.4 and the parametric model `cad/src/model.py`. The script imports the model's `PARAMS`, derived dimensions and part solids, so the heights, lengths, areas and volumes used here are those in the STEP files and in drawing HMN-DWG-001. It also reads `bom/bom.csv` and `budget_usd` in `project.yaml`. FieldNode figures (mass, cost, wind load, interior temperature, airtime, sensor allowance) are quoted from FND-CAL-001 v0.2 for the hot-climate node with its sun shield, and the calibration reference uncertainty from CLR-CAL-001 v0.1; no sibling repo was edited. Run the script from the repo root with `python docs/04-calcs/sizing.py`.

The design case is a node on a 114.3 mm (4.5 in) street pole with the arm axis 2.8 m above the pavement, air temperature up to 50 °C, full sun and 15 min reporting.

■ Assumptions

Table 1. Main assumptions.

Area	Assumption	Basis
Globe	150 mm copper sphere, 0.4 mm wall, emissivity 0.95; convection coefficient the larger of $6.3 v^{0.6} / D^{0.4}$ (forced) and $1.4 (\Delta T / D)^{0.25}$ (natural) W/m ² K	ISO 7726:1998 method as implemented in the open <code>pythermalcomfort t_mrt</code> function (defaults 0.15 m and 0.95). The coefficients 6.3 and 1.4 are the commonly quoted values and were not read from the standard itself; $6.3/\sigma$ equals the 1.1×10^8 of the TRL 2 precis [A1]
Wet bulb	Notional wick 7 mm diameter; cylinder in cross flow $Nu = 0.683 Re^{0.466} Pr^{(1/3)}$; Chilton-Colburn heat and mass analogy, Lewis number 0.85; the wick sees the radiant environment measured by the globe	Textbook correlations. A simplified stand-in for the Liljegren et al. (2008) model, which the data server will use through its open implementation
Sensors	SHT45 typical ± 0.1 °C and ± 1.0 %RH (Sensirion); globe probe ± 0.3 °C (R3); anemometer ± 0.5 m/s (R4) and start-up 0.8 m/s	Sensirion product page (checked 2026-09-25); anemometer start-up is a typical low-cost value, unverified
Shield	White ASA plates, solar absorptance 0.25; half of the absorbed heat reaches the air passing the sensor; with the fan off, air inside the stack moves at a quarter of the wind speed; 1,000 W/m ² global irradiance, sun 60° high, pavement albedo 0.15	Assumed; only a side-by-side test can set these
Fan	60 x 60 x 15 mm 5 V class fan, 0.90 W, 6.6 L/s (about 14 CFM) free air, 60 % of it delivered through the stack; FieldNode 5 V rail 85 % efficient; T and RH sensor time constant 2 s with its membrane cap	Typical values for the fan class and assumed shares; not checked against a chosen part
Height	Surface-layer similarity (Businger-Dyer functions) with a 250 W/m ² sensible heat flux from sunlit pavement and a 0.1 m roughness length	Assumed; similarity theory is only approximate inside a street canyon
Wind	35 m/s gust (750 Pa); drag coefficients 0.5 on the globe, 1.2 on the shield, mast and hub, 1.4 on open cups, 2.0 on the square arm	Screening values, not a code check
Clamp	1,000 N preload per strap band, friction coefficient 0.4	As FND-CAL-001, to keep the two notes consistent
Materials	Aluminium 6063, E 69 GPa, yield 145 MPa; aluminium 2.7, ASA 1.07, stainless 7.9, copper 8.96 g/cm ³	Handbook values
FieldNode	Hot-climate node with the sun shield: 2.55 kg, \$134.00 (\$126.00 base plus the \$8.00 shield), 88 N at 35 m/s (panel 52.2 N, shielded enclosure 36.3 N), interior 7.2 K above ambient when dusty with the sun in its worst position (28.3 K without the shield); 100 mW design sensor allowance, 32 B per stored reading, 23.7 s/day airtime at SF9	FND-CAL-001 v0.2

■ A. Mean radiant temperature from the globe (R3, R4, R5)

- **Worked example.** At 35 °C air, 50 °C globe and 1 m/s, the forced convection coefficient is 13.5 W/m²K against 4.4 W/m²K for natural convection, and MRT is 74.8 °C [A1]. The TRL 2 figure of about 75 °C stands.

- **Wind is the weakest input.** With 0.5, 1.5 and 3.0 m/s instead of 1 m/s, MRT is 66.9, 80.7 and 93.9 °C [A2]. A 0.5 m/s wind error moves MRT by about 6 to 8 °C; a 1 °C air temperature error moves it by 1.5 °C and a 0.3 °C globe error by 0.7 °C [A3].
- **Calm air.** Natural convection governs only below 0.16 m/s [A4]. Below the anemometer's start-up speed the node reads zero wind: at a true 0.5 m/s, MRT is then computed as 58.8 °C instead of 66.9 °C, 8.2 °C low [A5]. R4 now covers 0.8 to 20 m/s (HMN-DDR-002), and intervals with a large share of calm air are flagged by the server (section G) rather than corrected.

■ B. Natural wet bulb and WBGT (R5)

- **Check of the wick model.** With no radiant excess the model gives a wet bulb of 24.2 °C at 35 °C and 40 %RH [B1], the psychrometric value the TRL 2 precis assumed (about 24.5 °C).
- **Worked example.** In sun the natural wet bulb is 26.0 °C, and $WBGT = 0.7 \times 26.0 + 0.2 \times 50 + 0.1 \times 35 = 31.7$ °C [B2]. The TRL 2 estimate (about 31 °C, with an assumed 1 °C sun excess on the wet bulb) is slightly low; the model gives a 1.8 °C excess.
- **Sensitivity.** Per unit input, WBGT moves 0.53 °C per °C of air temperature, 0.15 °C per %RH, 0.28 °C per °C of globe temperature and -0.18 °C per m/s of wind [B3]. Air temperature matters most, because it enters WBGT directly, through the wet bulb and through MRT.
- **Error budget.** With the fan-aspirated shield (section C) the input terms are 0.23 °C (air temperature), 0.15 °C (humidity), 0.09 °C (globe) and 0.09 °C (wind): ± 0.30 °C root sum square and ± 0.55 °C worst case [B4]. With the passive shield at 1 m/s (v0.1) they were ± 0.59 °C and ± 0.88 °C [B5].
- **Calm air.** A true 0.5 m/s read as zero raises the computed WBGT by 0.9 °C [B6].
- **R5 is at risk.** The input budget fits the ± 1.0 °C target with a wide margin, and flagged calm intervals (section G) are marked rather than trusted, but the error of the Liljegren model itself against a reference WBGT meter is not included and can only be found by collocation.

■ C. Radiation error of the shield, passive and fan-aspirated (R1)

- **Heat input.** In full sun the top, sides and underside of the stack present 82, 59 and 70 cm² and absorb 3.74 W; with the fan off, air crosses the stack through about 60 cm² [C1].
- **Passive error (fan off).** The air at the sensor would read 2.09 °C high at 0.5 m/s, 1.04 °C at 1 m/s, 0.52 °C at 2 m/s and 0.35 °C at 3 m/s [C2]; with half the assumed ventilation, 2.09 °C at 1 m/s [C3]. This was the v0.1 design and is why R1 was not met.
- **Fan (HMN-DDR-002).** A 60 mm, 0.90 W fan in a cowl on the top plate draws about 4.0 L/s up the 56 mm center column of the stack, about 1.6 m/s. The steady error is 0.40 °C whatever the wind; after 6 s of running from the passive 1 m/s state the sensor reads 0.43 °C high [C4]. The fan needs at least 3.4 L/s through the stack, about half its assumed free-air flow, to hold ± 0.5 °C [C6], so the margin rests on the chosen fan and on how much flow the plate stack lets through.
- **Firmware rule.** The FieldNode switches the 5 V port on for 6 s every 3 min and reads the temperature and humidity sensor at the end of the run: 480 aspirated readings a day, 5 per 15 min mean. That costs 35.3 mW on average from the cell [C5].
- **R1 is met on paper** (± 0.5 °C at any wind speed), subject to the assumed fan flow and heat-transfer factors, which only a side-by-side test against an aspirated reference can confirm.

■ D. Globe response and probe accuracy (R3)

- **Globe.** The 0.4 mm copper shell weighs 253 g; with a 20 g boss its heat capacity is 105 J/K [D1]. The shell alone has a time constant of 1.8 min at 0.3 m/s, 1.2 min at 1 m/s and 0.7 min at 3 m/s [D2].
- **Bead inside.** The epoxy bead couples to the shell by radiation and still air inside the sphere, with a time constant of 4.2 min. Globe and bead together respond with a time constant of about 5.4 min at 1 m/s, a 90 % response in about 12 min [D5], inside the 30 min of R3. This is faster than the 20 to 30 min estimated at TRL 2. Conduction along the probe stem is not included and only a step test can confirm the figure.
- **Probe.** At 50 °C the NTC reads 3.59 k Ω ; in a 10 k Ω divider the slope is 24.3 mV/K, a 12-bit step is 33 mK, and self-heating is 0.21 mW for the 10 ms the divider is on [D3], which is negligible.
- **Calibration.** Calibrated in CalRig before it is fitted to the globe, the probe's expanded uncertainty is ± 0.18 °C with CalRig's typical reference, or ± 0.26 °C if the reference sensor is only as good as a maximum tolerance would allow [D4]. **R3 is met on paper.**

■ E. Measurement height and pole shading (R9)

- **Height correction.** On a sunny afternoon the air near the pavement is warmer than at the sensor. At 1 m/s the estimate gives +0.72 °C at 1.1 m, +0.44 °C at 1.5 m and +0.21 °C at 2.0 m relative to the 2.69 m of the shield; at 3 m/s, +0.80, +0.50 and +0.24 °C [E1]. A node at 2.7 m therefore reads pedestrian-height air temperature low by up to about 0.8 °C in strong sun, which would enter WBGT at about 0.4 °C (section B). At night and in shade the difference is smaller or reversed. The radiant field changes less with height, because the pavement fills about half of the globe's view at any height above an open street; walls change this in narrow streets.
- **R9 is not met.** The target is unchanged under HMN-DDR-001 D2, decided by Amish on 2026-09-25; the correction above, with a pilot comparing 2.0 and 2.8 m (TRL 4, on hold), is the decided path. The fan cowl lowers the shield by 25 mm, so the sensors now sit at 2.67 to 2.69 m.
- **Pole shading of the globe.** From the globe, the 114 mm pole spans 13.0°. With the arm pointing east or west the sun would pass behind it for about 0.9 h a day. The arm now points toward the equator (HMN-DDR-002), so the pole is on the poleward side of the globe, which the sun reaches only in the tropics, near noon and high in the sky [E2].
- **Shading of the FieldNode panel.** With the core below the arm and both facing the equator, the shield, cowl, globe and arm cast shadows onto the FieldNode panel. With the sun straight along the arm, 44 % of the panel is shaded at 30° elevation, 34 % at 45°, 27 % at 60° and 16 % at 75°; 30° off the arm's azimuth the shares are 15 to 33 %, and 60° off, 1 to 17 % [E3]. Shade on part of a series-connected panel can cut its output by much more than the shaded share, depending on its bypass diodes. This was not foreseen when the orientation was recommended and is raised in docs/REVIEW.md as a new item awaiting Amish.

■ F. Sensor power (R7)

The temperature and humidity sensor takes about 11 μ J per reading, now 480 times a day, and the NTC divider 8 μ J, 1,440 times a day; with the anemometer's reed resting closed in the worst case (0.109 mW), the sensors alone draw 0.116 mW [F1], [F2]. The fan adds 35.3 mW (section C), for a total of 35.4 mW, 35 % of FieldNode's 100 mW design allowance (FND-CAL-001) [F2]. **R7 is met on paper**, with the margin now set by the fan. The panel shading in section E reduces harvest and is not included in FieldNode's energy budget.

■ G. Payload, airtime and storage (R6)

- **Payload.** Eleven fields fit in 20 B: means of air temperature, humidity, globe temperature and wind, maxima of air and globe temperature, the gust, the share of the interval below the anemometer's start-up, battery voltage, status and a sequence number [G1]. The calm-share byte lets the server flag intervals where the MRT and WBGT are biased (sections A and B).
- **Airtime and storage.** At 96 uplinks a day the node uses 23.7 s/day of airtime at SF9 (FND-CAL-001). Seven days of records at FieldNode's 32 B each take 21.5 kB [G2]; the TRL 2 figure of 13 kB assumed 20 B records.
- **Calm flag.** The server marks MRT and WBGT as biased high in calm air for any interval whose calm share (time below the 0.8 m/s start-up) is 20 % or more, that is 3 min of 15 [G4]. This is the rule under the restated R4 (HMN-DDR-002); the threshold is a starting value for the pilot.
- **Latency.** Each 15 min mean is sent as its interval closes and reaches the gateway within about 16 min. The 1.02 % of uplinks lost at TwinKit's worst case arrive with the next uplink at about 31 min [G3]. **R6 is met on paper** for 99 % of intervals.

■ H. Wind load, arm and clamp (R11)

- **Loads.** A 35 m/s gust across the arm puts 6.6 N on the globe, 10.7 N on the shield, 2.1 N on the fan cowl, 7.2 N on the anemometer and 19.5 N on the arm: 46.1 N on the sensor head [H1]. The TRL 2 estimate of 110 N included the FieldNode panel and enclosure (88 N with the sun shield in FND-CAL-001 v0.2).
- **Arm.** The 25 x 25 x 2 mm tube (second moment of area 16,345 mm⁴) sees 14.1 N·m at its root and 10.8 MPa, a factor of 13.4 on yield [H2]. Its tip deflects 0.29 mm at 20 m/s and 0.89 mm at 35 m/s [H3], far inside the 10 mm of R11. Torsion from the offset loads is 0.84 N·m [H4].
- **Clamp.** Wind twists the arm about the pole with 18.2 N·m against 45.7 N·m of band friction, a factor of 2.5. The 1.20 kg on the arm, with its center of mass 435 mm out, pulls the upper band with 36 N against 2,000 N, and pushes down with 12 N against 800 N of friction [H5]. The formed 3 mm sheet saddle carries these loads through the band preload; its bending stiffness has not been checked and should be at detail design. **R11 is met on paper**, subject to the preload, which a torque figure at installation must secure; the twist factor of 2.5 is the smallest margin in this section.
- **Pole.** The node adds 46 N (head) plus 88 N (FieldNode with its shield) and about 337 N·m at the pole base [H6]. The pole owner should check this against the pole's rating.

■ I. Outdoor temperatures (R8)

- **Sensor head.** At 50 °C air and an 80 °C radiant field in near calm, the globe reaches 67.4 °C [I1]. The SHT45 and a 125 °C class epoxy NTC (assumed rating) are well within their limits; the ASA plates and aluminium arm are too.
- **FieldNode core.** HeatMap nodes now carry FieldNode's hot-climate sun shield (HMN-DDR-002). With it the core's interior runs up to 7.2 K above ambient when dusty with the sun in its worst position, 57.2 °C at 50 °C air, against a 70 °C electronics rating; without it the figure would be 78.3 °C [I2]. R8 is restated to +50 °C at the node, matching HMN-PRB-001. **R8 is met on paper**, resting on FieldNode's assumed shield factor.

■ J. Fit to poles and installation (R10)

- **Fit.** A 120° V-saddle touches a round pole at $\pm r \cos 60^\circ$ from its center line: ± 15 mm on a 60 mm pole, ± 29 mm on a 114 mm pole and ± 50 mm on a 200 mm pole, all inside the saddle's ± 55 mm; strap bands 338 to 778 mm

long cover the range [J1]. The same V-block geometry is used in the FieldNode adapter, because FieldNode's own 50 mm V-blocks only seat on poles up to about 71 mm (FND REVIEW). The fit part of R10 is met by design, with no drilling.

- **Time.** The tasks add up to 37 min for two people working in turn from one lift, with the arm and its sensors assembled on the ground [J2], against 30 min. **R10 is at risk**; only a timed trial can settle it.

■ K. Mass (R15)

- **Sensor head.** Arm 273 g, clamp 397 g (formed sheet saddle, 172 g lighter than the 5 mm wall), shield 230 g, fan and cowl 61 g, sensor 20 g, globe 283 g, probe 10 g, anemometer 300 g, harness 270 g, lanyards 20 g and hardware 50 g: 1.91 kg [K1].
- **Against R15.** R15 now covers the sensor head only (HMN-DDR-002), so 1.91 kg against 4.0 kg: **R15 is met on paper**. For information, with the FieldNode core and its sun shield (2.55 kg) and the pole adapter (0.24 kg) the complete node weighs 4.70 kg [K2]. The largest part other than the arm is the 290 mm FieldNode panel, within the 300 mm limit [K3].

■ L. Cost (R13)

The BOM has 13 lines. Under HMN-DDR-002 the pole adapter (line 12, \$7) counts against the FieldNode core, as it fixes a FieldNode fit limit, and the saddle is formed from sheet (\$3 saved). The sensor head (lines 2 to 11 and 13) costs \$127.00; the FieldNode core with its sun shield and the adapter (lines 1 and 12) cost \$141.00, and the full node \$268.00 [L1]. Against the \$120 `budget_usd`, which covers the sensor head only, the head is over by \$7.00 [L2]: without the fan the two decisions would have brought it to exactly \$120.00, and the fan and cowl (line 13) add \$7. **R13 is not met**. The options are in `docs/REVIEW.md`, awaiting Amish.

■ M. Results against every requirement

Table 2. Requirement status from this note.

ID	Requirement	Value	Target	Status
R9	Measurement height	Sensors at 2.67 to 2.69 m; pedestrian air 0.2 to 0.8 °C warmer [E1]	1.1 to 2.0 m	Not met
R13	Cost	Sensor head \$127.00 [L1]	\$120 or less (sensor head, excluding the FieldNode core and its pole adapter)	Not met (\$7 over)
R5	Derived heat stress	Input budget ± 0.30 °C RSS, ± 0.55 °C worst [B4]; calm intervals flagged [G4]; model error unknown	WBGT within ± 1.0 °C of a reference meter	At risk
R10	Fit to existing poles	Fits 60 to 200 mm [J1]; 37 min [J2]	Band clamps, no drilling, 30 min	At risk
R14	Traceable data	Probe calibrated before fitting fits a CalRig bay; the assembled globe does not (150 mm against a 90 x 70 x 50 mm bay); payload format defined [G1]	CalRig record per node; open documented format	At risk
R1	Air temperature accuracy	0.43 °C with the fan at any wind speed [C4]; 1.04 °C at 1 m/s with the fan off [C2]	± 0.5 °C	Met on paper (fan flow assumed)
R3	Globe temperature	± 0.18 °C (± 0.26 °C) [D4]; 90 % response about 12 min [D5]	± 0.3 °C; 30 min	Met on paper
R4	Wind speed	Start-up about 0.8 m/s (typical, unverified); calm share sent and flagged [G1], [G4]	0.8 to 20 m/s; calm intervals flagged	Met on paper (start-up unverified)
R6	Reporting	20 B, 23.7 s/day at SF9, 21.5 kB for 7 days, 16 min latency for 99 % [G1] to [G3]	15 min means; 30 min; 7 days	Met on paper
R7	Power autonomy	35.4 mW with the fan, 35 % of the allowance [F2]	5 days without sun on FieldNode	Met on paper (panel shading not included)
R8	Outdoor survival	FieldNode interior 57.2 °C at 50 °C air with its sun shield [I2]; sensor head parts within ratings	Operate at -20 to +50 °C at the node	Met on paper (shield factor assumed)
R11	Wind survival	Factor 13.4 on the arm; clamp twist factor 2.5; 0.29 mm at 20 m/s [H2] to [H5]	No failure at 35 m/s; under 10 mm at 20 m/s	Met on paper (preload assumed)
R15	Mass and loading	Sensor head 1.91 kg [K2]; largest part 290 mm [K3]	4 kg or less (sensor head); 300 mm	Met on paper
R2	Relative humidity	SHT45 ± 1.0 %RH typical	± 3 %RH	Met by design
R12	Privacy	No camera, microphone or radio scanning parts; payload has environmental fields only [G1]	Environmental data only	Met by design

Counts: 2 not met, 3 at risk, 8 met on paper, 2 met by design. In v0.1 the counts were 6 not met, 3 at risk, 4 met on paper and 2 met by design. None is left wholly unverifiable at TRL 3, although R1, R5, R8 and R10 each rest on assumptions that only a test can settle.

■ Checks against the TRL 2 figures

Table 3. TRL 2 claims (HMN-PRC-001 v0.2) against this note.

TRL 2 claim	This note	Action
MRT about 75 °C in the worked example	74.8 °C	Stands
WBGT about 31 °C	31.7 °C (natural wet bulb 26.0 °C, not 25.5 °C)	Precis updated
MRT about 67 / 80 °C at 0.5 / 1.5 m/s	66.9 / 80.7 °C	Stands
Globe response 20 to 30 min	About 12 min to 90 %	Precis and REQ updated
Sensor load under 1 mW; allowance about 115 mW	0.116 mW; 100 mW design allowance (115 mW published)	Precis updated
7 days of data about 13 kB	21.5 kB at FieldNode's 32 B records	Precis updated
Wind load about 110 N; about 17 N·m at the arm root	Head 46.1 N plus FieldNode 88 N (v0.2); 14.1 N·m at the root	Precis updated
Mass about 3.3 kg	4.70 kg complete node, 1.91 kg sensor head (v0.2)	Precis updated; R15 restated to the sensor head and met
Sensor head about \$120; full node about \$246	\$127.00; \$268.00 (v0.2)	Precis, BOM notes updated
Arm at about 2.8 m	Arm axis 2.80 m; sensors at 2.67 to 2.69 m (v0.2)	Stands