

SUNCLAVE · DESIGN DECISIONS REGISTER

SunClave design decisions register

Design Molecule Lab · designmolecule.com

DOCUMENT CONTROL

Document ID	SCL-DEC-001	Version	0.4
Status	Draft	Date	2026-10-03
Author	Amish Chadha	License	CERN-OHL-S-2.0
Project TRL	TRL 3 Proof of concept		
Repository	github.com/BoujeeEnjinia1701/sunclave		
Source	docs/06-design-decisions.md @ uncommitted		

REVISION HISTORY

Version	Date	Author	Change
0.4	2026-10-03	Amish Chadha	Amish accepted the R16 mass margin of 0.2 kg on 2026-10-03, to be weighed at TRL 4 with a canner of 5.0 kg or less; row added to decisions made
0.3	2026-10-02	Amish Chadha	Canner, adapter plate and drop pins priced and carried into the design; value engineering and items to confirm updated
0.2	2026-10-02	Amish Chadha	Amish approved the recommendations for open decisions 1 to 5 (lid fittings decided; SCL-DDR-003 accepted with a back-up drop pin); moved to decisions made
0.1	2026-10-01	Amish Chadha	Register opened with the open decisions from the TRL 2 and TRL 3 reviews and the design-for-construction work, items to confirm, value engineering and decisions made

SunClave design decisions register

Every design decision still to be made, and every decision made, in one place. Each decision is argued in full in its decision record under `docs/decisions/`; this register is the index Amish works from. The build plan (`docs/05-build-plan.md`) describes the design as it stands and does not list open decisions.

Safety: SunClave is a research and educational prototype, not a medical device. Decision 1 below is a pressure-safety decision and must be made before the cooker is ever pressurised with the fittings on its lid.

■ Open decisions

None. All open decisions were decided on 2026-10-02.

■ To confirm when parts are bought

#	What to confirm	Why it matters	Source
1	The canner's maker's rating for 103.4 kPa, its outside diameter (about 288 mm), its mass with fittings (about 4.8 kg, 5.0 kg at most), and handles whose undersides are about 28 mm below the rim and reach at least 214 mm from the centre	The rating is R8; the handles must rest on the 408 mm holder ring and the jacket must clear its 348 mm hole; the mass margin of R16 is 0.2 kg	SCL-DDR-001 items 4 and 5, SCL-DDR-003 C3
2	The reflector sheet takes a 12 mm flange fold without cracking its bright layer	The petals are fixed by riveting through these flanges	SCL-DDR-003 C6
3	A 20 x 3 mm bar bends on edge in the plywood jig without buckling (bend one rib first)	If it buckles, the ribs need a heavier bar or a fabricator's rolls	SCL-DDR-003 C6
4	Castor mounting height 102 mm and a top-plate hole pattern on a 42 mm square, all four with brakes	Sets the stand height and the drilling of the cross rails	SCL-DDR-003 C5
5	The power bank has a low-current (always-on) mode	The logger draws about 72 mA; many banks switch off below 50 to 100 mA	SCL-CAL-001 section 11
6	The canner's factory relief valve has a seat of 4 mm or more and a set pressure of 125 kPa gauge or less; the lid's vent-pipe hole and thread, for the adapter plate	R8 relief capacity; the adapter plate is made to fit the canner	SCL-CAL-001 section 8
7	The pressure transducer's overpressure rating is 600 kPa or more	It must survive a relief lift	SCL-DDR-002 item 18

■ Value engineering

Value-engineering target: USD 450 (a hypothetical control target, not a limit). Estimated cost of the constructable design: USD 528 (USD 78 over the target), validation consumables (USD 45) excluded. Main cost drivers and savings worth trying:

- The largest lines are the pressure canner with its gauge and relief valve (USD 100), the reflector petals (USD 75), the cycle logger (USD 66), the timber stand with castors, axles and plates (USD 58) and the adapter plate, gland and probe (USD 45).

- Making the design constructable added USD 57 (from USD 440): the yoke plates, stand-offs and locks (line 3, USD 18 to 30), the stand's axle plates, axles, collars and brackets (line 4, USD 44 to 58), the clips (line 2), the plate ring and brackets (line 5), the larger logger box and plug-in sensor leads (line 14) and more bolts (line 17).
- The decisions of 2026-10-02 added USD 31 (from USD 497): the pressure canner sold with its gauge and relief valve (line 6, USD 55 to 100) in place of the household cooker and the separate gauge and relief valve (lines 8 and 9, USD 35, now supplied with the canner), the vent-stem adapter plate (line 10, USD 30 to 45) and the drop pins and lanyards (line 3, USD 30 to 36).
- Savings worth trying: compare canners sold with a gauge in the target area, since line 6 is now the largest line; have one local cutting shop cut the yoke plates, axle plates, holder ring and hub plate from one sheet of steel (likely cheaper than four separate jobs); price aluminised film on plain 0.5 mm aluminium against bright reflector sheet; buy the logger modules as one combined board; buy bolts in boxes of 50 rather than by the piece.

■ Decisions made

Date	Decision	Decided by	Record
2026-09-25	TRL 2 review items 1 to 4 and 6 to 11: altitude option B, budget cuts with USD 450, pitch wording, 12 L household cooker, level cooker at the focus, petal dish, gnomon aiming, load limits, logger pass criteria, backup heat	Amish: "proceed with all of your recommendations across all batches. Make sure we don't proceed to TRL 4 on any of them."	SCL-DDR-001
2026-09-25	Items 13 to 18: retarget every 12 min, 45 kg total, whole vessel a marked hot zone, four locking castors, trimming rule, 0 to 300 kPa transducer	Amish: "i accept all your recommendations, go with them across all repos."	SCL-DDR-002
2026-09-25	TRL 4 is on hold for the whole portfolio	Amish: "Make sure we don't proceed to TRL 4 on any of them"	SCL-DDR-001
2026-09-30	Make the design physically buildable while drawing the build plan	Amish: "If you are realising that the design cannot be built as per concept - fix the design assumptions to match and be physically feasible as you draw the illustrations."	SCL-DDR-003 (accepted on 2026-10-02, below; was open for review as decision 2)
2026-09-30	Open decisions are kept in this register, not in the build plan	Amish: "don't log outstanding decisions in this build plan - that is not the place for it."	This register
2026-10-01	budget_usd is a value-engineering target, not a limit	Amish: "the budgets are a hypothetical control target to ensure we are thinking along a value engineering lens."	This register, Value engineering
2026-10-02	Lid fittings: the maker's lid is not drilled; a pressure canner sold with a factory gauge and relief valve is used, and the probe gland goes on an adapter plate on the vent stem that keeps a bore of 3 mm or more and leaves the overpressure plug untouched; a lid is drilled only with the maker's written approval	Amish: "i approve your recommendations for all 555 open decisions."	SCL-DDR-001, item 5
2026-10-02	Design for construction accepted: the changes C1 to C9, as made, with the tilt lock settled under decision 4	Amish: "i approve your recommendations for all 555 open decisions."	SCL-DDR-003, Table 1
2026-10-02	R16 mass margin of 0.6 kg accepted; the prototype is weighed at TRL 4, with the 5 mm yoke plates and lighter holder arms ready	Amish: "i approve your recommendations for all 555 open decisions."	SCL-DDR-003, A1
2026-10-02	Tilt lock: the two friction locks are kept for aiming and a drop pin through a row of holes in the fan is added as a back-up stop; the pin is removed only if the TRL 4 slip test shows the locks holding at least twice the 45 N·m worst torque	Amish: "i approve your recommendations for all 555 open decisions."	SCL-DDR-003, A2
2026-10-02	First partner to approach: a university biomedical or global health engineering group with an established rural clinic partner in a sunny region		SCL-DDR-001, item 12

Date	Decision	Decided by	Record
	below 2,400 m, for example through an Engineering World Health university chapter	Amish: "i approve your recommendations for all 555 open decisions."	
2026-10-03	R16 mass margin of 0.2 kg accepted (about 44.8 kg against 45 kg); the prototype is weighed at TRL 4 with a canner of 5.0 kg or less	Amish: "TIght Margins - i accept the margins"	SCL-REQ-001, R16; SCL-DDR-003, A1; REVIEW.md , session 2026-10-03