

SUNCLAVE · REQUIREMENTS

SunClave requirements

Design Molecule Lab · designmolecule.com

DOCUMENT CONTROL

Document ID	SCL-REQ-001	Version	0.5
Status	Draft	Date	2026-10-01
Author	Amish Chadha	License	CERN-OHL-S-2.0
Project TRL	TRL 3 Proof of concept		
Repository	github.com/BoujeeEnjinia1701/sunclave		
Source	docs/03-requirements.md @ uncommitted		

REVISION HISTORY

Version	Date	Author	Change
0.5	2026-10-01	Amish Chadha	Status from SCL-CAL-001 v0.3 for the constructable design (SCL-DDR-003); R17 reported against the value-engineering target
0.4	2026-09-25	Amish Chadha	Recommendations accepted by Amish (DDR-002)
0.3	2026-09-25	Amish Chadha	Apply SCL-DDR-001 (R1, R13 and R17 redefined, design case completed) and replace the status column with the TRL 3 results of SCL-CAL-001
0.2	2026-09-25	Amish Chadha	First measurable requirements for TRL 2, with design case and status against the concept estimates
0.1	2026-09-24	Amish Chadha	Initial scaffold

SunClave requirements

These requirements are checked by calculation in SCL-CAL-001 at TRL 3. Targets are still proposals, not yet validated with users, and will be revised after co-design sessions (see SCL-PRB-001). R1, R13 and R17 were restated on 2026-09-25 to apply Amish's decisions in SCL-DDR-001 (altitude option B, and the budget cuts and \$450 budget). In v0.4, R10, R11, R14 and R16 are restated or relaxed and R12's design basis changed, applying Amish's acceptance of the recommendations in SCL-DDR-002. The status column gives the TRL 3 result from SCL-CAL-001 v0.3, for the constructable design of SCL-DDR-003; every value is a paper estimate. The cost target in R17 is a value-engineering target (Amish, 2026-10-01), so R17 is reported as over or under it rather than as met or not met.

The **design case** is a clear day with 700 W/m² direct normal irradiance (DNI) and the sun 60° above the horizon, 25 °C ambient, wind 2 m/s (below 3 m/s), a site at sea level, and a load of 2.0 kg of unwrapped or single-wrapped solid stainless instruments in a 0.5 kg basket, with 1.5 L of water in a 12 L aluminum cooker.

Safety: These requirements describe a pressure vessel heated by concentrated sunlight, in a research and educational prototype that is not a medical device. R8 to R11 are safety requirements and take precedence over throughput and cost. A PASS against R1 and R12 records conditions; it does not prove sterility.

ID	Requirement	Target	Verification (TRL 3 or later)	TRL 3 status (SCL-CAL-001)
R1	Sterilizing condition (redefined 2026-09-25, SCL-DDR-001 item 1)	Saturated steam in the load zone for an exposure equal to 20 min (unwrapped) or 30 min (wrapped) at 121 °C, using $z = 10$ °C for any lower temperature; never below 115 °C nor above 124 °C in normal operation; the real temperature and hold are recorded and a cycle below 121 °C is never labeled 121 °C	Calculation; later instrumented cycles with biological indicators	Not verifiable at TRL 3. Met by calculation to 2,400 m (120.95 °C and 30.3 min at sea level; 117.7 °C and 63 min at 1,800 m), but the equivalence needs biological-indicator evidence
R2	Load capacity	Basket at least 250 mm diameter by 150 mm deep; 2.0 kg of solid instruments per cycle (about two delivery kits or four suture kits)	Model check	Met: 250 x 150 mm basket in a 12.3 L cooker, 16 mm above the water
R3	Load type	Solid instruments only, unwrapped or single-wrapped in porous wrap; no lumened, hollow or textile loads	Instructions and design review	Met by definition (decided, SCL-DDR-001 item 9)
R4	Cycle time	Cold start to end of hold in 90 min or less in the design case	Energy calculation; later timed cycles	At risk: about 80 min central, 71 to 109 min across scenarios
R5	Daily throughput	3 or more complete cycles on a clear day (DNI 600 W/m ² or more from 09:00 to 15:00 solar time)	Energy calculation	Met: 4 cycles in each case checked; zero on overcast days
R6	Cycle record	Load-zone temperature and chamber pressure logged at 1 s intervals from start to end; cycle ID, date and time, hold duration, minimum hold temperature, equivalent exposure and a pass or fail flag stored for 1,000 or more cycles and shown to the operator at cycle end	Design review; later bench test	Met by design: about 173 kB per cycle, about 23,000 cycles on 4 GB
R7	Measurement accuracy	Temperature within 0.5 °C at 121 °C; pressure within 5 kPa; field check against boiling water at each site	Component datasheets; calibration method at TRL 3	Met on datasheets: 0.44 °C with a 0.05 % reference resistor; 3 kPa with the 0 to 300 kPa transducer. The field check needs a reference barometer
R8	Pressure safety	Working pressure 103.4 kPa (15 psi) gauge set by the cooker's regulator; an independent relief valve set at 125 kPa gauge or less; the cooker's own overpressure plug retained; vessel rated by its maker for the working pressure	Design review; relief capacity calculation	Met: relief 5.2 times and vent 2.7 times the worst steam generation; vessel rating to confirm for the chosen model
R9	Heat input control	Operator can stop heat input within 10 s by turning the dish off the sun, and the dish is shaded when parked	Design review	Met: below 5 % of power at 15° off the sun; parking cover in the BOM

ID	Requirement	Target	Verification (TRL 3 or later)	TRL 3 status (SCL-CAL-001)
R10	Boil-dry protection (restated 2026-09-25, SCL-DDR-002 item 17)	At least 0.5 L of water left at the end of a cycle in the design case, and at any altitude to 2,400 m in 1,000 W/m ² sun when the operator follows the trimming rule; logger shows a trim reminder whenever the computed hold exceeds 40 min; logger alarm if base temperature exceeds 140 °C	Water budget; later test	Met: 1.26 L left in the design case; with trimming 1.31 L at 1,800 m and 1.28 L at 2,400 m (0.15 L at 1,800 m untrimmed). Depends on the operator following the reminder
R11	Burn and glare protection (restated 2026-09-25, SCL-DDR-002 item 15)	The whole pressure vessel and its fittings are a hot zone, like the lid, reached only after the dish is turned at least 15° off the sun (R9); the focus is reached only through the dish, so no physical guard; parking cover and eye protection supplied; a keep-out marked on the ground around the dish and vessel	Design review	Met by design review: parking cover, two pairs of goggles and keep-out marking in the BOM (items 19 to 21)
R12	Air removal check	Logger flags any hold where measured temperature is more than 2 °C below the saturation temperature for the measured pressure	Calculation; later test with deliberate air leak	Met, narrowly: check uncertainty 0.64 °C with the 0 to 300 kPa transducer (SCL-DDR-002 item 18), 32 % of the threshold; sure to flag about 8 % air
R13	Off-grid logger power (redefined 2026-09-25, SCL-DDR-001 item 2)	Logger runs 3 or more days on its own USB power bank without recharging; the bank recharges from any USB source and does not switch off at the logger's low current	Power budget	Met: about 8.7 days
R14	Tracking effort (relaxed 2026-09-25, SCL-DDR-002 item 13)	Retarget no more often than every 12 min, with a logger reminder at each interval; aim by a shadow gnomon without looking at the sun or the focus	Optics calculation	Met: power stays within 10 % of on-target for about 13 min
R15	Stability	Does not tip in a 10 m/s wind with the dish at any tilt and the cooker loaded	Moment calculation	At risk: tipping factor 1.38 at 15° elevation. Four locking castors (SCL-DDR-002 item 16) grip 235 N against 153 N of wind; park the dish face-up in high wind
R16	Portability and build (relaxed 2026-09-25, SCL-DDR-002 item 14)	Total mass 45 kg or less; separates into pieces of 20 kg or less; built with hand tools, a drill and bolted joints	Mass estimate; model check	Met: about 44.4 kg empty (0.6 kg margin); the bolted stand comes apart, largest piece 15.4 kg
R17	Cost (redefined 2026-09-25, SCL-DDR-001 item 2; a	Parts for one prototype against a value-engineering target of USD 450, validation consumables excluded	Priced BOM (bom/bom.csv)	Value-engineering target: USD 450. Estimated cost of the

ID	Requirement	Target	Verification (TRL 3 or later)	TRL 3 status (SCL-CAL-001)
	value-engineering target, 2026-10-01)			constructable design: USD 497 (USD 47 over the target)

■ Requirements not met or at risk

No requirement is now not met. Before SCL-DDR-002, R11, R14 and R16 were not met; they are met because their targets were restated or relaxed on Amish's acceptance of the recommendations, not because the design improved. R10 and R12 moved from at risk to met through the trimming rule and the 0 to 300 kPa transducer.

- **R4 cycle time (at risk).** Met in the central case (80 min), missed in the unfavourable one (109 min).
- **R15 stability (at risk).** Thin tipping margin at low sun (factor 1.38); the four locking castors now stop the stand rolling.
- **R16 mass (met, thin margin).** 44.4 kg against 45 kg after the constructable design added clips, plates, brackets and bolts.
- **R17 cost.** USD 47 over the value-engineering target; the cost drivers and savings worth trying are in the design decisions register (SCL-DEC-001).
- **R1 sterilizing condition (not verifiable at TRL 3).** The equivalent-exposure method needs biological indicators.

■ Assumptions

- Dish aperture 1.4 m (1.539 m²), focal length 500 mm, reflectance 0.85, slope error 10 mrad, absorber absorptance 0.92; optics by ray trace in SCL-CAL-001.
- Saturated steam temperatures from IAPWS-IF97; ICAO standard atmosphere for ambient pressure with altitude.
- Hold times follow CDC Table 7 and the IARC manual cited in SCL-PRB-001. Equivalent hold at lower temperature uses a z-value of 10 °C, which is a common engineering assumption and not a validated claim.
- "Pass" in R6 means the recorded cycle met R1 and R12. It does not prove sterility; biological and chemical indicators remain the reference.