

SUNCLAVE · DESIGN PRECIS

SunClave design precis

Design Molecule Lab · designmolecule.com

DOCUMENT CONTROL

Document ID	SCL-PRC-001	Version	0.4
Status	Draft	Date	2026-09-25
Author	Amish Chadha	License	CERN-OHL-S-2.0
Project TRL	TRL 3 Proof of concept		
Repository	github.com/BoujeeEnjinia1701/sunclave		
Source	docs/02-concept.md @ 169e834		

REVISION HISTORY

Version	Date	Author	Change
0.4	2026-09-25	Amish Chadha	Recommendations accepted by Amish (DDR-002)
0.3	2026-09-25	Amish Chadha	Apply SCL-DDR-001 decisions (option B, \$450 budget and cuts, vessel, holder, dish, aiming, load limits, pass criteria, backup heat); replace first-order numbers with SCL-CAL-001; TRL 3 model, drawing and media
0.2	2026-09-25	Amish Chadha	Populate to TRL 2 (architecture, components, first-order numbers, altitude finding, safety, media)
0.1	2026-09-24	Amish Chadha	Initial scaffold


SunClave design precis

SunClave is a 1.4 m parabolic dish of aluminum petals that focuses sunlight onto the blackened base of a 12 L household pressure cooker held level at the focus, with a cycle logger that measures temperature in the load zone and chamber pressure and flags each cycle as pass or fail. The TRL 3 calculations (SCL-CAL-001) put about 670 W into the cooker on a clear day, enough to go from cold to the end of a 30 min hold in about 79 min and to run about four cycles between 09:00 and 15:00. On 2026-09-25 Amish accepted the recommendations on the TRL 3 findings (SCL-DDR-002): the dish is retargeted every 12 min, the mass limit is 45 kg, the whole vessel is treated as a marked hot zone instead of guarding the focus, all four castors lock, a trimming rule protects the water at altitude and the pressure transducer spans 0 to 300 kPa. On paper no requirement is now missed; cycle time (R4) and wind stability (R15) remain at risk. Parts cost about \$440 against the \$450 budget Amish set on 2026-09-25.

Safety: SunClave is a research and educational prototype, not a medical device. It has not been cleared or approved by any regulator and must not be relied on to sterilize instruments used on patients. It combines concentrated sunlight that can burn skin, blind and start fires, with a pressure vessel holding steam at about 121 °C (250 °F). See the safety section before building or operating anything.

SunClave

CONCEPT, NOT FOR FABRICATION



Grey figure: 1.75 m person for scale

Figure 1. SunClave with the dish aimed at a sun 50 degrees above the horizon, and a 1.75 m person for scale. The cooker is held level at the focus on a holder fixed to the stand; the dish and yoke tilt about it.

■ How it works

1. **Load.** The operator puts 1.5 L of water in the cooker, sets cleaned instruments in the basket on its trivet above the water, closes the lid and sets the cooker in the level holder at the focus.
2. **Aim.** The operator unlocks the four castors, turns the stand to face the sun, locks them again and tilts the dish until the shadow of the sighting gnomon falls on the center of its target. Nobody needs to look at the sun or at the bright focus. The logger sounds a reminder every 12 min, and retargeting at that interval keeps the absorbed power within 10 % of on-target (SCL-CAL-001 section 3; decided, SCL-DDR-002 item 13).
3. **Heat and purge air.** About 670 W is absorbed by the blackened base and the black band of wall above it. The water boils, and steam leaves through the open vent for at least 5 min to push air out of the chamber before the weighted regulator is fitted. The logger recognizes this purge as a plateau at the local boiling point.
4. **Pressurize and hold.** With the regulator fitted, pressure rises to 103.4 kPa gauge and the regulator vents the excess. The hold is 20 min (unwrapped) or 30 min (wrapped) at sea level, and longer above it (decided option B): the logger computes the hold that gives the same exposure as 121 °C with $z = 10$ °C and records the real temperature. Whenever the computed hold exceeds 40 min (every site at 1,000 m and above), the logger shows a trim reminder and the operator trims the dish off the sun until the regulator only just vents, which keeps at least 0.5 L of water in strong sun up to 2,400 m (decided, SCL-DDR-002 item 17).
5. **Record.** Throughout, the logger reads a Pt100 probe in the load zone and an absolute pressure transducer on the lid. It checks that the load-zone temperature matches the saturation temperature for the measured pressure (air left in the chamber shows up as a lower temperature), times the hold, and at the end shows PASS or FAIL with a cycle number to copy into the register.
6. **Cool and unload.** The operator turns the dish away from the sun, fits the parking cover if the session is over, lets the pressure fall to zero on the gauge (about 10 min), removes the regulator, opens the lid and lets the load dry in the residual heat.

On cloudy days the same cooker runs on a wood, charcoal or LPG stove and is logged the same way (decided, SCL-DDR-001 item 11).

SunClave: power during heat-up at 700 W/m² DNI, W (SCL-CAL-001 central estimates)

CONCEPT, NOT FOR FABRICATION




Figure 2. Power flow during heat-up at 700 W/m² DNI and a sun 60° high, central estimates from SCL-CAL-001.

■ Main components

Numbers match the exploded view (Figure 3) and `bom/bom.csv`. The general arrangement is drawing SCL-DWG-001 (`cad/drawings/`), generated from `cad/src/model.py`.

#	Component	Choice	Notes
1	Reflector	12 petals of polished aluminum sheet 0.5 mm, 1.4 m aperture, focal length 500 mm	SK14-style petal layout (decided)
2	Dish ribs, rim and hub	Bent 20 x 3 mm steel flat-bar ribs, 20 x 4 mm rim, bolted hub	Holds the petal shape
3	Tilt yoke and quadrant lock	Two short arms from collars on the focal-axis stub axles to the dish rim; lock lever on a slotted quadrant	Dish-axis elevation 15 to 90 degrees; lock holds up to about 38 N·m of gravity torque
4	Stand with castors	Treated timber base 1.75 x 1.10 m, uprights to 1.12 m, braces; steel bearing blocks; four locking castors	Timber decided to save cost (SCL-DDR-001 item 2); all four castors lock (SCL-DDR-002 item 16); azimuth by turning the whole stand
5	Level pot holder	Steel ring under the body handles on two arms bolted to the uprights	Fixed to the stand: the loaded cooker's centre of mass is about 98 mm above the axis, so a swinging holder would be top-heavy
6	Pressure cooker	12 L aluminum household cooker, 280 mm inside diameter x 200 mm deep, 103.4 kPa weighted regulator, overpressure plug; base and lowest 80 mm of wall painted matte black	Decided (SCL-DDR-001 item 4)
7	Lid with regulator	Supplied with item 6; carries items 8 to 10	How items 8 to 10 are mounted is open for Amish (item 5)
8	Pressure gauge	0 to 250 kPa, 100 mm dial with siphon	Reads without power, independent of the logger
9	Independent relief valve	Spring valve, set 125 kPa gauge or less, seat 4 mm or more	Passes 5.1 times the worst steam generation
10	Lid gland, Pt100 probe and tee	3 mm class A Pt100 through a compression gland into the load zone; tee to the transducer	Measures where the instruments are
11	Insulated jacket	25 mm mineral wool with aluminized skin on the upper wall	Black band and base stay bare to take the focus
12	Water charge	1.5 L per cycle	About 1.26 L left after a central sea-level cycle
13	Instrument basket and trivet	Stainless basket 250 mm diameter x 150 mm deep on a 40 mm trivet	Resized from 270 x 180 mm, which did not fit a 12 L cooker
14	Cycle logger	ESP32-class board, Pt100 interface with 0.05 % reference, 16-bit ADC, 0 to 300 kPa absolute pressure transducer, base-edge thermocouple, RTC, microSD, OLED display, buzzer	1 s logging, pass or fail per cycle, boil-dry alarm, 12 min retarget reminder, trim reminder for holds over 40 min; OLED decided to save cost; transducer span decided (SCL-DDR-002 item 18)
15	Logger power bank	10,000 mAh USB bank with a low-current mode, kept in the shaded logger box	About 8.7 days per charge; replaces the panel and cell (decided)
16	Sighting gnomon	Pin parallel to the dish axis over a target plate	Aiming by shadow (decided)
19	Eye protection	Two pairs of shade 5 goggles	Added for R11
20	Parking cover	Opaque cover for the dish	Added for R9 and R11

#	Component	Choice	Notes
21	Keep-out marking	Barrier tape and four ground pegs marking 2 m around the dish and vessel	Added for the restated R11 (SCL-DDR-002 item 15)

SunClave: exploded view

CONCEPT, NOT FOR FABRICATION

- 1 Reflector, 12 aluminum petals
- 2 Dish ribs, rim and hub
- 3 Tilt yoke and quadrant lock
- 4 Timber stand with castors
- 5 Level pot holder (fixed to stand)
- 6 Pressure cooker body, 12 L
- 7 Lid with weighted regulator
- 8 Pressure gauge
- 9 Independent relief valve
- 10 Lid gland, Pt100 probe and tee
- 11 Insulated jacket
- 12 Water charge, 1.5 L
- 13 Instrument basket and trivet
- 14 Cycle logger
- 15 USB power bank, in the logger box
- 16 Sighting gnomon





Figure 3. Exploded view with numbered callouts matching the BOM. The cooker parts are lifted out along the vertical axis. Items 17 to 21 are not modelled.

SunClave: cutaway of the pressure vessel

CONCEPT, NOT FOR FABRICATION



6 cooker body, 7 lid, 9 relief valve, 10 Pt100 probe, 11 jacket, 12 water, 13 basket with load

Figure 4. Section through the pressure vessel: water below the trivet, the basket and instrument load in steam, the Pt100 probe reaching into the load zone, and the jacket on the upper wall above the bare black band.

■ Key numbers (TRL 3)

All values are paper estimates from SCL-CAL-001 (`python docs/04-calcs/sizing.py`) for the design case in SCL-REQ-001 v0.3: 700 W/m² DNI, sun 60° high, 25 °C, wind 2 m/s, sea level, 2.0 kg of instruments, 1.5 L of water.

Table 1. Headline results, central case unless a range is given.

Quantity	Value	Requirement
Sun on the aperture	1,078 W (1.539 m ²)	
Absorbed by the cooker	669 W on target (580 to 723 W across scenarios); 559 W at 15° sun, 755 W overhead	
Peak flux on the base	about 270 kW/m ² in the hottest 20 mm cell; mean 11 kW/m ²	
Heat loss at 121 °C	395 W (black base and band 245 W, lid 101 W)	
Cold start to end of 30 min hold	79 min (70 to 107 min)	R4 at risk
Cycles, 09:00 to 15:00	4	R5 met
Water left after a 30 min hold	1.25 L; with the trimming rule 1.31 L at 1,800 m in strong sun (0.14 L untrimmed)	R10 met (restated)
Steam temperature at 103.4 kPa gauge	120.95 °C at sea level; 117.7 °C at 1,800 m (hold 63 min)	R1 not verifiable at TRL 3
Temperature and pressure accuracy	0.44 °C; 3 kPa	R7 met
Air-removal check uncertainty	0.64 °C against a 2 °C threshold (0 to 300 kPa transducer)	R12 met, narrowly
Retarget interval for 90 % of on-target power	about 13 min, against a 12 min target	R14 met (relaxed)
Relief valve capacity	5.1 times the worst steam generation	R8 met
Tipping factor at 10 m/s	1.30 at 15° sun; four locked castors grip 218 N against 153 N	R15 at risk
Mass, empty	41.0 kg against 45 kg; largest piece 19.4 kg	R16 met (relaxed)
Logger autonomy	8.7 days	R13 met
Parts cost	\$440 against \$450	R17 met

Altitude and sterilizing temperature

A weighted regulator holds a fixed pressure **above ambient**, so the steam temperature falls with altitude. Under the decided option B the logger extends the hold to give the same exposure as 121 °C with $z = 10$ °C, and records the real temperature.

Table 2. Steam temperature and extended hold with altitude (IAPWS-IF97, standard atmosphere).

Altitude	Ambient pressure	Steam temperature at 103.4 kPa gauge	Gauge pressure needed for 121 °C	Hold for 20 / 30 min at 121 °C (z = 10 °C, not validated)
0 m	101.3 kPa	120.95 °C	103.7 kPa	20 / 30 min
500 m	95.5 kPa	120.03 °C	109.6 kPa	25 / 37 min
1,000 m	89.9 kPa	119.13 °C	115.2 kPa	31 / 46 min
1,500 m	84.6 kPa	118.26 °C	120.5 kPa	38 / 56 min
1,800 m	81.5 kPa	117.75 °C	123.5 kPa	42 / 63 min
2,400 m	75.6 kPa	116.74 °C	129.4 kPa	53 / 80 min

The TRL 2 version of this table gave 121.1 °C at sea level and a 300 m limit; the IAPWS-IF97 line gives 120.95 °C, so 121 °C holds only at sea level. A maker-rated vessel of about 130 kPa gauge (option A) would reach 121 °C to about 2,400 m and remains worth searching for.

■ Design choices

Decided by Amish on 2026-09-25 (SCL-DDR-001): option B for altitude; the budget cuts and a \$450 budget; the pitch wording; the household 12 L aluminum cooker; the level cooker at the focus with the dish tilting about it; the locally built petal dish; manual aiming by gnomon; solid, unwrapped or single-wrapped loads only; the logger pass criteria (purge plateau of 5 min or more, hold temperature and equivalent time met, and measured temperature within 2 °C of saturation throughout the hold); and backup heat on a stove.

Decided by Amish on 2026-09-25, going with the recommendation (SCL-DDR-002): R14 relaxed to retargeting every 12 min with a logger reminder (item 13); R16 relaxed to 45 kg in total with the 20 kg piece limit kept (item 14); R11 restated so the whole vessel and its fittings are a hot zone, with no physical guard, relying on turning the dish off the sun, the parking cover, goggles and a marked keep-out (item 15); four locking castors and a rule to park the dish face-up in high wind (item 16); a trimming rule with a logger trim reminder (item 17); and a 0 to 300 kPa absolute transducer (item 18).

Still **proposed**, awaiting Amish:

- **Item 5: mounting the lid fittings.** Drill the maker's lid (option i), or use a cooker with factory ports or an adapter plate on the regulator stem (option ii). This is a pressure-safety trade-off and has no recommendation. SCL-CAL-001 section 8 compares the options on holes, ligaments and relief and vent capacity; neither choice changes the relief sizing.
- **Item 12:** first partner and site, chosen per area later. No recommendation.

■ Safety

Safety: SunClave concentrates sunlight to a few hundred times normal intensity at the focus, heats a pressure vessel to about 121 °C, and is described in a medical context. Each of these is a serious hazard. It is a research and educational prototype and not a medical device.

- **Concentrated sunlight.** The focal spot reaches about 270 kW/m² in its hottest part and can burn skin within about a second, ignite paper, cloth and dry grass, and cause permanent eye damage. Never look at the focus or into the dish when it faces the sun; wear the shade 5 goggles near the focus; aim only by the gnomon shadow; turn the dish at least 15° away from the sun before reaching toward the cooker; fit the parking cover whenever the dish is idle; keep the ground below clear of anything that can burn; never leave the dish facing the sun unattended or with children nearby.
- **Timber stand.** The stand is timber (decided). It is outside the converging light cone, but a mis-aimed dish or stray reflections can scorch it; keep the steel bearing blocks and holder between the focus and the timber, and inspect for scorching.
- **Pressure and steam.** Use only a commercially made cooker rated for the working pressure, keep its overpressure plug, fit the independent relief valve, and check that the vent is clear before every cycle. Never force the lid open; wait until the gauge reads zero and the regulator has been lifted with a tool. Steam from the regulator and relief valve can scald, so point vents away from people. Do not modify the regulator weight. How the fittings are mounted on the lid (item 5) is undecided and must be settled before anything is built.
- **Boil-dry.** A dry base under concentrated sun would pass 200 °C, where aluminum loses much of its strength. Fill 1.5 L before every cycle and trim the dish during long holds; the base-edge thermocouple alarm at 140 °C prompts the operator to turn the dish away.
- **Hot surfaces.** The lid, handles, fittings, black lower wall, base and instruments reach 121 °C or more. The whole vessel is treated as a hot zone (decided, SCL-DDR-002 item 15): mark a 2 m keep-out on the ground with the barrier tape, use heat-resistant gloves and handle the cooker only when the dish is turned at least 15° away.
- **Tipping, rolling and pinch points.** Lock all four castors and the tilt quadrant; in high wind park the dish face-up. The tipping margin at low sun is thin (factor 1.30 at 10 m/s, SCL-CAL-001 section 10). Keep hands clear of the yoke collars and quadrant when tilting.
- **Lithium cells.** The power bank contains lithium cells; keep it shaded inside the logger box and do not charge it above 45 °C.
- **Medical claims.** A PASS on the logger shows the recorded conditions, not that the load is sterile. A cycle below 121 °C is recorded at its real temperature. Biological and chemical indicators remain the reference, and no load from this prototype should be used on a patient.

■ Open questions after TRL 3

- Decide item 5 (lid fittings).
- Confirm the cooker brand, dimensions and maker's rating in the first target area, and whether a factory-ported 12 L model exists.
- Validate the equivalent-exposure method (option B) with biological indicators; this is TRL 4 work and is on hold by Amish's instruction.
- Choose a partner and site to learn real loads, altitude and records practice.

Concept media: [blueprint sheet](#), [interactive 3D model](#). General arrangement: [SCL-DWG-001](#).