

TWINKIT · CALCULATION

TwinKit sizing calculations

Open Hardware Portfolio · amishchadha.com

DOCUMENT CONTROL

Document ID	TWK-CAL-001	Version	0.1
Status	Draft	Date	2026-09-25
Author	Amish Chadha	License	CERN-OHL-S-2.0
Project TRL	TRL 3 Proof of concept		
Repository	github.com/BoujeeEnjinia1701/twinkit		
Source	docs/04-calcs/01-sizing.md @ 652cdc0		

REVISION HISTORY

Version	Date	Author	Change
0.1	2026-09-25	Amish Chadha	First issue for TRL 3 (airtime and collisions, storage and card wear, latency, power and fuse, backup, enclosure and processor temperature, memory, rail, cost)

TwinKit sizing calculations

On paper, TwinKit meets twelve of its sixteen requirements (five by calculation, seven by design), has one at risk, misses two and has one that cannot be checked at TRL 3. R14 (cost) is not met: the priced BOM totals \$290 against `budget_usd` of \$200, although it fits the \$300 budget recommended in the TRL 2 review, which awaits Amish. R1 (uplink loss) is not met by a small margin at SF9: if all 50 nodes report every 5 min at SF9, pure ALOHA collisions lose 1.02 % of uplinks against a 1 % target. R12 (no processor throttling at 40 °C) is at risk: at light load the processor stays 16 K below its throttle point, but a sustained full load would throttle. R13 (setup time) needs a timed trial. The calculations changed two parts of the TRL 2 concept: the input fuse rises from 2 A to 3.15 A time-delay, and the UPS module is specified with a buck-boost charger so that it can charge the 12.8 V pack from a 9 V to 12 V input. Several TRL 2 figures were corrected (see the last section). Every number in this note is printed by `docs/04-calcs/sizing.py`; the tag in brackets, for example [A2], is the line of that script's output that carries it.

Safety: These are first-principles estimates for a paper proof of concept. They are not a substitute for electrical safety checks of the 12 V wiring and the LiFePO4 pack, or for a security audit of the gateway. See TWK-PRC-001, Safety.

■ Scope and method

The note checks every requirement in TWK-REQ-001 v0.3 against the design in TWK-PRC-001 v0.3, the decisions in TWK-DDR-001 and the parametric model `cad/src/model.py`. The script imports the model's `PARAMS` and derived dimensions, so the enclosure size, vent areas and rail length used here are the ones in the STEP files and in drawing TWK-DWG-001. It also reads `bom/bom.csv` and `budget_usd` in `project.yaml`. Run it from the repo root with `python docs/04-calcs/sizing.py`.

The design case is the R1 design point: 50 sensor nodes, each sending a 20-byte reading every 5 min, to one gateway on a bench or in an equipment room at up to 40 °C. FieldNode's default interval is 15 min (FND-PRC-001 v0.2), so the 5 min case is conservative for FieldNode fleets.

■ Assumptions

Table 1. Main assumptions.

Area	Assumption	Basis
Radio	20-byte payload plus 13 bytes of LoRaWAN overhead; 125 kHz, coding rate 4/5, 8-symbol preamble, explicit header, CRC on, low data rate optimization at SF11 and SF12; unconfirmed uplinks	FieldNode payload convention; Semtech time-on-air formula
Traffic	Uplinks spread evenly over 8 channels, random arrival (pure ALOHA); spreading factors treated as orthogonal; no capture effect	Conservative screening model
Storage	10 values per reading; 90 bytes per stored value in a narrow table with index, uncompressed; compressed chunks keep 10 % of that after 7 days; 8 GB for the system	Conservative for PostgreSQL rows; compression ratio assumed
Card wear	One 8 kB write-ahead log page per commit plus heap and index writes at twice the data size; write amplification inside the card of 10	Assumed; card endurance data not available
Latency	Forwarder 0.1 s, network server 0.3 s, MQTT 0.05 s, twin service 0.2 s, database 0.2 s, dashboard refresh 2 s	Typical figures for these tools on a Pi 5 class board, to be measured
Power	Board 4 W light load, 8 W sustained full load; fan 0.5 W; concentrator 1.0 W receiving, 2.5 W during a downlink; converter 90 %; UPS 0.3 W; charger 14.6 V at 0.5 A, 90 %	Typical figures, to confirm from datasheets and measurement
Backup	12.8 V, 1.5 Ah pack; 80 % usable; 85 % capacity at 0 °C; 80 % at end of life	Typical LiFePO4 data
Thermal	40 °C ambient; combined convection and radiation 5 W/m ² K (8 W/m ² K as a check); vent discharge coefficient 0.6; bench mounting, so the vents are only 42 mm apart vertically; processor dissipates 2.5 W at light load and 6.5 W at full load; 4 K/W from processor to enclosure air with the fan running; throttling at 85 °C	Handbook ranges; thermal resistance and throttle point assumed for a Pi 5 class board, to be measured

■ A. Airtime and collisions (R1)

- **Traffic.** 50 nodes at 5 min give 600 uplinks per hour, 75 per channel per hour [A1].
- **Time on air.** A 33-byte frame takes 71.9 ms at SF7, 133.6 ms at SF8, 246.8 ms at SF9, 452.6 ms at SF10 and 1810.4 ms at SF12 [A2]. These agree with FieldNode's airtime table (FND-PRC-001 v0.2, Table 3).
- **Loss.** With every node on one spreading factor, collisions lose 0.30 % at SF7, 0.56 % at SF8, 1.02 % at SF9, 1.87 % at SF10 and 7.27 % at SF12 [A2]. An even mix of SF7, SF8 and SF9 loses 0.21 % [A3]. At FieldNode's 15 min default every case up to SF10 stays under 1 % (0.34 % at SF9) [A2].
- **Verdict.** R1 is not met by a small margin in its worst stated case (all 50 nodes at SF9 and 5 min). The largest fleet that stays under 1 % in that case is 48 nodes [A5]. Adaptive data rate, which moves near nodes to faster spreading factors, or a 15 min interval both meet the target.
- **Regulatory duty cycle.** At SF9 and 5 min each node uses 0.08 % of air time, well inside the 1 % EU868 sub-band limit [A4]. The Things Network's 30 s per day fair-use limit does not apply on a private TwinKit gateway, but a node at SF9 and 5 min would exceed it (71 s per day) if moved to that public network [A2].

■ B. Storage and card wear (R3, R7)

- **Volume.** R3's case stores 52.6 million values a year. At the TRL 2 figure of 30 bytes that is 1.58 GB; at a conservative 90 bytes uncompressed it is 4.73 GB, and 0.55 GB with compression after 7 days [B1].

- **Capacity.** With 56 GB free on the 64 GB card, the data fits for 11.8 years uncompressed [B2]. R3 is met.
- **Sync buffer.** Seven days of readings for upstream sync take 91 MB [B3]. R7's buffer is met.
- **Wear.** Committing each uplink writes about 53 GB a year; batching commits every 10 s writes about 35 GB. At an assumed card write amplification of 10, that is 8.2 or 5.5 full-card program cycles a year [B4]. This is modest for a high-endurance card, but the card's own endurance and amplification are unknown. Batched commits are adopted in the twin service design, and an SSD remains the upgrade path.

■ C. Latency and flag timing (R5)

- **Reading to dashboard.** 0.9 s at SF7 with a pushed update, up to 4.7 s at SF12 with a 2 s dashboard refresh [C1]. R5 (60 s) is met with a wide margin.
- **Fault to flag.** A flag is raised only after the residual stays out of tolerance for the hold time. With the example 30 min hold, a step fault is flagged within 35 min at 5 min readings, or 45 min at FieldNode's 15 min default [C2]. The hold time is therefore the design lever for early warning, not the data path.

■ D. Power, peak current and fuse (R8)

- **Average.** 5.5 W on the 5 V rail becomes 6.41 W at the 12 V input, 0.53 A, or 56 kWh a year [D1]. R8 (8 W) is met. The TRL 2 figure of about 6 W was slightly low.
- **Peak.** With the board at full load, a downlink in progress and the pack charging, the input peaks at 20.6 W: 1.72 A at 12 V and 2.29 A at the 9 V lower limit of R8. The 5 V rail carries 2.16 A of the converter's 5 A [D2].
- **Fuse.** A 2 A fuse run at no more than 75 % of rating allows 1.50 A, too little at 9 V. A 3.15 A time-delay fuse allows 2.36 A [D3]. The BOM (line 13) is changed to 3.15 A T.
- **Charger interface.** The pack charges to 14.6 V, above a 12 V input. The UPS module (line 11) must therefore have a buck-boost charger that works from 9 V to 30 V. The BOM specification is changed accordingly; the price rises from \$25 to \$30 (indicative).

■ E. Backup (R9)

- **Runtime.** On battery the gateway draws 6.41 W. The pack gives 15.36 Wh usable, which lasts 2.40 h when new and 1.63 h for an aged pack at 0 °C [E1]. R9 (30 min) is met in every case.
- **Shutdown and recharge.** A clean shutdown needs 0.13 Wh; the pack refills from its cut-off in about 2.4 h at 0.5 A [E2].

■ F. Enclosure and processor temperature (R12)

- **Geometry.** The 157.5 x 90 x 60 mm enclosure exposes 0.0439 m². Two slot rows at each end give 640 mm² of low and of high vent, 42 mm apart vertically in the bench case. It holds 5.5 W at light load and 9.5 W at full load [F1].
- **Light load.** Vented, the enclosure air rises 19.1 K to 59.1 °C at 40 °C ambient and the processor reaches 69.1 °C, 15.9 K below throttling. Sealed, the air rises 25.1 K and the processor reaches 75.1 °C [F2].
- **Full load.** Sustained full load raises the processor to 96.9 °C vented and 109.3 °C sealed, so it would throttle [F2]. At the more typical 8 W/m²K it still reaches 88.3 °C [F3]. Doubling the vent area only brings it to 91.1 °C [F5].

- **Verdict.** R12 is at risk. The normal load (0.17 uplinks per second [G3]) is light, and short bursts are damped by the thermal mass of the cooler and the air, but a sustained heavy job such as a full database recompression or a dashboard rebuild at 40 °C would throttle. The thermal resistance and throttle point are assumptions to be measured. The software should schedule heavy jobs for cool hours, and a larger or metal enclosure is the hardware fallback.
- **Pack.** The LiFePO4 pack sits in the separate UPS module with only the charger's 0.81 W of loss while charging [E3], so it stays within a few kelvin of ambient and inside the usual 45 °C charge limit at 40 °C. A sealed street cabinet in sun (CityTwin) is a different case and is not covered here.

■ G. Memory

- **Budget.** At light load the stack uses about 2.42 GB of 4 GB: system 0.40, network server and Redis 0.25, MQTT 0.02, PostgreSQL with TimescaleDB 0.90, dashboard 0.20, twin service 0.15 and 0.50 GB of file cache headroom [G1]. A 2 GB board would be short by 0.42 GB [G2], which supports the 4 GB board adopted in TWK-DDR-001.
- **Load.** 0.17 uplinks per second, or 1.7 values per second, is a very light database load [G3].

■ H. Rail and mounting (R10)

- **Rail.** Terminals, enclosure, converter and UPS take 294 mm (16.8 modules) of a 320 mm rail [H1]. R10 (350 mm, 20 modules) is met.
- **Height.** The enclosure top is 67.5 mm above the plate and the antenna tip 264 mm [H2].

■ I. Cost (R14)

- **Total.** All 16 BOM lines are priced; the total is \$290.00: computer, cooler and card \$85, radio and antenna \$92, power and backup \$85, enclosure, rail and plate \$28 [I1].
- **Against budget.** The total exceeds `budget_usd` (\$200) by \$90.00. Against the \$300 recommended in the TRL 2 review, which awaits Amish, it leaves \$10.00 [I2]. R14 is not met against the current budget. No custom PCB is used.

■ J. Results against every requirement

Table 2. Requirement status at TRL 3 [J1, J2].

ID	Requirement	Value	Target	Status
R1	Receive readings	0.30 % (SF7), 0.56 % (SF8), 1.02 % (SF9) loss, all nodes on one SF; 0.21 % for a mix	Under 1 % at SF7 to SF9, 50 nodes at 5 min	Not met at SF9 (marginal)
R2	Common inputs	LoRaWAN concentrator, MQTT, HTTP	LoRaWAN, MQTT, HTTP	Met by design
R3	Store history	4.73 GB per year uncompressed on 56 GB free	1 year	Met
R4	Link data to model	Twin file schema, TWK-PRC-001	Every channel mapped to a part and an expected value	Met by design
R5	Compare measured and expected	4.7 s worst case	60 s	Met
R6	3D twin	glTF in a standard web viewer	Current browser, laptop or phone	Met by design; frame rate not verifiable at TRL 3
R7	Work offline	All local; 91 MB for 7 days	7-day buffer	Met by design
R8	Low-voltage power	6.41 W average; 20.6 W peak	9 to 30 V; 8 W average	Met
R9	Ride through outages	2.40 h new, 1.63 h worst	30 min and clean shutdown	Met
R10	Compact mounting	294 mm, 16.8 modules	350 mm, 20 modules	Met
R11	Secure by default	First-boot credentials, TLS, no WAN ports	As stated	Met by design
R12	Operate at 0 to 40 °C	Processor 69.1 °C light load, 96.9 °C sustained full load	No throttling (85 °C assumed)	At risk
R13	Quick setup	Not calculable	60 min	Not verifiable at TRL 3
R14	Low cost	\$290.00	\$200 (\$300 recommended, awaiting Amish)	Not met
R15	Open and exportable	Open-source stack, CSV and API	As stated	Met by design
R16	Monitoring only	No control outputs	As stated	Met by design

Summary: 2 not met, 1 at risk, 5 met by calculation, 7 met by design, 1 not verifiable at TRL 3.

■ Checks against the TRL 2 figures

Table 3. TRL 2 figures corrected by this note.

Quantity	TRL 2 (TWK-PRC-001 v0.2)	TRL 3	Change
Airtime, 20-byte reading	about 60 ms (SF7), 1.3 s (SF12)	71.9 ms, 1810.4 ms	Overhead bytes and low data rate optimization now counted
Loss at SF12, all nodes	about 5 %	7.27 %	Follows the airtime
R1 status	Met at SF7 to SF9	Not met at SF9 (1.02 %)	TRL 2 claim was wrong
Storage per year	about 1.6 GB	4.73 GB uncompressed (0.55 GB compressed)	90 bytes per value instead of 30
Average power	about 6 W	6.41 W	UPS loss counted
Backup time	about 2 h (2.3 h)	2.40 h new, 1.63 h worst	Load and derating recomputed
Enclosure air rise	about 20 K	19.1 K vented, 25.1 K sealed	Mounting face excluded, vents modeled
Rail used	about 300 mm (17 modules)	294 mm (16.8 modules)	From the model
Parts cost	about \$285	\$290.00	UPS with buck-boost charger
Input fuse	2 A	3.15 A time-delay	Peak current at 9 V