

# FDTD Simulation of Lossless Transmission Lines



Bram Popelier, Constantijn Coppers, Vincent Belpaire  
Supervisors: Prof. Dries Vande Ginste, ir. Emile Vanderstraeten  
Dec. 23, 2022

University of Ghent  
Faculty of Engineering and Architecture  
Bachelor of Science: Biomedical Engineering

## Abstract

Lorem ipsum dolor sit amet, consectetur adipiscing elit. Ut purus elit, vestibulum ut, placerat ac, adipiscing vitae, felis. Curabitur dictum gravida mauris. Nam arcu libero, nonummy eget, consectetur id, vulputate a, magna. Donec vehicula augue eu neque. Pellentesque habitant morbi tristique senectus et netus et malesuada fames ac turpis egestas. Mauris ut leo. Cras viverra metus rhoncus sem. Nulla et lectus vestibulum urna fringilla ultrices. Phasellus eu tellus sit amet tortor gravida placerat. Integer sapien est, iaculis in, pretium quis, viverra ac, nunc. Praesent eget sem vel leo ultrices bibendum. Aenean faucibus. Morbi dolor nulla, malesuada eu, pulvinar at, mollis ac, nulla. Curabitur auctor semper nulla. Donec varius orci eget risus. Duis nibh mi, congue eu, accumsan eleifend, sagittis quis, diam. Duis eget orci sit amet orci dignissim rutrum.

Nam dui ligula, fringilla a, euismod sodales, sollicitudin vel, wisi. Morbi auctor lorem non justo. Nam lacus libero, pretium at, lobortis vitae, ultricies et, tellus. Donec aliquet, tortor sed accumsan bibendum, erat ligula aliquet magna, vitae ornare odio metus a mi. Morbi ac orci et nisl hendrerit mollis. Suspendisse ut massa. Cras nec ante. Pellentesque a nulla. Cum sociis natoque penatibus et magnis dis parturient montes, nascetur ridiculus mus. Aliquam tincidunt urna. Nulla ullamcorper vestibulum turpis. Pellentesque cursus luctus mauris.

## 1 The update functions

The update functions are given as:

$$\tilde{I}_{n+\frac{1}{2}}^{m+\frac{1}{2}} = \tilde{I}_{n+\frac{1}{2}}^{m-\frac{1}{2}} + \alpha (V_n^m - V_{n+1}^m), \quad (1)$$

$$V_n^{m+1} = V_n^m + \alpha \left( \tilde{I}_{n-\frac{1}{2}}^{m+\frac{1}{2}} - \tilde{I}_{n+\frac{1}{2}}^{m+\frac{1}{2}} \right), \quad (2)$$

where

$$\alpha \triangleq \frac{v \Delta t}{\Delta z}, \quad (3)$$

is the dimensionless Courant factor and

$$\tilde{I}_{n+\frac{1}{2}}^{m+\frac{1}{2}} = I_{n+\frac{1}{2}}^{m+\frac{1}{2}} R_c \quad (4)$$

is the rescaled current.

At the boundaries the update function for  $V$  takes another form.

- At  $z = 0$

The voltage update function is given as:

$$V_0^{m+1} = V_0^m + \frac{2\Delta t}{C\Delta z} \left( I_g^{m+\frac{1}{2}} - I_{\frac{1}{2}}^{m+\frac{1}{2}} \right), \quad (5)$$

with

$$I_g^{m+\frac{1}{2}} = \frac{E_g^{E+\frac{1}{2}}}{R_g} - \frac{V_0^m + V_0^{m+1}}{2R_g}. \quad (6)$$

Substituting (6) in (5) and using (3), the two relations  $v = \frac{1}{\sqrt{LC}}$  and  $R_c = \sqrt{\frac{L}{C}}$  and the new defined constant  $\tilde{R}_g = \frac{R_c}{R_g}$  yields, after some rearrangements:

$$V_0^{m+1} = C_1 V_0^m + C_2 \left( E_g^{m+\frac{1}{2}} \tilde{R}_g - I_{\frac{1}{2}}^{m+\frac{1}{2}} \right) \quad (7)$$


where

$$C_1 = \frac{1 - \alpha \tilde{R}_g}{1 + \alpha \tilde{R}_g}, \quad (8)$$

$$C_2 = \frac{2\alpha}{1 + \alpha \tilde{R}_g}, \quad (9)$$

are two dimensionless constants.

- At  $z = l$



The voltage update function becomes:

$$V_N^{m+1} = V_N^m + \frac{2\Delta t}{C\Delta z} \left( I_{N-\frac{1}{2}}^{m+\frac{1}{2}} - I_L^{m+\frac{1}{2}} \right) \quad (10)$$

Kirchoff's voltage law in discretized form states that

$$I_L^{m+\frac{1}{2}} = \frac{V_N^{m+\frac{1}{2}}}{R_L} \quad (11)$$

$$= \frac{V_N^m + V_N^{m+1}}{2R_L} \quad (12)$$

Substituting (12) in (10) and using the same relations as for  $z = 0$  and the new defined constant  $\tilde{R}_L = \frac{R_c}{R_L}$  yields, after some rearrangements:

$$V_N^{m+1} = C_3 V_N^m + C_4 I_{N-\frac{1}{2}}^{m+\frac{1}{2}}, \quad (13)$$

where

$$C_3 = \frac{1 - \alpha \tilde{R}_L}{1 + \alpha \tilde{R}_L}, \quad (14)$$

$$C_4 = \frac{2\alpha}{1 + \alpha \tilde{R}_L}, \quad (15)$$

are two dimensionless constants.