



INDEPENDENCE HOUSING AUTHORITY

ITEMS MOST LIKELY TO FAIL HQS INSPECTIONS

24 Hour Emergency Repair Items

1. **Smoke Detectors:** Inoperable (including missing or bad batteries), missing or removed smoke detectors.
2. **Utilities:** Gas, Electric and/or Water not in Service.
3. **Major Plumbing Leaks or flooding:**

Non-Emergency Items

1. Deteriorating paint surfaces (peeling, chipping, cracked, water damaged, etc. or stained, cracked or buckling ceilings (interior or exterior).
2. Loose handrails (interior or exterior).
3. Absence of a handrail where there are four or more consecutive steps (interior or exterior).
4. Absent or non-secured railings around a porch or balcony, which is 30 inches or more above the ground.
5. Messy yards, grass not cut, trash, or other debris left on site or in the interior of the unit.
6. Infestation of roaches, rodents, bed bugs, or other insects.
7. Tuckpointing needed in foundation walls or other opening requiring caulking or sealing.
8. Deficient door weather-stripping allowing unacceptable air infiltration in unit.
9. Broken or cracked windows or torn screens(lower level only).
10. Inoperable window (will not open or fully close).
11. Windows without locks
12. Loose light fixtures, missing globes, missing or blown light bulbs and non-operative switches.
13. Tripping hazards, such as torn carpet, vinyl, etc.
14. Kitchen: Dirty stove burners or burners do not light on command.
15. Gaps or unsealed openings beneath kitchen sinks or bathroom vanity sinks.
16. Plumbing problems including leaks, broken or dripping faucets and running toilets
17. Loose toilets
18. No operable window or air ventilation fan in the bathroom
19. Loose electrical outlets, broken or missing outlet covers or electric wire connections not enclosed in junction boxes.
20. Gaps in electrical fittings & circuit breaker boxes.
21. Furnace or water heater flues not properly aligned and sealed at chimney.
22. Slope of flue on water heater and furnace to ensure property drafting and ventilation.
23. Dirty furnace filter
24. Water heater discharge line leaking, missing, or not terminating approximately 6 inches from the floor.