



INDEPENDENCE HOUSING AUTHORITY

ITEMS MOST LIKELY TO FAIL HQS INSPECTIONS

24 Hour Emergency Repair Items

1. **Smoke Detectors:** Inoperable (including missing or bad batteries), missing or removed smoke detectors.
2. **Utilities:** Gas, Electric and/or Water not in Service.
3. **Major Plumbing Leaks or flooding:**

Non-Emergency Items

1. Deteriorating paint surfaces (peeling, chipping, cracked, water damaged, etc. or stained, cracked or buckling ceilings (interior or exterior).
2. Loose handrails (interior or exterior).
3. Absence of a handrail where there are four or more consecutive steps (interior or exterior).
4. Absent or non-secured railings around a porch or balcony, which is 30 inches or more above the ground.
5. Messy yards, grass not cut, trash, or other debris left on site or in the interior of the unit.
6. Infestation of roaches, rodents, bed bugs, or other insects.
7. Tuckpointing needed in foundation walls or other opening requiring caulking or sealing.
8. Deficient door weather-stripping allowing unacceptable air infiltration in unit.
9. Broken or cracked windows or torn screens(lower level only).
10. Inoperable window (will not open or fully close).
11. Windows without locks
12. Loose light fixtures, missing globes, missing or blown light bulbs and non-operative switches.
13. Tripping hazards, such as torn carpet, vinyl, etc.
14. Kitchen: Dirty stove burners or burners do not light on command.
15. Gaps or unsealed openings beneath kitchen sinks or bathroom vanity sinks.
16. Plumbing problems including leaks, broken or dripping faucets and running toilets
17. Loose toilets
18. No operable window or air ventilation fan in the bathroom
19. Loose electrical outlets, broken or missing outlet covers or electric wire connections not enclosed in junction boxes.
20. Gaps in electrical fittings & circuit breaker boxes.
21. Furnace or water heater flues not properly aligned and sealed at chimney.
22. Slope of flue on water heater and furnace to ensure property drafting and ventilation.
23. Dirty furnace filter
24. Water heater discharge line leaking, missing, or not terminating approximately 6 inches from the floor.

Make Ready Checklist

Apt. #:	Date:	Service Team Member:	Housekeeping:
---------	-------	----------------------	---------------

For each item, check the box for "OK" (item was okay) , "R/R" (item was repaired or replaced) and "CLEAN" (Item was cleaned).
Notify the office of any vendors needed for carpet replacement, vinyl replacement, pest control, counter top repairs, etc.

Approach to Apartment/Entryway

	OK	R/R	CLEAN
Sidewalks			
Apartment # Sign			
Threshold/Weather stripping			
Front Door			
Exterior Lights			

Foyer

Ceiling light fixture working and clean			
---	--	--	--

Bedroom 1

Check in all rooms where present

	OK	R/R	CLEAN
Light Fixtures			
Walls and Ceilings			
Flooring			
Carpet			
Outlets/including cable and phone			
Light Switches (clean and dust free)			
Windows/window sills/no condensation or fogging of windows			
Window Screens			
Blinds			
Baseboards/Cove base			
Door Stops/Hinge/Closers			
Ceiling Fans			
Interior Doors/Folding Doors			

Bedroom 2 & 3

Check in all rooms where present

	OK	R/R	CLEAN
Light Fixtures			
Walls and Ceilings			
Flooring			
Carpet			
Outlets/including cable and phone			
Light Switches (clean and dust free)			
Windows/window sills/no condensation or fogging of windows			
Window Screens			
Blinds			
Baseboards/Cove base			
Door Stops/Hinge/Closers			
Interior Doors/Folding Doors			
Carport Roofs			
Light fixture			
Deck Surface - not cracked			
Railings secure/paint not chipped			
Exterior Paint			

Laundry

	OK	R/R	CLEAN
Hoses/water supply shut off handles operable			
Dryer Vent clean out			
Shelving			

Closets

	OK	R/R
Shelving		
Closet rods/racks		

Trash out Apartment Home

	OK	R/R
Remove trash and items from each room - reference SOP 4905		

Kitchen

	OK	R/R	CLEAN
Refrigerator - door gasket sealed			
Refrigerator - setting at 1			
Refrigerator grills/light/coils clean			
Icemaker			
Dishwasher (secured to cabinet)			
Disposer			
Range Top			
Range Elements			
Drip Pans			
Oven (anti-tip brackets installed)			
Microwave			
Vent Hood			
Counter Tops			
Cabinets			
Drawers			
Sink			
Supply lines			
Vegetable sprayer			
Splash guard/disposal side			
Faucets/Aerator/ Handles			
GFCI'S			
Caulking			
Sink stoppers/basket strainers			

Bathrooms

	OK	R/R	CLEAN
Sinks			
Sinks Faucets			
Sink Pop-Ups			
Handles and Index Buttons			
P-Trap			
Angle Stop			
Supply lines(no leaks - fill sink)			
Bath/Shower surround or shower door			
Bath/Shower Faucets			
Showerheads			
Escutcheons			
Tub Drains			
Toilets			
Toilet Seats (caps and bolt covers in place)			
Supply Lines (tightened)			
Mirrors /Clips (no peeling edges)			
Countertops (no damage below laminate)			
Cabinets/Drawers			
Medicine Cabinet			
Shelving			
Bath Hardware			
GFCI's			
Caulking			
Exhaust Fan (clean and operable)			

Living Room

	OK	R/R	CLEAN
Outlets			
Blinds			

Mechanical Room/Closet

	OK	R/R
Water Heater Temp _____		
Water Heater Leaks - check connections		
Water Heater pressure relief valve -18" from floor		
Water Lines		
Drain Lines		
Enclosure/Closet		
Venting		

HVAC

	OK	R/R
Operation		
Air Circulation		
Thermostat/calibrate		
Check/Clean Evaporator Coil		
Condensate Pan		
Check/Clean Condenser Coil		
Condenser Fan Motor		
Furnace		
Check/Clean Baseboard Heaters		
Check/Clean Wall Heater		
Check/Clean all vents/registers		
Change Filters		

Safety/Lock/Key

	OK	R/R
Peephole (160") (clear)		
Passage Set		
Strike Plate (3" screws)		
Window Latches		
Sliding Door Latches		
Sliding Door Pin		
Smoke Detectors		
Change/Rekey Lock (works smoothly)		
Attic access panels locked		
Mail box locks and keys (works smoothly)		

Moisture & AMG

	OK	R/R
Inspect for Moisture & AMG		
If found, follow the "SOP":		
4155 - Mold Prevention and Detection		

Before Leaving Apartment

	OK
Add Enzymes to Drains	
Close Blinds/Turn Off Lights	
Set winter temperature to 68°-73°F	
Set summer temperature to 78°F	
Lock All Windows and Doors	

Completed Make Ready (signoffs)

Service Supervisor must inspect apartment and safety/lock/key items and initial here: _____ Manager _____

Comments:

Pre-Move-Out/Scheduling Inspection

(Performed Once Notice is Received)

Apt. #	Onsite Transfer (Circle 1) YES NO	Move-Out Date
Unit Type	Bedrooms	Move-In Date
Baths	Date of inspection:	

Work Needed				Date	Vendor	Comments
Paint (circle items needed)	Touch-up	Complete Paint	+ Ceilings			
Clean (Include Comments)						
Carpet (circle items needed)	Repair	Replace	Stains			
Vinyl/Tile (circle items needed)	Repair	Replace				
Location:	Kitchen	Bath 1	Bath 2 Entry			
Blinds (circle items needed)	Full	Partial				
Appliances (circle items needed)	Repair	Replace				(Specify Appliance and Work Needed)
Other (Specify)						

Apartment Condition - Parts Needed		Anticipated Charges
Approach		
Entry		
Living Room		
Patio/Balcony		
Kitchen		
Bathrooms		
Bedrooms		
Closets		
Mechanical Room/Closet		
HVAC		
Pest Control		
OTHER:		

Comments: _____

Inspection Completed By: _____ Title: _____