

Northlake Source System Inventory

DATE September 14, 2026
PREPARED BY Northlake University

Packet 0.3 | Issued 2026-09-14 | Facilities, IT and Finance

Match each delivered measurement to the register. Only the AcquiSuite sample is supplied in this release; the remaining feeds require files, fixtures or services.

Source Name	Source Type	Service Category	Owner / Vendor	Delivery Method	Expected Cadence	File / System Reference	Credential Owner	Review Status	Notes
Campus AcquiSuite loggers	File delivery	AcquiSuite log	Facilities Operations	File delivery	Every 15 minutes	Student Center, Lakeview Residence Hall	Facilities Operations	Documented	UTC; interval-start timestamps for the onboarding sample. Supplied: AcquiSuite complete, gap and backfill.
Valley Electric meter-data service	File delivery	MV90 MDEF	Valley Electric District	File delivery	Daily	Science Center, Recreation and Aquatics Center, Central Plant	Valley Electric District	Documented	Local timestamps; timezone and DST behavior require acceptance. Sample / service not yet supplied.
Helios solar meter-data service	File delivery	MV90 MV9	Helios Onsite Solar	File delivery	Daily	Science Center, Student Center, Cedar Row Carport and Grounds	Helios Onsite Solar	Documented	Local timestamps; timezone and DST behavior require acceptance. Sample / service not yet supplied.
Central plant building automation	Device polling	BACnet	Thermal Plant	Device polling	Hourly	Science Center, Recreation and Aquatics Center, Central Plant	Thermal Plant	Documented	Poll time; historical replay is a separate input path. Sample / service not yet supplied.
KSAC weather observations	Weather service	NOAA	Facilities Operations	Weather service	Hourly	Weather Reference	Facilities Operations	Documented	Source observation time. Sample / service not yet supplied.
KSMF observations and forecast	Weather service	Aeris	Sustainability	Weather service	Hourly	Weather Reference	Sustainability	Documented	Observation and forecast valid times remain separate. Sample / service not yet supplied.
Science Center laboratory sensors	File delivery	Spinwave CSV	Facilities Operations	File delivery	Every 15 minutes	Science Center	Facilities Operations	Documented	Source timestamp. Sample / service not yet supplied.
Cedar Row A water export	File delivery	FIG family	River City Utilities	File delivery	Hourly	Cedar Row A	River City Utilities	Documented	Source timestamp with configured offset. Sample / service not yet supplied.
Central plant chiller controller	Device polling	Modbus TCP	Thermal Plant	Device polling	Every 5 minutes	Central Plant	Thermal Plant	Documented	Poll time. Sample / service not yet supplied.
Library historian	Database query	ODBC	IT	Database query	Every 15 minutes	Library	IT	Documented	Source timestamp and cursor. Sample / service not yet supplied.
Student Center commissioning test signal	Test signal	EEM Fake	Facilities Operations	Test signal	Every 15 minutes	Student Center	Facilities Operations	Documented	Generated time; excluded from customer consumption totals. Sample / service not yet supplied.

Source Name	Source Type	Service Category	Owner / Vendor	Delivery Method	Expected Cadence	File / System Reference	Credential Owner	Review Status	Notes
Cedar Row B water route	Handheld upload	Neptune	River City Utilities	Handheld upload	Monthly route	Cedar Row B	River City Utilities	Documented	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period. Sample / service not yet supplied.
Student Center gas route	Handheld upload	MVRS	Sierra Gas Utility	Handheld upload	Monthly route	Student Center	Sierra Gas Utility	Documented	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period. Sample / service not yet supplied.
Fixed-network electric submeters	File delivery	FIG fixed network	Facilities and Housing Operations	File delivery	Hourly	Cedar Row A, Cedar Row B, Lakeview Residence Hall, Parking Structure	Facilities and Housing Operations	Documented	Source timestamp. Sample / service not yet supplied.
Cedar Row apartment water submeter route	Handheld upload	Neptune	Housing Operations	Handheld upload	Monthly route	Cedar Row A, Cedar Row B	Housing Operations	Documented	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period. Sample / service not yet supplied.
Handheld reading exceptions	Reading event upload	HMR events	Facilities Operations	Reading event upload	With each route	Neptune and MVRS reading events	Facilities Operations	Documented	Event timestamp. Sample / service not yet supplied.
Helios Onsite Solar billing	Billing statement	Monthly utility / allocation / PPA statement	Finance	Statement and supported bill-import file	Monthly	HOS	Finance	Documented	Existing illustrated bills are examples; reconcile their values before rate or bill acceptance.
Northlake Thermal Plant billing	Billing statement	Monthly utility / allocation / PPA statement	Finance	Statement and supported bill-import file	Monthly	NTP	Finance	Documented	Existing illustrated bills are examples; reconcile their values before rate or bill acceptance.
River City Utilities billing	Billing statement	Monthly utility / allocation / PPA statement	Finance	Statement and supported bill-import file	Monthly	RCU	Finance	Documented	Existing illustrated bills are examples; reconcile their values before rate or bill acceptance.
Sierra Gas Utility billing	Billing statement	Monthly utility / allocation / PPA statement	Finance	Statement and supported bill-import file	Monthly	SGU	Finance	Documented	Existing illustrated bills are examples; reconcile their values before rate or bill acceptance.

Source Name	Source Type	Service Category	Owner / Vendor	Delivery Method	Expected Cadence	File / System Reference	Credential Owner	Review Status	Notes
Valley Electric District billing	Billing statement	Monthly utility / allocation / PPA statement	Finance	Statement and supported bill-import file	Monthly	VED	Finance	Documented	Existing illustrated bills are examples; reconcile their values before rate or bill acceptance.

Measurement mapping

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Campus AcquiSuite loggers	Student Center Electric Main	Delivered kWh 15m	ASQVED01	DeviceID=STUDENT; Row Number=1; PointType=kWh	kWh	UTC; interval-start timestamps for the onboarding sample
Campus AcquiSuite loggers	Student Center Electric Main	Demand kW 15m	ASQVED01	DeviceID=STUDENT; Row Number=2; PointType=kW	kW	UTC; interval-start timestamps for the onboarding sample
Campus AcquiSuite loggers	Lakeview Hall Electric Main	Delivered kWh 15m	ASQVED02	DeviceID=LAKEVIEW; Row Number=1; PointType=kWh	kWh	UTC; interval-start timestamps for the onboarding sample
Campus AcquiSuite loggers	Lakeview Hall Electric Main	Demand kW 15m	ASQVED02	DeviceID=LAKEVIEW; Row Number=2; PointType=kW	kW	UTC; interval-start timestamps for the onboarding sample
Valley Electric meter-data service	Science Center Electric Main	Delivered kWh 15m	MV90-MDEF-VED-SCIENCE	RecorderID=VEDSCIENCE01; Channel=1; PointType=kWh	kWh	Local timestamps; timezone and DST behavior require acceptance
Valley Electric meter-data service	Science Center Electric Main	Demand kW 15m	MV90-MDEF-VED-SCIENCE	RecorderID=VEDSCIENCE01; Channel=2; PointType=kW	kW	Local timestamps; timezone and DST behavior require acceptance

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Valley Electric meter-data service	Recreation Center Electric Main	Delivered kWh 15m	MV90-MDEF-VED-RECREATION	RecorderID=VEDRECREATION01; Channel=1; PointType=kWh	kWh	Local timestamps; timezone and DST behavior require acceptance
Valley Electric meter-data service	Recreation Center Electric Main	Demand kW 15m	MV90-MDEF-VED-RECREATION	RecorderID=VEDRECREATION01; Channel=2; PointType=kW	kW	Local timestamps; timezone and DST behavior require acceptance
Valley Electric meter-data service	Central Plant Electric Service	Delivered kWh 15m	MV90-MDEF-VED-PLANT	RecorderID=VEDPLANT01; Channel=1; PointType=kWh	kWh	Local timestamps; timezone and DST behavior require acceptance
Valley Electric meter-data service	Central Plant Electric Service	Demand kW 15m	MV90-MDEF-VED-PLANT	RecorderID=VEDPLANT01; Channel=2; PointType=kW	kW	Local timestamps; timezone and DST behavior require acceptance
Helios solar meter-data service	Science Center PV Array	Generated kWh 15m	MV90-MV9-HELIOS	RecorderID=HOSSCIENCE01; Channel=1; PointType=kWh	kWh	Local timestamps; timezone and DST behavior require acceptance
Helios solar meter-data service	Science Center PV Array	Exported kWh 15m	MV90-MV9-HELIOS	RecorderID=HOSSCIENCE01; Channel=2; PointType=kWh	kWh	Local timestamps; timezone and DST behavior require acceptance
Helios solar meter-data service	Student Center PV Array	Generated kWh 15m	MV90-MV9-HELIOS	RecorderID=HOSSTUDENT01; Channel=1; PointType=kWh	kWh	Local timestamps; timezone and DST behavior require acceptance
Helios solar meter-data service	Cedar Row Solar Carport	Generated kWh 15m	MV90-MV9-HELIOS	RecorderID=HOSCARPORT01; Channel=1; PointType=kWh	kWh	Local timestamps; timezone and DST behavior require acceptance
Central plant building automation	Science Center Chilled Water	Delivered Ton-Hours 60m	NTP-BACNET-SCIENCE-CHW	DeviceID=5301001; ObjectID=1001; Object Type=2; Array Index=0; PointType=ton_hours	Ton-Hours	Poll time; historical replay is a separate input path

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Central plant building automation	Science Center Chilled Water	Demand Tons 60m	NTP-BACNET-SCIENCE-CHW	DeviceID=5301001; ObjectID=1002; ObjectType=2; Array Index=0; PointType=tons	Tons	Poll time; historical replay is a separate input path
Central plant building automation	Recreation Center Chilled Water	Delivered Ton-Hours 60m	NTP-BACNET-RECREATION-CHW	DeviceID=5301002; ObjectID=1001; ObjectType=2; Array Index=0; PointType=ton_hours	Ton-Hours	Poll time; historical replay is a separate input path
Central plant building automation	Recreation Center Chilled Water	Demand Tons 60m	NTP-BACNET-RECREATION-CHW	DeviceID=5301002; ObjectID=1002; ObjectType=2; Array Index=0; PointType=tons	Tons	Poll time; historical replay is a separate input path
Central plant building automation	Central Plant Chilled Water Supply	Produced Ton-Hours 60m	NTP-BACNET-PLANT-HEADERS	DeviceID=5301003; ObjectID=2001; ObjectType=2; Array Index=0; PointType=ton_hours	Ton-Hours	Poll time; historical replay is a separate input path
Central plant building automation	Central Plant Chilled Water Supply	Production Rate Tons 60m	NTP-BACNET-PLANT-HEADERS	DeviceID=5301003; ObjectID=2002; ObjectType=2; Array Index=0; PointType=tons	Tons	Poll time; historical replay is a separate input path
Central plant building automation	Central Plant Steam Production	Produced klb 60m	NTP-BACNET-PLANT-HEADERS	DeviceID=5301003; ObjectID=2003; ObjectType=2; Array Index=0; PointType=klb	klb	Poll time; historical replay is a separate input path
Central plant building automation	Central Plant Steam Production	Production Rate lb/h 60m	NTP-BACNET-PLANT-HEADERS	DeviceID=5301003; ObjectID=2004; ObjectType=2; Array Index=0; PointType=lb_per_hour	lb/h	Poll time; historical replay is a separate input path
Central plant building automation	Central Plant Condensate Return	Produced kgal 60m	NTP-BACNET-PLANT-HEADERS	DeviceID=5301003; ObjectID=2005; ObjectType=2; Array Index=0; PointType=kgal	kgal	Poll time; historical replay is a separate input path
KSAC weather observations	KSAC Sacramento Executive Airport	KSAC Outside Air Temperature	NOAA-KSAC	WeatherTypeName=tempi; PointType=temp_f	degF	Source observation time
KSAC weather observations	KSAC Sacramento Executive Airport	KSAC Relative Humidity	NOAA-KSAC	WeatherTypeName=hum; PointType=relative_humidity	pct	Source observation time

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
KSAC weather observations	KSAC Sacramento Executive Airport	KSAC Wind Speed	NOAA-KSAC	WeatherTypeName=wspdi; PointType=wind_mph	mph	Source observation time
KSMF observations and forecast	KSMF Sacramento International Airport	KSMF Outside Air Temperature	AERIS-KSMF-OBS	WeatherTypeName=tempF; PointType=tempF	degF	Observation and forecast valid times remain separate
KSMF observations and forecast	KSMF Sacramento International Airport	KSMF Forecast Temperature	AERIS-KSMF-FORECAST	WeatherTypeName=tempF; PointType=tempF	degF	Observation and forecast valid times remain separate
Science Center laboratory sensors	Science Center Lab Environment	Lab Air Temperature	SPINWAVE-SCIENCE-LAB	Device Address=SW-SCI-LAB-01; Channel Number=1; PointType=temp_f	degF	Source timestamp
Science Center laboratory sensors	Science Center Lab Environment	Lab Relative Humidity	SPINWAVE-SCIENCE-LAB	Device Address=SW-SCI-LAB-01; Channel Number=2; PointType=relative_humidity	pct	Source timestamp
Cedar Row A water export	Cedar Row A Water Master	Delivered kgal 60m	FIG-CEDAR-ROW	Point Alias=FIG_CEDAR_ROW_A_WATER; Channel=01; UOM=kgal; Multiplier=1; OffsetTimeMinutes=0; PointType=kgal	kgal	Source timestamp with configured offset
Central plant chiller controller	Central Plant Chiller Controller	Chiller Demand kW 5m	NTP-MODBUS-CHILLER	Register Type=Floating Point MSR First; Register Address=40001; Multiplier=1; Offset=0; PointType=kW	kW	Poll time
Library historian	Library Electric Historian	Historian Delivered kWh 15m	ODBC-LIBRARY-HISTORIAN	SourceTable=SyntheticIntervalReadings; PointType=kWh	kWh	Source timestamp and cursor
Student Center commissioning test signal	Student Center Fake Gateway Smoke	Fake Gateway Smoke kWh 15m	FAKE-SMOKE	GenerationMode=sinusoidal; MinValue=12; MaxValue=36; PeriodMinutes=1440; Seed=104729; PointType=kWh	kWh	Generated time; excluded from customer consumption totals

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row B water route	Cedar Row B Water Master	Route Usage kgal	NEPTUNE-RCU-CEDAR-B	Route ID=660004; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=1200; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Student Center gas route	Student Center Kitchen Gas	Route Usage Therms	MVRS-SGU-STUDENT-CENTER	Route ID=650004; TextPrompt=THRM; UN_Units=CurRead; MeterConstant=1; LastReadingValue=800; PointType=therms	Therms	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Fixed-network electric submeters	Cedar Row A Electric House	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_HOUSE_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 101 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_101_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 102 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_102_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 103 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_103_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 104 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_104_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 105 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_105_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 106 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_106_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row A Unit 107 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_107_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 108 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_108_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 109 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_109_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 110 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_110_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 111 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_111_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 112 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_112_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 113 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_113_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 114 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_114_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 115 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_115_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 116 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_116_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 117 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_117_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row A Unit 118 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_118_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 119 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_119_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 120 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_120_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 201 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_201_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 202 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_202_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 203 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_203_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 204 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_204_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 205 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_205_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 206 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_206_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 207 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_207_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 208 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_208_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row A Unit 209 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_209_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 210 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_210_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 211 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_211_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 212 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_212_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 213 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_213_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 214 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_214_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 215 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_215_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 216 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_216_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 217 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_217_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 218 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_218_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 219 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_219_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row A Unit 220 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_220_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 301 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_301_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 302 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_302_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 303 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_303_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 304 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_304_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 305 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_305_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 306 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_306_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 307 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_307_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 308 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_308_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 309 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_309_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 310 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_310_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row A Unit 311 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_311_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 312 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_312_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 313 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_313_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 314 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_314_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 315 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_315_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 316 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_316_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 317 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_317_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 318 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_318_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 319 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_319_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row A Unit 320 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-A-UNITS	Point Alias=FN_CRA_320_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Electric House	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_HOUSE_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row B Unit 101 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_101_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 102 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_102_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 103 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_103_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 104 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_104_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 105 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_105_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 106 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_106_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 107 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_107_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 108 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_108_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 109 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_109_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 110 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_110_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 111 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_111_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row B Unit 112 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_112_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 113 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_113_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 114 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_114_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 115 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_115_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 116 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_116_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 201 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_201_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 202 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_202_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 203 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_203_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 204 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_204_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 205 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_205_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 206 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_206_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row B Unit 207 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_207_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 208 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_208_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 209 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_209_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 210 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_210_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 211 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_211_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 212 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_212_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 213 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_213_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 214 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_214_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 215 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_215_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 216 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_216_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 301 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_301_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row B Unit 302 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_302_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 303 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_303_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 304 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_304_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 305 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_305_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 306 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_306_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 307 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_307_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 308 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_308_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 309 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_309_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 310 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_310_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 311 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_311_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 312 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_312_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row B Unit 313 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_313_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 314 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_314_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 315 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_315_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 316 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_316_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 401 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_401_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 402 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_402_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 403 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_403_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 404 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_404_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 405 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_405_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 406 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_406_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 407 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_407_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Fixed-network electric submeters	Cedar Row B Unit 408 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_408_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 409 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_409_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 410 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_410_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 411 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_411_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 412 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_412_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 413 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_413_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 414 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_414_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 415 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_415_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Cedar Row B Unit 416 Electric	Submeter kWh 60m	FIG-CEDAR-ROW-B-UNITS	Point Alias=FN_CRB_416_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Lakeview Hall Laundry Electric	Submeter kWh 60m	FIG-CAMPUS-SUBMETERS	Point Alias=FN_LAKEVIEW_LAUNDRY_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp
Fixed-network electric submeters	Parking Structure EV Chargers	Submeter kWh 60m	FIG-CAMPUS-SUBMETERS	Point Alias=FN_PARKING_EV_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh	kWh	Source timestamp

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Water House	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=660101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=300; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 101 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 102 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 103 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 104 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 105 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 106 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 107 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 108 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 109 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 110 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 111 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 112 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 113 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 114 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 115 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 116 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 117 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661171; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 118 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661181; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 119 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661191; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 120 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=661201; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 201 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 202 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 203 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 204 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 205 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 206 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 207 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 208 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 209 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 210 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 211 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 212 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 213 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 214 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 215 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 216 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 217 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662171; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 218 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662181; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 219 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662191; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 220 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=662201; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 301 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 302 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 303 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 304 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 305 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 306 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 307 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 308 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 309 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 310 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 311 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 312 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 313 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 314 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 315 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 316 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 317 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663171; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 318 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663181; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row A Unit 319 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663191; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row A Unit 320 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-A-UNITS	Route ID=663201; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Water House	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=670101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=300; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 101 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 102 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 103 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 104 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 105 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 106 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 107 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 108 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 109 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 110 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 111 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 112 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 113 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 114 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 115 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 116 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=671161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 201 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 202 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 203 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 204 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 205 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 206 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 207 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 208 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 209 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 210 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 211 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 212 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 213 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 214 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 215 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 216 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=672161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 301 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 302 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 303 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 304 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 305 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 306 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 307 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 308 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 309 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 310 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 311 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 312 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 313 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 314 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 315 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 316 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=673161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 401 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 402 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 403 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 404 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 405 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 406 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 407 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 408 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 409 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 410 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period

Source System	Meter	Measurement	Device / Station	Channel / Source Fields	Unit	Timestamp Convention
Cedar Row apartment water submeter route	Cedar Row B Unit 411 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 412 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 413 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 414 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 415 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period
Cedar Row apartment water submeter route	Cedar Row B Unit 416 Water	Route Usage kgal	NEPTUNE-CEDAR-ROW-B-UNITS	Route ID=674161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal	kgal	Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period