

# Northlake Source System Inventory

DATE September 14, 2026  
PREPARED BY Northlake University

---

Packet 0.3 | Issued 2026-09-14 | Facilities, IT and Finance

Match each delivered measurement to the register. Only the AcquiSuite sample is supplied in this release; the remaining feeds require files, fixtures or services.

| Source Name                              | Source Type     | Service Category | Owner / Vendor           | Delivery Method | Expected Cadence | File / System Reference                                       | Credential Owner         | Review Status | Notes                                                                                                      |
|------------------------------------------|-----------------|------------------|--------------------------|-----------------|------------------|---------------------------------------------------------------|--------------------------|---------------|------------------------------------------------------------------------------------------------------------|
| Campus AcquiSuite loggers                | File delivery   | AcquiSuite log   | Facilities Operations    | File delivery   | Every 15 minutes | Student Center, Lakeview Residence Hall                       | Facilities Operations    | Documented    | UTC; interval-start timestamps for the onboarding sample. Supplied: AcquiSuite complete, gap and backfill. |
| Valley Electric meter-data service       | File delivery   | MV90 MDEF        | Valley Electric District | File delivery   | Daily            | Science Center, Recreation and Aquatics Center, Central Plant | Valley Electric District | Documented    | Local timestamps; timezone and DST behavior require acceptance. Sample / service not yet supplied.         |
| Helios solar meter-data service          | File delivery   | MV90 MV9         | Helios Onsite Solar      | File delivery   | Daily            | Science Center, Student Center, Cedar Row Carport and Grounds | Helios Onsite Solar      | Documented    | Local timestamps; timezone and DST behavior require acceptance. Sample / service not yet supplied.         |
| Central plant building automation        | Device polling  | BACnet           | Thermal Plant            | Device polling  | Hourly           | Science Center, Recreation and Aquatics Center, Central Plant | Thermal Plant            | Documented    | Poll time; historical replay is a separate input path. Sample / service not yet supplied.                  |
| KSAC weather observations                | Weather service | NOAA             | Facilities Operations    | Weather service | Hourly           | Weather Reference                                             | Facilities Operations    | Documented    | Source observation time. Sample / service not yet supplied.                                                |
| KSMF observations and forecast           | Weather service | Aeris            | Sustainability           | Weather service | Hourly           | Weather Reference                                             | Sustainability           | Documented    | Observation and forecast valid times remain separate. Sample / service not yet supplied.                   |
| Science Center laboratory sensors        | File delivery   | Spinwave CSV     | Facilities Operations    | File delivery   | Every 15 minutes | Science Center                                                | Facilities Operations    | Documented    | Source timestamp. Sample / service not yet supplied.                                                       |
| Cedar Row A water export                 | File delivery   | FIG family       | River City Utilities     | File delivery   | Hourly           | Cedar Row A                                                   | River City Utilities     | Documented    | Source timestamp with configured offset. Sample / service not yet supplied.                                |
| Central plant chiller controller         | Device polling  | Modbus TCP       | Thermal Plant            | Device polling  | Every 5 minutes  | Central Plant                                                 | Thermal Plant            | Documented    | Poll time. Sample / service not yet supplied.                                                              |
| Library historian                        | Database query  | ODBC             | IT                       | Database query  | Every 15 minutes | Library                                                       | IT                       | Documented    | Source timestamp and cursor. Sample / service not yet supplied.                                            |
| Student Center commissioning test signal | Test signal     | EEM Fake         | Facilities Operations    | Test signal     | Every 15 minutes | Student Center                                                | Facilities Operations    | Documented    | Generated time; excluded from customer consumption totals. Sample / service not yet supplied.              |

| Source Name                              | Source Type          | Service Category                             | Owner / Vendor                    | Delivery Method                          | Expected Cadence | File / System Reference                                              | Credential Owner                  | Review Status | Notes                                                                                                                |
|------------------------------------------|----------------------|----------------------------------------------|-----------------------------------|------------------------------------------|------------------|----------------------------------------------------------------------|-----------------------------------|---------------|----------------------------------------------------------------------------------------------------------------------|
| Cedar Row B water route                  | Handheld upload      | Neptune                                      | River City Utilities              | Handheld upload                          | Monthly route    | Cedar Row B                                                          | River City Utilities              | Documented    | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period. Sample / service not yet supplied. |
| Student Center gas route                 | Handheld upload      | MVRS                                         | Sierra Gas Utility                | Handheld upload                          | Monthly route    | Student Center                                                       | Sierra Gas Utility                | Documented    | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period. Sample / service not yet supplied. |
| Fixed-network electric submeters         | File delivery        | FIG fixed network                            | Facilities and Housing Operations | File delivery                            | Hourly           | Cedar Row A, Cedar Row B, Lakeview Residence Hall, Parking Structure | Facilities and Housing Operations | Documented    | Source timestamp. Sample / service not yet supplied.                                                                 |
| Cedar Row apartment water submeter route | Handheld upload      | Neptune                                      | Housing Operations                | Handheld upload                          | Monthly route    | Cedar Row A, Cedar Row B                                             | Housing Operations                | Documented    | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period. Sample / service not yet supplied. |
| Handheld reading exceptions              | Reading event upload | HMR events                                   | Facilities Operations             | Reading event upload                     | With each route  | Neptune and MVRS reading events                                      | Facilities Operations             | Documented    | Event timestamp. Sample / service not yet supplied.                                                                  |
| Helios Onsite Solar billing              | Billing statement    | Monthly utility / allocation / PPA statement | Finance                           | Statement and supported bill-import file | Monthly          | HOS                                                                  | Finance                           | Documented    | Existing illustrated bills are examples; reconcile their values before rate or bill acceptance.                      |
| Northlake Thermal Plant billing          | Billing statement    | Monthly utility / allocation / PPA statement | Finance                           | Statement and supported bill-import file | Monthly          | NTP                                                                  | Finance                           | Documented    | Existing illustrated bills are examples; reconcile their values before rate or bill acceptance.                      |
| River City Utilities billing             | Billing statement    | Monthly utility / allocation / PPA statement | Finance                           | Statement and supported bill-import file | Monthly          | RCU                                                                  | Finance                           | Documented    | Existing illustrated bills are examples; reconcile their values before rate or bill acceptance.                      |
| Sierra Gas Utility billing               | Billing statement    | Monthly utility / allocation / PPA statement | Finance                           | Statement and supported bill-import file | Monthly          | SGU                                                                  | Finance                           | Documented    | Existing illustrated bills are examples; reconcile their values before rate or bill acceptance.                      |

| Source Name                      | Source Type       | Service Category                             | Owner / Vendor | Delivery Method                          | Expected Cadence | File / System Reference | Credential Owner | Review Status | Notes                                                                                           |
|----------------------------------|-------------------|----------------------------------------------|----------------|------------------------------------------|------------------|-------------------------|------------------|---------------|-------------------------------------------------------------------------------------------------|
| Valley Electric District billing | Billing statement | Monthly utility / allocation / PPA statement | Finance        | Statement and supported bill-import file | Monthly          | VED                     | Finance          | Documented    | Existing illustrated bills are examples; reconcile their values before rate or bill acceptance. |

## Measurement mapping

| Source System                      | Meter                           | Measurement       | Device / Station         | Channel / Source Fields                              | Unit | Timestamp Convention                                           |
|------------------------------------|---------------------------------|-------------------|--------------------------|------------------------------------------------------|------|----------------------------------------------------------------|
| Campus AcquiSuite loggers          | Student Center Electric Main    | Delivered kWh 15m | ASQVED01                 | DeviceID=STUDENT; Row Number=1; PointType=kWh        | kWh  | UTC; interval-start timestamps for the onboarding sample       |
| Campus AcquiSuite loggers          | Student Center Electric Main    | Demand kW 15m     | ASQVED01                 | DeviceID=STUDENT; Row Number=2; PointType=kW         | kW   | UTC; interval-start timestamps for the onboarding sample       |
| Campus AcquiSuite loggers          | Lakeview Hall Electric Main     | Delivered kWh 15m | ASQVED02                 | DeviceID=LAKEVIEW; Row Number=1; PointType=kWh       | kWh  | UTC; interval-start timestamps for the onboarding sample       |
| Campus AcquiSuite loggers          | Lakeview Hall Electric Main     | Demand kW 15m     | ASQVED02                 | DeviceID=LAKEVIEW; Row Number=2; PointType=kW        | kW   | UTC; interval-start timestamps for the onboarding sample       |
| Valley Electric meter-data service | Science Center Electric Main    | Delivered kWh 15m | MV90-MDEF-VED-SCIENCE    | RecorderID=VEDSCIENCE01; Channel=1; PointType=kWh    | kWh  | Local timestamps; timezone and DST behavior require acceptance |
| Valley Electric meter-data service | Science Center Electric Main    | Demand kW 15m     | MV90-MDEF-VED-SCIENCE    | RecorderID=VEDSCIENCE01; Channel=2; PointType=kW     | kW   | Local timestamps; timezone and DST behavior require acceptance |
| Valley Electric meter-data service | Recreation Center Electric Main | Delivered kWh 15m | MV90-MDEF-VED-RECREATION | RecorderID=VEDRECREATION01; Channel=1; PointType=kWh | kWh  | Local timestamps; timezone and DST behavior require acceptance |

| Source System                      | Meter                           | Measurement             | Device / Station         | Channel / Source Fields                                                            | Unit      | Timestamp Convention                                           |
|------------------------------------|---------------------------------|-------------------------|--------------------------|------------------------------------------------------------------------------------|-----------|----------------------------------------------------------------|
| Valley Electric meter-data service | Recreation Center Electric Main | Demand kW 15m           | MV90-MDEF-VED-RECREATION | RecorderID=VEDRECREATION01; Channel=2; PointType=kW                                | kW        | Local timestamps; timezone and DST behavior require acceptance |
| Valley Electric meter-data service | Central Plant Electric Service  | Delivered kWh 15m       | MV90-MDEF-VED-PLANT      | RecorderID=VEDPLANT01; Channel=1; PointType=kWh                                    | kWh       | Local timestamps; timezone and DST behavior require acceptance |
| Valley Electric meter-data service | Central Plant Electric Service  | Demand kW 15m           | MV90-MDEF-VED-PLANT      | RecorderID=VEDPLANT01; Channel=2; PointType=kW                                     | kW        | Local timestamps; timezone and DST behavior require acceptance |
| Helios solar meter-data service    | Science Center PV Array         | Generated kWh 15m       | MV90-MV9-HELIOS          | RecorderID=HOSSCIENCE01; Channel=1; PointType=kWh                                  | kWh       | Local timestamps; timezone and DST behavior require acceptance |
| Helios solar meter-data service    | Science Center PV Array         | Exported kWh 15m        | MV90-MV9-HELIOS          | RecorderID=HOSSCIENCE01; Channel=2; PointType=kWh                                  | kWh       | Local timestamps; timezone and DST behavior require acceptance |
| Helios solar meter-data service    | Student Center PV Array         | Generated kWh 15m       | MV90-MV9-HELIOS          | RecorderID=HOSSTUDENT01; Channel=1; PointType=kWh                                  | kWh       | Local timestamps; timezone and DST behavior require acceptance |
| Helios solar meter-data service    | Cedar Row Solar Carport         | Generated kWh 15m       | MV90-MV9-HELIOS          | RecorderID=HOSCARPORT01; Channel=1; PointType=kWh                                  | kWh       | Local timestamps; timezone and DST behavior require acceptance |
| Central plant building automation  | Science Center Chilled Water    | Delivered Ton-Hours 60m | NTP-BACNET-SCIENCE-CHW   | DeviceID=5301001; ObjectID=1001; Object Type=2; Array Index=0; PointType=ton_hours | ton_hours | Poll time; historical replay is a separate input path          |
| Central plant building automation  | Science Center Chilled Water    | Demand Tons 60m         | NTP-BACNET-SCIENCE-CHW   | DeviceID=5301001; ObjectID=1002; Object Type=2; Array Index=0; PointType=tons      | tons      | Poll time; historical replay is a separate input path          |

| Source System                     | Meter                              | Measurement                  | Device / Station          | Channel / Source Fields                                                             | Unit        | Timestamp Convention                                  |
|-----------------------------------|------------------------------------|------------------------------|---------------------------|-------------------------------------------------------------------------------------|-------------|-------------------------------------------------------|
| Central plant building automation | Recreation Center Chilled Water    | Delivered Ton-Hours 60m      | NTP-BACNET-RECREATION-CHW | DeviceID=5301002; ObjectID=1001; ObjectType=2; Array Index=0; PointType=ton_hours   | ton_hours   | Poll time; historical replay is a separate input path |
| Central plant building automation | Recreation Center Chilled Water    | Demand Tons 60m              | NTP-BACNET-RECREATION-CHW | DeviceID=5301002; ObjectID=1002; ObjectType=2; Array Index=0; PointType=tons        | tons        | Poll time; historical replay is a separate input path |
| Central plant building automation | Central Plant Chilled Water Supply | Produced Ton-Hours 60m       | NTP-BACNET-PLANT-HEADERS  | DeviceID=5301003; ObjectID=2001; ObjectType=2; Array Index=0; PointType=ton_hours   | ton_hours   | Poll time; historical replay is a separate input path |
| Central plant building automation | Central Plant Chilled Water Supply | Production Rate Tons 60m     | NTP-BACNET-PLANT-HEADERS  | DeviceID=5301003; ObjectID=2002; ObjectType=2; Array Index=0; PointType=tons        | tons        | Poll time; historical replay is a separate input path |
| Central plant building automation | Central Plant Steam Production     | Produced klb 60m             | NTP-BACNET-PLANT-HEADERS  | DeviceID=5301003; ObjectID=2003; ObjectType=2; Array Index=0; PointType=klb         | klb         | Poll time; historical replay is a separate input path |
| Central plant building automation | Central Plant Steam Production     | Production Rate lb/h 60m     | NTP-BACNET-PLANT-HEADERS  | DeviceID=5301003; ObjectID=2004; ObjectType=2; Array Index=0; PointType=lb_per_hour | lb_per_hour | Poll time; historical replay is a separate input path |
| Central plant building automation | Central Plant Condensate Return    | Produced kgal 60m            | NTP-BACNET-PLANT-HEADERS  | DeviceID=5301003; ObjectID=2005; ObjectType=2; Array Index=0; PointType=kgal        | kgal        | Poll time; historical replay is a separate input path |
| KSAC weather observations         | KSAC Sacramento Executive Airport  | KSAC Outside Air Temperature | NOAA-KSAC                 | WeatherTypeName=tempi; PointType=temp_f                                             | degF        | Source observation time                               |
| KSAC weather observations         | KSAC Sacramento Executive Airport  | KSAC Relative Humidity       | NOAA-KSAC                 | WeatherTypeName=hum; PointType=relative_humidity                                    | pct         | Source observation time                               |
| KSAC weather observations         | KSAC Sacramento Executive Airport  | KSAC Wind Speed              | NOAA-KSAC                 | WeatherTypeName=wspdi; PointType=wind_mph                                           | mph         | Source observation time                               |

| Source System                            | Meter                                 | Measurement                  | Device / Station       | Channel / Source Fields                                                                                    | Unit | Timestamp Convention                                                             |
|------------------------------------------|---------------------------------------|------------------------------|------------------------|------------------------------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| KSMF observations and forecast           | KSMF Sacramento International Airport | KSMF Outside Air Temperature | AERIS-KSMF-OBS         | WeatherTypeName=tempF; PointType=tempF                                                                     | degF | Observation and forecast valid times remain separate                             |
| KSMF observations and forecast           | KSMF Sacramento International Airport | KSMF Forecast Temperature    | AERIS-KSMF-FORECAST    | WeatherTypeName=tempF; PointType=tempF                                                                     | degF | Observation and forecast valid times remain separate                             |
| Science Center laboratory sensors        | Science Center Lab Environment        | Lab Air Temperature          | SPINWAVE-SCIENCE-LAB   | Device Address=SW-SCI-LAB-01; Channel Number=1; PointType=temp_f                                           | degF | Source timestamp                                                                 |
| Science Center laboratory sensors        | Science Center Lab Environment        | Lab Relative Humidity        | SPINWAVE-SCIENCE-LAB   | Device Address=SW-SCI-LAB-01; Channel Number=2; PointType=relative_humidity                                | pct  | Source timestamp                                                                 |
| Cedar Row A water export                 | Cedar Row A Water Master              | Delivered kgal 60m           | FIG-CEDAR-ROW          | Point Alias=FIG_CEDAR_ROW_A_WATER; Channel=01; UOM=kgal; Multiplier=1; OffsetTimeMinutes=0; PointType=kgal | kgal | Source timestamp with configured offset                                          |
| Central plant chiller controller         | Central Plant Chiller Controller      | Chiller Demand kW 5m         | NTP-MODBUS-CHILLER     | Register Type=Floating Point MSR First; Register Address=40001; Multiplier=1; Offset=0; PointType=kW       | kW   | Poll time                                                                        |
| Library historian                        | Library Electric Historian            | Historian Delivered kWh 15m  | ODBC-LIBRARY-HISTORIAN | SourceTable=SyntheticIntervalReadings; PointType=kWh                                                       | kWh  | Source timestamp and cursor                                                      |
| Student Center commissioning test signal | Student Center Fake Gateway Smoke     | Fake Gateway Smoke kWh 15m   | FAKE-SMOKE             | GenerationMode=sinusoidal; MinValue=12; MaxValue=36; PeriodMinutes=1440; Seed=104729; PointType=kWh        | kWh  | Generated time; excluded from customer consumption totals                        |
| Cedar Row B water route                  | Cedar Row B Water Master              | Route Usage kgal             | NEPTUNE-RCU-CEDAR-B    | Route ID=660004; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=1200; PointType=kgal                   | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                    | Meter                         | Measurement        | Device / Station        | Channel / Source Fields                                                                                     | Unit   | Timestamp Convention                                                             |
|----------------------------------|-------------------------------|--------------------|-------------------------|-------------------------------------------------------------------------------------------------------------|--------|----------------------------------------------------------------------------------|
| Student Center gas route         | Student Center Kitchen Gas    | Route Usage Therms | MVRS-SGU-STUDENT-CENTER | Route ID=650004; TextPrompt=THRM; UN_Units=CurRead; MeterConstant=1; LastReadingValue=800; PointType=therms | therms | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Fixed-network electric submeters | Cedar Row A Electric House    | Submeter kWh 60m   | FIG-CEDAR-ROW-A-UNITS   | Point Alias=FN_CRA_HOUSE_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh           | kWh    | Source timestamp                                                                 |
| Fixed-network electric submeters | Cedar Row A Unit 101 Electric | Submeter kWh 60m   | FIG-CEDAR-ROW-A-UNITS   | Point Alias=FN_CRA_101_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh             | kWh    | Source timestamp                                                                 |
| Fixed-network electric submeters | Cedar Row A Unit 102 Electric | Submeter kWh 60m   | FIG-CEDAR-ROW-A-UNITS   | Point Alias=FN_CRA_102_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh             | kWh    | Source timestamp                                                                 |
| Fixed-network electric submeters | Cedar Row A Unit 103 Electric | Submeter kWh 60m   | FIG-CEDAR-ROW-A-UNITS   | Point Alias=FN_CRA_103_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh             | kWh    | Source timestamp                                                                 |
| Fixed-network electric submeters | Cedar Row A Unit 104 Electric | Submeter kWh 60m   | FIG-CEDAR-ROW-A-UNITS   | Point Alias=FN_CRA_104_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh             | kWh    | Source timestamp                                                                 |
| Fixed-network electric submeters | Cedar Row A Unit 105 Electric | Submeter kWh 60m   | FIG-CEDAR-ROW-A-UNITS   | Point Alias=FN_CRA_105_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh             | kWh    | Source timestamp                                                                 |
| Fixed-network electric submeters | Cedar Row A Unit 106 Electric | Submeter kWh 60m   | FIG-CEDAR-ROW-A-UNITS   | Point Alias=FN_CRA_106_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh             | kWh    | Source timestamp                                                                 |
| Fixed-network electric submeters | Cedar Row A Unit 107 Electric | Submeter kWh 60m   | FIG-CEDAR-ROW-A-UNITS   | Point Alias=FN_CRA_107_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh             | kWh    | Source timestamp                                                                 |
| Fixed-network electric submeters | Cedar Row A Unit 108 Electric | Submeter kWh 60m   | FIG-CEDAR-ROW-A-UNITS   | Point Alias=FN_CRA_108_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh             | kWh    | Source timestamp                                                                 |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                         | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|-------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row A Unit 109 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_109_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 110 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_110_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 111 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_111_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 112 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_112_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 113 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_113_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 114 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_114_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 115 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_115_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 116 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_116_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 117 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_117_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 118 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_118_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 119 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_119_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                         | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|-------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row A Unit 120 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_120_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 201 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_201_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 202 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_202_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 203 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_203_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 204 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_204_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 205 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_205_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 206 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_206_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 207 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_207_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 208 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_208_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 209 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_209_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 210 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_210_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                         | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|-------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row A Unit 211 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_211_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 212 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_212_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 213 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_213_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 214 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_214_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 215 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_215_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 216 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_216_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 217 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_217_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 218 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_218_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 219 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_219_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 220 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_220_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 301 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_301_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                         | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|-------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row A Unit 302 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_302_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 303 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_303_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 304 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_304_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 305 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_305_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 306 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_306_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 307 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_307_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 308 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_308_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 309 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_309_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 310 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_310_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 311 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_311_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 312 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_312_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                           | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|---------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row A Unit 313 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_313_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 314 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_314_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 315 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_315_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 316 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_316_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 317 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_317_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 318 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_318_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 319 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_319_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row A Unit 320 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-A-UNITS | Point Alias=FN_CRA_320_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Electric House    | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_HOUSE_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 101 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_101_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 102 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_102_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh   | kWh  | Source timestamp     |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                         | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|-------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row B Unit 103 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_103_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 104 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_104_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 105 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_105_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 106 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_106_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 107 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_107_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 108 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_108_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 109 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_109_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 110 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_110_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 111 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_111_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 112 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_112_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 113 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_113_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                         | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|-------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row B Unit 114 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_114_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 115 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_115_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 116 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_116_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 201 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_201_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 202 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_202_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 203 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_203_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 204 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_204_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 205 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_205_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 206 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_206_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 207 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_207_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 208 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_208_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                         | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|-------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row B Unit 209 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_209_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 210 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_210_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 211 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_211_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 212 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_212_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 213 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_213_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 214 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_214_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 215 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_215_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 216 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_216_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 301 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_301_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 302 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_302_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 303 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_303_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                         | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|-------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row B Unit 304 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_304_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 305 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_305_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 306 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_306_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 307 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_307_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 308 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_308_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 309 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_309_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 310 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_310_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 311 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_311_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 312 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_312_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 313 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_313_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 314 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_314_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |

| Source System                    | Meter                         | Measurement      | Device / Station      | Channel / Source Fields                                                                         | Unit | Timestamp Convention |
|----------------------------------|-------------------------------|------------------|-----------------------|-------------------------------------------------------------------------------------------------|------|----------------------|
| Fixed-network electric submeters | Cedar Row B Unit 315 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_315_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 316 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_316_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 401 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_401_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 402 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_402_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 403 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_403_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 404 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_404_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 405 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_405_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 406 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_406_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 407 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_407_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 408 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_408_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |
| Fixed-network electric submeters | Cedar Row B Unit 409 Electric | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS | Point Alias=FN_CRB_409_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp     |

| Source System                            | Meter                          | Measurement      | Device / Station          | Channel / Source Fields                                                                                  | Unit | Timestamp Convention                                                             |
|------------------------------------------|--------------------------------|------------------|---------------------------|----------------------------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Fixed-network electric submeters         | Cedar Row B Unit 410 Electric  | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS     | Point Alias=FN_CRB_410_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh          | kWh  | Source timestamp                                                                 |
| Fixed-network electric submeters         | Cedar Row B Unit 411 Electric  | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS     | Point Alias=FN_CRB_411_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh          | kWh  | Source timestamp                                                                 |
| Fixed-network electric submeters         | Cedar Row B Unit 412 Electric  | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS     | Point Alias=FN_CRB_412_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh          | kWh  | Source timestamp                                                                 |
| Fixed-network electric submeters         | Cedar Row B Unit 413 Electric  | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS     | Point Alias=FN_CRB_413_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh          | kWh  | Source timestamp                                                                 |
| Fixed-network electric submeters         | Cedar Row B Unit 414 Electric  | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS     | Point Alias=FN_CRB_414_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh          | kWh  | Source timestamp                                                                 |
| Fixed-network electric submeters         | Cedar Row B Unit 415 Electric  | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS     | Point Alias=FN_CRB_415_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh          | kWh  | Source timestamp                                                                 |
| Fixed-network electric submeters         | Cedar Row B Unit 416 Electric  | Submeter kWh 60m | FIG-CEDAR-ROW-B-UNITS     | Point Alias=FN_CRB_416_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh          | kWh  | Source timestamp                                                                 |
| Fixed-network electric submeters         | Lakeview Hall Laundry Electric | Submeter kWh 60m | FIG-CAMPUS-SUBMETERS      | Point Alias=FN_LAKEVIEW_LAUNDRY_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh | kWh  | Source timestamp                                                                 |
| Fixed-network electric submeters         | Parking Structure EV Chargers  | Submeter kWh 60m | FIG-CAMPUS-SUBMETERS      | Point Alias=FN_PARKING_EV_E; Channel=01; UOM=kWh; Multiplier=1; OffsetTimeMinutes=0; PointType=kWh       | kWh  | Source timestamp                                                                 |
| Cedar Row apartment water submeter route | Cedar Row A Water House        | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=660101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=300; PointType=kgal                  | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 101 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 102 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 103 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 104 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 105 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 106 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 107 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 108 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 109 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 110 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 111 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 112 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 113 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 114 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 115 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 116 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 117 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661171; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 118 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661181; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 119 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661191; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 120 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=661201; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 201 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 202 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 203 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 204 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 205 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 206 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 207 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 208 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 209 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 210 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 211 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 212 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 213 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 214 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 215 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 216 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 217 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662171; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 218 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662181; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 219 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662191; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 220 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=662201; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 301 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 302 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 303 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 304 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 305 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 306 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 307 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 308 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 309 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 310 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 311 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 312 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 313 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 314 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row A Unit 315 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 316 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 317 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663171; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 318 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663181; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 319 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663191; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row A Unit 320 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-A-UNITS | Route ID=663201; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Water House    | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=670101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=300; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 101 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 102 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 103 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 104 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 105 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 106 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 107 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 108 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 109 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 110 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 111 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 112 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 113 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 114 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 115 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 116 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=671161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 201 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 202 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 203 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 204 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 205 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 206 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 207 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 208 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 209 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 210 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 211 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 212 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 213 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 214 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 215 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 216 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=672161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 301 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 302 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 303 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 304 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 305 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 306 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 307 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 308 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 309 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 310 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 311 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 312 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 313 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 314 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 315 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 316 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=673161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 401 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674011; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 402 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674021; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 403 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674031; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 404 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674041; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 405 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674051; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 406 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674061; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 407 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674071; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 408 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674081; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 409 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674091; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 410 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674101; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 411 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674111; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |

| Source System                            | Meter                      | Measurement      | Device / Station          | Channel / Source Fields                                                                 | Unit | Timestamp Convention                                                             |
|------------------------------------------|----------------------------|------------------|---------------------------|-----------------------------------------------------------------------------------------|------|----------------------------------------------------------------------------------|
| Cedar Row apartment water submeter route | Cedar Row B Unit 412 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674121; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 413 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674131; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 414 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674141; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 415 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674151; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |
| Cedar Row apartment water submeter route | Cedar Row B Unit 416 Water | Route Usage kgal | NEPTUNE-CEDAR-ROW-B-UNITS | Route ID=674161; TextPrompt=KGAL; MeterConstant=1; LastReadingValue=120; PointType=kgal | kgal | Actual reading timestamp; monthly is a cadence rather than a fixed 30-day period |