

Users's Manual for CPU Simulators

Brent Seidel
Phoenix, AZ

July 2, 2026

This document is ©2024 Brent Seidel. All rights reserved.

Note that this is a draft version and not the final version for publication.

Contents

1	Introduction	5
1.1	Disclaimer	5
1.2	License	5
2	How To Obtain	6
2.1	Dependencies	6
2.1.1	Ada Libraries	6
2.1.2	Other Libraries	7
3	Usage Instructions	8
3.1	Using Alire	8
3.2	Using gprbuild	8
4	API Description	9
4.1	General	9
4.1.1	Numerical Data Types	9
4.1.2	Enumeration Data Types	9
4.1.3	The CPU Objects	10
4.1.4	The Bus Objects	11
4.1.5	The I/O Objects	17
4.1.6	Loading Data to Memory	18
4.1.7	Running a Simulation	18
4.1.8	Variants	19
4.1.9	Other	20
4.2	Example	20
4.3	8080 Family	20
4.4	68000 Family	20
4.5	6502 Family	21
4.6	PDP-11 Family	21
5	I/O Devices	22
5.1	Clock	23
5.2	Serial Ports	23
5.2.1	Basic Serial Port	23
5.2.2	Single Line Telnet Port	23

5.2.3	Multi-Line Telnet Port	23
5.2.4	Tape	23
5.3	Disk Interfaces	23
6	Command Line Interface	25
6.1	Device Names	25
6.2	Commands	26
6.2.1	Attach Command	27
6.2.2	CPU Command	28
6.2.3	Disk Commands	28
6.2.4	Interrupt Commands	29
6.2.5	Set Commands	29
6.2.6	Tape Commands	30
6.2.7	Printer Commands	30
6.3	Lisp Programming	30
6.3.1	Attach	30
6.3.2	Disk-Close	31
6.3.3	Disk-Geom	31
6.3.4	Disk-Open	31
6.3.5	Go	32
6.3.6	Halted	32
6.3.7	Int-state	32
6.3.8	Last-out-addr	33
6.3.9	Last-out-data	33
6.3.10	Memb	33
6.3.11	Meml	34
6.3.12	Memw	34
6.3.13	Num-reg	34
6.3.14	Override-in	34
6.3.15	Print-Close	35
6.3.16	Print-Open	35
6.3.17	Reg-val	35
6.3.18	Send-int	36
6.3.19	Set-pause-char	36
6.3.20	Set-pause-count	36
6.3.21	Sim-CPU	37
6.3.22	Sim-init	37
6.3.23	Sim-load	37
6.3.24	Sim-step	38
6.3.25	Tape-Close	38
6.3.26	Tape-Open	38
6.3.27	Examples	38
	Bibleography	40

Chapter 1

Introduction

This project includes simulators for some existing processors. It can be embedded into other code as a library, or used stand-alone with a command line interpreter. The intent of these simulators are to provide instruction level simulation and not hardware level. Generally, no attempt has been made to count clock cycles - instructions may not even take the same relative amount of time to execute.

Interfaces are provided to allow the simulator to be controlled by and display data on a simulated control panel (see the Pi-Mainframe (<https://github.com/BrentSeidel/Pi-Mainframe>) project. These may be stubbed out or ignored if not needed.

1.1 Disclaimer

I have tried to make the documentation and software as accurate as possible. However, it is inevitable that errors exist. Should you find an error, feel free to write an issue on the GitHub project and I will look at it. For software errors especially, please provide information as to what change is needed. If you would like some particular hardware added, feel free to request that as well. Note that this is a hobby project maintained by one person who has other demands on their time.

1.2 License

This project is licensed using the GNU General Public License V3.0. Should you wish other licensing terms, contact the author.

THE SOFTWARE IS PROVIDED "AS IS", WITHOUT WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE AND NONINFRINGEMENT. IN NO EVENT SHALL THE AUTHORS BE LIABLE FOR ANY CLAIM, DAMAGES OR OTHER LIABILITY, WHETHER IN AN ACTION OF CONTRACT, TORT OR OTHERWISE, ARISING FROM, OUT OF OR IN CONNECTION WITH THE SOFTWARE OR THE USE OR OTHER DEALINGS IN THE SOFTWARE.

Chapter 2

How To Obtain

This package is currently available on GitHub at <https://github.com/BrentSeidel/Sim-CPU>

2.1 Dependencies

2.1.1 Ada Libraries

The following Ada packages are used:

- `Ada.Calendar`
- `Ada.Characters.Latin_1`
- `Ada.Containers.Indefinite_Ordered_Maps`
- `Ada.Direct_IO`
- `Ada.Exceptions`
- `Ada.Integer_Text_IO`
- `Ada.Streams`
- `Ada.Strings.Fixed`
- `Ada.Strings.Maps.Constants`
- `Ada.Strings.Unbounded`
- `Ada.Text_IO`
- `Ada.Text_IO.Unbounded_IO`
- `Ada.Unchecked_Conversion`

2.1.2 Other Libraries

This library depends on the root package BBS available at <https://github.com/BrentSeidel/BBS-Ada> or using alire via “`alr get bbs`” and the BBS.Lisp package available at <https://github.com/BrentSeidel/Ada-Lisp> or using alire via “`alr get bbs_lisp`”.

Chapter 3

Usage Instructions

3.1 Using Alire

Alire automatically handles dependencies. To use this in your project, just issue the command “**alr with bbs_simcpu**” in your project directory. To build the standalone CLI program, first obtain the cli using “**alr get simcpucli**”. Change to the appropriate directory and use “**alr build**” and “**alr run**”. To use the load CP/M program, use “**alr get loadcpm**”. Change to the appropriate directory and use “**alr build**” and “**alr run**”.

3.2 Using gprbuild

This is a library of routines intended to be used by some program. To use these in your program, edit your *.gpr file to include a line to **with** the path to **bbs_simcpu_noalr.gpr**. Then in your Ada code **with** in the package(s) you need and use the routines.

This is also available as a standalone program with a command line interface (CLI). This can be used for development or debugging. To build the CLI, just build the **simcli_noalr.gpr** project file, after making sure that the dependencies are in the expected places.

There is another program **loadcpm** available to create a bootable CP/M floppy disk image. It is build using the **loadcpm_noalr.gpr** project. It takes an Intel hex file image and writes it to a floppy disk image.

Chapter 4

API Description

4.1 General

Several simulators are available for use. Each simulator may also have variation. So, one simulator may provide variations for different processors in a family of processors.

Each simulator is based on an object that derives from the `simulator` object defined in the `BBS.Sim_CPU` package. A generic simulator interface is defined with some procedures or functions that must be defined by a specific simulator and some that may be defined, if needed. There are also a number of utility functions that are not expected to be overridden by a specific simulator.

The current design has memory included in the simulator instead of being an external device. Any I/O decoding is also handled inside the simulator. This means that any reading and writing of memory has to be done via routines defined by the simulator.

4.1.1 Numerical Data Types

Currently, processors with address and data busses up to 32 bits wide are supported. For the address bus, use the data type `addr_bus` and for the data bus, use `data_bus`. These are both defined as a 32 bit unsigned integer. Each simulator may use as many or as few of these bits as are needed. This means that if (as in most cases) a simulator doesn't define a full 4 GB of memory, the external program can try to read or write non-existent memory. This will probably cause an exception.

4.1.2 Enumeration Data Types

The `proc_mode` enumeration is used to indicate the processor mode. Not all modes will be used by any given processor and the meanings are processor specific. Any of these modes could be used by a processor that doesn't define multiple modes. The defined modes are:

- *PROC_NONE* - Unspecified processor mode.
- *PROC_KERN* - Kernel mode. This is usually the most privileged mode.
- *PROC_EXEC* - Executive mode. This is a little less privileged.

- *PROC_SUP* - Supervisor mode. This is a little less privileged.
- *PROC_USER* - User mode. This is usually the least privileged mode.

The *addr_type* enumeration is used to indicate the type of memory access. They may be used for controlling access to memory. The defined types are:

- *ADDR_NONE* - Unspecified address type.
- *ADDR_INTR* - Reading interrupt data, typically an interrupt vector.
- *ADDR_DATA* - Reading or writing data.
- *ADDR_INS* - Reading instructions (probably not writing).
- *ADDR_IO* - Reading or writing to I/O ports for processors that have separate I/O addresses.

The *bus_type* enumeration defines the type of bus for attaching I/O devices and bus accesses. This can either be the I/O bus (for processors with separate I/O space) or the memory bus for memory and memory mapped I/O. The defined busses are:

- *BUS_MEMORY* - Use the memory bus.
- *BUS_IO* - Use the I/O bus

The *bus_stat* enumeration is used for reporting the result of a bus transaction. The defined results are:

- *BUS_SUCC* - The transaction succeeded. This is the result that you hope you get.
- *BUS_NONE* - Nothing exists at this address. Either uninstalled memory or non-existent I/O device.
- *BUS_PROT* - A protection violation occurred. This is typically reported by a memory management unit when the *proc_mode* doesn't match the required level for the address.
- *BUS_PARITY* - A parity error occurred during the bus transaction. This would usually be used for testing error handlers.
- *BUS_ECC1* - A correctable ECC error occurred during the bus transaction. This would usually be used for testing error handlers.
- *BUS_ECC2* - An uncorrectable ECC error occurred during the bus transaction. This would usually be used for testing error handlers

4.1.3 The CPU Objects

The CPU object is responsible for executing instructions. Generally before using a simulator, it must be initialized, a variant selected, and a bus attached. However this is all implementation dependent.

To initialize the CPU, use:

```
procedure init(self : in out simulator) is abstract;
```

- **self** - The simulator object to initialize.

To select a CPU variant, use:

```
procedure variant(self : in out simulator; v : Natural) is abstract;
```

- **self** - The simulator object to initialize.
- **v** - The index of the variant to use. This value is defined by the specific CPU object.

Attaching a bus to a CPU also requires attaching the cpu to the bus. This gives both the CPU and the bus object a reference to each other. The routine to attach a bus to a CPU automatically calls the routine to attach the CPU the bus. To attach a bus, use (note that this is declared as null since some CPUs may not need this and thus they won't have to create a null implementation):

```
procedure attach_bus(self : in out simulator;  
                    bus : BBS.Sim_CPU.bus.bus_access;  
                    index : Natural) is Null;
```

- **self** - The simulator object to initialize.
- **bus** - The bus object to attach.
- **index** - The CPU index. Expected to be used for future multi-CPU simulations. Currently unused by all defined bus objects.

4.1.4 The Bus Objects

This bus object contains the memory for the CPU and interfaces with the I/O devices. Once the bus object is created, the main action a host program needs to do is to attach I/O devices.

```
procedure attach_io(self : in out bus;  
                   io_dev : BBS.Sim_CPU.io.io_access;  
                   base_addr : addr_bus;  
                   which_bus : bus_type) is abstract;
```

- **self** - The bus object to initialize.
- **io_dev** - The I/O device object to attach to the bus.
- **base_addr** - The base address to use to access the device registers.
- **which_bus** - One of the defined **bus_type** values.

The bus object provides routines for accessing memory by physical or logical addresses. In some cases these will be identical. When some sort of address translation is provided, such as bank switching or a full MMU, they may be different. All memory access routines provide a **status** parameter that contains the **bus_state** the status of the operation. If **status** is not *BUS_SUCC*, the operation did not complete and any data returned by a read operation should be ignored.

To read from physical memory, use:

```
function readp(self : in out bus; addr : addr_bus; status : out bus_stat)
    return data_bus is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **status** - the **bus_status** result of the operation.
- Returns the value at the specified address.

To write to physical memory, use:

```
procedure writep(self : in out bus; addr : addr_bus; data: data_bus;
    status : out bus_stat) is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **data** - The value to write to memory.
- **status** - the **bus_status** result of the operation.

To read from logical memory, use:

```
function readl(self : in out bus; addr : addr_bus; mode : proc_mode;
    addr_kind : addr_type; status : out bus_stat)
    return data_bus is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **mode** - The **proc_mode** for the operation.
- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.
- Returns the value at the specified address.

To write to logical memory, use:

```
procedure writel(self : in out bus; addr : addr_bus; data: data_bus;
    mode : proc_mode; addr_kind : addr_type;
    status : out bus_stat) is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.

- **data** - The value to write to memory.
- **mode** - The **proc_mode** for the operation.
- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.

For reading from logical memory in bytes, words, and long words in LSB first or MSB first format, the following are provided:

LSB First:

```
function readl8l(self : in out bus; addr : addr_bus; mode : proc_mode;  
                addr_kind : addr_type; status : out bus_stat)  
    return byte is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **mode** - The **proc_mode** for the operation.
- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.
- Returns the **byte** at the specified address.

```
function readl16l(self : in out bus; addr : addr_bus; mode : proc_mode;  
                 addr_kind : addr_type; status : out bus_stat)  
    return word is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **mode** - The **proc_mode** for the operation.
- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.
- Returns the **word** at the specified address with LSB first.

```
function readl32l(self : in out bus; addr : addr_bus; mode : proc_mode;  
                 addr_kind : addr_type; status : out bus_stat)  
    return long is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.

- **mode** - The **proc_mode** for the operation.
- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.
- Returns the **long** at the specified address with LSB first.

MSB First:

```
function readl8m(self : in out bus; addr : addr_bus; mode : proc_mode;  
                addr_kind : addr_type; status : out bus_stat)  
    return byte is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **mode** - The **proc_mode** for the operation.
- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.
- Returns the **byte** at the specified address (this is the same as readl8l).

```
function readl16m(self : in out bus; addr : addr_bus; mode : proc_mode;  
                 addr_kind : addr_type; status : out bus_stat)  
    return word is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **mode** - The **proc_mode** for the operation.
- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.
- Returns the **word** at the specified address with MSB first.

```
function readl32m(self : in out bus; addr : addr_bus; mode : proc_mode;  
                 addr_kind : addr_type; status : out bus_stat)  
    return long is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **mode** - The **proc_mode** for the operation.

- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.
- Returns the **long** at the specified address with MSB first.

For writing to logical memory in bytes, words, and long words in LSB first or MSB first format, the following are provided:

LSB first:

```
procedure writel8l(self : in out bus; addr : addr_bus;  
                  data: byte; mode : proc_mode;  
                  addr_kind : addr_type; status : out bus_stat) is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **data** - The **byte** to write to memory.
- **mode** - The **proc_mode** for the operation.
- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.

```
procedure writel16l(self : in out bus; addr : addr_bus;  
                   data: byte; mode : proc_mode;  
                   addr_kind : addr_type; status : out bus_stat) is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **data** - The **word** to write to memory (LSB first).
- **mode** - The **proc_mode** for the operation.
- **addr_kind** - The **addr_type** for the operation.
- **status** - the **bus_status** result of the operation.

```
procedure writel32l(self : in out bus; addr : addr_bus;  
                   data: byte; mode : proc_mode;  
                   addr_kind : addr_type; status : out bus_stat) is abstract;
```

- **self** - The bus object to access.
- **addr** - The memory address to read.
- **data** - The **long** to write to memory (LSB first).

- `mode` - The `proc_mode` for the operation.
- `addr_kind` - The `addr_type` for the operation.
- `status` - the `bus_status` result of the operation.

MSB first:

```
procedure writel8m(self : in out bus; addr : addr_bus;  
                  data: byte; mode : proc_mode;  
                  addr_kind : addr_type; status : out bus_stat) is abstract;
```

- `self` - The bus object to access.
- `addr` - The memory address to read.
- `data` - The `byte` to write to memory.
- `mode` - The `proc_mode` for the operation.
- `addr_kind` - The `addr_type` for the operation.
- `status` - the `bus_status` result of the operation.

```
procedure writel16m(self : in out bus; addr : addr_bus;  
                   data: byte; mode : proc_mode;  
                   addr_kind : addr_type; status : out bus_stat) is abstract;
```

- `self` - The bus object to access.
- `addr` - The memory address to read.
- `data` - The `word` to write to memory (MSB first).
- `mode` - The `proc_mode` for the operation.
- `addr_kind` - The `addr_type` for the operation.
- `status` - the `bus_status` result of the operation.

```
procedure writel32m(self : in out bus; addr : addr_bus;  
                   data: byte; mode : proc_mode;  
                   addr_kind : addr_type; status : out bus_stat) is abstract;
```

- `self` - The bus object to access.
- `addr` - The memory address to read.
- `data` - The `long` to write to memory (MSB first).
- `mode` - The `proc_mode` for the operation.
- `addr_kind` - The `addr_type` for the operation.
- `status` - the `bus_status` result of the operation.

4.1.5 The I/O Objects

I/O objects are used to simulate various I/O devices. From the viewpoint of a CPU, an I/O device consists of a contiguous range of addresses for the device registers on either the memory or I/O bus. These device registers are used to interface with and control the device. Once a device has been attached to a bus, the CPU may communicate with it via the device registers.

If a device uses interrupts, the owning CPU must be set along with an exception code. If a device uses DMA, the owning CPU must be specified (note that this may change to be the bus that the device is attached to).

To set the owning CPU, use:

```
procedure setOwner(self : in out io_device;  
                  owner : BBS.Sim_CPU.CPU.sim_access);
```

- **self** - The I/O object to access.
- **owner** - The CPU object for the owning CPU.

To set the exception code, use:

```
procedure setException(self : in out io_device;  
                      except : long) is abstract;
```

- **self** - The I/O object to access.
- **except** - The exception code to use. The interpretation of this code depends on the specific CPU.

To write to the device use:

```
procedure write(self : in out io_device; addr : addr_bus;  
               data : data_bus) is abstract;
```

- **self** - The I/O object to access.
- **addr** - The address of the device register to access.
- **data** - The data to write to the device register.

To read from the device use:

```
function read(self : in out io_device; addr : addr_bus)  
            return data_bus is abstract;
```

- **self** - The I/O object to access.
- **addr** - The address of the device register to access.
- Returns the value from the specified device register.

4.1.6 Loading Data to Memory

The main routines for reading and writing simulator memory are:

Called to set a memory value.

```
procedure set_mem(self : in out simulator;  
                 mem_addr : addr_bus;  
                 data : data_bus) is abstract;
```

- **self** - The simulator owning the memory to set.
- **mem_addr** - The memory address. This is allowed to be a 32 bit value. The simulator itself may do range limiting or wrapping (eg. only low order 16 bits are used) internally.
- **data** - The data value to write into the memory address. This is allowed to be a 32 bit value. The simulator decides how to handle this value and what value actually gets written.

Called to read a memory value.

```
function read_mem(self : in out simulator;  
                 mem_addr : addr_bus) return  
data_bus is abstract;
```

- **self** - The simulator owning the memory to read.
- **mem_addr** - The memory address. This is allowed to be a 32 bit value. The simulator itself may do range limiting or wrapping (eg. only low order 16 bits are used) internally.
- Returns the value of memory at the specified memory address.

The actual addressing and data bus used are defined by the specific simulator.

For loading bulk data into memory use:

```
procedure load(self : in out simulator; name : String)  
is null;
```

Its implementation is defined by the simulator. Typically it loads an Intel Hex file or Motorola S-Record file representing a memory image.

4.1.7 Running a Simulation

The **start** procedure is called first to specify a starting address for program execution. This is called to start simulator execution at a specific address. This is made null rather than abstract so that simulators that don't use it don't need to override it.

```
procedure start(self : in out simulator; addr : addr_bus) is null;
```

Then, each instruction is individually executed using the **run** procedure. This is called once per frame when start/stop is in the start position and run/pause is in the run position.

```
procedure run(self : in out simulator) is abstract;
```

Certain conditions or instruction can cause a simulator to halt. The `halted` and `continue_proc` routines can be used to test for this condition and clear it.

Check if simulator is halted. If a simulator doesn't define this, it will return *False*.

```
function halted(self : in out simulator) return Boolean is (False);
```

This clears the halted flag allowing processing to continue. If a simulator doesn't define this, it has no action.

```
procedure continue_proc(self : in out simulator) is null;
```

From all of this, one can write the core of a simulator as follows:

```
—
—  A bunch of other stuff including defining some
—  simulator as "sim"
—
begin
  sim.init;
  —
  —  I/O devices can be added here...
  —
  sim.load("image.hex");
  sim.start(0); — Start execution at address 0
  while not sim.halted loop
    sim.run;
  end loop;
end
```

4.1.8 Variants

Each simulator can support variants. This enables one simulator to support multiple CPUs in a family. Since the variants supported are unique to each simulator a universal data type cannot be used. Variants are identified by a **Natural** number. The following routines are used to get the number of variants supported by a simulator, the name of each variant, the currently selected variant, and to select a variant:

Called to get number of variants. This defaults to returning one if the simulator doesn't define an alternative.

```
function variants(self : in out simulator) return Natural is (1);
```

Called to get variant name. This needs to be overridden by the simulator.

```
function variant(self : in out simulator; v : Natural)
  return String is abstract;
```

Called to get current variant index. This needs to be overridden by the simulator.

```
function variant(self : in out simulator) return Natural is abstract;
```

Called to set variant. This needs to be overridden by the simulator.

```
procedure variant(self : in out simulator; v : Natural) is abstract;
```

4.1.9 Other

A number of other functions are defined to support I/O devices, interfaces with a front panel, and other things. The I/O support routines will be discussed more in chapter 5 on I/O devices.

4.2 Example

The example simulator provides an example of using the simulator object interface. Its primary purpose is to blink the lights in interesting ways in the Pi-Mainframe (<https://github.com/BrentSeidel/Pi-Mainframe>) project. There are a number of different patterns selectable. Variants are defined for “Copy Switches”, “Count”, “16-Bit Scan”, “16-Bit Bouncer”, “Fibonacci Counter”, “32-Bit Scan”, and “32-Bit Bouncer”.

This simulator is unusual in that it has no memory defined, but instead has several registers defined that act as memory. When reading or writing memory, the address is ignored and the value returned depends on the pattern (variant) selected.

4.3 8080 Family

The 8080 simulator has variants defined for the 8080, 8085, and Z-80 processors. These are 8 bit processors with an 8 bit data bus and a 16 bit address bus. In addition to a memory bus, these processors also include an I/O bus with 8 bit I/O port addressing. See [3] for more information about the 8080/8085. See [8] and [7] for more information about the Z-80.

Currently, the 8080 family does not have memory mapped I/O. This may be added at some time in the future.

When loading data using the `load` routine, the specified file is assumed to be in Intel Hex format.

4.4 68000 Family

The 68000 simulator has variants defined for the 68000, 68008, 68010, and CPU32. Only the 68000 and 68008 are currently implemented. The 68010 and CPU32 are for future development. Internally, these are 32 bit processors with 32 bit data and 32 bit address busses. These processors do not have a separate I/O address space. All I/O is mapped as part of the main memory. The external address and data bus sizes depend on the variant selected. See [4] and [5] for more information about the 68000 family.

The interrupt code is interpreted with the low order bits (7-0) representing the vector number and the next 8 bits (15-8) representing the priority. Interrupts with vectors that match internally defined exception vectors are ignored. Thus only interrupt vectors in the range 25-31 and 64-255 are processed.

When loading data using the `load` routine, the specified file is assumed to be in Motorola S-Record format.

4.5 6502 Family

The 6502 simulator currently has only a working variants defined for the 6502 processor. This is an 8 bit processors with an 8 bit data bus and a 16 bit address bus. This processor does not have a separate I/O address space. All I/O is mapped as part of the main memory. Three interrupts are define for normal interrupts, non-maskable interrupts, and reset. See [6] for more information about the 6502.

When loading data using the `load` routine, the specified file is assumed to be in Intel Hex format.

4.6 PDP-11 Family

Most of the 16 bit addressing members are supported, except the LSI-11, PDP-11/03. Future models with memory management are planned at some point. This is a line of 16 bit minicomputers that was developed in the 1970s and was popular through the 1990s. Models with no memory management had 16 address bit. With memory management, depending on the model, addresses of 18 or 22 bits was supported. These processors do not have a separate I/O address space. All I/O is mapped as part of the main memory. By convention, all I/O is located in the upper 8kBytes of memory. See [1] and [2] for more information about the PDP-11.

A wealth of information about the PDP-11 (and other DEC hardware) is on bitsavers at <https://www.bitsavers.org/pdf/dec/>. Software can also be found on bitsavers at <https://www.bitsavers.org/bits/DEC/>. Various diagnostic software can be found using the PDP-11 Diagnostics - Database at <https://www.retrocmp.com/tools/pdp-11-diagnostic-database/202-pdp-11-diagnostics-database>.

Chapter 5

I/O Devices

Each I/O device is based on an object that derives from the `io_device` object defined in the `BBS.Sim_CPU` package. A generic I/O device interface is defined with some procedures or functions that must be defined by a specific I/O device and some that may be defined, if needed. There are also a number of utility functions that are not expected to be overridden by a specific I/O device.

To be used by a simulator, an I/O device must first be attached to the simulator using the `attach_io` routine. This is called to attach an I/O device to a simulator at a specific address. Bus is simulator dependent as some CPUs have separate I/O and memory space.

```
procedure attach_io(self : in out simulator;  
                    io_dev : io_access;  
                    base_addr : addr_bus;  
                    bus : bus_type) is abstract;
```

Many of the I/O devices will have an initialization routine specific for that device. Since this may have device specific parameters, it can't be defined as part of the `io_device` object.

Along with attaching the I/O device to the simulator, the base address needs to be set in the I/O device object. The value for `base` in this routine should match the value for `base_addr` in the `attach_io` routine. Bad things may happen if they don't match.

```
procedure setBase(self : in out io_device;  
                  base : addr_bus) is abstract;
```

The I/O device `read` and `write` functions are called by the simulator when an address within the devices address range is accessed. Note that the address range starts at the `base_addr` specified in the `attach_io` call and extends through the number of addresses specified in the `getSize` function. If needed, the simulator can query the I/O device for its base address using the `getBase` function. If a device needs to do DMA or interrupt a simulator, the `setOwner` procedure must be called first to give the device a reference to the simulator. For interrupts, the `setException` routine is used to define a `long` value that the device passes to the simulator on exception.

```
procedure setException(self : in out io_device;  
                       except : long);
```

If a device does not use interrupts, this routine can be declared as `null`.

5.1 Clock

The main function of the clock device is to provide a periodic interrupt. It can be enabled or disabled and the time between interrupts can be set in $\frac{1}{10}$ th of a second. The base time can be changed by editing the code. Note that the timing is only approximate and depends on many things. Also since the simulation is not running at the same speed as actual hardware the number of instructions between each interrupt will be different from actual hardware.

5.2 Serial Ports

Serial ports provide a way to provide a terminal interface to a simulator. Unlike real serial ports, output buffering is done by the host operating system and it is not obvious to the I/O device if the output has been completed or not. As a result, currently no status is set or interrupts generated on output. The output is assumed to complete instantly.

5.2.1 Basic Serial Port

The basic serial port was developed in early testing to send output to and get input from the terminal controlling the simulator. It worked well enough to test some initial concepts, but has been superseded by the single line telnet port.

5.2.2 Single Line Telnet Port

The single line telnet port provides a replacement for the basic serial port. This device has an `init` routine that is used to set the TCP port. Using `telnet` to connect to this port connects to the device and will allow communication with software running on the simulator. If enabled, this device can provide interrupts to the simulator when characters are received.

5.2.3 Multi-Line Telnet Port

The multi-line telnet port combines 8 ports into a single simulated device. The `init` routine specifies the starting TCP port. It and the next seven ports can be accessed by `telnet` to communicate with software running on the simulator. This uses a single exception and requires fewer addresses than having 8 single line telnet ports.

5.2.4 Tape

The “paper” tape interface is based on a serial port. From the point of view of the host program, it reads bytes and writes bytes. The read bytes come from an attached file and the written bytes are written to an attached file (note that there should be two different files). One could also imagine this as a cassette tape interface if that better fits the computer you’re simulating.

5.3 Disk Interfaces

The initial `disk_ctrl` device was designed with 8 inch floppy disks in mind for use by CP/M. It has been extended to allow other disk geometries, but follows the model of tracks, sectors per track,

and heads for defining a disk. It currently supports 16 bit DMA, but may be extended to support 32 bit DMA. All data transfers occur between the request and the next instruction processed by the simulator.

Additional disk controllers based on actual hardware have been developed to support the PDP-11 CPU. Enough of the hardware has been simulated to support the RT-11 operating system. The controllers supported here are RK11 and RK611. The TM11 tape controller is also internally treated as a disk drive. This may change in the future.

Chapter 6

Command Line Interface

The command line interface first requests which simulator to use. The choices are currently 8080 and 68000. This will change as more simulators are added. Depending on which simulator is selected, a number of I/O devices are attached to the simulator. Currently, changing this will require editing and rebuilding the program.

6.1 Device Names

Each device has a name that can be used to refer to it. The name consists of an alphabetic device code followed by a decimal unit number. If no unit number is specified, 0 is assumed. A unit number of zero is special. It is used to refer to a generic device, such as when attaching a device - the unit number is assigned during the attachment. The currently defined device codes are (note that not all are implemented in the CLI, but will eventually be):

CLK – A clock device to generate a periodic interrupt.

CON – A console serial device. In most cases, this should not be used.

FD – Main disk controller with a track and sector interface. It started out as a floppy disk controller, but geometries can be defined beyond that.

HD – An experimental disk controller using just block numbers. It is not yet implemented and tested.

MUX – An 8 channel terminal multiplexer using a telnet interface.

PRN – A simple printer output device.

PTP – A paper tape interface. It can read and write simulated tapes.

TEL – A single channel terminal device using a telnet interface.

The following devices simulate actual hardware for PDP-11 computers.

DL11 – A single line serial interface.

KW11 – A clock for the PDP-11 series of computer.

RK11 – A disk controller that can have up to 8 attached RK05 simulated drives.

RK611 – A disk controller than can have up to 8 attached RK07 simulated drives (RK06 drives are not supported).

PC11 – A combination paper tape reader/punch.

MT11 – A magnetic tape controller that can have up to 8 attached tape drives. Note that this is internally treated as a disk drive so use the disk command to control it.

6.2 Commands

A number of commands are provided to allow the user to run and interact with software running on the simulator. The commands and their exact operation may change depending on feedback from usage. All commands may be abbreviated to the first 4 character. Some may be abbreviated further.

; – A comment. Everything following on the line is ignored, except if the rest of the line is being used as a file name.

ATTACH **<device>** **<addr>** **<bus>** [**<dev-specific>**] – Attaches a specific I/O device at the bus address. Depending on the device, device specific parameters may be required.

BREAK **<addr>** – Sets a breakpoint at the specified address.

CONTINUE – Clear a simulation halted condition. This can be abbreviated to **C**.

CPU **<cpu-name>** – Set the CPU to be simulated. This can only be done once per session and must be done before any command that requires a CPU.

DEP **<addr>** **<byte>** – Deposit a byte into memory.

DISK – Commands related to floppy disks and image files (see below for more details).

DUMP **<addr>** – Dump a block of memory starting at the specified address. This can be abbreviated to **D**.

EXIT – Exit the simulation (synonym for **QUIT**).

GO **<addr>** – Sets the execution address.

INTERRUPT – Can be abbreviated to **INT**. Used to enable or disable interrupt processing by the simulated CPU.

LISP [**<filename>**] – Starts the Tiny-Lisp environment. If a filename is specified, Lisp commands come from that file.

LIST [**<devname>**] – Lists all the I/O devices attached to the simulator. If **<devname>** is supplied, it provides information for that specific device.

LOAD <filename> – Loads memory with the specified file (typically Intel Hex or S-Record format).

TAPE – Commands relating to printer and attached file (see below for more details).

QUIT – Exit the simulation (synonym for **EXIT**).

REG – Display the registers and their contents.

RESET – Calls the simulator's `init` routine.

RUN – Runs the simulator. While running, it can be interrupted by a control-E character. This can be abbreviated to **R**.

SET – Sets certain simulator options.

STEP – Execute a single instruction, if the simulation is not halted.

TAPE – Commands relating to paper (or cassette) tape and attached files (see below for more details).

TRACE <value> – Sets the trace value. The value is interpreted by the simulator and typically causes certain information to be printed while processing.

UNBREAK <addr> – Clears a breakpoint at the specified address. For some simulators, the address is ignored and may not need to be specified. In this case, all or the only breakpoint is cleared.

6.2.1 Attach Command

The attach command is used to attach a device to the current CPU simulator. The device is specified as a generic device name. The address is given in decimal. The bus is:

IO – Use the I/O bus (only available on some CPUs).

MEM – Use memory mapped I/O (only available on some CPUs).

Some of the devices take additional parameters.

CLK – Takes one additional decimal value for the exception code to be presented to the CPU when an interrupt occurs.

DL11 – Takes two additional decimal parameters. The first is the TCP/IP port for the first terminal (the additional terminals are assigned sequential port numbers). The second is a 32 bit integer combination of two exception codes to be presented to the CPU when an interrupt occurs. The lower order 16 bits are the receive vector and the upper 16 bits are the transmit vector.

FD – Takes one additional decimal parameter for the number of attached drives in the range 0-15, though 0 drives is rather pointless.

HD – Not yet implemented for ATTACH (experimental - under development).

KW11 – Takes one additional decimal value for the exception code to be presented to the CPU when an interrupt occurs.

MUX – Takes two additional decimal parameters. The first is the TCP/IP port for the first terminal (the additional terminals are assigned sequential port numbers). The second is the exception code to be presented to the CPU when an interrupt occurs.

PC11 – Takes one additional parameter. It is a 32 bit integer combination of two exception codes to be presented to the CPU when an interrupt occurs. The lower order 16 bits are the receive vector and the upper 16 bits are the transmit vector.

PRN – Takes no additional parameters.

PTP – Takes no additional parameters.

RK11 – Takes one additional decimal value for the exception code to be presented to the CPU when an interrupt occurs.

RK611 – Takes one additional decimal value for the exception code to be presented to the CPU when an interrupt occurs.

TEL – Takes two additional decimal parameters. The first is the TCP/IP port for the first terminal (the additional terminals are assigned sequential port numbers). The second is the exception code to be presented to the CPU when an interrupt occurs.

TM11 – Takes one additional decimal value for the exception code to be presented to the CPU when an interrupt occurs.

6.2.2 CPU Command

This command is deprecated. SET CPU is the preferred command.

6.2.3 Disk Commands

A number of subcommands are available for interfacing with simulated floppy disks and image files. The DISK command takes the form:

- DISK <controller> <subcommand> <parameters for subcommand>

The controller is the device name of an attached disk controller. The subcommands are:

CLOSE <drive number> – Closes the image file associated with the specified drive number.

OPEN <drive number> <file name> – Attaches the specified file to the specified drive.

READONLY <drive number> – Sets the specified drive to read-only.

READWRITE <drive number> – Sets the specified drive to read-write.

6.2.4 Interrupt Commands

A number of subcommands are available for interfacing with interrupts.

ON – Enables interrupt processing by the simulator (if supported).

OFF – Disables interrupt processing by the simulator. This may be useful for single-stepping through some code without getting interrupted by the clock or other devices.

SEND <interrupt number> – Sends the specified interrupt number to the simulator (if supported).

6.2.5 Set Commands

This allows setting of some simulator options. The current options are:

CPU – The same as the CPU command above. The following CPUs are currently defined:

8080 – The Intel 8080 processor. An 8 bit processor that can address up to 64kBytes of memory and 256 I/O ports.

8085 – Made by Intel. Very similar to the 8080 with mostly hardware enhancements, with 2 added instructions.

Z80 – Made by Zilog. It is mostly upward compatible with the 8080 (one flag is different on some instructions). The added instruction codes for the 8085 are completely different instructions on the Z80.

68000 – The Motorola 68000 processor. This is internally a 32 bit processor with a 16 bit data bus, and 24 address lines. It can address up to 16MBytes of memory.

68008 – A stripped down version of the 68000. The core is the same, but it has an 8 bit address bus and only 20 address lines.

PDP-11/04 – A version of the PDP-11 series of minicomputers. Currently, this is a placeholder.

PDP-11/05 – A version of the PDP-11 series of minicomputers.

PDP-11/10 – The same as the PDP-11/05.

PDP-11/15 – A version of the PDP-11 series of minicomputers.

PDP-11/20 – The same as the PDP-11/15.

PDP-11/34 – Under development.

PDP-11/35 – Under development.

PDP-11/40 – The same as PDP-11/40.

It is likely that more PDP-11 models will be added.

PAUSE – Sets either the pause count or the pause character. This controls how often to check for the pause/interrupt character while the simulator is running. Since the check for the character takes much longer than simulating an instruction, increasing this value can speed the simulation.

6.2.6 Tape Commands

The tape interface consists of a reader called **RDR** and a writer called **PUN** (for punch). Files can be opened or closed for either of these devices. The **TAPE** command takes the form:

- **TAPE** <controller> <subcommand> <parameters for subcommand>

The controller is the device name of an attached tape controller. The subcommands are:

CLOSE <**PUN** or **RDR**> – Closes the file attached to the reader or punch.

OPEN <**PUN** or **RDR**> <file name> – Attaches the specified file to the reader or punch.

6.2.7 Printer Commands

The printer device simply writes data sent to it to an output file. If no file is open, the data is discarded. The **PRINT** command takes the form:

- **PRINT** <controller> <subcommand> <parameters for subcommand>

The controller is the device name of an attached printer controller. The subcommands are:

CLOSE – Closes the file attached to the printer.

OPEN <file name> – Attaches the specified file to the printer.

6.3 Lisp Programming

The Lisp environment is based on Ada-Lisp, available at <https://github.com/BrentSeidel/Ada-Lisp>, with a few commands added to interface with a simulator. Refer to the Ada-Lisp documentation for details about the core language. This section just describes the additional commands.

6.3.1 Attach

Inputs

The following inputs are expected:

- A string representing the device name.
- An integer for the device address.
- A string representing the address bus used (“IO” or “MEM”).
- Additional items specific to the device may be required.

Outputs

None

Description

Attaches an I/O device at the specified address and address bus. Refer to the Attach command (section 6.2.1) for more information.

6.3.2 Disk-Close

The following inputs are expected:

- A string representing the disk controller name.
- An integer for the drive number.

Outputs

None

Description

Closes the file attached to the specified disk drive.

6.3.3 Disk-Geom

The following inputs are expected:

- A string representing the disk controller name.
- An integer for the drive number.
- A string representing the geometry (currently “IBM” for 8 inch diskettes or “HD” for a 5MB hard disk). It is planned to extend this to allow a list specifying arbitrary geometry as well.

Outputs

None

Description

Sets the disk geometry (tracks, sectors, heads) of the specified disk drive.

6.3.4 Disk-Open

The following inputs are expected:

- A string representing the disk controller name.
- An integer for the drive number.
- A string representing the file name to attach to the disk drive.

Outputs

None

Description

Opens a file and attaches it to the specified disk drive.

6.3.5 Go

Inputs

A number representing the starting address for program execution.

Outputs

None

Description

Sets the starting address for program execution. The next (**sim-step**) command executes the instruction at this location.

6.3.6 Halted

Inputs

An optional boolean that if set true, clears the halted state of the simulator. If set false, does nothing.

Outputs

If no input is provided, it returns a boolean representing the halted state,

Description

This is used to clear to test the halted state of a simulator.

6.3.7 Int-state

Inputs

None

Outputs

A simulator dependent integer representing the state of interrupts.

Description

Returns a simulator dependent integer representing the state of the interrupts. Typically it is something like 0 for interrupts disabled and 1 for interrupts enabled. For systems with priorities, it may be the processor priority.

6.3.8 Last-out-addr

Inputs

None

Outputs

The address used by the last output instruction.

Description

Returns the address used by the last output instruction. This is only meaningful if the processor being simulated has a separate output bus rather than memory mapped I/O.

6.3.9 Last-out-data

Inputs

None

Outputs

The data used by the last output instruction.

Description

The data used by the last output instruction. This is only meaningful if the processor being simulated has a separate output bus rather than memory mapped I/O.

6.3.10 Memb

Inputs

A memory address and an optional byte value.

Outputs

If no byte value is provided, it returns the byte at the memory address.

Description

Reads or writes a byte value in memory.

6.3.11 Meml

Inputs

A memory address and an optional long value.

Outputs

If no long value is provided, it returns the long at the memory address.

Description

Reads or writes a long value in memory.

6.3.12 Memw

Inputs

A memory address and an optional word value.

Outputs

If no word value is provided, it returns the word at the memory address.

Description

Reads or writes a word value in memory.

6.3.13 Num-reg

Inputs

None

Outputs

The number of registers defined by the simulator.

Description

Returns the number of registers defined by the simulator. This could be used for iterating through the registers and displaying their values.

6.3.14 Override-in

Inputs

Two integers representing the address of an I/O port and the data to provide.

Outputs

None

Description

Provides an address and data to override the next input instruction. If the instruction reads from the address, the provided data is read by the simulator instead of reading from the actual I/O device. Inputs from a different address work normally and any input instruction clears the override. This is intended for testing purposes.

6.3.15 Print-Close

The following inputs are expected:

- A string representing the printer controller name.

Outputs

None

Description

Closes the file attached to the specified printer.

6.3.16 Print-Open

The following inputs are expected:

- A string representing the printer controller name.
- A string representing the file name to attach to the printer.

Outputs

None

Description

Opens a file and attaches it to the specified printer.

6.3.17 Reg-val

Inputs

A register number

Outputs

The value of the specified register, or an error if the register number is not in range.

Description

Returns the value of the specified register.

6.3.18 Send-int

Inputs

An integer interrupt code.

Outputs

None.

Description

Sends the specified interrupt code to the simulator for processing. The processing done depends on the specific simulator. It may be ignored, be a vector number, be an instruction, or something else.

6.3.19 Set-pause-char

Inputs

An integer in the range 0-255 as the ASCII value of the pause character. Note that if you're on a system that doesn't use ASCII, then this is whatever the numerical value for the character is.

Outputs

The current pause character.

Description

Sets the pause character. Pressing this character while a simulation is running will cause the simulation to return to the command line. If no character is specified, it just returns the current pause character.

6.3.20 Set-pause-count

Inputs

A positive integer.

Outputs

The current value of the pause count.

Description

Sets the number of instructions to execute between checks for the pause character.

6.3.21 Sim-CPU

Inputs

A string containing the CPU name. See the “SET CPU” (section 6.2.5) command for valid CPU names.

Outputs

None

Description

Selects the CPU to simulate. This can only be done once and must be done before any command that attempts to access the CPU.

6.3.22 Sim-init

Inputs

None.

Outputs

None.

Description

Calls the initialization routine to the current simulator. The action is simulator dependent, but typically clears the registers. The memory may, or may not be cleared.

6.3.23 Sim-load

Inputs

A string containing a file name.

Outputs

None.

Description

Calls the load routine for the current simulator and passes the string containing the file name. The effect is simulator dependent, but the 8080 simulator will attempt to load the file as an Intel hex format file and the 68000 simulator will attempt to load the file as a Motorola S-record file. The PDP-11 simulator will load a binary file in absolute loader format.

6.3.24 Sim-step

Inputs

None.

Outputs

None.

Description

Executes one instruction or step of the simulator.

6.3.25 Tape-Close

The following inputs are expected:

- A string representing the tape controller name.
- A string representing the output (“PUN” for punch) or input (“RDR” for reader).

Outputs

None

Description

Closes the file attached to the specified tape drive unit.

6.3.26 Tape-Open

The following inputs are expected:

- A string representing the tape controller name.
- A string representing the output (“PUN” for punch) or input (“RDR” for reader).
- A string representing the file name to attach to the tape drive.

Outputs

None

Description

Opens a file and attaches it to the specified tape drive unit.

6.3.27 Examples

The Lisp environment is useful for writing automated tests and for writing utilities to enhance the CLI.

Watch a Memory Location

The following Lisp program will execute instructions until the specified memory location changes.

```
(defun watch (addr)
  (setq old-value (meml addr))
  (dowhile (= old-value (meml addr))
    (sim-step)))
```

Bibliography

- [1] Digital. *PDP11 Processor Handbook*. Digital Equipment Corporation, 1980.
- [2] Digital. *PDP-11 Architecture Handbook*. Digital Equipment Corporation, 1984.
- [3] Intel. *8080/8085 Assembly Language Programming*. Intel, 1978.
- [4] Motorola. *M68000 16/32-Bit Microprocessor Programmer's Reference Manual*. Prentice-Hall, 4th edition, 1984.
- [5] Motorola/NXP. *Motorola M68000 Programmer's Reference Manual*. Motorola/NXP, 1992.
- [6] MOS Technology. *MSC6502 Microcomputer Family Programming Manual*. MOS Technology, July 1976.
- [7] Sean Young and Jan Wilmans. *The undocumented z80 documented*, 2005.
- [8] Zilog/IXYS. *Z80 CPU User Manual*. Zilog, 2016.