



COMMISSIONING REPORT

BRIGHTBLU INDIA PRIVATE LIMITED

ADDRESS: PLOT NO. 33, 2/59, PAN CARD CLUB RD, BANER, PUNE, MAHARASHTRA, INDIA - 411045.

WEBSITE: WWW.BRIGHTBLU.COM | EMAIL: IN.SUPPORT@BRIGHTBLU.COM

CUSTOMER DETAILS				CHARGER DETAILS	
Customer Name:				Charger Serial No:	
Contact Number:				Commissioning Date:	
Site Name:				Charger Type:	
Site Address:				Model Name:	
				Date of Manufacture:	
				Warranty Date:	
				Product Serial No:	
				Network (SIM/Wifi/LAN):	
City:		State:		SIM Provider:	

COMMISSIONING DETAILS						
CPO Charger ID:			Physical Conditions of Charger:		Ok	Not Ok
Communication Controller Firmware:				Charger Location (✓)	Open	Covered
Charge Box Firmware Version:				MCB Make & Rating:		
Type Of Earthing (✓)	Chemical Earthing	Conventional Earthing	Cable Make Type & Size:			
Mandatory Photo* (✓)	Charger Sticker	MCB Connection	Brightblu Service Page	Charger Photo	<u>Any Other Comment</u>	
Input Supply EB (Voltage): 1. N-E Voltage should be ≤5V. 2. Voltage should be b/w 190 – 270V, Nominal Voltage is 230V.	R-N (Volt)		Y-N (Volt)			
	R-Y (Volt)		Y-B (Volt)			
	B-N (Volt)		N-E (Volt)			
	B-R (Volt)		P-E (Volt)			
Voltage Fluctuation (✓)	Yes / No	LED Indication Status:		Yes / No		
Customer Or Representative Name:				Customer Signature:		
Contact:						
Designation:						
Email Id:						
Commisioning Done By: Please Tick (✓)			BRIGHTBLU Team		Service Partner	
Service Partner Name:					Service Partner Signature:	
Service Partner Contact:						