

Totally Integrated Automation Portal

Inverter_controller

Inverter_controller Properties

General

Name	Inverter_controller	Number	24	Type	UDT	Language	
Numbering							

Information

Title		Author		Comment		Family	
Version		User-defined ID					

Name	Data type	Default value	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion			Comment
Enabled	Bool	false	True	True	True	False				
RemReady	Bool	false	True	True	True	False				
Error	Bool	false	True	True	True	False				
CommError	Bool	false	True	True	True	False				
OperMode	DInt	0	True	True	True	False				Operating state of the inverter, setpoint
Wactive	DInt	0	True	True	True	False				
Qactive	DInt	0	True	True	True	False				
WMode	DInt	0	True	True	True	False				Selection of procedure for setpoint for active power
VARMode	DInt	0	True	True	True	False				Selection of procedure for setpoint for reactive power
WSpt	DInt	0	True	True	True	False				Inverter active power setpoint.
VARspt	DInt	0	True	True	True	False				Inverter reactive power setpoint (if Q control).
PFSpt	DInt	0	True	True	True	False				Inverter power factor setpoint (if PF control).
WAval	DInt	0	True	True	True	False				Available active power.
VARAval	DInt	0	True	True	True	False				Available reactive power.
PwrOffReas	DInt	0	True	True	True	False				Detect why inverter disconnected.
DrtStt	DInt	0	True	True	True	False				Derating state.