

Totally Integrated Automation Portal

PPC_Controller [DB39]

PPC_Controller Properties

General

Name	PPC_Controller	Number	39	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
▼ Inverters	"PPC_inverters"		False	True	True	True	False		
▼ PPC_Inverters	Array[0..9] of "Inverter_controller"		False	True	True	True	False		
▼ PPC_Inverters[0]	"Inverter_controller"		False	True	True	True	False		
Enabled	Bool	false	False	True	True	True	False		
RemReady	Bool	false	False	True	True	True	False		
Error	Bool	false	False	True	True	True	False		
CommError	Bool	false	False	True	True	True	False		
OperMode	DInt	0	False	True	True	True	False		Operating state of the inverter, set-point
Wactive	DInt	0	False	True	True	True	False		
Qactive	DInt	0	False	True	True	True	False		
WMode	DInt	0	False	True	True	True	False		Selection of procedure for setpoint for active power
VArMode	DInt	0	False	True	True	True	False		Selection of procedure for setpoint for reactive power
WSpt	DInt	0	False	True	True	True	False		Inverter active power setpoint.
VArSpt	DInt	0	False	True	True	True	False		Inverter reactive power setpoint (if Q control).
PFSpt	DInt	0	False	True	True	True	False		Inverter power factor setpoint (if PF control).
WAval	DInt	0	False	True	True	True	False		Available active power.
VArAval	DInt	0	False	True	True	True	False		Available reactive power.
PwrOffReas	DInt	0	False	True	True	True	False		Detect why inverter disconnected.
DrtStt	DInt	0	False	True	True	True	False		Derating state.
▼ PPC_Inverters[1]	"Inverter_controller"		False	True	True	True	False		
Enabled	Bool	false	False	True	True	True	False		
RemReady	Bool	false	False	True	True	True	False		
Error	Bool	false	False	True	True	True	False		
CommError	Bool	false	False	True	True	True	False		
OperMode	DInt	0	False	True	True	True	False		Operating state of the inverter, set-point
Wactive	DInt	0	False	True	True	True	False		
Qactive	DInt	0	False	True	True	True	False		
WMode	DInt	0	False	True	True	True	False		Selection of procedure for setpoint for active power
VArMode	DInt	0	False	True	True	True	False		Selection of procedure for setpoint for reactive power
WSpt	DInt	0	False	True	True	True	False		Inverter active power setpoint.
VArSpt	DInt	0	False	True	True	True	False		Inverter reactive power setpoint (if Q control).
PFSpt	DInt	0	False	True	True	True	False		Inverter power factor setpoint (if PF control).
WAval	DInt	0	False	True	True	True	False		Available active power.
VArAval	DInt	0	False	True	True	True	False		Available reactive power.
PwrOffReas	DInt	0	False	True	True	True	False		Detect why inverter disconnected.
DrtStt	DInt	0	False	True	True	True	False		Derating state.
▼ PPC_Inverters[2]	"Inverter_controller"		False	True	True	True	False		
Enabled	Bool	false	False	True	True	True	False		
RemReady	Bool	false	False	True	True	True	False		
Error	Bool	false	False	True	True	True	False		
CommError	Bool	false	False	True	True	True	False		
OperMode	DInt	0	False	True	True	True	False		Operating state of the inverter, set-point
Wactive	DInt	0	False	True	True	True	False		
Qactive	DInt	0	False	True	True	True	False		
WMode	DInt	0	False	True	True	True	False		Selection of procedure for setpoint for active power
VArMode	DInt	0	False	True	True	True	False		Selection of procedure for setpoint for reactive power
WSpt	DInt	0	False	True	True	True	False		Inverter active power setpoint.

Totally Integrated Automation Portal													
Name	Data type	Start value	Retain	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/ OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion				Comment	
VARspt	DInt	0	False	True	True	True	False					Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False					Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False					Available active power.	
VARAval	DInt	0	False	True	True	True	False					Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False					Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False					Derating state.	
▼ PPC_Inverters[3]	"Inverter_controller"		False	True	True	True	False						
Enabled	Bool	false	False	True	True	True	False						
RemReady	Bool	false	False	True	True	True	False						
Error	Bool	false	False	True	True	True	False						
CommError	Bool	false	False	True	True	True	False						
OperMode	DInt	0	False	True	True	True	False					Operating state of the inverter, set-point	
Wactive	DInt	0	False	True	True	True	False						
Qactive	DInt	0	False	True	True	True	False						
WMode	DInt	0	False	True	True	True	False					Selection of procedure for setpoint for active power	
VARMode	DInt	0	False	True	True	True	False					Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False					Inverter active power setpoint.	
VARspt	DInt	0	False	True	True	True	False					Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False					Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False					Available active power.	
VARAval	DInt	0	False	True	True	True	False					Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False					Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False					Derating state.	
▼ PPC_Inverters[4]	"Inverter_controller"		False	True	True	True	False						
Enabled	Bool	false	False	True	True	True	False						
RemReady	Bool	false	False	True	True	True	False						
Error	Bool	false	False	True	True	True	False						
CommError	Bool	false	False	True	True	True	False						
OperMode	DInt	0	False	True	True	True	False					Operating state of the inverter, set-point	
Wactive	DInt	0	False	True	True	True	False						
Qactive	DInt	0	False	True	True	True	False						
WMode	DInt	0	False	True	True	True	False					Selection of procedure for setpoint for active power	
VARMode	DInt	0	False	True	True	True	False					Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False					Inverter active power setpoint.	
VARspt	DInt	0	False	True	True	True	False					Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False					Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False					Available active power.	
VARAval	DInt	0	False	True	True	True	False					Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False					Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False					Derating state.	
▼ PPC_Inverters[5]	"Inverter_controller"		False	True	True	True	False						
Enabled	Bool	false	False	True	True	True	False						
RemReady	Bool	false	False	True	True	True	False						
Error	Bool	false	False	True	True	True	False						
CommError	Bool	false	False	True	True	True	False						
OperMode	DInt	0	False	True	True	True	False					Operating state of the inverter, set-point	
Wactive	DInt	0	False	True	True	True	False						
Qactive	DInt	0	False	True	True	True	False						
WMode	DInt	0	False	True	True	True	False					Selection of procedure for setpoint for active power	
VARMode	DInt	0	False	True	True	True	False					Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False					Inverter active power setpoint.	
VARspt	DInt	0	False	True	True	True	False					Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False					Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False					Available active power.	
VARAval	DInt	0	False	True	True	True	False					Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False					Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False					Derating state.	
▼ PPC_Inverters[6]	"Inverter_controller"		False	True	True	True	False						

Totally Integrated Automation Portal													
Name		Data type	Start value	Retain	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/ OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion			Comment	
Enabled		Bool	false	False	True	True	True	False					
RemReady		Bool	false	False	True	True	True	False					
Error		Bool	false	False	True	True	True	False					
CommError		Bool	false	False	True	True	True	False					
OperMode		DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive		DInt	0	False	True	True	True	False					
Qactive		DInt	0	False	True	True	True	False					
WMode		DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VArMode		DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt		DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VArSpt		DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt		DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval		DInt	0	False	True	True	True	False				Available active power.	
VArAval		DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas		DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt		DInt	0	False	True	True	True	False				Derating state.	
▼ PPC_Inverters[7]		"Inverter_controller"		False	True	True	True	False					
Enabled		Bool	false	False	True	True	True	False					
RemReady		Bool	false	False	True	True	True	False					
Error		Bool	false	False	True	True	True	False					
CommError		Bool	false	False	True	True	True	False					
OperMode		DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive		DInt	0	False	True	True	True	False					
Qactive		DInt	0	False	True	True	True	False					
WMode		DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VArMode		DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt		DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VArSpt		DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt		DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval		DInt	0	False	True	True	True	False				Available active power.	
VArAval		DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas		DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt		DInt	0	False	True	True	True	False				Derating state.	
▼ PPC_Inverters[8]		"Inverter_controller"		False	True	True	True	False					
Enabled		Bool	false	False	True	True	True	False					
RemReady		Bool	false	False	True	True	True	False					
Error		Bool	false	False	True	True	True	False					
CommError		Bool	false	False	True	True	True	False					
OperMode		DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive		DInt	0	False	True	True	True	False					
Qactive		DInt	0	False	True	True	True	False					
WMode		DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VArMode		DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt		DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VArSpt		DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt		DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval		DInt	0	False	True	True	True	False				Available active power.	
VArAval		DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas		DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt		DInt	0	False	True	True	True	False				Derating state.	
▼ PPC_Inverters[9]		"Inverter_controller"		False	True	True	True	False					
Enabled		Bool	false	False	True	True	True	False					
RemReady		Bool	false	False	True	True	True	False					
Error		Bool	false	False	True	True	True	False					
CommError		Bool	false	False	True	True	True	False					
OperMode		DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive		DInt	0	False	True	True	True	False					
Qactive		DInt	0	False	True	True	True	False					

Totally Integrated Automation Portal												
Name	Data type	Start value	Retain	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/ OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion			Comment	
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VArMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VArSpt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False				Available active power.	
VArAval	DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False				Derating state.	
▼ Inverter1	"Inverter_controller"		False	True	True	True	False					
Enabled	Bool	false	False	True	True	True	False					
RemReady	Bool	false	False	True	True	True	False					
Error	Bool	false	False	True	True	True	False					
CommError	Bool	false	False	True	True	True	False					
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive	DInt	0	False	True	True	True	False					
Qactive	DInt	0	False	True	True	True	False					
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VArMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VArSpt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False				Available active power.	
VArAval	DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False				Derating state.	
▼ Inverter2	"Inverter_controller"		False	True	True	True	True					
Enabled	Bool	false	False	True	True	True	False					
RemReady	Bool	false	False	True	True	True	False					
Error	Bool	false	False	True	True	True	False					
CommError	Bool	false	False	True	True	True	False					
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive	DInt	0	False	True	True	True	False					
Qactive	DInt	0	False	True	True	True	False					
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VArMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VArSpt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False				Available active power.	
VArAval	DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False				Derating state.	
▼ Inverter3	"Inverter_controller"		False	True	True	True	True					
Enabled	Bool	false	False	True	True	True	False					
RemReady	Bool	false	False	True	True	True	False					
Error	Bool	false	False	True	True	True	False					
CommError	Bool	false	False	True	True	True	False					
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive	DInt	0	False	True	True	True	False					
Qactive	DInt	0	False	True	True	True	False					
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VArMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VArSpt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False				Available active power.	

Totally Integrated Automation Portal												
Name	Data type	Start value	Retain	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/ OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion			Comment	
VARaval	DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False				Derating state.	
▼ Inverter4	"Inverter_controller"		False	True	True	True	True					
Enabled	Bool	false	False	True	True	True	False					
RemReady	Bool	false	False	True	True	True	False					
Error	Bool	false	False	True	True	True	False					
CommError	Bool	false	False	True	True	True	False					
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive	DInt	0	False	True	True	True	False					
Qactive	DInt	0	False	True	True	True	False					
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VARmode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VARspt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False				Available active power.	
VARaval	DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False				Derating state.	
▼ Inverter5	"Inverter_controller"		False	True	True	True	True					
Enabled	Bool	false	False	True	True	True	False					
RemReady	Bool	false	False	True	True	True	False					
Error	Bool	false	False	True	True	True	False					
CommError	Bool	false	False	True	True	True	False					
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive	DInt	0	False	True	True	True	False					
Qactive	DInt	0	False	True	True	True	False					
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VARmode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VARspt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False				Available active power.	
VARaval	DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False				Derating state.	
▼ Inverter6	"Inverter_controller"		False	True	True	True	True					
Enabled	Bool	false	False	True	True	True	False					
RemReady	Bool	false	False	True	True	True	False					
Error	Bool	false	False	True	True	True	False					
CommError	Bool	false	False	True	True	True	False					
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point	
Wactive	DInt	0	False	True	True	True	False					
Qactive	DInt	0	False	True	True	True	False					
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power	
VARmode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power	
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.	
VARspt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).	
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).	
WAval	DInt	0	False	True	True	True	False				Available active power.	
VARaval	DInt	0	False	True	True	True	False				Available reactive power.	
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.	
DrtStt	DInt	0	False	True	True	True	False				Derating state.	
▼ Inverter7	"Inverter_controller"		False	True	True	True	True					
Enabled	Bool	false	False	True	True	True	False					
RemReady	Bool	false	False	True	True	True	False					
Error	Bool	false	False	True	True	True	False					
CommError	Bool	false	False	True	True	True	False					

Totally Integrated Automation Portal											
Name	Data type	Start value	Retain	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/ OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion			Comment
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point
Wactive	DInt	0	False	True	True	True	False				
Qactive	DInt	0	False	True	True	True	False				
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power
VArMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.
VArSpt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).
WAval	DInt	0	False	True	True	True	False				Available active power.
VArAval	DInt	0	False	True	True	True	False				Available reactive power.
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.
DrtStt	DInt	0	False	True	True	True	False				Derating state.
▼ Inverter8	"Inverter_controller"		False	True	True	True	True				
Enabled	Bool	false	False	True	True	True	False				
RemReady	Bool	false	False	True	True	True	False				
Error	Bool	false	False	True	True	True	False				
CommError	Bool	false	False	True	True	True	False				
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point
Wactive	DInt	0	False	True	True	True	False				
Qactive	DInt	0	False	True	True	True	False				
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power
VArMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.
VArSpt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).
WAval	DInt	0	False	True	True	True	False				Available active power.
VArAval	DInt	0	False	True	True	True	False				Available reactive power.
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.
DrtStt	DInt	0	False	True	True	True	False				Derating state.
▼ Inverter9	"Inverter_controller"		False	True	True	True	True				
Enabled	Bool	false	False	True	True	True	False				
RemReady	Bool	false	False	True	True	True	False				
Error	Bool	false	False	True	True	True	False				
CommError	Bool	false	False	True	True	True	False				
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point
Wactive	DInt	0	False	True	True	True	False				
Qactive	DInt	0	False	True	True	True	False				
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power
VArMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.
VArSpt	DInt	0	False	True	True	True	False				Inverter reactive power setpoint (if Q control).
PFSpt	DInt	0	False	True	True	True	False				Inverter power factor setpoint (if PF control).
WAval	DInt	0	False	True	True	True	False				Available active power.
VArAval	DInt	0	False	True	True	True	False				Available reactive power.
PwrOffReas	DInt	0	False	True	True	True	False				Detect why inverter disconnected.
DrtStt	DInt	0	False	True	True	True	False				Derating state.
▼ Inverter10	"Inverter_controller"		False	True	True	True	True				
Enabled	Bool	false	False	True	True	True	False				
RemReady	Bool	false	False	True	True	True	False				
Error	Bool	false	False	True	True	True	False				
CommError	Bool	false	False	True	True	True	False				
OperMode	DInt	0	False	True	True	True	False				Operating state of the inverter, set-point
Wactive	DInt	0	False	True	True	True	False				
Qactive	DInt	0	False	True	True	True	False				
WMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for active power
VArMode	DInt	0	False	True	True	True	False				Selection of procedure for setpoint for reactive power
WSpt	DInt	0	False	True	True	True	False				Inverter active power setpoint.

