



EQ-01 CW13 marked L-18 (precast block lintel) on an ICF opening

Status: Open | see GA-01

Engineer Carb Zero 26-92-01 rev C

ICF model (GA-01)



ISSUE CW13 (2875 wide, head +2400) is an opening in the external 150mm-core ICF wall. It is marked L-18, which the lintel schedule gives as a Naylor precast lintel R8 (140x215) / R7 (215x145) for 140/215 blockwork. The matching opening CW14 in the same wall is L-10 (300x150 RC, 2-H12 top / 2-H16 bott.).

QUESTION Please confirm the lintel for CW13: is L-18 intended, or should it be an RC lintel cast in the ICF core (e.g. as L-10)?

ENGINEER'S RESPONSE

Name / date:




EQ-02 D1: steel B-6 as the head of the 5575 opening (confirm interpretation)

Status: Open | see GA-01

Engineer Carb Zero 26-92-01 rev C

ICF model (GA-01)

Section at D1 (model)



ISSUE D1 is the 5575 wide full-length opening in the ICF wall between the conservatory and the room to its east (Wall 21). Your drawing gives it no lintel mark and shows B-6 254x254x73 UC S355 (with 200x100x10 ledger angle one side) along that line. We have modelled B-6 at BOS +2400 / TOS +2654 as the head of the opening, with the structural opening in the ICF up to +2654 and ICF over the steel to the wall top at +3350, giving 2400 clear under the steel.

QUESTION Please confirm that B-6 forms the head of D1 as described (clear opening 2400 under B-6, ICF bearing on the steel above), or advise the intended arrangement.

ENGINEER'S RESPONSE

Name / date:

QUESTIONS REGISTER

QUERIES

Ref	Subject	Drawing	Status
EQ-01	CW13 marked L-18 (precast block lintel) on an ICF opening	GA-01	Open
EQ-02	D1: steel B-6 as the head of the 5575 opening (confirm interpretation)	GA-01	Open

NOTES

- Questions raised on the ICF approval drawings against the structural engineer's drawing Carb Zero 26-92-01 rev C.
- Each panel shows the engineer's drawing beside the architect's drawing and/or the ICF model, cropped to the same area.
- Please answer in the response box of each question (or by email quoting the EQ reference); the approval drawings will be revised to suit.
- EQ tags on the GA drawings link to these panels.

REVISIONS

REV	DATE	DESCRIPTION
P01	14.09.26	Approval issue



CLIENT
Mr A Kirkpatrick

PROJECT
11767 Horrobin Farm, Turton

DRAWING TITLE

QUESTIONS FOR THE ENGINEER

Structural queries on the ICF approval drawings - sheet 1 of 1

SCALE	SIZE	DATE	DRAWN
NTS	A3	14.09.26	TS

STATUS	DRAWING No.	REV
FOR APPROVAL	UKPCS-002-EQ-01	P01