
ICF PACKAGE: Nudura ICF formwork and accessories are our supply. Raft and foundations AS PER THE ARCHITECTURAL DRAWINGS; joist ledgers by the engineer. Floors, stairs, partitions, roof and joinery are drawn as DESIGN ASSUMPTIONS for coordination - check by the relevant professional.

FOR APPROVAL - NOT FOR CONSTRUCTION

SECTION DETAIL - RAFT EDGE (single-sided unassembled 6in XR35 panel)

1:10 - as drawn on Beech section A-A



QUANTITIES - one Alwen

Slab outline (inside panel)	12.401 x 7.788 m
Concrete @ 257.2	24.84 m3 (order 26.1 m3 +5%)
PIR 2 x 100, joints staggered	2 x 96.6 m2 (36 boards / layer)
Type 3 MOT 150	20.44 m3 / 42.9 t
Edge panel face, 1 course	41.19 lm

NOTES

1. AS PER THE ARCHITECTURAL DRAWINGS - Beech section A-A governs the raft.
2. Flat insulated raft: 257.2 RC slab on 200 PIR (2 x 100 staggered) inside a one-course (457.2) edge of UNASSEMBLED 6in XR35 panel - the external face only, pre-cut. No vertical joint clips on the single-sided edge.
3. The L1 6in XR35 wall over bears its core and inner panel on the slab; starters core to slab by the engineer.
4. Slab, reinforcement and bearings by the engineer. Quantities: myf_raft.py, this house type.
5. Alwen 4P2B Type A (semi). Datum 0 = GF FFL. Architect: Beech Developments - BD0165-ALW rev A (JHG 28/08/26).

REVISIONS

REV	DATE	DESCRIPTION
P01	29.10.26	Approval issue

Nudura™ BuildEase

CLIENT: Beech Developments (NW) Ltd	PROJECT: Maes Y Felin, Glan Conwy - Alwen

DRAWING TITLE: **ALWEN - RAFT EDGE DETAIL**

SCALE	SIZE	DATE
1:10 @ A2	A2	29.10.26
DRAWN: TS	CHECKED	APPROVED

STATUS	DRAWING No.	REV
FOR APPROVAL	ES26-020-ALW-DT-02	P01

Do not scale. All dimensions in millimetres, levels in metres from GF FFL. Check all dimensions on site.