
ICF PACKAGE: Nudura ICF formwork and accessories are our supply. Raft and foundations AS PER THE ARCHITECTURAL DRAWINGS; joist ledgers by the engineer. Floors, stairs, partitions, roof and joinery are drawn as DESIGN ASSUMPTIONS for coordination - check by the relevant professional.

FOR APPROVAL - NOT FOR CONSTRUCTION

SECTION DETAIL - EAVES AND WALL PLATE

1:5 - over Beech section A-A (BD0165-ALW rev A)



1 47 x 150 C24 TREATED WALL PLATE on the concrete core, 101.6 to 251.6 from the outer ICF face; top of plate +5,076 above GF FFL (all four walls - hip roof)

2 M12 resin anchors into the core @ 1,200 max, 300 from each end and each side of every joint (engineer to confirm) - the plate bears on the CONCRETE CORE ONLY

3 6in XR35 = 101.6 EPS / 152.4 concrete core / 101.6 EPS. The EPS is formwork and insulation - NOT STRUCTURAL, no load on it. Core top +5,029.2 above GF FFL

4 Fink trussed rafter @ 600, 35 deg (truss designer) - bears on the plate, heel 183.1 at the outer ICF face; truss clip each truss to the plate (truss designer)

5 Tiles on battens, counter-battens and breather membrane (as Beech)

6 Fascia + vented soffit (as Beech)

7 Gutter (as Beech)

8 Dryvit ICF 500 render system on the EPS

9 Ceiling plasterboard + vapour control layer (as Beech)

10 Loft insulation (as Beech)

11 L2 window head: 47 x 150 timber closer, 25 overfly - see DT-01

NOTES

1. Beech's 75 x 50 plate as drawn is replaced by the 47 x 150 C24 treated wall plate shown red, on the core.
2. The roof bears on the 152.4 concrete core only - the EPS either side is not structural.
3. Plate anchors and the truss clips / restraint straps are design assumptions for the engineer and the truss designer to confirm. Plate setting-out: RF-00.
4. Ogwen 5P4B (detached), Datum 0 = GF FFL. Architect: Beech Developments - BD0154-OGW rev A (JHG 28/10/26).

REVISIONS

REV	DATE	DESCRIPTION
P01	29.10.26	Approval issue

Nudura™ BuildEase

CLIENT	PROJECT
Beech Developments (NW) Ltd	Maes Y Felin, Glan Conwy - Ogwen

DRAWING TITLE

OGWEN - EAVES DETAIL - WALL PLATE ON THE ICF CORE

SCALE	SIZE	DATE
1:5 @ A2	A2	29.10.26
DRAWN	CHECKED	APPROVED
TS		

STATUS	DRAWING No.	REV
FOR APPROVAL	ES26-020-OGW-DT-03	P01

Do not scale. All dimensions in millimetres, levels in metres from GF FFL. Check all dimensions on site.