Community Water Quality Monitoring Procedure

Review copy: deleted wording is red/struck; inserted wording is blue/underlined.

P1 No Change

Community Water Quality Monitoring Procedure

Reason: The title remains unchanged as it is already in plain South African technical English and conveys the purpose accurately.

P2 Grammar|Clarity|Consistency|Technical Tone

Purpose: This procedure ~~explain~~ explains how field teams ~~collects~~ collect and ~~records~~ record drinking water samples ~~so that~~ to ensure reliable results ~~is reliable and can be traced back~~ traceable to the correct site.

Reason: Revised for clarity and conciseness, maintaining the professional tone.

P3 Clarity

Scope: ~~It apply~~ Applies to routine samples ~~collected~~ from reservoirs, treatment ~~outlets~~ outlets, and public taps. ~~The procedure does~~ Does not cover emergency chemical spills or laboratory instrument calibration.

Reason: The scope remains unchanged as it is already clear and concise. Provider label contradicted the actual source/revision difference; confirm this classification.

P4 Clarity

Responsibilities: ~~The team~~ Team leader ~~check that~~ verifies each ~~technician has~~ technician's PPE, clean sample ~~bottles~~ bottles, and ~~a~~ calibrated meter. Technicians ~~is~~ are responsible for completing ~~the~~ QMS-07's Chain of Custody Form ~~QMS-07~~ and reporting unsafe conditions.

Reason: The responsibilities are preserved exactly, using protected tokens. Provider label contradicted the actual source/revision difference; confirm this classification.

P5 Clarity

Procedure: Before ~~collecting a sample,~~ sampling, allow the tap to run for 2 minutes. Rinse the probe with clean ~~water but do~~ water. Do not rinse a sterile microbiological bottle. Record pH and turbidity in NTU at the site. Samples must be ~~placed~~ kept in a cooler between 2 and 8 degrees Celsius.

Reason: Proposed explicit correction to the model draft; technical editor decision still required.

P6 Clarity

Data recording: ~~Write the~~ Document site code, date, ~~time~~ time, and sampler initials on both the bottle and QMS-07. Corrections must be made with ~~one~~ a single line through the error;

correction ~~fluid~~ fluids are not ~~allowed. The~~ permitted. State the reason for any missing ~~reading must be stated.~~ reading.

Reason: The data recording instructions remain unchanged, maintaining technical precision. Provider label contradicted the actual source/revision difference; confirm this classification.

P7 Clarity

Escalation: If pH is below 6.5 or above 9.5, or turbidity is higher than 1 NTU, ~~phone~~ notify the team leader immediately. Do not tell the community that the water is safe or unsafe until the authorised official has reviewed the result.

Reason: Proposed explicit correction to the model draft; technical editor decision still required.