

Community Water Quality Monitoring Procedure

Review copy: deleted wording is red/struck; inserted wording is blue/underlined.

P1 No Change

Community Water Quality Monitoring Procedure

Reason: Title is clear and accurate; no changes needed.

P2 No Change

Purpose: This procedure explains how field teams collect and record drinking water samples so that results are reliable and traceable to the correct site.

Reason: Sentence is grammatically correct and clear.

P3 No Change

Scope: It applies to routine samples collected from reservoirs, treatment outlets, and public taps. The procedure does not cover emergency chemical spills or laboratory instrument calibration.

Reason: Clear and consistent with the rest of the document.

P4 No Change

Responsibilities: The team leader checks that each technician has PBT, clean sample bottles, and a calibrated meter. Technicians are responsible for completing the Chain of Custody Form QMS-07 and reporting unsafe conditions.

Reason: Responsibilities are clearly stated; no changes needed.

P5 No Change

Procedure: Before collecting a sample, allow the tap to run for 2 minutes. Rinse the probe with clean water, but do not rinse a sterile microbiological bottle. Record pH and turbidity in NTU at the site. Samples must be placed in a cooler between 2 and 8 degrees Celsius.

Reason: Instructions are clear and technically accurate.

P6 No Change

Data recording: Write the site code, date, time, and sampler initials on both the bottle and QMS-07. Corrections must be made with a single line through the error; correction fluid is not allowed. The reason for any missing reading must be stated.

Reason: Clear and consistent with standard data recording practices.

P7 No Change

Escalation: If pH is below 6.5 or above 9.5, or turbidity is higher than 1 NTU, phone the team leader immediately. Do not tell the community that the water is safe or unsafe until the authorised official has reviewed the result.

Reason: Clear and unambiguous; no changes needed.