

Circuit breaker selectivity report

New_project
Full

Content

1	Project description.....	4
1.1	Project general settings	4
2	Selectivity	5

1 Project description

1.1 Project general settings

Installation standard	IEC60364
Calculation standard	TR50480
Circuit breaker standard	IEC 60947-2
Frequency	50 Hz

2 Selectivity - Full

2.1 Selectivity Results - Normal

DownStream	UpStream	Selectivity Limit
QA 15 MTZ2 20N1 MicroLogic 6.0 X 2000 A / 4P4d	NA	Selectivity can't be determinated : no upstream Lv Breaker
QA 18 NSX400F Micrologic 5.3 E 400 A / 4P4d	QA 15 MTZ2 20N1 MicroLogic 6.0 X 2000 A / 4P4d	Total Selectivity
QA 21 NSX160B Micrologic 5.2 E 160 A / 4P4d	QA 18 NSX400F Micrologic 5.3 E 400 A / 4P4d	Total Selectivity
QA 33 (1) (1) iC40 C 10 A / 2P1d	QA 21 (1) NSX160B Micrologic 5.2 E 160 A / 4P4d	Total Selectivity
QA 21 (1) NSX160B Micrologic 5.2 E 160 A / 4P4d	QA 18 NSX400F Micrologic 5.3 E 400 A / 4P4d	Total Selectivity
QA 27 NSX160N Micrologic 5.2 E 160 A / 4P4d	QA 18 NSX400F Micrologic 5.3 E 400 A / 4P4d	Total Selectivity
QA 30 NSX100B Micrologic 5.2 E 40 A / 4P4d	QA 18 NSX400F Micrologic 5.3 E 400 A / 4P4d	Total Selectivity
QA 33 iC40 C 4 A / 2P1d	QA 21 NSX160B Micrologic 5.2 E 160 A / 4P4d	Total Selectivity
QA 35 iC60H C 63 A / 4P4d	QA 27 NSX160N Micrologic 5.2 E 160 A / 4P4d	Total Selectivity
QA 36 iC40 C 6 A / 4P3d	QA 30 NSX100B Micrologic 5.2 E 40 A / 4P4d	Total Selectivity
QA 38 NSX400F Micrologic 5.3 E 400 A / 4P4d	QA 15 MTZ2 20N1 MicroLogic 6.0 X 2000 A / 4P4d	Total Selectivity
QA 42 NSX250B Micrologic 5.2 E 250 A / 4P4d	QA 38 NSX400F Micrologic 5.3 E 400 A / 4P4d	4800 A
QA 42 (1) NSX250B Micrologic 5.2 E 250 A / 4P4d	QA 38 (1) NSX400F Micrologic 5.3 E 400 A / 4P4d	4800 A
QA 38 (1)	QA 15	Total Selectivity

NSX400F Micrologic 5.3 E 400 A / 4P4d	MTZ2 20N1 MicroLogic 6.0 X 2000 A / 4P4d	
QA 42 (2) NSX250B Micrologic 5.2 E 250 A / 4P4d	QA 38 (2) NSX400F Micrologic 5.3 E 400 A / 4P4d	4800 A
QA 38 (2) NSX400F Micrologic 5.3 E 400 A / 4P4d	QA 15 MTZ2 20N1 MicroLogic 6.0 X 2000 A / 4P4d	Total Selectivity
QA 42 (3) NSX250B Micrologic 5.2 E 250 A / 4P4d	QA 38 (3) NSX400F Micrologic 5.3 E 400 A / 4P4d	4800 A
QA 38 (3) NSX400F Micrologic 5.3 E 400 A / 4P4d	QA 15 MTZ2 20N1 MicroLogic 6.0 X 2000 A / 4P4d	Total Selectivity
QA 42 (4) NSX250B Micrologic 5.2 E 250 A / 4P4d	QA 38 (4) NSX400F Micrologic 5.3 E 400 A / 4P4d	4800 A
QA 38 (4) NSX400F Micrologic 5.3 E 400 A / 4P4d	QA 15 MTZ2 20N1 MicroLogic 6.0 X 2000 A / 4P4d	Total Selectivity
QA 42 (5) NSX250B Micrologic 5.2 E 250 A / 4P4d	QA 38 (5) NSX400F Micrologic 5.3 E 400 A / 4P4d	4800 A
QA 38 (5) NSX400F Micrologic 5.3 E 400 A / 4P4d	QA 15 MTZ2 20N1 MicroLogic 6.0 X 2000 A / 4P4d	Total Selectivity
QA 42 (6) NSX250B Micrologic 5.2 E 250 A / 4P4d	QA 38 (6) NSX400F Micrologic 5.3 E 400 A / 4P4d	4800 A
QA 38 (6) NSX400F Micrologic 5.3 E 400 A / 4P4d	QA 15 MTZ2 20N1 MicroLogic 6.0 X 2000 A / 4P4d	Total Selectivity
QA 51 iC40 C 25 A / 4P3d	QA 30 NSX100B Micrologic 5.2 E 40 A / 4P4d	Total Selectivity
QA 33 (1) iC40 C 10 A / 2P1d	QA 21 NSX160B Micrologic 5.2 E 160 A / 4P4d	Total Selectivity
QA 33 (2) iC40N C 13 A / 2P1d	QA 21 NSX160B Micrologic 5.2 E 160 A / 4P4d	Total Selectivity
QA 33 (3) iC40N C 13 A / 4P3d	QA 21 NSX160B Micrologic 5.2 E 160 A / 4P4d	Total Selectivity
QA 33 (4) iC40 C	QA 21 (1) NSX160B Micrologic 5.2 E	Total Selectivity

4 A / 2P1d	160 A / 4P4d	
QA 33 (2) (1) iC40N C 13 A / 2P1d	QA 21 (1) NSX160B Micrologic 5.2 E 160 A / 4P4d	Total Selectivity
QA 33 (3) (1) iC40N C 13 A / 4P3d	QA 21 (1) NSX160B Micrologic 5.2 E 160 A / 4P4d	Total Selectivity

NOTICE**RISK OF INACCURATE DATA RESULTS.**

- Configure the software correctly to get accurate reports and/or data results.
- Do not rely solely on software messages and reports to determine if the system is functioning correctly.
- Make sure that you have entered the correct inputs for the required components.
- Review the calculated results and solutions provided by the software before submitting the report.

Failure to follow these instructions can result in incorrect bill of material and loss of business.