



Panel 1 - Device Details

Panel 1 - Causes and Effects

[illegible]

| # | Action | Occurs when... | | | Resets when... | | |
|----|-----------------------|----------------|-------------------------------|-------------------------|----------------|----------------------------|-----------------|
| 1 | Sounder evac | All Groups | More than one zone in 'Alarm' | | is True | Panel input | Input 1 |
| 2 | Sounder alert | All Groups | Loop 1 device triggered | 25: CAST PRO OpHTCO V/C | is False | Zone has device in 'Alarm' | Zone 32 |
| 3 | Reset panel | | Zone AND | Zone 3 and 21 | is False | Event AND | Event 15 and 12 |
| 4 | Abstract event | | Timer event | Time: T16 | is False | Panel unoccupied | |
| 5 | Trigger loop 2 device | Not set | | | | | |
| 6 | Trigger loop 1 device | 4: CAST MCP | Not set | | | | |
| 7 | None | | | | | | |
| 8 | None | | | | | | |
| 9 | None | | | | | | |
| 10 | None | | | | | | |
| 11 | None | | | | | | |
| 12 | None | | | | | | |
| 13 | None | | | | | | |
| 14 | None | | | | | | |
| 15 | None | | | | | | |
| 16 | None | | | | | | |