





























Panel 1 - Device Details

Loop 1 Devices												
#	Device Type	Zone/Group	Device Name	Vol/Sens/ Mode	Day:Night	Remote LED	Base Sounder	I/O Configuration				
								Sub.	I/O	Chan.	Z/G/S	Desc.
1												
2		XP95/S90 Optical	Use in Special C&E	XXXXXXXXXXXXXXXXXXXX XXXXXXXXXXXXXXXXXXXX	Sensitivity	100:100	N	Group 11				
3		Discovery Ion	Use in Special C&E		Sensitivity	1:5	N	Group 12				
4		XP95/S90 Ion	Use in Special C&E		Sensitivity	75:100	N	Group 2				
7		XP95 High Temp	Zone 1		Sensitivity	75:125	N	Group 2				
8		Discovery CO	Zone 5		Sensitivity	5:3	N	Group 3				
9		Discovery CO/Heat	Zone 1		Sensitivity	5:3	N	Group 6				
10		Discovery MCP	Zone 32		--	--	--	Group 0				
11		XP95 MCP	Zone 1		--	--	--	Group 0				
12		S90 Manual Callpoint	Use in Special C&E		--	--	--	Group 0				
13		Discovery Multi	Zone 1		Sensitivity	5:1	N	Group 2				
14		XP95 Multi	Zone 1		Sensitivity	100:100	Y	--				
15		XP95/S90 I/O Unit	See I/O configuration		--	--	--	Group 1	0 1	Output Output	1 2	Use in Special C&E Set 1 Set 16 Set 16 Use in Special C&E Use in Special C&E MMMMMMMMMMMMMMMM MMMMMMMMMMMMMMMM adfsdfsdf
16		XP95 Switch Monitor	See I/O configuration		--	--	--	Group 0	0 2	Output Input	3 1	Use in Special C&E Use in Special C&E WW
17		Intelligent Beam Detector	Use in Special C&E		--	--	--	Group 0				
18		XP95 Flame Detector	Use in Special C&E		Sensitivity	75:75	N	Group 3				
19		XP95/S90 Zone Monitor	See I/O configuration		--	--	--	Group 0	0	Input	1	Use in Special C&E
20		Sounder I/O Unit	Group 4		Volume	6:6	--	Group 0				
21		Non-Latching I/O Unit	See I/O configuration		--	--	--	Group 0	0 1	Input Output	1 1	Zone 1 Set 1
22		Sounder Controller	Use in Special C&E		Volume	6:6	--	Group 0				
23		Sounder Controller	Group 1		Volume	6:6	--	Group 0				
24		Sounder Controller	Use in Special C&E		Volume	6:6	--	Group 0				
25		Sounder Beacon Base	Group 6		Volume	6:6	--	Group 0				
26		Sounder Base	Use in Special C&E		Volume	6:6	--	Group 0				
27		Sounder I/O Unit	Group 15		Volume	6:6	--	Group 0				
28		Voice Sounder Beacon	Use in Special C&E		Volume	6:6	--	Group 0				
29		Voice Sounder	Group 3		Volume	6:6	--	Group 0				