XFP Configuration

System Name: XFP

Loop 1 Devices

#	Device Type	Zone/Group	Device Name	Vol/Sens Mode	Day:Night	Remote LED	Base Sounder	I/O	Chan.	Zone/Group/Set	Description
22	Sounder Controller	Use in Special C&E		Volume	6:6		--				
24	Sounder Controller	Use in Special C&E		Volume	6:6		--				
28	Voice Sounder Beacon	Use in Special C&E		Volume	6:6		--				
2	XP95/S90 Optical	Use in Special C&E		Sensitivity	100:100		Group 11				
3	Discovery Ion	Use in Special C&E		Sensitivity	3:3		Group 12				
4	XP95/S90 Ion	Use in Special C&E		Sensitivity	100:100		Group 2				
18	XP95 Flame Detector	Use in Special C&E		Sensitivity	75:75		Group 3				
17	Intelligent Beam Detector	Use in Special C&E					--				
12	S90 Manual Callpoint	Use in Special C&E					--				
23	Sounder Controller	Group 1		Volume	6:6		--				
29	Voice Sounder	Group 3		Volume	6:6		--				
20	Sounder I/O Unit	Group 4		Volume	6:6		--				
25	Sounder Beacon Base	Group 6		Volume	6:6		--				
27	Sounder I/O Unit	Group 15		Volume	6:6		--				
26	Sounder Base	Group 16		Volume	6:6		--				
13	Discovery Multi	Zone 1		Sensitivity	5:1		Group 2				
11	XP95 MCP	Zone 1					--				
9	Discovery CO/Heat	Zone 1		Sensitivity	5:3		Group 6				
7	XP95 High Temp	Zone 1		Sensitivity	75:125		Group 2				
14	XP95 Multi	Zone 1		Sensitivity	100:100		Group 2				
6	S90 Manual Callpoint	Zone 2					--				
8	Discovery CO	Zone 5		Sensitivity	5:3		Group 3				
1	Discovery Optical	Zone 6		Sensitivity	3:3	✓	Group 11				
5	Discovery Heat	Zone 7		Sensitivity	5:3		Group 14				
10	Discovery MCP	Zone 32					--				
15	XP95/S90 I/O Unit	See I/O configuration					Group 1	1	Output 1		Use in Special C&E
								2	Output 2	Set 1	ertrtertertert
								3	Output 3	Set 16	
								4	Output 3	Set 16	
19	XP95/S90 Zone Monitor	See I/O configuration					--	1	Input 1		Use in Special C&E
16	XP95 Switch Monitor	See I/O configuration					--	1	Input 1		Use in Special C&E
								3	Input 1		Use in Special C&E subname2
21	Non-Latching I/O Unit	See I/O configuration					--	1	Input 1	Zone 1	
								2	Output 1	Set 1	

Loop 2 Devices

#	Device Type	Zone/Group	Device Name	Vol/Sens Mode	Day:Night	Remote LED	Base Sounder	I/O	Chan.	Zone/Group/Set	Description