

S90/XP95/XPlorer/Discovery Type Code Allocation

Device Type	Type Code Bits				Reply Bits		
	Decimal						
	S90	XP95	Dis	210	43	765	
U	Shop Unit Monitor/User Defined	0	0	0	000	00	000
U	User Defined	0	1	8	000	01	000
U	User Defined	0	2	16	000	10	000
U	User Defined	0	3	24	000	11	000
S/Xp/Xd	Sounder Circuit Controller/Unit, Loop Sounders/(Beacons), & Beacon	1	4	32	001	00	000
Xa	Sounder Control Module	1	5	40	001	01	000
D	Sounder Beacon	1	6	48	001	10	000
D	Voice Sounder Beacon	1	6	52	001	10	100
		1	7	56	001	11	000
Xp/XI/Xa/I/O & Output Units and XP95A Relay Output Module	2	8	64	010	00	000	
Xa	Mini Switch Monitor Module	2	9	72	010	01	000
Xa	Switch Monitor Module	2	10	80	010	10	000
Xa	Switch Monitor I/O Module	2	11	88	010	11	000
S/Xp/Xa/D/Ionisation Detector	3	12	96	011	00	000	
D	MOST	3	13	104	011	01	000
D	CO : Gaseous Fire Detector	3	13	105	011	01	001
D	CO Heat	3	14	112	011	10	000
D	CO : Personal Protection Monitor	3	14	113	011	10	001
		3	15	120	011	11	000
D	CO : Environmental Gas Monitor	3	15	121	011	11	001
S/Xp/Xd	Zone Monitor Unit & Control Unit Monitor	4	16	128	100	00	000
Xp/XI	Mini Switch Monitor, Switch Monitor Unit & Switch Monitor Plus	4	17	136	100	01	000
		4	18	144	100	10	000
Xp/D	Aspirating Detectors	4	19	152	100	11	000
S/Xp/Xa/XI/Optical Detector & Beam Detector(EUR)	5	20	160	101	00	000	
D	Reserved	5	20	161	101	00	001
Xp/Xa	Beam Detector(USA) & Reflective Beam	5	21	168	101	01	000
Xp	Flame Detector	5	22	176	101	10	000
D	Multi-sensor (Opt / Heat)	5	23	184	101	11	000
Xp	Multi-sensor (Opt / Heat)	5	23	185	101	11	001
S/Xp/Xa/XI/Heat Detector	6	24	192	110	00	000	
D	Reserved	6	24	193	110	00	001
Xp/XI	High Temperature Heat Detector	6	25	200	110	01	000
		6	26	208	110	10	000
		6	27	216	110	11	000
S	Manual Call Point & Manual Call Point Monitor	7	28	224	111	00	000
Xa	Mini Priority Switch Monitor Module	7	29	232	111	01	000
Xa	Priority Switch Monitor Module	7	30	240	111	10	000
Xp/XI/D/Xd	Mini Switch Monitor with Interrupt	7	31	248	111	11	000

Notes: Series 90, XP95, XPlorer and Discovery smoke and heat detectors share the same generic 3 bit type code XP95/XPlorer are distinguished from S90 by the XP95 flag. Discovery detectors/MCPs are distinguished from XP95 by at least one of the Mode/Sensitivity bits being set (in XP95 these are all logic 0).

NOT IF TRUE = 0 ON
DISCOVERY SOUNDER