

Gulf Remediation, Inc.

Accepted:

6649 Northdale St.~Houston, TX 77087

Jadwin Facility PM Service

Contract #W912HY21C0004

Start Time:_____

Date:_____

End Time:_____

Name:_____

Total Hours:_____

Signature:_____

Location: All Mechanical Rooms

OAT:

Title:_____

Daily PMIS Air Handlers

Equip ID	Make	Serial #	Notes	Supply Water Temp.	Return Water Temp.	Supply Water Pressure	Return Water Pressure								
AHU-1-1	Trane	K91F20264													
AHU-1-2	Trane	K91F20265													
AHU-2-1	Trane	K91F20266													
AHU-2-2	Trane	K91F20267													
AHU-3-1	Trane	K91F20268													
AHU-3-2	Trane	K91F20269													
Model #	AHU-1-1 CCDB31B20M AHU-3-2 CCDB31BF0M			Task Completed											
	AHU-1-2 to AHU-3-1 CCDB25B20M			AHU-1-1		AHU-1-2		AHU-2-1		AHU-2-2		AHU-3-1		AHU-3-2	
Check Point #	To be Performed at Each Inspection Service			Yes	No	Yes	No	Yes	No	Yes	No	Yes	No	Yes	No
1	Observe Operating Temperature, Pressure OAT, Set Points & General Conditions														
2	Check for Service Codes or Lockout on the Display Panel														
3	Inspect Air Filters for Dirt and Debris														
4	Inspect all Piping Components and Insulation														
5	Inspect Motors for Proper Operation														
6	Inspect Belts for Tension, Noise, Vibration and Wear														
7	Observe any Unusual Noises or Operating Conditions														
8	Check for Leaks														
Notes:															