



AFFIDAVIT – SELF CERTIFICATION FOR THE INSTALLATION OF CARBON MONOXIDE AND SMOKE ALARMS

FOR COMPLIANCE WITH SECTIONS 420.4, 907.2.11 & 3401.6.1 OF THE SAN FRANCISCO BUILDING CODE

PROPERTY ADDRESS: _____

PERMIT APPLICATION NO.: _____ BLOCK: _____ LOT: _____

NUMBER OF CARBON MONOXIDE ALARMS INSTALLED: _____

NUMBER OF SMOKE ALARMS INSTALLED: _____

NUMBER OF MULTI-PURPOSE ALARMS INSTALLED: _____

CARBON MONOXIDE Alarms: See San Francisco Building Code Section 420.4

<http://publicecodes.citation.com/st/ca/st/b200v10/index.htm?bu=CA-P-2010-000008>

SMOKE ALARMS: See San Francisco Building Code Section 907.2.11.2, 907.2.11.4, and 3401.6.1

<http://publicecodes.citation.com/st/ca/st/b200v10/index.htm?bu=CA-P-2010-000008>

[http://www.amlegal.com/nxt/gateway.dll/California/sfbuilding/buildingcode2010edition/chapter34existingstructures?f=templates\\$fn=document-frameset.htm\\$q=3401.6.1%20\\$x=server\\$3.0#LPHit1](http://www.amlegal.com/nxt/gateway.dll/California/sfbuilding/buildingcode2010edition/chapter34existingstructures?f=templates$fn=document-frameset.htm$q=3401.6.1%20$x=server$3.0#LPHit1)


**FOR HOTEL OR MOTEL REQUIREMENTS,
PLEASE CALL HOUSING INSPECTION SERVICES AT (415) 558-6220.**

SMOKE & CARBON MONOXIDE ALARMS

Example of Location for Smoke & CO Alarms

Legend

- ☐ Photoelectric smoke alarms shall be installed on ceiling or wall at each floor level including basement but not including crawl spaces and uninhabitable attics, in each bedroom and outside each sleeping area in the immediate vicinity of the bedrooms.
- ☒ Dual sensor (Photoelectric/Ionization) smoke alarms shall be used if located not less than 20 ft from kitchen, fireplace or wood-burning stove. Avoid locating dual sensor smoke alarms in the following locations:
 - a. Outside a bathroom
 - b. In a kitchen or within 20 ft of an entry to a kitchen.
 - c. In a room with a wood burning appliance or within 20 ft of an entry to a room containing a wood burning appliance.
 - d. In a garage or mechanical room/closet.
- ☐ Carbon Monoxide (CO) Alarms shall be installed outside of each separate dwelling unit sleeping area in the immediate vicinity of the bedroom(s) AND on every level of the dwelling unit including basements.



Special Considerations:

Hallways over 40 ft in length need a smoke alarms at each end. Smoke detectors are either to be ceiling or wall mounted. Wall mounted smoke alarms are not to be located lower than 12 inches below the ceiling. Smoke alarms are not to be mounted within 4 inches of a wall/ceiling corner.

FOR ILLUSTRATION ONLY. THIS DIAGRAM IS NOT PART OF THE SAN FRANCISCO BUILDING CODE.

As owner of the above-referenced property, I hereby certify that carbon monoxide/smoke alarm(s) have been installed in accordance with the manufacturer's instructions and in compliance with Sections 420.4, 907.2.11 and 3401.6.1 of the San Francisco Building Code. The carbon monoxide/smoke alarms have been tested and are operational.

Print Name: _____

Signature: _____

Date: _____

This certification must be returned to the Building Inspector prior to final sign-off of all building permits requiring compliance with Sections 420.4, 907.2.11 and 3401.6.1 of the San Francisco Building Code. This form may be mailed to Inspection Services at the address provided below.

Inspection Services Division
 1660 Mission Street – San Francisco CA 94103-2414
 Office (415) 558-6570 – FAX (415) 558-6261 – www.sfdbi.org