




DEPARTMENT OF BUILDING INSPECTION

City and County of San Francisco
1660 Mission Street, San Francisco, CA 94103

Building Code Interpretation Disabled Access 004

Knee Clearance

Subject: Knee clearance at employee break room sinks	Date: January 15, 2008 (revised from 11/5/07 based on CBC code change)
San Francisco Building Code Sections: 1122B.3, 1123B.1, 1115B.4.7.1 & 2	Code Year: 2007
Approved By: Isam Hasenin, P.E., C.B.O., Director	Signature: 
Question: Is knee clearance required to be provided for wheelchair access for forward approach to employee break room sinks and similar fixtures in commercial spaces?	

Answer: Knee clearance for forward approach to break room sinks is required.
This Code Application and Interpretation is subject to change at any time. To determine if this interpretation is still current, please call (415) 558-6205 or visit our website http://www.sfgov.org/site/dbi