

---

---

---

जलीय तरल पदार्थों को प्रतिधारित करने के  
लिए कंक्रीट संरचनाएँ — रीति संहिता

भाग 4 डिजाइन तालिकाएँ

अनुभाग 2 आयताकार टैंक

( पहला पुनरीक्षण )

**Concrete Structures for Retaining  
Aqueous Liquids — Code of Practice**

Part 4 Design Tables

Section 2 Rectangular tanks

( First Revision )

ICS 23.020.01; 91.080.40

© BIS 2021



भारतीय मानक ब्यूरो  
BUREAU OF INDIAN STANDARDS  
मानक भवन, 9 बहादुरशाह जफर मार्ग, नई दिल्ली – 110002  
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG  
NEW DELHI-110002  
[www.bis.gov.in](http://www.bis.gov.in) [www.standardsbis.in](http://www.standardsbis.in)

Cement and Concrete Sectional Committee, CED 02

## FOREWORD

This Indian Standard (Part 4/Sec 2) (First Revision) was adopted by the Bureau of Indian Standards, after the draft finalized by the Cement and Concrete Sectional Committee had been approved by the Civil Engineering Division Council.

The design and construction methods in reinforced concrete and prestressed concrete structures for retaining aqueous liquids are influenced by the prevailing construction practices, the physical properties of the materials and the climatic condition. To lay down uniform requirements of structures for the retaining liquids giving due consideration to the above mentioned factors, this standard has been published in four parts. The other parts in the series are:

- Part 1 General requirements
- Part 2 Plain and reinforced concrete
- Part 3 Prestressed concrete

This standard was first published in 1967. The present revision has been brought out with a view to keeping abreast with the rapid development in the field of structural analysis and the results available from finite element analyses of rectangular plates and tanks, and circular tanks (without prestressing), and also to bring further modifications in the light of experience gained while applying the earlier version of this standard. In this revision, the title of the standard has been modified from ‘Concrete structures for storage of liquids — Code of practice: Part 4 Design tables’ to ‘Concrete structures for retaining aqueous liquids — Code of practice: Part 4 Design tables’ for better representation of the contents of the revised standard. Furthermore, this standard (Part 4) has been trifurcated into 3 sections for giving due emphasis to each topic covered and convenience of use and handling:

- Sec 1 Plates
- Sec 2 Rectangular tanks
- Sec 3 Circular tanks

This standard (Part 4/Sec 2) deals with design tables for rectangular tanks. The object of the design tables covered in this part is mainly to present data for ready reference of designers and as an aid to speedy design calculations. The designer has the option to adopt any established method of analysis, such as classical elastic plate analysis, finite element analysis, or use of design tables given in this standard as long as the design complies with the requirements of IS 3370 (Parts 1 to 3), and the structural adequacy and safety shall be ensured.

Tables relating to design of rectangular as well as cylindrical tanks have been given and by proper combination of various tables it may be possible to design different types of tanks involving many sets of conditions for rectangular and cylindrical containers built in or on ground.

Some of the data given in the tables for design of rectangular tanks may be used for design of some of the earth retaining structures subjected to earth pressure for which hydrostatic type of loading may be suitably substituted by earth pressure in the design calculations. The circular tanks having radius of curvature greater than 12 times the panel width, in plan and wall panels stiffened by counterforts may be analysed as rectangular panels neglecting the shell action due to curvature. However, such panels should have horizontal tension compatibility which is to be calculated with reactions of panels at the junction.

In this standard it has been assumed that the design of liquid retaining structures, whether of plain, reinforced or prestressed concrete is entrusted to a qualified engineer and that the execution of the work is carried out under the direction of a qualified and experienced engineer.

The requirements of IS 456 : 2000 ‘Plain and reinforced concrete — Code of practice (*fourth revision*)’ and IS 1343 : 2012 ‘Prestressed concrete — Code of practice (*second revision*)’, in so far as they apply, shall be deemed to form part of this standard except where otherwise laid down in this standard.

Following are the significant modifications incorporated in this revision:

- a) Title of the standard has been modified from ‘Concrete structures for storage of liquids — Code of practice: Part 4 Design tables’ to ‘Concrete structures for retaining aqueous liquids — Code of practice: Part 4 Design tables, Section 2 Rectangular tanks’.

(Continued on third cover)

## CONTENTS

	<i>Page No.</i>
1 SCOPE	1
2 REFERENCES	1
3 SINGLE-CELL RECTANGULAR TANKS	1
3.1 Rectangular Tank Analysis Results	1
3.2 General Assumptions in Design	2
4 MULTI-CELL RECTANGULAR TANKS	2
4.1 Multi-cell Tanks	2

## LIST OF FIGURES

FIG. 1 COORDINATE SYSTEM FOR RECTANGULAR TANKS	2
FIG. 2 WALL INTERSECTIONS IN MULTI-CELL TANKS	5

## LIST OF TABLES

TABLE 1 LOADING CONFIGURATIONS AND END-RESTRAINT CONDITIONS FOR RECTANGULAR TANKS ...	3
TABLE 2 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 1 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	6
TABLE 3 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 1 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	6
TABLE 4 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-SPAN ( $x = b/2$ ) FOR TANKS HAVING CASE 1 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	7
TABLE 5 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-SPAN ( $z = c/2$ ) FOR TANKS HAVING CASE 1 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	7
TABLE 6 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	8
TABLE 7 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	9
TABLE 8 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	10

TABLE 9 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 11
TABLE 10 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 12
TABLE 11 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 13
TABLE 12 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 14
TABLE 13 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 15
TABLE 14 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 16
TABLE 15 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 17
TABLE 16 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 18
TABLE 17 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 19
TABLE 18 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 20
TABLE 19 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 21
TABLE 20 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 22
TABLE 21 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 23
TABLE 22 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 24
TABLE 23 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 25
TABLE 24 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 26
TABLE 25 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 27
TABLE 26 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 28
TABLE 27 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 29

TABLE 28 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 30
TABLE 29 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 31
TABLE 30 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 32
TABLE 31 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 33
TABLE 32 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 34
TABLE 33 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 35
TABLE 34 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 36
TABLE 35 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 1 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 37
TABLE 36 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 2 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 38
TABLE 37 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 2 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 38
TABLE 38 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-SPAN ( $x = b/2$ ) FOR TANKS HAVING CASE 2 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 39
TABLE 39 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-SPAN ( $z = c/2$ ) FOR TANKS HAVING CASE 2 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 39
TABLE 40 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 40
TABLE 41 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 41
TABLE 42 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 42
TABLE 43 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 43
TABLE 44 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 44

TABLE 45 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 45
TABLE 46 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 46
TABLE 47 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 47
TABLE 48 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 48
TABLE 49 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 49
TABLE 50 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 50
TABLE 51 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 51
TABLE 52 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 52
TABLE 53 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 53
TABLE 54 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 54
TABLE 55 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 55
TABLE 56 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 56
TABLE 57 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 57
TABLE 58 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 58
TABLE 59 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 59
TABLE 60 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 60
TABLE 61 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 61
TABLE 62 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 62
TABLE 63 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 63

TABLE 64 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 64
TABLE 65 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 65
TABLE 66 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 66
TABLE 67 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 67
TABLE 68 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 68
TABLE 69 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 2 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 69
TABLE 70 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 3 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 70
TABLE 71 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 3 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 70
TABLE 72 DEFLECTION COEFFICIENTS ALONG LONG side, MID-SPAN ( $x = b/2$ ) FOR TANKS HAVING CASE 3 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 71
TABLE 73 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-SPAN ( $z = c/2$ ) FOR TANKS HAVING CASE 3 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 71
TABLE 74 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 72
TABLE 75 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 73
TABLE 76 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 74
TABLE 77 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 75
TABLE 78 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 76
TABLE 79 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 77
TABLE 80 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 78

TABLE 81 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 79
TABLE 82 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 80
TABLE 83 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 81
TABLE 84 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 82
TABLE 85 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 83
TABLE 86 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 84
TABLE 87 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 85
TABLE 88 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 86
TABLE 89 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 87
TABLE 90 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 88
TABLE 91 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 89
TABLE 92 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 90
TABLE 93 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 91
TABLE 94 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 92
TABLE 95 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 93
TABLE 96 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 94
TABLE 97 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 95
TABLE 98 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 96
TABLE 99 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 97

TABLE 100 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 98
TABLE 101 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 99
TABLE 102 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 100
TABLE 103 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 3 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 101
TABLE 104 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 4 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 102
TABLE 105 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 4 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 102
TABLE 106 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-SPAN ( $x = b/2$ ) FOR TANKS HAVING CASE 4 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 103
TABLE 107 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-SPAN ( $z = c/2$ ) FOR TANKS HAVING CASE 4 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 103
TABLE 108 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 104
TABLE 109 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 105
TABLE 110 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 106
TABLE 111 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 107
TABLE 112 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 108
TABLE 113 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 109
TABLE 114 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 110
TABLE 115 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 111
TABLE 116 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 112

TABLE 117 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 113
TABLE 118 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 114
TABLE 119 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 115
TABLE 120 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 116
TABLE 121 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 117
TABLE 122 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 118
TABLE 123 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 119
TABLE 124 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 120
TABLE 125 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 121
TABLE 126 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 122
TABLE 127 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 123
TABLE 128 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 124
TABLE 129 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 125
TABLE 130 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 126
TABLE 131 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 127
TABLE 132 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 128
TABLE 133 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 129
TABLE 134 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 130
TABLE 135 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 131

TABLE 136 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 132
TABLE 137 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 4 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 133
TABLE 138 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 5 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 134
TABLE 139 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 5 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 134
TABLE 140 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-SPAN ( $x = b/2$ ) FOR TANKS HAVING CASE 5 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 135
TABLE 141 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-SPAN ( $z = c/2$ ) FOR TANKS HAVING CASE 5 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 135
TABLE 142 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 136
TABLE 143 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 137
TABLE 144 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 138
TABLE 145 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 139
TABLE 146 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 140
TABLE 147 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 141
TABLE 148 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 142
TABLE 149 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 143
TABLE 150 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 144
TABLE 151 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 145
TABLE 152 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 146

TABLE 153 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 147
TABLE 154 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 148
TABLE 155 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 149
TABLE 156 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 150
TABLE 157 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 151
TABLE 158 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 152
TABLE 159 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 153
TABLE 160 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 154
TABLE 161 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 155
TABLE 162 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 156
TABLE 163 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 157
TABLE 164 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 158
TABLE 165 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 159
TABLE 166 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 160
TABLE 167 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 161
TABLE 168 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 162
TABLE 169 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 163
TABLE 170 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 164
TABLE 171 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 5 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 165

TABLE 172 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 6 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 166
TABLE 173 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 6 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 166
TABLE 174 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-SPAN ( $x = b/2$ ) FOR TANKS HAVING CASE 6 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 167
TABLE 175 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-SPAN ( $z = c/2$ ) FOR TANKS HAVING CASE 6 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 167
TABLE 176 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 168
TABLE 177 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 169
TABLE 178 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 170
TABLE 179 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 171
TABLE 180 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 172
TABLE 181 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 173
TABLE 182 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 174
TABLE 183 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 175
TABLE 184 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 176
TABLE 185 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 177
TABLE 186 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 178
TABLE 187 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 179
TABLE 188 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 180

TABLE 189 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 181
TABLE 190 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 182
TABLE 191 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 183
TABLE 192 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 184
TABLE 193 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 185
TABLE 194 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 186
TABLE 195 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 187
TABLE 196 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 188
TABLE 197 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 189
TABLE 198 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 190
TABLE 199 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 191
TABLE 200 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 192
TABLE 201 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 193
TABLE 202 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 194
TABLE 203 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 195
TABLE 204 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 196
TABLE 205 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 6 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 197
TABLE 206 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 7 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 198

TABLE 207 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 7 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 198
TABLE 208 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-SPAN ( $x = b/2$ ) FOR TANKS HAVING CASE 7 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 199
TABLE 209 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-SPAN ( $z = c/2$ ) FOR TANKS HAVING CASE 7 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 199
TABLE 210 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 200
TABLE 211 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 201
TABLE 212 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 202
TABLE 213 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 203
TABLE 214 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 204
TABLE 215 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 205
TABLE 216 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 206
TABLE 217 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 207
TABLE 218 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 208
TABLE 219 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 209
TABLE 220 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 210
TABLE 221 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 211
TABLE 222 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS 8 HAVING CASE 7 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 212
TABLE 223 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 213
TABLE 224 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 214

**IS 3370 (Part 4/Sec 2) : 2021**

*Page No.*

TABLE 225 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 215
TABLE 226 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 216
TABLE 227 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 217
TABLE 228 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 218
TABLE 229 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 219
TABLE 230 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 220
TABLE 231 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 221
TABLE 232 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 222
TABLE 233 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 223
TABLE 234 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 224
TABLE 235 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 225
TABLE 236 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 226
TABLE 237 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 227
TABLE 238 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 228
TABLE 239 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 7 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 229
TABLE 240 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 8 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 230
TABLE 241 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-HEIGHT ( $y = a/2$ ) FOR TANKS HAVING CASE 8 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 230
TABLE 242 DEFLECTION COEFFICIENTS ALONG LONG SIDE, MID-SPAN ( $x = b/2$ ) FOR TANKS HAVING CASE 8 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 231

TABLE 243 DEFLECTION COEFFICIENTS ALONG SHORT SIDE, MID-SPAN ( $z = c/2$ ) FOR TANKS HAVING CASE 8 ARRANGEMENTS FOR VARIOUS LENGTH/HEIGHT AND WIDTH/HEIGHT RATIOS	... 231
TABLE 244 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 232
TABLE 245 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 3.0$	... 233
TABLE 246 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 234
TABLE 247 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 2.0$	... 235
TABLE 248 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 236
TABLE 249 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.5$	... 237
TABLE 250 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 238
TABLE 251 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 1.0$	... 239
TABLE 252 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 240
TABLE 253 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 4.0, c/a = 0.5$	... 241
TABLE 254 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 242
TABLE 255 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 3.0, c/a = 2.0$	... 243
TABLE 256 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 244
TABLE 257 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.5$	... 245
TABLE 258 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 246
TABLE 259 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 3.0, c/a = 1.0$	... 247
TABLE 260 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 248

**IS 3370 (Part 4/Sec 2) : 2021**

TABLE 261 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 3.0, c/a = 0.5$	... 249
TABLE 262 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 250
TABLE 263 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.5$	... 251
TABLE 264 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 252
TABLE 265 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 2.0, c/a = 1.0$	... 253
TABLE 266 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 254
TABLE 267 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 2.0, c/a = 0.5$	... 255
TABLE 268 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 256
TABLE 269 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 1.5, c/a = 1.0$	... 257
TABLE 270 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 258
TABLE 271 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 1.5, c/a = 0.5$	... 259
TABLE 272 MOMENT COEFFICIENTS ALONG LONG SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 260
TABLE 273 MOMENT COEFFICIENTS ALONG SHORT SIDE FOR RECTANGULAR TANKS HAVING CASE 8 ARRANGEMENTS FOR $b/a = 1.0, c/a = 0.5$	... 261
ANNEX A	... 262

## Indian Standard

# CONCRETE STRUCTURES FOR RETAINING AQUEOUS LIQUIDS — CODE OF PRACTICE

## PART 4 DESIGN TABLES

### Section 2 Rectangular tanks

(First Revision)

#### 1 SCOPE

This standard (Part 4/Sec 2) gives design tables of deflection and moment coefficients for rectangular tanks for use as an aid in the design of rectangular reinforced concrete structures for retaining liquids.

#### 2 REFERENCES

The following standards contain provision, which through reference in this text constitute provisions of this standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this standard are encouraged to investigate the possibility of applying the most recent edition of the standards indicated below:

IS No.	Title
456 : 2000	Plain and reinforced concrete — Code of practice ( <i>fourth revision</i> )
3370 (Part 4/Sec 1) : 2020	Concrete structures for retaining aqueous liquids — Code of practice: Part 4 Design tables, Section 1 Plates ( <i>first revision</i> )

#### 3 SINGLE-CELL RECTANGULAR TANKS

##### 3.1 Rectangular Tank Analysis Results

The design coefficients for deflection ( $\delta_c$ ) and moments ( $M_{xc}$ ,  $M_{yc}$ ,  $M_{zc}$ ,  $M_{xyc}$ ) for rectangular tanks with different loading configurations and end-restraint conditions (see 3.1.3) obtained from finite element analyses of tanks have been tabulated in Table 2 to 273.

###### 3.1.1 Shear

The shear coefficient ( $C_s$ ) given in IS 3370 (Part 4/Sec 1) for design of plates having fixed side edges may be used for design of rectangular tanks.

###### 3.1.2 Deflection

Deflection,  $\delta$ , in mm, is given by the following equation:

$$\delta = 12 \delta_c q a^4 (1 - \mu^2) / (1000 E_c t^3)$$

where

- $\delta_c$  = deflection coefficient (see col 3 of Table 1);  
 $q$  = kwa, pressure at bottom of plate for triangular load distribution, MPa  
= kw, pressure uniformly applied along height of plate, MPa;  
 $k$  = coefficient for active or passive earth pressure, whichever is applicable = 1, for liquids;  
 $w$  = unit weight of liquid (or soil), N/mm<sup>3</sup>;  
 $a$  = height of loaded portion of plate, mm;  
 $\mu$  = Poisson's ratio of concrete (may be taken as 0.15, in absence of test results);  
 $E_c$  = Modulus of elasticity of concrete, MPa (see IS 456); and  
 $t$  = thickness of wall, mm.

###### 3.1.3 Moment

Moment per unit width, in N-m/m is given by the following equations:

$$\begin{aligned} M_x &= M_{xc} q a^2 / 1000 \\ M_y &= M_{yc} q a^2 / 1000 \\ M_z &= M_{zc} q a^2 / 1000 \\ M_{xy} &= M_{xyc} q a^2 / 1000 \\ M_{yz} &= M_{yzc} q a^2 / 1000 \end{aligned}$$

where,

$M_x$  = moment per unit width about the x-axis stretching the fibres in the y-direction when the plate is in the x-y plane. The moment is used to determine steel in the y-direction of the plate (see Fig.1);

$M_y$  = moment per unit width about the y-axis stretching the fibres in the x-direction when the plate is in the x-y plane, or in the z-direction when the plate is in the y-z plane. The moment is used to determine steel in the x or z direction of the plate (see Fig.1);

$M_z$  = moment per unit width about the z-axis stretching the fibres in the y-direction when the

## IS 3370 (Part 4/Sec 2) : 2021

plate is in the y-z plane. The moment is used to determine steel in the y direction of the plate (see Fig.1);

$M_{xy}$  = torsion moment per unit width for the plate in the x-y plane (see Fig.1);

$M_{yz}$  = torsion moment per unit width for the plate in the y-z plane (see Fig.1);

$M_{zc}$  = moment coefficient for computation of  $M_x$  (see col 4 of Table 1);

$M_{yc}$  = moment coefficient for computation of  $M_y$  (see col 4 of Table 1);

$M_{zc}$  = moment coefficient for computation of  $M_z$  (see col 4 of Table 1);

$M_{xyc}$  = moment coefficient for computation of  $M_{xy}$  (see col 4 of Table 1). These are given in absolute values in the respective tables; and

$M_{yxc}$  = moment coefficient for computation of  $M_{yz}$  (see col 4 of Table 1). These are given in absolute values in the respective tables.

### 3.1.4 Loading Configurations and End-restraint Conditions

The various loading configurations and end-restraint conditions of rectangular tanks for which deflection ( $\delta_c$ ) and moment ( $M_{xc}$ ,  $M_{yc}$ ,  $M_{zc}$ ,  $M_{xyc}$  and  $M_{yxc}$ ) coefficients have been tabulated in Tables 2 to 273 are given in Table 1.

### 3.2 General Assumptions in Design

The moment coefficients given in IS 3370 (Part 4/Sec 1) for design of plates may be used for tanks that have square plan dimensions.

For rectangular tanks, the plate analysis results are, however, not applicable as they do not account for moment distribution that occurs between the walls of different stiffnesses. Adjustments must be made similar to the modification of fixed-end moments in a frame analyzed by moment distribution. However, it must be noted that moment distribution method may not be applied as easily to continuous tank walls as it can to framed structures due to two-way action of each plate. Bending moments must be distributed simultaneously along the entire length of the side edge so that moments become equal at both sides at any point of the edge. Moreover, tanks will develop in-plane axial compression or tension. Effects of the tension force, if significant, should be recognized. If significant compression forces are developed, the reduction in the effective stiffness of the member may also need to be considered.

## 4 MULTI-CELL RECTANGULAR TANKS

### 4.1 Multi-cell Tanks

**4.1.1** Rectangular tanks may have interior walls making it a multi-cell unit, in which moment at the junctions of wall may be determined using the approach given below.

Moments in the walls of a multi-cell tank are almost same as in single-cell tanks, except at corners where more than two walls intersect because each wall plate has two-way action due to which carry-over effect of moment adjustment at one edge has a very small effect on opposite edge, which may be neglected.




FIG. 1 COORDINATE SYSTEM FOR RECTANGULAR TANKS

**Table 1 Loading Configurations and End-restaint Conditions for Rectangular Tanks**  
*(Foreword, Clauses 3.1.2, 3.1.3 and 3.1.4)*

Case	Figure (see Note 1)	Tables of, Ref to	
		Deflection Coefficients, $\delta_c$	Moment Coefficients, $M_{xc}, M_{yc}, M_{zc}, M_{xyc}$ and $M_{yzc}$
(1) Case 1	(2)	(3)	(4)
		Tables 2 to 5	Tables 6 to 35
	a) Hinged top, hinged base, subjected to triangular loading		
Case 2		Tables 36 to 39	Tables 40 to 69
	b) Free top, hinged base subjected to triangular loading		
Case 3		Tables 70 to 73	Tables 74 to 103
	c) Free top, fixed base, subjected to triangular loading		
Case 4		Tables 104 to 107	Tables 108 to 137
	d) Hinged top, fixed base, subjected to triangular loading		

IS 3370 (Part 4/Sec 2) : 2021

**Table 1 ( Concluded )**

Case	Figure (see Note 1)	Tables of, Ref to	
		Deflection Coefficients, $\delta_c$	Moment Coefficients, $M_{xc}, M_{yc}, M_{zc}, M_{xyc}$ and $M_{ycz}$
(1)	(2)	(3)	(4)
Case 5		Tables 138 to 141	Tables 142 to 171
	e) Hinged top, hinged base, subjected to uniformly distributed loading		
Case 6		Tables 172 to 175	Tables 176 to 205
	f) Free top, hinged base, subjected to uniformly distributed loading		
Case 7		Tables 206 to 209	Tables 210 to 239
	g) Free top, fixed base, subjected to uniformly distributed loading		
Case 8		Tables 240 to 243	Tables 244 to 273
	h) Hinged top, fixed base, subjected to uniformly distributed loading		

NOTE —  $b$  is span of longer wall and  $c$  is the span of shorter wall in plan.

Design moment coefficients for the rectangular tanks given in 3 apply to L-shaped corners (where two walls meet) of multi-cell tanks (see Fig. 2A) as well as to interior sections in all walls and are known as  $M_{Lc}$  coefficients.

Where more than two walls are meeting, the junctions may be treated as given in 4.1.2 and 4.1.3.

#### 4.1.2 Analysis of T-shaped Walls (Junction of Three Walls)

Fig. 2B shows a typical T-shaped wall.

If the continuous wall, or top of the T, is part of the long sides of two adjacent rectangular cells, the moment in the continuous wall at the intersection is maximum when both cells are filled. The intersection is then fixed and moment coefficients, designated as  $M_{Fc}$  coefficients, may be taken from IS 3370 (Part 4/Sec 1), depending on edge conditions at top and bottom.

If the continuous wall is part of the short sides of two adjacent rectangular cells, moment at one side of the intersection is maximum, when the cell on that side is filled while the other cell is empty, and the end moment in the centre wall is maximum when only one cell is filled. For this loading condition, the

magnitude of moment,  $M$  lies between the  $M_{Lc}$  and the  $M_{Fc}$  coefficients and the same may be obtained from the following equation:

$$M = M_{Lc} - \left[ \frac{n}{n+2} (M_{Lc} - M_{Fc}) \right]$$


where,  $n$  = number of adjacent unloaded walls.

#### 4.1.3 Analysis of Cross-shaped Walls (Junction of Four Walls)

Fig. 2C shows a typical cross-shaped wall.

If intersecting walls are the walls of square cells, moments at the intersection are maximum when any two cells are full, and the  $M_{Fc}$  coefficients from IS 3370 (Part 4/Sec 1) apply because there is no rotation of the joint.

If the cells are rectangular, moments in the longer of the intersecting walls will be maximum when two cells on the same side of the wall under consideration are filled, again the  $M_{Fc}$  coefficients apply. Maximum moments in the shorter wall adjacent to the intersection occur when diagonally opposite cells are filled, and for this condition the  $M_{Lc}$  coefficients apply.



2A L-SHAPED CORNER

2B T-SHAPED JUNCTION

2C CROSS-SHAPED JUNCTION

FIG. 2 WALL INTERSECTIONS IN MULTI-CELL TANKS

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 2 Deflection Coefficients along Long Side, Mid-height ( $y = a/2$ ) for Tanks having Case 1 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	x	END	0.1b	0.2b	0.3b	0.4b	0.5b
				0.9b	0.8b	0.7b	0.6b	
4.0	3.0	0	0	2.30	4.70	5.80	6.20	6.30
4.0	2.0	0	0	2.30	4.70	5.80	6.20	6.30
4.0	1.5	0	0	2.40	4.70	5.80	6.20	6.30
4.0	1.0	0	0	2.60	4.80	5.80	6.30	6.30
4.0	0.5	0	0	2.80	4.90	5.90	6.30	6.40
3.0	2.0	0	0	1.60	3.60	5.00	5.60	5.80
3.0	1.5	0	0	1.70	3.70	5.00	5.70	5.90
3.0	1.0	0	0	1.80	3.80	5.10	5.70	5.90
3.0	0.5	0	0	2.10	4.00	5.20	5.80	6.00
2.0	1.5	0	0	0.90	2.20	3.30	4.00	4.30
2.0	1.0	0	0	1.00	2.40	3.50	4.20	4.40
2.0	0.5	0	0	1.20	2.80	3.70	4.40	4.60
1.5	1.0	0	0	0.60	1.40	2.20	2.70	2.90
1.5	0.5	0	0	0.80	1.70	2.50	3.00	3.10
1.0	0.5	0	0	0.30	0.70	1.00	1.20	1.30

**Table 3 Deflection Coefficients along Short Side, Mid-height ( $y = a/2$ ) for Tanks Having Case 1 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	z	END	0.1c	0.2c	0.3c	0.4c	0.5c
				0.9c	0.8c	0.7c	0.6c	
4.0	3.0	0	0	1.60	3.60	5.00	5.60	5.80
4.0	2.0	0	0	0.80	2.10	3.30	3.30	4.20
4.0	1.5	0	0	0.30	1.10	1.90	1.90	2.60
4.0	1.0	0	0	0.00	0.10	0.40	0.40	0.60
4.0	0.5	0	0	-0.20	-0.30	-0.40	-0.40	-0.40
3.0	2.0	0	0	0.80	2.10	3.30	3.30	4.20
3.0	1.5	0	0	0.30	1.10	1.90	1.90	2.60
3.0	1.0	0	0	0.00	0.10	0.40	0.40	0.60
3.0	0.5	0	0	-0.20	-0.30	-0.40	-0.40	-0.40
2.0	1.5	0	0	0.40	1.20	1.90	1.90	2.60
2.0	1.0	0	0	0.00	0.20	0.40	0.40	0.60
2.0	0.5	0	0	-0.20	-0.30	-0.30	-0.30	-0.40
1.5	1.0	0	0	0.00	0.20	0.50	0.50	0.70
1.5	0.5	0	0	-0.10	-0.20	-0.30	-0.30	-0.30
1.0	0.5	0	0	-0.10	-0.10	-0.20	-0.20	-0.20

**Table 4 Deflection Coefficients along Long Side, Mid-span ( $x = b/2$ ) for Tanks having Case 1 Arrangements for Various Length/Height and Width/Height Ratios**  
*(Table 1, Clauses 3.1 and 3.1.4)*

b/a	y	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
c/a		0	2.10	4.00	5.30	6.10	6.30	5.90	5.00	3.60	1.90	0
4.0	2.0	0	2.10	4.00	5.30	6.10	6.30	5.90	5.00	3.60	1.90	0
4.0	1.5	0	2.10	4.00	5.30	6.10	6.30	5.90	5.00	3.60	1.90	0
4.0	1.0	0	2.10	4.00	5.40	6.20	6.30	5.90	5.00	3.60	1.90	0
4.0	0.5	0	2.10	4.00	5.40	6.20	6.40	5.90	5.00	3.60	1.90	0
3.0	2.0	0	2.00	3.70	4.90	5.70	5.80	5.50	4.60	3.30	1.70	0
3.0	1.5	0	2.00	3.70	5.00	5.70	5.90	5.50	4.60	3.30	1.70	0
3.0	1.0	0	2.00	3.70	5.00	5.70	5.90	5.50	4.60	3.30	1.70	0
3.0	0.5	0	2.00	3.70	5.00	5.80	6.00	5.60	4.70	3.30	1.70	0
2.0	1.5	0	1.50	2.70	3.70	4.20	4.30	4.00	3.30	2.40	1.20	0
2.0	1.0	0	1.50	2.80	3.80	4.30	4.40	4.10	3.40	2.40	1.30	0
2.0	0.5	0	1.60	2.90	3.90	4.50	4.60	4.20	3.50	2.50	1.30	0
1.5	1.0	0	1.00	1.90	2.50	2.80	2.90	2.60	2.20	1.50	0.80	0
1.5	0.5	0	1.10	2.10	2.70	3.10	3.10	2.90	2.40	1.70	0.90	0
1.0	0.5	0	0.50	0.90	1.20	1.30	1.30	1.20	1.00	0.70	0.30	0

**Table 5 Deflection Coefficients along Short Side, Mid-span ( $z = c/2$ ) for Tanks having Case 1 Arrangements for Various Length/Height and Width/Height Ratios**

*(Table 1, Clauses 3.1 and 3.1.4)*

b/a	y	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
c/a		0	2.00	3.70	4.90	5.70	5.80	5.50	4.60	3.30	1.70	0
4.0	2.0	0	1.50	2.70	3.60	4.10	4.20	3.90	3.20	2.30	1.20	0
4.0	1.5	0	0.9	1.70	2.30	2.50	2.60	2.30	1.90	1.40	0.70	0
4.0	1.0	0	0.30	0.50	0.60	0.60	0.60	0.50	0.40	0.30	0.10	0
4.0	0.5	0	-0.10	-0.20	-0.30	-0.40	-0.40	-0.40	-0.30	-0.20	-0.10	0
3.0	2.0	0	1.50	2.70	3.60	4.10	4.20	3.9	3.20	2.30	1.20	0
3.0	1.5	0	0.90	1.70	2.30	2.50	2.60	2.30	1.90	1.40	0.70	0
3.0	1.0	0	0.30	0.50	0.60	0.60	0.60	0.50	0.40	0.30	0.10	0
3.0	0.5	0	-0.10	-0.20	-0.30	-0.40	-0.40	-0.40	-0.30	-0.20	-0.10	0
2.0	1.5	0	0.90	1.70	2.30	2.60	2.60	2.40	1.90	1.40	0.70	0
2.0	1.0	0	0.30	0.50	0.70	0.70	0.60	0.50	0.40	0.30	0.10	0
2.0	0.5	0	-0.10	-0.20	-0.30	-0.40	-0.40	-0.40	-0.30	-0.20	-0.10	0
1.5	1.0	0	0.30	0.60	0.70	0.80	0.70	0.60	0.50	0.30	0.20	0
1.5	0.5	0	-0.10	-0.20	-0.20	-0.30	-0.30	-0.30	-0.30	-0.20	-0.10	0
1.0	0.5	0	0.00	-0.10	-0.10	-0.10	-0.20	-0.20	-0.10	-0.10	-0.10	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 6 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0$ ,  $c/a = 3.0$**   
 ( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner		0.1b		0.2b		0.3b		0.4b		0.5b	
			0.9b		0.8b		0.7b		0.6b			
	$M_{xc}$	$M_{yc}$										
TOP	0	1	0	0	17	0	10	0	4	0	1	0
0.9a	-3	1	-16	5	17	2	11	10	5	15	4	4
0.8a	-6	1	-32	10	14	4	22	8	9	28	4	8
0.7a	-9	1	-45	15	11	6	32	6	12	40	3	11
0.6a	-11	1	-56	19	7	8	40	3	15	50	1	14
0.5a	-12	0	-62	22	1	9	46	0	17	56	0	15
0.4a	-13	0	-64	24	4	10	48	3	17	58	1	15
0.3a	-12	1	-59	25	10	10	46	6	15	54	2	14
0.2a	-10	1	-48	22	15	8	38	8	12	44	3	11
0.1a	-6	2	-28	15	18	5	23	10	7	27	4	7
BOT.	0	2	0	0	20	0	0	10	0	0	4	0

**Table 7 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0, c/a = 3.0$**   
 ( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	Moment Coefficients
TOP	0	1	0	0	17	0	0	14	0	0	M <sub>xc</sub>
0.9a	-3	1	-16	3	17	0	9	14	4	12	M <sub>yc</sub>
0.8a	-6	1	-32	6	15	0	17	12	8	24	M <sub>xc</sub>
0.7a	-9	1	-45	9	12	0	25	9	11	35	M <sub>yc</sub>
0.6a	-11	1	-56	11	7	0	31	5	14	43	M <sub>xc</sub>
0.5a	-12	0	-62	14	2	1	36	1	16	49	M <sub>yc</sub>
0.4a	-13	0	-64	16	4	2	38	4	16	51	M <sub>xc</sub>
0.3a	-12	1	-59	17	10	3	37	8	15	48	M <sub>yc</sub>
0.2a	-10	1	-48	15	15	4	32	12	12	40	M <sub>xc</sub>
0.1a	-6	2	-28	11	20	3	20	14	7	24	M <sub>yc</sub>
BOT.	0	2	0	0	21	0	0	15	0	0	M <sub>xc</sub>
											M <sub>yc</sub>

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 8 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0$ ,  $c/a = 2.0$**   
 ( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner		0.1b		0.2b		0.3b		0.4b		0.5b	
			0.9b		0.8b		0.7b		0.6b			
	$M_{xc}$	$M_{yc}$										
TOP	0	2	0	0	17	0	10	0	4	0	1	0
0.9a	-3	2	-16	5	16	2	12	10	5	15	4	16
0.8a	-6	2	-31	10	15	4	22	8	9	28	3	31
0.7a	-9	1	-44	15	11	6	32	6	12	40	3	11
0.6a	-11	1	-54	19	7	8	40	3	15	50	1	14
0.5a	-12	0	-61	23	1	9	46	0	17	56	0	15
0.4a	-12	0	-62	25	4	10	48	3	17	58	1	15
0.3a	-12	1	-58	25	10	10	46	6	15	54	2	14
0.2a	-9	2	-47	22	15	8	38	8	12	44	3	11
0.1a	-6	2	-28	15	18	5	23	10	7	27	4	7
BOT.	0	3	0	0	20	0	0	10	0	0	4	0
											1	0
											0	0
											0	0

**Table 9 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0, c/a = 2.0$**   
 ( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c		
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c	
	$\mathbf{M}_{xc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$									
TOP	0	2	0	0	14	0	0	15	0	0	11	0
0.9a	-3	2	-16	1	14	-3	5	15	2	8	11	5
0.8a	-6	2	-31	1	12	-7	9	13	5	15	10	9
0.7a	-9	1	-44	2	10	-9	13	10	7	22	7	13
0.6a	11	1	-54	3	6	-10	17	6	9	28	4	16
0.5a	-12	0	-61	4	2	-10	21	1	10	33	1	17
0.4a	-12	0	-62	6	3	-9	23	4	11	35	3	18
0.3a	-12	1	-58	7	8	-7	23	9	11	35	7	16
0.2a	-9	2	-47	7	13	-4	21	14	9	30	10	13
0.1a	-6	2	-28	6	17	-1	14	17	5	19	12	7
BOT.	0	3	0	0	19	0	0	18	0	0	13	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 10 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner		0.1b		0.2b		0.3b		0.4b		0.5b	
	$M_{xc}$	$M_{yc}$										
TOP	0	3	0	0	17	0	10	0	0	4	0	1
0.9a	-3	3	-15	5	16	2	12	9	5	15	4	4
0.8a	-6	3	-29	11	14	4	23	8	9	28	3	8
0.7a	-8	2	-41	15	11	6	33	6	12	14	3	11
0.6a	-10	1	-51	20	7	8	41	3	15	50	1	14
0.5a	-11	0	-57	23	1	10	46	0	17	56	0	15
0.4a	-12	1	-59	25	4	10	48	3	17	58	1	15
0.3a	-11	2	-55	26	10	10	46	6	15	55	2	14
0.2a	-9	3	-45	23	15	9	38	8	12	44	3	11
0.1a	-5	4	-27	15	18	5	23	10	7	27	4	7
BOT.	0	4	0	0	20	0	0	0	0	4	0	0

**Table 11 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0, c/a = 1.5$**   
 ( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
	$\mathbf{M}_x$	$\mathbf{M}_{yc}$	$\mathbf{M}_{xc}$	$\mathbf{M}_{yec}$	$\mathbf{M}_{xe}$	$\mathbf{M}_{ye}$	$\mathbf{M}_{xe}$	$\mathbf{M}_{ye}$	$\mathbf{M}_{xc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_x$
TOP	0	3	0	0	9	0	0	12	0	0	10
0.9a	-3	3	-15	-1	9	-5	2	12	1	4	10
0.8a	-6	3	-29	-1	8	-10	4	11	1	8	9
0.7a	-8	2	-41	-1	7	-13	6	9	2	12	7
0.6a	-10	1	-51	-1	5	-16	8	6	3	16	4
0.5a	-11	0	-57	-1	2	-17	10	2	4	19	1
0.4a	-12	1	-59	0	1	-16	12	2	5	22	2
0.3a	-11	2	-55	2	5	-13	14	7	6	23	6
0.2a	-9	3	-45	3	9	-9	13	11	5	21	9
0.1a	-5	4	-27	3	13	-4	10	15	4	14	11
BOT.	0	4	0	0	15	0	0	16	0	0	12

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 12 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0, c/a = 1.0$**

(*Table 1, Clauses 3.1 and 3.1.4*)

Moment Coefficients	Corner		0.1b		0.2b		0.3b		0.4b		0.5b	
	$M_{xc}$	$M_{yc}$										
TOP	0	7	0	0	17	0	9	0	0	4	0	0
0.9a	-2	6	-12	6	16	3	12	9	5	15	4	4
0.8a	-5	6	-23	12	14	5	23	8	9	29	3	8
0.7a	-7	4	-34	17	11	7	33	6	12	41	2	11
0.6a	-8	2	-42	22	7	9	42	3	15	51	1	14
0.5a	-10	0	-48	25	1	11	47	0	17	57	0	15
0.4a	-10	2	-50	27	4	12	49	3	17	59	1	15
0.3a	-9	4	-47	27	10	11	47	5	15	55	2	14
0.2a	-8	6	-39	24	15	9	39	8	12	45	3	11
0.1a	-5	7	-24	15	18	6	24	9	7	27	4	7
BOT.	0	8	0	0	19	0	0	10	0	0	4	0
											1	0
											0	0
											0	0

**Table 13 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.9c		0.8c		0.2c		0.3c		0.7c		0.6c		0.4c		0.5c		
		$M_{zc}$	$M_{yc}$																	
TOP	0	7	0	0	1	0	0	4	0	0	0	4	0	0	3	0	3	1	0	0
0.9a	-2	6	-12	-2	1	-6	-1	4	-2	0	4	1	0	3	3	0	0	0	0	3
0.8a	-5	6	-23	-3	1	-11	-1	4	-3	0	4	2	1	2	5	1	0	0	0	6
0.7a	-7	4	-34	-4	2	-16	-2	4	-4	1	3	4	2	2	8	3	0	0	0	9
0.6a	-8	2	-42	-5	2	-20	-1	3	-5	2	3	5	4	2	10	4	0	0	0	12
0.5a	-10	0	-48	-5	2	-22	0	2	-4	3	1	6	6	1	12	7	0	0	0	14
0.4a	-10	2	-50	-5	1	-21	1	0	-3	6	0	7	19	0	13	10	0	0	0	14
0.3a	-9	4	-47	-3	0	-19	3	2	-2	8	2	8	11	1	12	12	0	0	0	14
0.2a	-8	6	-39	-2	2	-14	4	5	0	9	5	7	12	3	10	13	0	0	0	11
0.1a	-5	7	-24	0	4	-7	4	7	1	7	7	4	9	4	6	10	0	0	0	7
BOT.	0	8	0	0	6	0	0	9	0	0	7	0	0	4	0	0	0	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 14 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner		0.1b		0.2b		0.3b		0.4b		0.5b	
	$M_{xc}$	$M_{yc}$										
TOP	0	11	0	0	16	0	9	0	0	0	1	0
0.9a	-2	11	-9	7	16	3	12	8	5	15	3	4
0.8a	-3	9	-17	13	14	6	24	7	9	29	3	8
0.7a	-5	7	-25	19	11	9	34	5	12	41	2	11
0.6a	-6	4	-31	24	6	11	43	3	15	51	1	13
0.5a	-7	1	-35	28	1	13	48	0	17	57	0	15
0.4a	-7	3	-37	30	4	13	50	3	17	59	1	15
0.3a	-7	6	-35	29	10	13	48	5	15	55	2	14
0.2a	-6	10	-30	25	14	10	39	7	12	45	3	11
0.1a	-4	12	-19	16	18	6	24	9	7	27	3	6
BOT	0	13	0	0	19	0	0	9	0	0	4	0
											1	0
											0	0
											0	0

**Table 15 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$	$M_{zec}$	$M_{yec}$	$M_{zc}$	$M_{yc}$	$M_{zec}$	$M_{yec}$	$M_{zc}$	$M_{yc}$
TOP	0	11	0	0	7	0	0	5	0	0	0
0.9a	-2	11	-99	-2	7	-9	-2	5	-5	-2	3
0.8a	-3	9	-17	-4	6	-17	-4	4	10	-4	2
0.7a	-5	7	-25	-5	4	-25	-5	3	-14	-5	2
0.6a	-6	4	-31	-6	2	-31	-6	1	-17	-6	1
0.5a	-7	1	-35	-7	0	-35	-7	0	-19	-7	0
0.4a	-7	3	-37	-7	3	-37	-7	2	-18	-6	1
0.3a	-7	6	-35	-5	5	-35	-5	3	-16	-5	2
0.2a	-6	10	-30	-3	6	-30	-3	4	-11	-2	2
0.1a	-4	12	-19	-1	6	-19	-1	3	-5	0	2
BOT.	0	13	0	0	6	0	0	3	0	1	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 16 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner		0.1b		0.2b		0.3b		0.4b		0.5b	
	0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b	0.8b	0.7b
TOP	0	2	0	0	17	0	0	14	0	0	8	0
0.9a	-3	1	-16	3	17	0	9	13	4	12	7	5
0.8a	-6	1	-31	6	15	0	17	11	8	24	6	9
0.7a	-9	1	-44	9	12	0	25	9	11	35	5	13
0.6a	-11	1	-54	12	7	1	31	5	14	43	3	15
0.5a	-12	0	-61	14	2	2	36	1	16	49	0	17
0.4a	-12	0	-62	16	4	3	38	4	16	51	2	17
0.3a	-12	1	-58	17	10	4	37	8	15	48	5	16
0.2a	-9	1	-47	16	15	4	32	12	12	401	6	12
0.1a	-6	2	-28	11	19	3	20	14	7	24	8	7
BOT.	0	2	0	0	21	0	0	15	0	0	8	0
											3	0
											0	0
											0	0

**Table 17 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	2	0	0	14	0	0	15	0	0	11
0.9a	-3	1	-16	1	14	-3	5	15	2	8	11
0.8a	-6	1	-31	1	12	-7	9	13	5	15	10
0.7a	-9	1	-44	2	10	-9	13	10	7	22	7
0.6a	-11	1	-54	3	69	-10	17	6	9	28	4
0.5a	-12	0	-61	4	2	-10	21	1	10	33	1
0.4a	-12	0	-62	6	3	-9	23	4	11	35	3
0.3a	-12	1	-58	7	8	-7	23	9	11	35	7
0.2a	-9	1	-47	7	13	-4	21	14	9	30	10
0.1a	-6	2	-28	6	17	-1	14	17	5	19	12
BOT	0	2	0	0	19	0	0	18	0	0	13

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 18 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner		0.1b		0.2b		0.3b		0.4b		0.5b	
	$M_{xc}$	$M_{yc}$										
TOP	0	3	0	0	17	0	0	14	0	0	8	0
0.9a	-3	3	-15	3	17	0	9	13	4	12	7	5
0.8a	-6	2	-29	7	15	0	17	11	8	24	6	9
0.7a	-8	2	-41	10	12	1	25	9	12	36	5	13
0.6a	-10	1	-51	12	7	2	32	5	14	43	3	15
0.5a	-11	0	-57	15	2	3	37	1	16	49	0	17
0.4a	-12	1	-59	17	4	4	39	4	16	51	2	17
0.3a	-11	2	-55	17	10	4	38	8	15	49	4	16
0.2a	-9	2	-45	16	15	4	32	11	12	40	6	12
0.1a	-5	3	-27	11	20	3	20	14	7	24	8	7
BOT.	0	4	0	0	21	0	0	15	0	0	8	0
											3	0
											0	0
											0	0

**Table 19 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c		
		<b>0.9c</b>	<b>0.8c</b>	<b>0.7c</b>	<b>0.6c</b>	<b>0.5c</b>	<b>0.4c</b>	<b>0.3c</b>	<b>0.2c</b>	<b>0.1c</b>	<b>0.9c</b>	<b>0.8c</b>	<b>0.7c</b>	<b>0.6c</b>	<b>0.5c</b>	
TOP	0	3	0	0	9	0	0	12	0	0	10	0	0	6	0	0
0.9a	-3	3	-15	-1	9	-5	2	12	1	4	10	4	5	5	6	0
0.8a	-6	3	-29	-1	8	-10	4	11	1	8	9	7	11	5	10	12
0.7a	-8	2	-41	-1	7	-13	6	9	2	12	7	10	16	4	14	17
0.6a	-10	1	-51	-1	5	-16	8	6	3	16	4	13	21	2	17	22
0.5a	-11	0	-57	-1	2	-17	10	2	4	19	1	15	25	1	19	27
0.4a	-12	1	-59	0	1	-16	12	2	5	22	2	15	28	1	19	29
0.3a	-11	2	-55	2	5	-13	14	7	6	23	6	14	28	3	18	30
0.2a	-9	3	-45	3	9	-9	13	11	5	21	9	12	25	5	14	26
0.1a	-5	4	-27	3	13	-4	10	15	4	14	11	7	16	6	8	17
BOT.	0	4	0	0	15	0	0	16	0	0	12	0	0	6	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 20 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner		0.1b		0.2b		0.3b		0.4b		0.5b	
	$M_{xc}$	$M_{yc}$										
TOP	0	7	0	0	17	0	0	13	0	0	7	0
0.9a	-2	6	-12	4	17	1	9	13	4	13	7	5
0.8a	-5	5	-23	8	15	2	18	11	8	25	6	9
0.7a	-7	4	-34	11	12	3	26	8	12	36	4	12
0.6a	-8	2	-42	15	7	4	33	5	15	44	2	15
0.5a	-10	0	-48	17	2	5	38	1	16	50	0	17
0.4a	-10	2	-50	19	4	6	40	4	17	52	2	17
0.3a	-9	4	-47	19	10	6	39	8	15	49	4	15
0.2a	-8	5	-39	17	16	6	33	11	12	40	6	12
0.1a	-5	7	-24	12	20	4	20	13	7	25	7	7
BOT.	0	7	0	0	21	0	0	14	0	0	8	0
											3	0
											0	0
											0	0

**Table 21 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		$M_{zc}$	$M_{yc}$	$M_{yc}$	$M_{zc}$	$M_{yc}$	$M_{yc}$	$M_{zc}$	$M_{yc}$	$M_{yc}$	$M_{zc}$	$M_{yc}$	$M_{zc}$	$M_{yc}$	$M_{zc}$	$M_{yc}$	
TOP	0	7	0	0	0	1	0	0	4	0	0	4	0	0	3	0	0
0.9a	-2	6	-12	-2	1	-6	-1	4	-2	0	4	1	0	3	3	1	0
0.8a	-5	5	-23	-3	1	-11	-1	4	-3	0	4	2	1	2	5	1	0
0.7a	-7	4	-34	-4	2	-16	-2	4	-4	1	3	4	2	2	8	3	0
0.6a	-8	2	-42	-5	2	-20	-1	3	-5	2	3	5	4	2	10	4	0
0.5a	-10	0	-48	-5	2	-22	0	2	-4	3	1	6	6	1	12	7	0
0.4a	-10	2	-50	-5	1	-21	1	0	-3	6	0	7	9	0	13	10	0
0.3a	-9	4	-47	-3	0	-19	3	2	-2	8	2	8	11	1	12	12	0
0.2a	-8	5	-39	-2	2	-14	4	5	0	9	5	7	12	3	10	13	0
0.1a	-5	7	-24	0	4	-7	4	7	1	7	4	9	4	6	10	0	7
BOT.	0	7	0	0	6	0	0	9	0	0	7	0	0	4	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 22 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner		0.1b		0.2b		0.3b		0.4b		0.5b	
	$M_{xc}$	$M_{yc}$										
TOP	0	11	0	0	18	0	0	12	0	0	7	0
0.9a	-2	10	-9	5	17	2	10	12	4	31	7	5
0.8a	-3	9	-17	9	15	3	19	10	9	25	6	9
0.7a	-5	7	-25	13	12	5	28	8	12	36	4	12
0.6a	-6	4	-31	17	7	7	35	5	15	45	2	15
0.5a	-7	1	-35	20	2	8	40	1	17	51	0	17
0.4a	-7	3	-37	22	4	9	42	3	17	53	2	17
0.3a	-7	6	-35	22	10	9	40	7	16	50	4	15
0.2a	-6	9	-30	19	16	8	34	11	12	41	6	12
0.1a	-4	12	-19	13	20	5	21	13	7	25	7	7
BOT.	0	13	0	0	21	0	0	13	0	0	7	0
									0	3	0	0

**Table 23 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
	$\mathbf{M}_{xc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{yec}$	$\mathbf{M}_{rc}$	$\mathbf{M}_{yrc}$	$\mathbf{M}_{yec}$	$\mathbf{M}_{rc}$	$\mathbf{M}_{yrc}$	$\mathbf{M}_{yec}$	$\mathbf{M}_{rc}$	$\mathbf{M}_{yec}$
TOP	0	11	0	0	7	0	5	0	0	3	0
0.9a	-2	10	-9	-2	7	-7	-2	4	-5	-2	3
0.8a	-3	9	-17	-4	6	-13	-4	4	-10	-4	2
0.7a	-5	7	-25	-5	4	-19	-5	3	-14	-5	2
0.6a	-6	4	-31	-6	2	-23	-6	1	-17	-6	1
0.5a	-7	1	-35	-7	0	-26	-7	0	-19	-6	0
0.4a	-7	3	-37	-7	3	-26	-6	2	-18	-6	1
0.3a	-7	6	-35	-6	5	-24	-5	3	-16	-5	2
0.2a	-6	9	-30	-5	6	-19	-3	4	-11	-2	2
0.1a	-4	12	-19	-2	6	-10	-1	3	-5	0	2
BOT.	0	13	0	0	6	0	0	3	0	1	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 24 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$
TOP	0	2	0	0	15	0	0	15	0	0	11
0.9a	-3	2	-14	1	14	-3	5	15	3	8	11
0.8a	-6	2	-28	2	13	-5	10	13	5	16	9
0.7a	-8	1	-40	3	10	-7	14	10	7	23	7
0.6a	-10	1	-50	4	7	-8	18	6	9	29	4
0.5a	-11	0	-56	6	2	-8	22	1	11	34	1
0.4a	-12	0	-58	7	3	-7	24	4	11	36	3
0.3a	-11	1	-54	8	8	-5	24	9	11	35	6
0.2a	-9	2	-44	8	14	-3	22	13	9	30	9
0.1a	-5	2	-26	7	18	-1	14	17	6	19	11
BOT.	0	3	0	0	20	0	0	18	0	0	12

**Table 25 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	2	0	0	10	0	0	12	0	0	10
0.9a	-3	2	-14	-1	9	-5	2	12	1	4	10
0.8a	-6	2	-28	-1	9	-9	4	11	2	8	9
0.7a	-8	1	-40	-1	7	-13	6	9	3	12	7
0.6a	-10	1	-50	-1	5	-15	8	6	4	16	4
0.5a	-11	0	-56	0	2	-16	11	2	5	20	1
0.4a	-12	0	-58	1	1	-15	13	2	6	22	2
0.3a	-11	1	-54	2	5	-13	14	7	6	23	6
0.2a	-9	2	-44	3	9	-9	14	11	6	21	9
0.1a	-5	2	-26	3	13	-4	10	15	4	14	11
BOT.	0	3	0	0	15	0	0	16	0	0	12

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 26 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b			
		$M_{xc}$	$M_{yc}$	$M_{jc}$	$M_{vc}$	$M_{yc}$	$M_{vc}$	$M_{xc}$	$M_{yc}$	$M_{vc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{vc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{vc}$	$M_{yc}$		
TOP	0	6	0	0	16	0	0	15	0	0	11	0	0	5	0	0	0	0	0	0	
0.9a	-2	5	-12	2	15	-2	6	14	3	8	10	5	10	5	5	11	0	0	5		
0.8a	-5	5	-23	3	13	-3	11	13	6	17	9	9	20	4	10	21	0	0	10		
0.7a	-7	4	-33	5	11	-4	16	10	8	24	7	13	29	3	14	31	0	0	15		
0.6a	-8	2	-41	7	7	-5	20	6	11	30	4	16	36	2	17	38	0	0	18		
0.5a	-9	0	-46	8	2	-5	24	1	12	35	1	18	42	0	19	44	0	0	19		
0.4a	-10	2	-49	9	3	-4	26	4	13	38	3	18	44	1	19	46	0	0	19		
0.3a	-9	3	-46	10	9	-2	26	9	12	37	6	16	42	3	17	44	0	0	18		
0.2a	-8	5	-38	10	14	-1	23	13	10	31	9	13	36	4	14	37	0	0	14		
0.1a	-5	6	-23	7	19	0	15	16	6	20	11	8	22	5	8	23	0	0	8		
BOT.	0	6	0	0	20	0	0	18	0	0	12	0	0	6	0	0	0	0	0		

**Table 27 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.9c		0.8c		0.2c		0.7c		0.3c		0.4c		0.6c		0.5c		
		$M_{zc}$	$M_{yc}$																	
TOP	0	6	0	0	1	0	0	4	0	0	4	0	0	3	0	3	0	0	0	0
0.9a	-2	5	-12	-1	1	-6	-1	4	-1	0	4	1	1	3	3	1	0	0	0	3
0.8a	-5	5	-23	-3	2	-11	-1	4	-3	0	4	3	1	2	6	2	0	0	7	
0.7a	-7	4	-33	-4	2	-16	-1	4	-4	1	3	4	2	2	8	3	0	0	10	
0.6a	-8	2	-41	-5	2	-19	-1	3	-4	2	3	5	4	2	10	5	0	0	12	
0.5a	-9	0	-46	-5	2	-21	0	2	-4	4	1	7	6	1	12	7	0	0	14	
0.4a	-10	2	-49	-4	1	-21	1	0	-3	6	0	8	9	0	13	10	0	0	15	
0.3a	-9	3	-46	-3	0	-18	3	2	-2	8	2	8	11	1	13	12	0	0	14	
0.2a	-8	5	-38	-1	2	-13	5	5	0	9	5	7	12	3	10	13	0	0	11	
0.1a	-5	6	-23	0	5	-7	5	8	1	7	7	4	9	4	6	10	0	0	7	
BOT.	0	6	0	0	6	0	0	9	0	0	7	0	0	4	0	0	0	0	0	

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 28 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b						
	$M_{vc}$	$M_{yc}$	$M_{vc}$								
TOP	0	10	0	0	17	0	0	15	0	0	10
0.9a	-2	10	-9	2	16	0	6	14	3	9	10
0.8a	-3	9	-17	5	14	0	12	13	7	18	9
0.7a	-5	7	-24	7	11	-1	18	10	10	26	6
0.6a	-6	4	-30	9	7	0	23	6	12	32	4
0.5a	-7	1	-34	11	2	0	26	1	14	37	1
0.4a	-7	2	-36	12	3	1	28	4	14	40	3
0.3a	-7	6	-35	13	9	2	28	9	14	38	6
0.2a	-6	9	-29	12	15	2	25	13	11	32	9
0.1a	-4	11	-18	8	20	2	16	16	7	20	11
BOT.	0	12	0	0	21	0	0	17	0	0	11

**Table 29 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( *Table I, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
	$\mathbf{M}_{xc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{yec}$	$\mathbf{M}_{xc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{yec}$	$\mathbf{M}_{xc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{yec}$	$\mathbf{M}_{xc}$	$\mathbf{M}_{yc}$
TOP	0	10	0	0	7	0	0	4	0	0	0
0.9a	-2	10	-7	-2	7	-7	-2	4	-5	-2	3
0.8a	-3	9	-13	-3	6	-13	-3	4	-10	-3	2
0.7a	-5	7	-24	-5	4	-18	-5	3	-14	-5	1
0.6a	-6	4	-30	-6	2	-22	-6	1	-17	-6	1
0.5a	-7	1	-34	-7	0	-25	-6	0	-18	-6	0
0.4a	-7	2	-36	-7	2	-25	-6	2	-17	-6	1
0.3a	-7	6	-35	-6	4	-23	-5	3	-15	-4	2
0.2a	-6	9	-29	-5	6	-18	-3	4	-11	-2	2
0.1a	-4	11	-18	-2	6	-10	-1	3	-5	0	1
BOT.	0	12	0	0	5	0	0	2	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 30 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b						
		$M_{xc}$	$M_{yc}$								
TOP	0	4	0	0	12	0	0	13	0	0	10
0.9a	-2	4	-11	0	12	-3	3	12	2	5	10
0.8a	-4	3	-21	1	10	-6	6	11	3	10	8
0.7a	-6	3	-30	2	8	-8	9	9	5	15	7
0.6a	-8	1	-38	2	6	-9	11	6	6	19	4
0.5a	-9	0	-43	3	2	-10	14	2	8	22	1
0.4a	-9	1	-46	4	2	-9	16	3	8	25	2
0.3a	-9	2	-44	4	6	-8	17	7	8	25	6
0.2a	-7	3	-36	5	11	-5	15	12	7	23	9
0.1a	-4	4	-22	4	15	-2	11	15	5	15	11
BOT.	0	5	0	0	17	0	0	16	0	0	12

**Table 31 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	4	0	0	2	0	0	5	0	0	0
0.9a	-2	4	-11	-1	2	-5	0	5	-1	0	4
0.8a	-4	3	-21	-2	2	-10	-1	4	-2	1	4
0.7a	-6	3	-30	-3	2	-14	-1	4	-3	2	4
0.6a	-8	1	-38	-4	2	-17	0	3	-3	3	3
0.5a	-9	0	-43	-4	2	-19	1	2	-3	5	1
0.4a	-9	1	-46	-4	1	-19	2	0	-2	7	0
0.3a	-9	2	-44	-2	1	-17	4	2	-1	9	3
0.2a	-7	3	-36	-1	3	-12	5	5	1	10	5
0.1a	-4	4	-22	1	6	-6	5	8	1	8	7
BOT.	0	5	0	0	7	0	0	9	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 32 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b						
	$M_{xc}$	$M_{yc}$									
TOP	0	9	0	0	14	0	0	13	0	10	0
0.9a	-2	8	-8	1	13	-1	4	13	3	6	10
0.8a	-3	7	-15	3	12	-2	8	11	5	11	8
0.7a	-4	6	-22	4	10	-3	11	9	7	17	7
0.6a	-5	4	-27	5	6	-4	14	6	9	22	4
0.5a	-6	1	-31	6	2	-4	17	2	10	25	1
0.4a	-7	2	-33	7	2	-3	19	3	11	28	2
0.3a	-6	5	-32	7	8	-2	19	8	1	28	6
0.2a	-5	8	-27	7	13	-1	18	12	9	24	9
0.1a	-3	10	-17	6	17	0	12	16	6	16	11
BOT.	0	11	0	0	19	0	0	17	0	0	12

**Table 33 Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		$M_{xc}$	$M_{yc}$								
TOP	0	9	0	0	6	0	0	4	0	2	0
0.9a	-2	8	-8	-2	6	-6	-2	4	-4	-2	2
0.8a	-3	7	-15	-3	5	-11	-3	3	-9	-3	1
0.7a	-4	6	-22	-4	4	-16	-4	2	-12	-4	1
0.6a	-5	4	-27	-5	2	-20	-5	1	-14	-5	0
0.5a	-6	1	-31	-6	0	-22	-6	0	-16	-5	0
0.4a	-7	2	-33	-6	2	-23	-5	2	-15	-5	1
0.3a	-6	5	-32	-5	4	-21	-5	3	-13	-4	2
0.2a	-5	8	-27	-4	5	-17	-3	3	-9	-2	2
0.1a	-3	10	-17	-2	5	-9	0	2	-5	1	1
BOT.	0	11	0	0	4	0	0	2	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 34 Moment Coefficients along Long Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b						
	$M_{xc}$	$M_{yc}$									
TOP	0	5	0	0	8	0	0	8	0	6	0
0.9a	-1	5	-5	0	8	-1	1	8	1	2	6
0.8a	-2	4	-10	0	7	-3	3	7	3	4	5
0.7a	-3	4	-15	1	6	-4	4	6	4	6	4
0.6a	-4	2	-20	1	4	-5	5	4	5	9	3
0.5a	-5	1	-23	1	2	-6	7	2	6	11	1
0.4a	-5	1	-25	2	1	-6	8	1	6	13	1
0.3a	-5	3	-25	2	4	-5	9	4	7	14	3
0.2a	-5	5	-23	3	8	-4	9	8	6	14	6
0.1a	-3	6	-15	3	11	-2	7	11	4	10	8
BOT.	0	7	0	0	13	0	0	12	0	0	0

**Table 35** Moment Coefficients along Short Side for Rectangular Tanks having Case 1 Arrangements for  $b/a = 1.0, c/a = 0.5$

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		$M_{xc}$	$M_{yc}$	$M_{yec}$	$M_{zc}$	$M_{yec}$	$M_{yec}$										
TOP	0	5	0	0	3	0	0	2	0	0	1	0	0	0	0	0	0
0.9a	-1	5	-5	-1	3	-4	-1	2	-3	-1	1	-2	-1	0	-1	0	-1
0.8a	-2	4	-10	-2	3	-7	-2	2	-5	-2	1	-3	-2	0	-2	0	-2
0.7a	-3	4	-15	-3	2	-11	-2	1	-7	-2	0	-5	-2	0	-3	-2	0
0.6a	-4	2	-20	-3	1	-14	-3	0	-9	-3	0	-6	-3	0	-4	-3	0
0.5a	-5	1	-23	-4	0	-15	-3	1	-10	-3	1	-6	-3	0	-3	0	-2
0.4a	-5	1	-25	-4	1	-16	-3	1	-10	-3	1	-5	-2	1	-2	-2	0
0.3a	-5	3	-25	-4	2	-16	-3	2	-8	-2	1	-3	-1	1	-1	0	0
0.2a	-5	5	-23	-3	3	-13	-1	2	-6	0	1	-2	1	0	1	1	2
0.1a	-3	6	-15	-1	3	-7	0	1	-3	1	0	0	2	0	1	2	0
BOT.	0	7	0	0	2	0	0	0	0	1	0	0	1	0	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 36 Deflection Coefficients along Long Side, Mid-height ( $y = a/2$ ) for Tanks having Case 2 Arrangements for Various Length/Height and Width/height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	x	End	0.1b	0.2b	0.3b	0.4b	0.5b
				0.9b	0.8b	0.7b	0.6b	
4.0	3.0		0	14.10	34.30	51.80	63.20	67.00
4.0	2.0		0	17.40	39.10	57.10	68.60	72.50
4.0	1.5		0	18.80	41.00	59.20	70.80	74.70
4.0	1.0		0	19.40	41.80	60.10	71.70	75.70
4.0	0.5		0	17.90	39.60	57.60	69.10	73.00
3.0	2.0		0	7.30	17.30	26.00	31.70	33.70
3.0	1.5		0	8.60	19.10	28.10	33.90	35.90
3.0	1.0		0	9.30	20.20	29.30	35.20	37.20
3.0	0.5		0	8.70	19.20	28.10	33.90	36.00
2.0	1.5		0	2.30	5.50	8.30	10.30	10.90
2.0	1.0		0	3.00	6.60	9.70	11.70	12.40
2.0	0.5		0	3.00	6.60	9.70	11.70	12.40
1.5	1.0		0	1.10	2.60	3.90	4.80	5.10
1.5	0.5		0	1.40	2.90	4.30	5.30	5.60
1.0	0.5		0	0.40	0.80	1.30	1.50	1.60

**Table 37 Deflection Coefficients along Short Side, Mid-height ( $y = a/2$ ) for Tanks having Case 2 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	z	End	0.1c	0.2c	0.3c	0.4c	0.5c
				0.9c	0.8c	0.7c	0.6c	
4.0	3.0		0	1.60	8.60	15.90	21.00	22.80
4.0	2.0		0	-2.80	-2.90	-1.90	-1.00	-0.60
4.0	1.5		0	-3.40	-5.00	-5.70	-6.00	-6.00
4.0	1.0		0	-2.80	-4.70	-5.90	-6.50	-6.80
4.0	0.5		0	-1.20	-2.20	-2.80	-3.20	-3.40
3.0	2.0		0	-0.70	0.60	2.30	3.70	4.20
3.0	1.5		0	-1.80	-2.30	-2.30	-2.10	-2.00
3.0	1.0		0	-1.80	-2.90	-3.60	-3.90	-4.00
3.0	0.5		0	-0.90	-1.50	-1.90	-2.20	-2.30
2.0	1.5		0	-0.20	-0.40	-1.10	-1.70	-1.90
2.0	1.0		0	-0.80	-1.10	-1.30	-1.30	-1.30
2.0	0.5		0	-0.50	-0.80	-1.10	-1.20	-1.20
1.5	1.0		0	-0.30	-0.30	-0.20	-0.10	0.00
1.5	0.5		0	-0.30	-0.50	-0.60	-0.70	-0.70
1.0	0.5		0	-0.10	-0.20	-0.20	-0.30	-0.30

**Table 38 Deflection Coefficients along Long Side, Mid-span ( $x = b/2$ ) for Tanks having Case 2 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	y c/a	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	14.10	28.00	41.50	54.50	67.00	79.10	90.80	102.20	113.40	124.70
4.0	2.0	0	15.20	30.20	44.80	58.90	72.50	85.70	96.40	110.90	123.20	135.60
4.0	1.5	0	15.70	31.10	46.20	60.70	74.70	88.30	101.50	114.40	127.20	140.00
4.0	1.0	0	15.90	31.50	46.70	61.40	75.70	89.40	102.80	115.80	128.80	141.80
4.0	0.5	0	15.30	30.40	45.10	59.30	73.00	86.20	99.10	111.70	124.10	136.60
3.0	2.0	0	7.40	14.60	21.40	27.70	33.70	39.20	44.40	49.30	54.20	59.10
3.0	1.5	0	7.90	15.50	22.70	29.60	35.90	41.90	47.50	52.90	58.20	63.50
3.0	1.0	0	8.10	16.00	23.50	30.60	37.20	43.40	49.30	54.90	60.50	66.00
3.0	0.5	0	7.90	15.50	22.80	29.60	36.00	41.90	47.50	52.90	58.20	63.50
2.0	1.5	0	2.70	5.20	7.50	9.40	10.90	12.20	13.30	14.30	15.20	16.10
2.0	1.0	0	3.00	5.80	8.40	10.60	12.40	14.00	15.40	16.60	17.70	18.90
2.0	0.5	0	3.00	5.90	8.40	10.60	12.40	14.00	15.30	16.50	17.60	18.80
1.5	1.0	0	1.40	2.70	3.80	4.60	5.10	5.50	5.80	6.00	6.10	6.30
1.5	0.5	0	1.50	2.90	4.10	4.90	5.60	6.00	6.30	6.50	6.70	7.00
1.0	0.5	0	0.60	1.00	1.40	1.50	1.50	1.60	1.60	1.50	1.40	1.40

**Table 39 Deflection Coefficients along Short Side, Mid-span ( $z = c/2$ ) for Tanks having Case 2 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	y c/a	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	5.20	10.20	14.80	19.00	22.80	26.20	29.30	32.20	35.00	37.80
4.0	2.0	0	0.30	0.50	0.40	0.00	-0.60	-1.50	-2.50	-3.60	-4.80	-5.90
4.0	1.5	0	-0.90	-1.90	-3.10	-4.50	-6.00	-7.60	-9.30	-11.00	-1260	-14.30
4.0	1.0	0	-1.20	-2.50	-3.90	-5.30	-6.80	-8.20	-9.60	-10.90	-12.20	-13.60
4.0	0.5	0	-0.70	-1.40	-2.00	-2.70	-3.40	-4.00	-4.50	-5.00	-5.50	-6.20
3.0	2.0	0	1.30	2.40	3.30	3.90	4.20	4.20	4.10	3.80	3.50	3.30
3.0	1.5	0	-0.10	-0.30	-0.70	-1.20	-2.00	-2.90	-3.80	-4.80	-5.80	-6.80
3.0	1.0	0	-0.70	-1.40	-2.20	-3.10	-4.00	-4.90	-5.80	-6.70	-7.60	-8.50
3.0	0.5	0	-0.50	-0.90	-1.40	-1.90	-2.30	-2.70	-3.00	-3.40	-3.70	-4.10
2.0	1.5	0	0.70	1.40	1.80	1.90	1.90	1.80	1.50	1.20	0.80	0.50
2.0	1.0	0	-0.10	-0.30	-0.50	-0.90	1.30	-1.80	-2.20	-2.60	-3.10	-3.50
2.0	0.5	0	-0.20	-0.50	-0.80	-1.00	-1.20	-1.40	-1.60	-1.70	-1.90	-2.00
1.5	1.0	0	0.20	0.30	0.30	0.10	0.00	-0.30	-0.50	-0.80	-1.00	-1.20
1.5	0.5	0	-0.10	-0.30	-0.50	-0.60	-0.70	-0.80	-0.90	-1.00	-1.00	-1.10
1.0	0.5	0	0.00	-0.10	-0.20	-0.20	-0.30	-0.30	-0.30	-0.30	-0.40	-0.40

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 40 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$
TOP	-39	11	0	0	65	0	0	68	0	0	52
0.9a	-52	22	-196	-6	62	-61	5	66	30	11	51
0.8a	-46	23	-261	-8	62	-57	12	66	29	22	51
0.7a	-41	22	-231	-5	63	-51	19	68	28	32	52
0.6a	-37	22	-207	-1	66	-45	27	70	28	41	54
0.5a	-33	22	-186	5	69	-37	33	73	27	48	55
0.4a	-29	23	-165	10	73	-30	36	75	26	50	57
0.3a	-23	23	-143	14	77	-22	37	78	23	48	53
0.2a	-17	23	-117	15	81	-14	32	80	20	40	59
0.1a	-9	24	-85	11	83	-8	20	82	15	24	60
BOT.	0	25	0	0	84	0	0	82	0	0	60
											31
										0	0
										0	0
										0	0

**Table 41 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>
TOP	-39	11	0	0	17	0	29	0	0	26	0
0.9a	-52	22	-196	-12	14	-99	0	27	8	6	25
0.8a	-46	23	-261	-16	14	-92	3	26	7	14	25
0.7a	-41	22	-231	-14	15	-84	8	28	4	22	26
0.6a	-37	22	-207	-10	17	-75	14	30	2	29	37
0.5a	-33	22	-186	4	19	-65	20	33	1	35	30
0.4a	-29	23	-165	1	23	-54	24	37	4	39	32
0.3a	-23	23	-143	6	27	-42	26	40	5	39	34
0.2a	-17	23	-117	8	31	-30	24	43	6	33	36
0.1a	-9	24	-85	7	34	-19	16	45	6	21	37
BOT.	0	25	0	0	36	0	0	46	0	0	37

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 42 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	-30	33	-150	0	72	-41	0	71	39	0	53
0.9a	-42	40	-209	-4	70	-37	6	70	37	11	53
0.8a	-38	41	-188	-4	69	-33	14	70	36	23	53
0.7a	-34	41	-170	-1	71	-28	22	71	35	34	54
0.6a	-31	41	-155	4	73	-23	29	73	33	43	55
0.5a	-28	41	-140	9	77	-17	35	76	31	49	56
0.4a	-25	42	-123	14	81	-12	39	79	28	52	58
0.3a	-20	43	-102	17	85	-7	38	81	23	49	59
0.2a	-15	43	-75	17	89	-3	33	83	17	41	60
0.1a	-8	44	-42	12	92	0	21	85	10	25	61
BOT	0	45	0	0	93	0	0	85	0	0	61

**Table 43 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-30	33	-150	0	18	116	0	5	49	0	0
0.9a	-42	40	-209	-15	20	107	-6	7	45	-1	1
0.8a	-38	41	-188	-20	20	99	-7	8	40	1	2
0.7a	-34	41	-170	-19	19	90	-5	7	34	5	1
0.6a	-31	41	-155	-15	19	79	-1	5	28	11	1
0.5a	-28	41	-140	-11	17	67	5	3	22	16	3
0.4a	-25	42	-123	-6	14	54	9	1	15	21	5
0.3a	-20	43	-102	-2	11	40	13	4	9	23	8
0.2a	-15	43	-75	1	7	26	14	7	4	22	10
0.1a	-8	44	-42	3	4	12	11	10	1	15	11
BOT	0	45	0	0	2	0	0	11	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 44 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		$M_{xc}$	$M_{yc}$								
TOP	0	41	-135	0	75	-32	0	72	43	0	54
0.9a	-27	47	-191	0	73	-30	0	71	41	0	54
0.8a	-38	47	-171	-3	72	-26	7	71	39	12	5
0.7a	-34	47	-155	-2	74	-22	15	73	38	23	455
0.6a	-32	48	-141	1	76	-17	23	75	36	34	56
0.5a	-28	49	-128	6	80	-12	30	77	33	43	57
0.4a	-26	50	-113	11	84	-8	36	80	29	50	58
0.3a	-23	51	-94	16	88	-4	40	83	24	52	60
0.2a	-19	52	-70	18	92	-1	39	85	18	50	61
0.1a	-14	53	-39	18	95	1	33	86	10	41	61
BOT.	-8	54	0	12	96	0	21	86	0	25	62

**Table 45 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c				0.2c				0.3c				0.4c				0.5c			
		0.9c		0.8c		0.7c		0.6c		0.5c		0.4c		0.3c		0.2c		0.1c			
		$M_x$	$M_{yc}$	$M_{zc}$	$M_{yzc}$																
TOP	-27	41	0	0	31	0	0	17	0	0	10	0	0	4	0	0	0	0	0	0	0
0.9a	-38	47	-135	-18	32	-128	-10	20	-79	-6	11	-47	-4	5	-28	-3	0	0	-22		
0.8a	-34	47	-191	-23	31	-119	-14	20	-73	-8	12	-43	-5	5	-25	-4	0	0	-19		
0.7a	-32	47	-171	-22	31	-110	-13	20	-66	-7	12	-37	-3	5	-21	-1	0	0	-15		
0.6a	-28	48	-155	-19	32	-100	-10	19	-59	-3	11	-31	2	5	-16	3	0	0	-11		
0.5a	-26	49	-141	-15	31	-89	-5	18	-50	2	9	-25	7	4	-11	9	0	0	-6		
0.4a	-23	50	-128	-11	30	-76	0	16	-41	8	7	-18	13	3	-6	14	0	0	-2		
0.3a	-19	51	-113	-7	27	-62	4	13	-31	12	5	-12	16	2	-2	18	0	0	2		
0.2a	-14	52	-94	-3	24	-47	7	10	-22	13	3	-7	17	1	1	18	0	0	4		
0.1a	-8	53	-70	-1	21	-32	7	7	-13	10	2	-3	12	0	3	13	0	0	4		
BOT.	0	54	-39	0	20	-15	0	6	-6	0	1	0	0	0	2	0	0	0	3		

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 46 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	-27	43	-133	0	77	-29	0	73	44	0	54
0.9a	-37	47	-187	-3	74	-26	7	72	42	12	54
0.8a	-33	47	-165	-2	74	-23	15	72	41	24	54
0.7a	-29	48	-147	2	75	-19	23	73	39	35	55
0.6a	-27	49	-133	7	78	-15	31	75	37	44	56
0.5a	-24	51	-119	13	81	-10	37	78	34	50	57
0.4a	-21	53	-106	17	85	-6	41	81	30	52	59
0.3a	-17	55	-87	19	90	-2	40	83	25	50	35
0.2a	-13	56	-65	19	93	0	34	85	18	41	61
0.1a	-7	58	-36	13	96	1	21	86	10	25	62
BOT	0	59	0	0	97	0	0	87	0	0	62
											31
										0	0
										0	0

**Table 47 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c				0.2c				0.3c				0.4c				0.5c			
		0.9c		0.8c		0.7c		0.6c		0.5c		0.4c		0.3c		0.2c		0.1c			
		$M_x$	$M_{yc}$	$M_{zc}$	$M_{yec}$																
TOP	-27	43	-133	0	38	-154	0	24	-124	0	15	-103	0	7	-91	0	0	0	0	0	-87
0.9a	-37	47	-187	-24	35	-142	-17	25	-114	-13	16	-96	-11	8	-84	-11	0	0	0	-81	
0.8a	-33	47	-165	-28	34	-131	-23	25	-105	-19	16	-87	-17	8	-76	-17	0	0	0	-72	
0.7a	-29	48	-147	-26	36	-119	-23	26	-94	-20	17	-77	-18	8	-66	-18	0	0	0	-63	
0.6a	-27	49	-133	-23	37	-105	-20	27	-82	-17	17	-66	-16	8	-56	-15	0	0	0	-53	
0.5a	-24	51	-119	-20	39	-91	-16	27	-69	-13	17	-54	-11	8	-45	-10	0	0	0	-42	
0.4a	-21	53	-106	-16	39	-75	-11	27	-55	-8	17	-41	-5	8	-34	-4	0	0	0	-31	
0.3a	-17	55	-87	-12	39	-58	-6	26	-40	-2	16	-29	1	7	-23	1	0	0	0	-21	
0.2a	-13	56	-65	-7	37	-40	-1	24	-26	3	14	-18	5	7	-14	6	0	0	0	-12	
0.1a	-7	58	-36	-2	35	-20	2	22	-12	4	13	-8	6	6	-6	6	0	0	0	-5	
BOT.	0	59	0	0	34	0	0	21	0	0	12	0	0	6	0	0	0	0	0	0	

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 48 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-31	33	-153	0	73	-39	0	72	40	0	54
0.9a	-43	37	-216	-4	71	-36	7	71	38	12	53
0.8a	-28	37	-188	-3	71	-31	14	71	37	23	53
0.7a	-33	37	-165	0	72	-27	22	72	35	34	54
0.6a	-29	39	-145	6	75	-21	30	74	34	43	55
0.5a	-25	41	-127	11	78	-16	36	76	31	49	57
0.4a	-22	43	-109	16	82	-10	40	79	28	52	58
0.3a	-18	46	-89	19	86	-5	39	81	23	49	59
0.2a	-13	48	-65	18	89	-2	34	83	17	41	60
0.1a	-7	50	-36	13	92	0	21	85	10	25	61
BOT.	0	51	0	0	93	0	0	85	0	0	61
											31
										0	0
										0	0
										0	0

**Table 49 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-31	33	-153	0	41	-211	0	26	-198	0	16
0.9a	-43	37	-216	-37	27	-195	-31	21	-182	-26	14
0.8a	-28	37	-188	-36	26	-177	-35	19	-168	-34	12
0.7a	-33	37	-165	-33	28	-157	-33	20	-151	-33	13
0.6a	-29	39	-145	-29	30	-138	-29	22	-132	-29	15
0.5a	-25	41	-127	-25	32	-119	-25	24	-113	-25	16
0.4a	-22	43	-109	-21	34	-100	-21	26	-92	-20	17
0.3a	-18	46	-89	-17	35	-78	-16	26	-71	-15	18
0.2a	-13	48	-65	-12	36	-55	-10	27	-48	-9	17
0.1a	-7	50	-36	-6	36	-28	-4	26	-24	-3	17
BOT.	0	51	0	0	35	0	0	25	0	0	16
											0
											0
											0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 50 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-19	12	-97	0	37	-45	0	39	20	0	31
0.9a	-30	19	-152	-5	34	-42	3	37	20	8	30
0.8a	28	20	-141	-6	34	-38	9	37	20	17	30
0.7a	-26	20	-132	-3	35	-34	15	39	20	26	31
0.6a	-28	20	-124	0	37	-29	21	41	21	34	33
0.5a	-23	20	-115	4	41	-23	27	44	20	40	35
0.4a	-21	21	-106	8	45	-17	30	47	19	43	37
0.3a	-17	21	-87	11	49	-11	31	51	17	42	39
0.2a	-13	22	-66	12	54	-6	27	54	13	36	40
0.1a	-7	22	-37	9	57	-2	18	56	7	22	41
BOT.	0	23	0	0	59	0	0	56	0	0	42

**Table 51 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-19	12	-97	0	6	-80	0	2	-26	0	4
0.9a	-30	19	-152	-10	8	-74	3	0	-23	1	3
0.8a	28	20	-141	-13	8	-69	3	1	-20	5	3
0.7a	-26	20	-132	-12	7	-63	0	0	-16	9	4
0.6a	-28	20	-124	-10	6	-56	4	2	-12	15	5
0.5a	-23	20	-115	-6	4	-48	9	5	-8	20	8
0.4a	-21	21	-106	-3	1	-39	13	99	-4	25	10
0.3a	-17	21	-87	1	3	-29	16	12	-1	26	13
0.2a	-13	22	-66	3	7	-18	16	16	1	24	15
0.1a	-7	22	-37	4	10	-8	12	18	2	16	16
BOT.	0	23	0	0	12	0	0	19	0	0	17

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 52 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 3.0$ ,  $c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		$M_{xc}$	$M_{yc}$								
TOP	-16	20	-82	0	40	-34	0	41	26	0	32
0.9a	-26	26	-132	-4	38	-32	4	40	25	9	31
0.8a	-25	26	-123	-4	38	-29	10	40	25	18	31
0.7a	-23	27	-116	-1	39	-25	16	41	25	27	32
0.6a	-22	27	-109	3	41	-21	23	43	25	35	34
0.5a	-20	28	-102	7	45	-16	28	46	24	41	36
0.4a	-19	29	-93	10	49	-11	32	50	22	44	38
0.3a	-16	30	-79	13	54	-7	32	53	19	43	40
0.2a	-12	31	-60	13	58	-3	28	56	15	36	41
0.1a	-7	32	-34	10	62	-1	18	58	8	22	42
BOT.	0	32	0	0	63	0	0	58	0	0	42

**Table 53 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-16	20	-82	0	18	-86	0	10	-48	0	5
0.9a	-26	26	-132	-12	19	-80	-6	12	-44	-3	6
0.8a	-25	26	-123	-15	19	-75	-8	12	-40	-3	7
0.7a	-23	27	-116	-15	19	-69	-7	12	-35	-1	7
0.6a	-22	27	-109	-13	19	-62	-4	11	-19	3	5
0.5a	-20	28	-102	-10	18	-54	0	99	-23	8	4
0.4a	-19	29	-93	-7	16	-45	4	6	-17	12	2
0.3a	-16	30	-79	-4	13	-35	7	3	-11	15	1
0.2a	-12	31	-60	-1	10	-23	9	0	-6	16	3
0.1a	-7	32	-34	2	6	-11	8	3	-2	11	5
BOT.	0	32	0	0	5	0	0	4	0	6	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 54 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	-16	24	-78	0	43	-29	0	42	30	0	33
0.9a	-25	28	-124	-3	40	-26	5	41	29	9	32
0.8a	-23	28	-113	-2	40	-23	11	41	28	19	32
0.7a	-21	29	-105	1	41	-20	17	42	28	28	33
0.6a	-20	30	-99	5	44	-16	24	45	27	36	35
0.5a	-18	32	-92	9	47	-12	30	48	26	42	36
0.4a	-17	34	-83	12	52	-8	33	51	24	45	38
0.3a	-14	35	-72	14	56	-4	33	54	20	44	31
0.2a	-11	37	-55	14	61	-1	29	57	15	37	42
0.1a	-6	38	-31	10	64	0	18	59	9	23	43
BOT.	0	39	0	0	66	0	0	59	0	0	43

**Table 55** Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 3.0, c/a = 1.0$

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c				
		$M_{zc}$	$M_{yc}$															
TOP	-16	24	-78	0	25	-101	0	16	-80	0	10	-65	0	5	-56	0	0	-53
0.9a	-25	28	-124	-16	23	-93	-11	17	-74	-8	11	-60	-7	5	-51	-7	0	-48
0.8a	-23	28	-113	-19	22	-88	-15	17	-68	-12	11	-54	-11	6	-45	-10	0	-42
0.7a	-21	29	-105	-18	23	-81	-15	17	-61	-12	11	-47	-11	6	-38	-10	0	-36
0.6a	-20	30	-99	-16	24	-73	-13	18	-53	-10	12	-39	-9	6	-31	-8	0	-28
0.5a	-18	32	-92	-14	25	-65	-10	18	-45	-7	11	-31	-5	6	-24	-4	0	-21
0.4a	-17	34	-83	-12	25	-55	-7	17	-36	-3	10	-24	0	5	-16	1	0	-14
0.3a	-14	35	-72	-8	24	-43	3	15	-26	2	9	-15	4	4	-10	5	0	-8
0.2a	-11	37	-55	-5	22	-30	1	13	16	5	7	-9	7	3	-5	8	0	-3
0.1a	-6	38	-31	-1	20	-15	3	11	-7	5	5	-3	7	2	-1	7	0	-1
BOT.	0	39	0	0	19	0	0	10	0	0	5	0	2	0	0	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 56 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	-18	18	-90	0	41	-35	0	41	27	0	32
0.9a	-28	22	-142	-4	38	-32	4	40	26	9	31
0.8a	-25	22	-126	-4	38	-29	10	40	25	18	32
0.7a	-23	22	-114	0	39	-25	17	41	25	28	33
0.6a	-21	24	-103	4	42	-20	24	44	25	36	34
0.5a	-19	26	-93	9	45	-15	29	47	24	42	36
0.4a	-16	28	-82	12	49	-10	33	50	22	45	38
0.3a	-14	31	-69	15	54	-5	33	53	19	44	39
0.2a	-10	34	-52	15	58	-2	29	55	15	37	41
0.1a	-6	36	-30	11	62	0	19	57	8	23	42
BOT.	0	37	0	0	63	0	0	58	0	42	0
										22	0
										0	0
										0	0

**Table 57 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>
TOP	-18	18	-90	0	26	-137	0	17	-130	0	10
0.9a	-28	22	-142	-24	17	-129	-20	13	-121	-17	9
0.8a	-25	22	-126	-24	16	-119	-23	12	-112	-22	8
0.7a	-23	22	-114	-22	17	-108	-22	3	-102	-22	9
0.6a	-21	24	-103	-20	19	-97	-20	14	-91	-20	10
0.5a	-19	26	-93	-18	21	-85	-18	16	-79	-18	11
0.4a	-16	28	-82	-16	23	-72	-15	17	-65	-15	12
0.3a	-14	31	-69	-13	24	-58	-12	18	-50	-11	12
0.2a	-10	34	-52	-9	25	-41	-7	18	-34	-6	12
0.1a	-6	36	-30	-4	25	-22	-3	17	-17	-2	11
BOT.	0	37	0	0	24	0	0	17	0	0	11

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 58 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-7	3	-36	0	10	-30	0	12	7	0	10	33
0.9a	-15	7	-76	-4	8	-28	1	10	7	4	9	32
0.8a	-15	7	-77	-4	8	-27	4	10	8	10	9	31
0.7a	-15	8	-77	-3	9	-25	8	11	10	16	10	31
0.6a	-16	8	-78	-1	11	-23	12	13	11	22	11	30
0.5a	-15	9	-77	1	14	-20	16	16	12	27	14	29
0.4a	-15	9	-73	3	18	-16	19	20	12	30	16	26
0.3a	-13	10	-64	5	22	-11	21	24	11	31	19	22
0.2a	-10	10	-51	7	27	-7	19	28	9	27	21	17
0.1a	-6	11	-30	6	30	-3	13	30	6	17	23	9
BOT.	0	11	0	0	32	0	0	31	0	0	23	0

**Table 59** Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 2.0, c/a = 1.5$

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-7	3	-36	0	6	-45	0	2	-18	0	0
0.9a	-15	7	-76	-6	7	-42	-2	4	-16	0	2
0.8a	-15	7	-77	-8	7	-41	-2	4	-14	2	2
0.7a	-15	8	-77	-8	7	-39	-1	4	-11	5	2
0.6a	-16	8	-78	-6	6	-36	2	3	-8	9	0
0.5a	-15	9	-77	-5	4	-33	5	0	-5	13	2
0.4a	-15	9	-73	-3	2	-28	8	3	-2	17	4
0.3a	-13	10	-64	-1	1	-22	11	6	0	19	7
0.2a	-10	10	-51	1	5	-14	11	10	2	18	9
0.1a	-6	11	-30	3	8	-7	9	13	2	13	11
BOT.	0	11	0	0	10	0	0	14	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 60 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-6	8	-29	0	13	-21	0	14	0	11	38
0.9a	-13	11	-64	-2	12	-19	2	13	14	5	10
0.8a	-13	11	-64	-2	12	-18	5	12	15	11	10
0.7a	-13	12	-64	-1	13	-17	10	13	15	17	11
0.6a	-13	13	-65	2	15	-15	14	16	16	23	13
0.5a	-13	14	-64	4	18	-13	18	19	16	29	15
0.4a	-12	15	-62	6	22	-10	21	22	16	32	18
0.3a	-11	17	-56	7	26	-7	22	26	14	32	20
0.2a	-9	18	-44	8	31	-3	21	30	11	28	23
0.1a	-5	19	-26	6	35	-1	14	33	7	18	24
BOT	0	19	0	0	37	0	0	34	0	0	25
											13
											0
											0
											0

**Table 61 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-6	8	-29	0	12	-49	0	8	-37	0	5
0.9a	-13	11	-64	-8	11	-47	-5	9	-34	-4	6
0.8a	-13	11	-64	-10	11	-46	-7	9	-31	-5	6
0.7a	-13	12	-64	-10	11	-44	-7	9	-29	-5	6
0.6a	-13	13	-65	-9	12	-42	-6	9	-25	-3	6
0.5a	-13	14	-64	-8	12	-36	-4	9	-21	-1	5
0.4a	-12	15	-62	-7	11	-34	-2	7	-16	3	4
0.3a	-11	17	-56	-5	10	-28	1	5	-12	6	2
0.2a	-9	18	-44	-3	8	-20	3	3	-7	8	0
0.1a	-5	19	-26	0	6	-10	4	0	-3	7	2
BOT.	0	19	0	0	4	0	0	1	0	2	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 62 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-7	6	-35	0	13	-23	0	14	0	12	38
0.9a	-14	8	-71	-3	11	-21	2	13	14	5	11
0.8a	-13	8	-67	-3	11	-19	5	13	14	11	11
0.7a	-13	8	-64	0	12	-17	10	14	15	18	12
0.6a	-12	10	-62	2	14	-14	15	16	16	24	13
0.5a	-12	12	-59	5	17	-11	1	19	16	29	15
0.4a	-11	14	-55	7	21	-8	23	22	16	33	18
0.3a	-10	17	-48	9	26	-5	24	26	15	33	20
0.2a	-8	19	-38	9	31	-2	21	30	12	29	18
0.1a	-5	21	-23	7	35	0	14	32	7	18	24
BOT	0	22	0	0	37	0	0	33	0	0	24
											13
											0
											0
											0

**Table 63 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-7	6	-35	0	12	-67	0	8	-65	0	5
0.9a	-14	8	-71	-12	7	-64	-10	6	-61	-8	4
0.8a	-13	8	-67	-13	6	-62	-12	5	-68	-11	4
0.7a	-13	8	-64	-12	7	-59	-12	6	-54	-12	4
0.6a	-12	10	-62	-12	9	-55	-12	7	-50	-12	5
0.5a	-12	12	-59	-11	10	-51	-11	8	-45	-11	6
0.4a	-11	14	-55	-10	12	-45	-10	9	-38	-9	6
0.3a	-10	17	-48	-9	13	-38	-8	10	-30	-7	7
0.2a	-8	19	-38	-6	14	-28	-5	10	-21	-4	6
0.1a	-5	21	-23	-3	14	-15	-1	9	-10	0	6
BOT.	0	22	0	0	13	0	0	8	0	5	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 64 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-2	2	-12	0	3	-14	0	4	6	0	3
0.9a	-7	4	-37	-2	2	-14	1	2	7	2	22
0.8a	-8	4	-41	-2	2	-14	2	2	7	6	22
0.7a	-9	4	-45	-1	2	-14	5	3	8	10	3
0.6a	-10	5	-48	0	4	-14	8	4	9	14	4
0.5a	-10	6	-50	1	6	-13	11	7	10	18	6
0.4a	-10	7	-50	2	9	-12	13	10	10	21	8
0.3a	-9	8	-47	3	13	-9	15	14	10	23	11
0.2a	-8	9	-38	4	17	-6	14	18	8	21	14
0.1a	-5	9	-23	4	21	-2	10	21	5	14	16
BOT	0	10	0	0	23	0	0	22	0	0	0

**Table 65** Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 1.5, c/a = 1.0$

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-2	2	-12	0	6	-26	0	4	-17	0	3
0.9a	-7	4	-37	-4	6	-26	-3	5	-16	-2	3
0.8a	-8	4	-41	-6	6	-26	-4	5	-15	-2	4
0.7a	-9	4	-45	-6	6	-27	-3	5	-13	-1	4
0.6a	-10	5	-48	-6	6	-27	-2	5	-12	0	4
0.5a	-10	6	-50	-5	6	-26	-1	4	-10	3	3
0.4a	-10	7	-50	-4	5	-24	1	3	-7	5	1
0.3a	-9	8	-47	-3	3	-20	3	1	-4	8	1
0.2a	-8	9	-38	-1	1	-15	5	2	-2	9	3
0.1a	-5	9	-23	0	1	-7	5	5	0	8	5
BOT.	0	10	0	0	3	0	0	6	0	0	3

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 66 Moment Coefficients along Long side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	-3	1	-15	0	3	-13	0	4	8	0	4
0.9a	-8	3	-39	-2	2	-12	1	3	9	2	3
0.8a	8	2	-39	-2	2	-12	3	3	10	6	3
0.7a	-8	3	-40	0	3	-11	6	3	10	11	3
0.6a	-8	4	-42	1	4	-10	9	5	11	16	5
0.5a	-8	6	-42	3	7	-9	13	8	12	20	6
0.4a	-8	8	-41	4	10	-7	15	11	12	23	9
0.3a	-8	10	-38	6	15	-5	17	15	12	24	12
0.2a	-6	12	-31	6	19	-3	16	19	10	22	14
0.1a	-4	14	-19	5	23	-1	11	22	6	15	9
BOT	0	15	0	0	25	0	0	23	0	0	0

**Table 67 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-3	1	-15	0	6	-36	0	4	-35	0	2
0.9a	-8	3	-39	-6	3	-35	-5	3	-34	-4	2
0.8a	-8	2	-39	-7	3	-36	-7	2	-33	-6	2
0.7a	-8	3	-40	-8	3	-36	-7	3	-32	-7	2
0.6a	-8	4	-42	-8	4	-35	-7	4	-30	-7	3
0.5a	-8	6	-42	-8	5	-34	-7	4	-28	-7	3
0.4a	-8	8	-41	-7	7	-32	-7	5	-25	-6	4
0.3a	-8	10	-38	-6	8	-27	-5	6	-20	-4	4
0.2a	-6	12	-31	-5	9	-21	-3	6	-14	-2	4
0.1a	-4	14	-19	-2	9	-11	-1	5	-7	1	3
BOT.	0	15	0	0	8	0	0	4	0	2	0
										1	0
										0	0
										0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 68 Moment Coefficients along Long Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		$M_{xc}$	$M_{yc}$								
TOP	-1	1	-3	0	1	-4	0	0	4	0	10
0.9a	-3	0	-14	-1	2	-4	0	1	4	0	0
0.8a	-3	1	-17	-1	2	-5	1	2	5	2	1
0.7a	-4	0	-20	-1	2	-6	2	2	5	4	1
0.6a	-5	0	-23	0	1	-6	4	1	6	7	1
0.5a	-5	1	-25	1	0	-6	5	0	7	9	0
0.4a	-5	3	-27	1	3	-6	7	3	7	11	2
0.3a	-5	4	-26	2	5	-5	8	6	7	13	4
0.2a	-5	6	-23	2	9	-4	9	9	6	13	7
0.1a	-3	7	-15	2	12	-2	7	12	4	10	9
BOT.	0	8	0	0	14	0	0	13	0	0	10
											5
											0
											0
											0

**Table 69 Moment Coefficients along Short Side for Rectangular Tanks having Case 2 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c				0.2c				0.3c				0.4c				0.5c				
		$M_{zc}$	$M_{yc}$	$M_{zec}$	$M_{yec}$																	
TOP	-1	1	-3	0	2	-12	0	1	-12	0	1	-12	0	0	0	-11	0	0	0	0	-11	
0.9a	-3	0	-14	-2	1	-13	-2	1	-12	-1	1	-11	-1	0	-11	-1	0	0	-1	0	0	-10
0.8a	-3	1	-17	-3	0	-14	-2	1	-12	-2	1	-11	-2	0	-10	-2	0	0	-2	0	0	-10
0.7a	-4	0	-20	-3	1	-16	-3	1	-13	-3	1	-10	-2	0	-9	-2	0	-2	0	0	-2	-9
0.6a	-5	0	-23	-4	1	-17	-3	1	-13	-3	1	-10	-3	1	-8	-3	1	-8	-3	0	0	-7
0.5a	-5	1	-25	-4	2	-18	-4	2	-13	-3	1	-9	-3	1	-6	-3	0	-3	0	0	0	-6
0.4a	-5	3	-27	-4	3	-18	-3	2	-12	-3	2	-7	-2	1	-4	-2	0	-2	0	0	-4	
0.3a	-5	4	-26	-4	3	-17	-3	3	-10	-2	2	-5	-1	1	-2	-1	0	0	0	0	0	-1
0.2a	-5	6	-23	-3	4	-13	-1	2	-7	0	1	-3	1	1	0	0	0	0	0	0	1	
0.1a	-3	7	-15	-1	3	-7	0	1	-3	1	0	-1	2	0	1	2	0	1	2	0	1	
BOT.	0	8	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 70 Deflection Coefficients along Long Side, Mid-height ( $y = a/2$ ) for Tanks having Case 3 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	x	End	0.1b	0.2b	0.3b	0.4b	0.5b
				0.9b	0.8b	0.7b	0.6b	
4.0	3.0	0	0	2.60	6.30	8.80	10.10	10.50
4.0	2.0	0	0	2.90	6.50	8.90	10.30	10.70
4.0	1.5	0	0	3.20	6.80	9.10	10.40	10.80
4.0	1.0	0	0	3.50	7.10	9.30	10.50	10.90
4.0	0.5	0	0	3.60	7.10	9.40	10.60	10.90
3.0	2.0	0	0	1.80	4.50	6.60	7.90	8.30
3.0	1.5	0	0	2.10	4.80	6.90	8.10	8.60
3.0	1.0	0	0	2.40	5.20	7.20	8.40	8.80
3.0	0.5	0	0	2.50	5.30	7.30	8.50	8.90
2.0	1.5	0	0	0.90	2.30	3.60	4.40	4.60
2.0	1.0	0	0	1.20	2.70	4.00	4.80	5.10
2.0	0.5	0	0	1.30	2.90	4.20	2.00	5.20
1.5	1.0	0	0	0.60	1.40	2.10	2.60	2.80
1.5	0.5	0	0	0.80	1.60	2.40	2.90	3.10
1.5	0.5	0	0	0.30	0.60	0.90	1.10	1.20

**Table 71 Deflection Coefficients along Short Side, Mid-height ( $y = a/2$ ) for Tanks having Case 3 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	z	END	0.1c	0.2c	0.3c	0.4c	0.5c
				0.9c	0.8c	0.7c	0.6c	
4.0	3.0	0	0	1.50	4.10	6.30	7.60	8.10
4.0	2.0	0	0	0.50	1.60	2.80	3.60	3.90
4.0	1.5	0	0	0.00	0.40	1.00	1.30	1.50
4.0	1.0	0	0	-0.30	-0.40	-0.40	-0.30	-0.30
4.0	0.5	0	0	-0.20	-0.40	-0.50	-0.60	-0.60
3.0	2.0	0	0	0.50	1.70	2.90	3.70	3.90
3.0	1.5	0	0	0.00	0.50	1.00	1.40	1.60
3.0	1.0	0	0	-0.30	-0.30	-0.30	-0.20	-0.20
3.0	0.5	0	0	-0.20	-0.40	-0.50	-0.60	-0.60
2.0	1.5	0	0	0.20	0.70	1.30	1.80	1.90
2.0	1.0	0	0	-0.20	-0.20	-0.10	0.00	0.00
2.0	0.5	0	0	-0.20	-0.30	-0.40	-0.50	-0.50
1.5	1.0	0	0	-0.10	0.00	0.20	0.30	0.40
1.5	0.5	0	0	-0.10	-0.20	-0.30	-0.30	-0.40
1.5	0.5	0	0	-0.10	-0.10	-0.10	-0.10	-0.20

**Table 72 Deflection Coefficients along Long side, Mid-span ( $x = b/2$ ) for Tanks having Case 3 Arrangements for Various Length/Height and Width/Height Ratios**  
*(Table 1, Clauses 3.1 and 3.1.4)*

b/a	y c/a	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	0.50	1.70	3.20	4.40	5.20	5.40	4.90	3.70	2.00	0
4.0	2.0	0	0.70	2.40	4.80	7.50	10.50	13.60	16.70	19.80	22.80	25.90
4.0	1.5	0	0.70	2.40	4.80	7.60	10.70	13.80	16.90	20.00	23.10	26.20
4.0	1.0	0	0.70	2.40	4.80	7.70	10.80	13.90	17.10	20.30	23.40	26.60
4.0	0.5	0	0.70	2.40	4.90	7.80	10.90	14.10	17.30	20.60	23.80	27.00
3.0	2.0	0	0.70	2.40	4.90	7.80	10.90	14.10	17.40	20.60	23.80	27.00
3.0	1.5	0	0.60	2.00	3.90	6.10	8.30	10.60	12.80	14.90	17.00	19.00
3.0	1.0	0	0.60	2.00	4.00	6.20	8.60	10.90	13.20	15.40	17.50	19.70
3.0	0.5	0	0.60	2.10	4.10	6.40	8.80	11.20	13.60	15.90	18.20	20.40
2.0	1.5	0	0.40	1.30	2.40	3.50	4.60	5.60	6.50	7.20	8.00	8.70
2.0	1.0	0	0.40	1.40	2.60	3.80	5.10	6.20	7.20	8.10	9.00	9.90
2.0	0.5	0	0.40	1.40	2.60	4.00	5.20	6.40	7.50	8.40	9.40	10.30
1.5	1.0	0	0.30	0.90	1.60	2.20	2.80	3.20	3.60	3.80	4.00	4.30
1.5	0.5	0	0.30	0.90	1.70	2.40	3.10	3.60	4.00	4.30	4.60	4.90
1.0	0.5	0	0.20	0.50	0.80	1.00	1.20	1.20	1.20	1.20	1.20	1.20

**Table 73 Deflection Coefficients along Short Side, Mid-span ( $z = c/2$ ) for Tanks having Case 3 Arrangements for Various Length/Height and Width/Height Ratios**

*(Table 1, Clauses 3.1 and 3.1.4)*

b/a	y c/a	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	0.60	1.90	3.80	5.90	8.10	10.20	12.30	14.30	16.30	18.20
4.0	2.0	0	0.30	1.10	2.10	3.00	3.90	4.60	5.20	5.70	6.10	6.60
4.0	1.5	0	0.20	0.60	1.00	1.30	1.50	1.50	1.40	1.30	1.10	0.90
4.0	1.0	0	0.10	0.10	0.10	-0.10	-0.30	-0.60	-1.00	-1.30	-1.70	-2.10
4.0	0.5	0	0.00	-0.10	0.30	-0.40	-0.60	-0.80	-1.00	-1.20	-1.30	-1.50
3.0	2.0	0	0.30	1.10	2.10	3.10	3.90	4.70	5.30	5.80	6.30	6.80
3.0	1.5	0	0.20	0.60	1.00	1.40	1.60	1.60	1.60	1.40	1.30	1.20
3.0	1.0	0	0.10	0.10	0.10	0.00	-0.20	-0.50	-0.90	-1.20	-1.50	-1.90
3.0	0.5	0	0.00	-0.10	-0.20	-0.40	-0.60	-0.80	-1.00	-1.10	-1.30	-1.40
2.0	1.5	0	0.20	0.70	1.20	1.60	1.90	2.10	2.10	2.10	2.10	2.10
2.0	1.0	0	0.10	0.20	0.20	0.20	0.00	-0.20	-0.40	-0.70	-0.90	-1.20
2.0	0.5	0	0.00	-0.10	-0.20	-0.30	-0.50	-0.60	-0.80	-0.90	-1.00	-1.10
1.5	1.0	0	0.10	0.30	0.40	0.40	0.40	0.20	0.10	-0.10	-0.30	-0.40
1.5	0.5	0	0.00	-0.10	-0.10	-0.20	-0.40	-0.50	-0.50	-0.60	-0.70	-0.70
1.0	0.5	0	0.00	0.00	0.00	-0.10	-0.20	-0.20	-0.20	-0.30	-0.30	-0.30

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 74 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-15	2	-76	0	19	-13	0	19	13	0	13	17
0.9a	-19	2	-95	-2	18	-11	2	19	13	3	13	16
0.8a	-17	2	-83	-1	18	-9	5	19	12	6	13	15
0.7a	-15	2	-73	0	19	-7	6	19	11	7	13	13
0.6a	-13	2	-64	2	20	-4	6	19	10	5	13	10
0.5a	-11	2	-55	2	20	-2	3	19	8	-1	12	7
0.4a	-9	2	-44	1	20	-1	-3	18	5	-12	11	3
0.3a	-6	2	-32	-3	19	-1	-16	16	1	-29	9	-3
0.2a	-4	1	-18	-12	16	-2	-35	12	-5	-53	7	-9
0.1a	-1	1	-5	-27	10	-5	-63	7	-12	-87	4	-17
BOT.	0	0	0	-51	0	-10	-102	0	-20	-131	0	-26

**Table 75 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-15	2	-76	0	14	-26	0	17	7	0	14
0.9a	-19	2	-95	-3	13	-23	1	16	7	4	14
0.8a	-17	2	-83	-4	13	-20	4	17	8	7	14
0.7a	-15	2	-73	-2	14	-16	6	17	8	10	14
0.6a	-13	2	-64	0	15	-13	7	18	8	10	14
0.5a	-11	2	-55	1	16	-9	7	19	7	7	14
0.4a	-9	2	-44	2	16	-5	3	18	5	-1	14
0.3a	-6	2	-32	-1	16	-3	-6	17	2	-14	12
0.2a	-4	1	-18	-6	14	-2	-20	14	-2	-35	9
0.1a	-1	1	-5	-17	10	-3	-43	8	-8	-65	5
BOT.	0	0	0	-34	0	-7	-76	0	-15	-105	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 76 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-12	3	-61	0	20	-9	0	19	14	0	13
0.9a	-16	6	-81	-1	19	-8	2	19	13	3	13
0.8a	-15	6	-73	-1	19	-6	5	19	13	6	13
0.7a	-13	6	-66	1	19	-4	6	19	12	6	13
0.6a	-12	5	-60	2	20	-2	6	19	10	4	13
0.5a	-10	5	-52	2	21	-1	3	19	8	-2	12
0.4a	-9	5	-43	0	21	0	-4	18	5	-13	11
0.3a	-6	4	-32	-5	19	0	-17	15	0	-30	9
0.2a	-4	3	-18	-14	16	-2	-37	12	-5	-55	7
0.1a	-1	2	-6	-30	10	-6	-65	7	-13	-89	4
BOT.	0	0	0	-54	0	-11	-104	0	-21	-133	0

**Table 77 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
	$M_{zc}$	$M_{yc}$	$M_{zc}$								
TOP	-12	3	-61	0	4	-35	0	8	-4	0	7
0.9a	-16	6	-81	-5	2	-32	0	6	-3	3	6
0.8a	-15	6	-73	-5	3	-29	2	6	-1	6	7
0.7a	-13	6	-66	-4	3	-25	4	7	0	10	7
0.6a	-12	5	-60	-2	4	-20	7	9	2	12	9
0.5a	-10	5	-52	0	6	-15	9	11	3	13	10
0.4a	-9	5	-43	2	8	-11	8	12	4	11	10
0.3a	-6	4	-32	2	10	-6	4	13	3	4	10
0.2a	-4	3	-18	0	10	-3	-4	11	1	-10	9
0.1a	-1	2	-6	7	-2	-19	8	-3	-31	6	-5
BOT.	0	0	0	-17	0	-3	-43	0	-9	-46	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 78 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-10	7	-49	0	20	-6	0	18	15	0	13
0.9a	-14	10	-69	-1	19	-5	3	18	14	3	13
0.8a	-13	10	-63	0	19	-3	5	18	13	6	13
0.7a	-12	9	-58	1	20	-2	6	19	12	6	12
0.6a	-11	9	-54	2	20	0	6	19	11	4	12
0.5a	-10	8	-48	2	21	1	3	18	8	-2	12
0.4a	-8	8	-41	0	21	1	-5	17	5	-13	10
0.3a	-6	7	-31	-6	20	1	-18	15	0	-31	9
0.2a	-4	5	-18	-16	17	-2	-39	12	-6	-56	6
0.1a	-1	3	-6	-32	10	-6	-68	7	-13	-90	4
BOT.	0	0	0	-58	0	-12	-107	0	-21	-134	0

**Table 79 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-10	7	-49	0	4	-37	0	0	-12	0	1
0.9a	-14	10	-69	-6	5	-34	-2	1	-11	1	0
0.8a	-13	10	-63	-6	5	-31	-1	1	-9	3	0
0.7a	-12	9	-58	-5	4	-27	1	1	-6	6	1
0.6a	-11	9	-54	-3	3	-23	4	1	-3	10	2
0.5a	-10	8	-48	-1	1	-19	7	3	-1	12	4
0.4a	-8	8	-41	1	1	-13	8	5	1	13	5
0.3a	-6	7	-31	2	4	-9	7	7	2	10	6
0.2a	-4	5	-18	2	5	-4	3	8	1	2	6
0.1a	-1	3	-6	-1	5	-2	-7	6	-1	-13	5
BOT.	0	0	0	-8	0	-2	-25	0	-5	-39	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 80 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-8	11	-39	0	21	-1	0	18	16	0	12
0.9a	-11	13	-56	0	20	-1	3	18	15	3	12
0.8a	-10	13	-51	1	20	0	5	18	14	5	12
0.7a	-10	13	-48	2	20	2	7	18	13	6	12
0.6a	-9	13	-45	3	21	3	6	18	11	4	12
0.5a	-8	12	-41	3	22	3	2	18	8	-3	11
0.4a	-7	12	-36	0	21	3	-6	17	5	-14	10
0.3a	-6	10	-28	-7	20	1	-20	15	0	-32	8
0.2a	-3	8	-17	-18	17	-2	-41	11	-6	-58	6
0.1a	-1	5	-6	-36	10	-6	-71	6	-14	-92	3
BOT.	0	0	0	-63	0	-13	-111	0	-22	-137	0

**Table 81 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-8	11	-39	0	10	-40	0	6	-26	0	3
0.9a	-11	13	-56	-7	10	-37	-4	7	-23	-3	4
0.8a	-10	13	-51	-7	10	-34	-5	7	-20	-3	5
0.7a	-10	13	-48	-6	10	-30	-3	7	-17	-1	4
0.6a	-9	13	-45	-5	9	-26	-1	6	-13	2	4
0.5a	-8	12	-41	-3	8	-22	2	5	-9	5	3
0.4a	-7	12	-36	-1	6	-17	4	3	-5	8	1
0.3a	-6	10	-28	1	4	-11	6	1	-2	10	0
0.2a	-3	8	-17	2	1	-6	6	2	8	3	10
0.1a	-1	5	-6	2	1	-2	3	3	0	2	1
BOT.	0	0	0	0	0	-7	0	-1	-13	0	-3

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 82 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-9	10	-43	0	21	0	0	18	16	0	12
0.9a	-11	11	-57	0	20	0	3	18	15	3	12
0.8a	-10	11	-49	1	20	1	5	18	14	5	12
0.7a	-9	11	-44	3	21	3	7	18	13	6	12
0.6a	-8	12	-39	4	21	3	6	18	11	3	12
0.5a	-7	12	-34	3	22	4	2	18	8	-3	11
0.4a	-6	13	-29	0	22	3	-6	17	5	-15	10
0.3a	-4	12	-22	-6	20	2	-20	14	0	-33	8
0.2a	-3	10	-14	-18	17	-2	-41	11	-6	-58	6
0.1a	-1	7	-5	-37	10	-7	-71	6	-14	-93	3
BOT.	0	9	0	-66	0	-13	-112	0	-22	-137	0

**Table 83 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
TOP	-9	10	-43	0	11	-55	0	7	-50	0	4
0.9a	-11	11	-57	-10	8	-50	-8	6	-45	-7	4
0.8a	-10	11	-49	-9	8	-45	-9	6	-41	-8	4
0.7a	-9	11	-44	-8	9	-39	-8	7	-35	-8	5
0.6a	-8	12	-39	-7	10	-34	-6	7	-29	-6	5
0.5a	-7	12	-34	-6	10	-38	-5	8	-23	-4	5
0.4a	-6	13	-29	-4	10	-22	-3	7	-17	-2	5
0.3a	-4	12	-22	-2	9	-15	0	6	-11	1	4
0.2a	-3	10	-14	0	7	-8	2	4	-5	4	3
0.1a	-1	7	-5	2	3	-2	4	2	-1	6	1
BOT.	0	9	0	3	0	1	4	0	1	3	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 84 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		$M_{xc}$	$M_{yc}$								
TOP	-11	1	-55	0	16	-20	0	17	9	0	13
0.9a	-16	5	-78	-2	14	-18	2	17	9	4	13
0.8a	-14	5	-71	-3	14	-15	4	17	9	7	13
0.7a	-13	4	-65	-1	15	-12	6	17	9	9	14
0.6a	-12	4	-59	0	16	-9	7	18	9	9	14
0.5a	-10	4	-52	1	17	-6	6	18	8	6	14
0.4a	-9	4	-43	1	18	-4	2	16	6	-2	13
0.3a	-6	3	-32	-2	18	-2	-7	17	2	-16	11
0.2a	-4	2	-18	-8	15	-2	-23	14	-2	-37	9
0.1a	-1	1	-6	-19	10	-4	-46	8	-9	-67	5
BOT.	0	0	0	-38	0	-8	-80	0	-16	-109	0

**Table 85 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-11	1	-55	0	4	-34	0	8	-3	0	7
0.9a	-16	5	-78	-5	3	-31	0	7	-2	3	7
0.8a	-14	5	-71	-5	3	-28	2	7	-1	6	7
0.7a	-13	4	-65	-4	4	-24	4	8	1	10	8
0.6a	-12	4	-59	-1	5	-20	7	9	2	12	9
0.5a	-10	4	-52	0	7	-15	8	11	3	13	10
0.4a	-9	4	-43	2	8	-10	8	12	4	11	10
0.3a	-6	3	-32	1	10	-6	4	13	3	10	9
0.2a	-4	2	-18	-1	10	-3	-4	12	1	-10	9
0.1a	-1	1	-6	-6	8	-2	-20	8	-3	-32	6
BOT.	0	0	0	-17	0	-3	-44	0	-9	-65	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 86 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-9	6	-44	0	17	-15	0	17	11	0	13	20
0.9a	-13	8	-66	-2	15	-13	2	17	11	4	13	19
0.8a	-12	8	-61	-2	15	-11	4	17	11	7	13	18
0.7a	-11	8	-57	0	16	-9	6	17	10	9	13	16
0.6a	-11	8	-53	1	17	-6	7	18	10	9	14	13
0.5a	-10	7	-48	1	18	-4	6	18	8	5	13	10
0.4a	-8	7	-41	0	19	-2	1	18	6	-3	13	6
0.3a	-6	6	-31	-3	18	-1	-9	17	2	-17	11	1
0.2a	-4	4	-18	-9	16	-2	-25	13	-3	-39	9	-6
0.1a	-1	3	-6	-21	11	-4	-49	8	-9	-70	5	-13
BOT.	0	0	0	-41	0	-8	-84	0	-17	-112	0	-22

**Table 87 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-9	6	-44	0	3	-35	0	0	-11	0	1
0.9a	-13	8	-66	-5	4	-32	-1	1	-10	1	1
0.8a	-12	8	-61	-6	4	-30	-1	1	-8	3	1
0.7a	-11	8	-57	-4	4	-26	2	0	-5	6	1
0.6a	-11	8	-53	-3	2	-22	4	1	-3	10	2
0.5a	-10	7	-48	-1	1	-18	7	3	-1	12	4
0.4a	-8	7	-41	1	2	-13	8	5	1	13	5
0.3a	-6	6	-31	2	4	-8	7	7	2	10	7
0.2a	-4	4	-18	1	6	-4	3	8	1	2	7
0.1a	-1	3	-6	-2	5	-2	-7	6	-1	-14	5
BOT.	0	0	0	-8	0	-2	-25	0	-5	-39	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 88 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-7	9	-34	0	18	-9	0	17	13	0	13
0.9a	-11	11	-53	-1	17	-8	2	17	13	4	13
0.8a	-10	11	-49	0	17	-6	5	17	12	7	13
0.7a	-9	12	-46	1	17	-4	7	18	12	9	13
0.6a	-9	12	-44	2	18	-3	7	18	11	9	13
0.5a	-8	11	-41	2	19	-1	5	19	9	5	13
0.4a	-7	11	-36	0	20	0	0	18	6	-4	12
0.3a	-6	10	-28	-4	19	0	-10	16	2	-19	11
0.2a	-3	8	-17	-11	17	-1	-27	13	-3	-41	8
0.1a	-1	4	-6	-25	11	-4	-53	8	-10	-73	5
BOT.	0	0	0	-46	0	-9	-89	0	-18	-115	0

**Table 89 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		$M_{zc}$	$M_{yc}$	$M_{yzc}$													
TOP	-7	9	-34	0	9	-38	0	5	-24	0	3	-14	0	2	-8	0	0
0.9a	-11	11	-53	-6	9	-35	-4	6	-22	-2	4	-12	-2	2	-6	-2	0
0.8a	-10	11	-49	-7	9	-32	-4	7	-19	-2	4	-9	-1	2	-4	-1	0
0.7a	-9	12	-46	-6	9	-29	-3	7	-16	-1	4	-6	1	2	-1	1	0
0.6a	-9	12	-44	-5	9	-25	-1	6	-12	2	4	-3	4	2	2	5	0
0.5a	-8	11	-41	-3	8	-21	2	6	-8	5	3	0	7	1	5	8	0
0.4a	-7	11	-36	-1	6	-17	4	3	-5	8	1	2	10	0	6	11	0
0.3a	-6	10	-28	1	3	-11	6	0	-2	9	1	3	11	1	6	12	0
0.2a	-3	8	-17	2	1	-6	6	2	0	8	2	3	9	1	4	9	0
0.1a	-1	4	-6	2	1	-2	2	3	0	1	3	1	1	1	0	0	1
BOT.	0	0	0	-1	0	0	-7	0	-1	-14	0	-3	-18	0	-4	-20	0
																	-4

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 90 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b		0.8b		0.7b		0.6b			
$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$
TOP	07	9	-37	0	18	-7	0	18	14	0	13
0.9a	-11	10	-54	-1	17	-6	2	17	13	4	13
0.8a	-9	10	-47	0	17	-5	5	17	13	7	13
0.7a	-8	10	-42	2	18	-3	7	18	12	9	13
0.6a	-8	11	-38	3	19	-1	8	18	11	9	13
0.5a	-7	12	-34	3	20	0	6	19	9	5	13
0.4a	-6	12	-29	1	20	1	0	18	6	-4	12
0.3a	-4	12	-22	-3	19	1	-11	16	2	-19	11
0.2a	-3	10	-14	-12	17	-1	-28	13	-3	-42	8
0.1a	-1	6	-5	-26	11	-5	-54	8	-10	-74	5
BOT.	0	0	0	-49	0	-10	-90	0	-18	-116	0

**Table 91 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c		0.8c		0.7c		0.6c			
		$M_{zc}$	$M_{yc}$								
TOP	07	9	-37	0	10	-51	0	7	-47	0	4
0.9a	-11	10	-54	-9	8	-47	-8	6	-43	-7	4
0.8a	-9	10	-47	-9	8	-42	-8	6	-39	-8	4
0.7a	-8	10	-42	-8	8	-38	-8	6	-34	-7	4
0.6a	-8	11	-38	-7	9	-33	-6	7	-28	-6	5
0.5a	-7	12	-34	-6	9	-27	-5	7	-23	-4	5
0.4a	-6	12	-29	-4	9	-22	-3	7	-16	-2	5
0.3a	-4	12	-22	-2	8	-15	0	6	-10	1	4
0.2a	-3	10	-14	0	6	-8	2	4	-5	4	3
0.1a	-1	6	-5	2	3	-2	4	2	-1	5	1
BOT.	0	0	0	3	0	-1	4	0	1	3	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 92 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
		$M_{xc}$	$M_{yc}$								
TOP	-6	1	-30	0	8	-21	0	9	4	0	8
0.9a	-11	4	-54	-3	7	-19	1	8	4	3	7
0.8a	-11	4	-53	-3	7	-17	3	8	5	7	7
0.7a	-10	4	-51	-2	7	-15	5	9	5	10	8
0.6a	-10	4	-49	0	9	-13	7	11	6	12	9
0.5a	-9	4	-46	1	10	-10	8	12	6	12	10
0.4a	-8	4	-40	1	12	-7	6	14	6	9	11
0.3a	-6	3	-31	0	13	-4	2	14	4	0	11
0.2a	-4	3	-19	-3	13	-3	-8	12	0	-15	9
0.1a	-1	2	-6	-10	9	-2	-25	8	-4	-38	6
BOT	0	0	0	-22	0	-4	-52	0	-10	-73	0

**Table 93 Moment Coefficients along Short Side for Rectangular Tanks Having Case 3 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-6	1	-30	0	1	-28	0	1	-7	0	2
0.9a	-11	4	-54	-4	2	-26	-1	0	-6	1	1
0.8a	-11	4	-53	-5	2	-24	0	0	-4	4	1
0.7a	-10	14	-51	-4	1	-22	2	1	-2	7	2
0.6a	-10	4	-49	-2	0	-19	5	2	-1	10	3
0.5a	-9	4	-46	-1	1	-16	7	4	1	12	5
0.4a	-8	4	-40	1	4	-12	7	7	2	12	6
0.3a	-6	3	-31	1	6	-8	6	8	2	8	7
0.2a	-4	3	-19	1	7	-4	1	9	1	0	7
0.1a	-1	2	-6	-3	6	-2	-9	7	-1	-16	5
BOT.	0	0	0	-10	0	-2	-29	0	-6	-43	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 94 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-4	5	-22	0	10	-13	0	10	8	0	20
0.9a	-8	7	-42	-2	9	-12	1	10	8	3	8
0.8a	-8	7	-41	-1	9	-11	4	10	8	7	8
0.7a	-8	8	-41	0	10	-10	6	11	8	10	9
0.6a	-8	8	-41	1	11	-8	8	12	8	12	10
0.5a	-8	8	-39	1	12	-6	8	13	8	12	11
0.4a	-7	8	-35	1	14	-4	6	14	7	8	11
0.3a	-6	7	-28	-1	15	-3	0	15	4	-2	11
0.2a	-4	6	-18	-5	14	-2	-11	13	0	-18	9
0.1a	-1	3	-6	-13	10	-3	-29	8	-5	-43	6
BOT.	0	0	0	-27	0	-5	-57	0	-11	-79	0

**Table 95 Moment Coefficients along Short Side for Rectangular Tanks Having Case 3 Arrangements for  $b/a = 2.0, c/a = 1.0$**   
 ( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-4	5	-22	0	7	-29	0	4	-18	0	2
0.9a	-8	7	-42	-5	7	-27	-3	5	-16	-2	3
0.8a	-8	7	-41	-6	7	-26	-3	5	-14	-2	4
0.7a	-8	8	-41	-5	7	-24	-2	5	-11	0	3
0.6a	-8	8	-41	-4	7	-22	0	5	-9	3	3
0.5a	-8	8	-39	-3	6	-19	2	3	-6	5	2
0.4a	-7	8	-35	-1	4	-15	4	1	-3	8	0
0.3a	-6	7	-28	0	2	-11	5	1	-1	9	2
0.2a	-4	6	-18	1	1	-6	5	3	0	7	3
0.1a	-1	3	-6	1	2	-2	1	4	0	-1	3
BOT.	0	0	0	-2	0	0	-10	0	-2	-17	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 96 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-5	5	-24	0	10	-11	0	9	0	9	21
0.9a	-8	6	-41	-1	9	-10	2	10	9	4	8
0.8a	-8	7	-38	-1	10	-9	4	10	9	7	9
0.7a	-7	7	-36	1	10	-7	7	11	10	11	9
0.6a	-7	8	-34	2	12	-5	9	12	10	13	10
0.5a	-6	9	-31	3	13	-3	9	14	9	12	11
0.4a	-5	10	-27	2	15	-2	6	15	7	7	11
0.3a	-3	10	-22	0	16	-1	0	15	5	-2	11
0.2a	-3	9	-14	-5	15	-1	-12	13	0	-19	9
0.1a	-1	6	-5	-14	10	-3	-31	8	-5	-44	6
BOT.	0	0	0	-31	0	-6	-61	0	-12	-81	0

**Table 97 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-5	-24	0	8	-39	0	5	-36	0	3	-34
0.9a	-8	6	-41	-7	5	-36	-6	4	-33	-5	3
0.8a	-8	7	-38	-7	5	-34	-7	4	-30	-6	3
0.7a	-7	7	-36	-7	6	-31	-6	5	-27	-6	3
0.6a	-7	8	-34	-6	7	-28	-6	5	-23	-5	4
0.5a	-6	9	-31	-5	7	-24	-4	6	-19	-4	4
0.4a	-5	10	-27	-4	8	-20	-3	6	-14	-2	4
0.3a	-3	10	-22	-2	7	-14	-1	5	-9	1	3
0.2a	-3	9	-14	0	5	-8	2	3	-4	3	2
0.1a	-1	6	-5	2	3	-2	4	1	-1	5	0
BOT.	0	0	0	3	0	1	3	0	1	2	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 98 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-2	2	-12	-0	4	-12	0	4	0	4	15
0.9a	-6	3	-31	-2	3	-11	1	3	4	2	3
0.8a	-7	4	-33	-2	3	-11	2	3	5	3	15
0.7a	-7	4	-35	-1	3	-11	4	4	5	8	4
0.6a	-7	4	-36	0	5	-10	6	5	6	11	5
0.5a	-7	5	-36	0	7	-9	7	7	6	12	6
0.4a	-7	5	-33	1	8	-7	7	9	6	10	8
0.3a	-5	4	-27	0	10	-5	4	11	4	5	14
0.2a	-4	4	-18	-2	11	-3	11	2	-3	8	3
0.1a	-1	2	-6	-7	8	-2	-16	8	-2	-24	5
BOT.	0	0	0	-16	0	-3	-38	0	-8	-54	0

**Table 99 Moment Coefficients along Short Side for rectangular tanks having Case 3 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-2	2	-12	0	4	-20	0	3	-11	0	2
0.9a	-6	3	-31	-3	4	-19	-2	4	-10	-1	-2
0.8a	-7	4	-33	-4	4	-19	-2	4	-8	0	3
0.7a	-7	4	-35	-4	4	-19	-1	4	-7	1	2
0.6a	-7	4	-36	-3	4	-18	0	3	-5	3	2
0.5a	-7	5	-36	-2	3	-16	2	2	-3	6	1
0.4a	-7	5	-33	-1	2	-13	4	0	-1	7	1
0.3a	-5	4	-27	0	0	-10	5	3	0	8	3
0.2a	-4	4	-18	1	2	-5	4	4	1	5	4
0.1a	-1	2	-6	0	3	-2	-1	4	0	-3	4
BOT.	0	0	0	-4	0	-1	-13	0	-3	-21	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 100 Moment Coefficients along Long Side for Rectangular Tanks Having Case 3 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		$M_{xc}$	$M_{yc}$								
TOP	-3	2	-13	0	4	-9	0	5	6	0	4
0.9a	-6	3	-28	-1	4	-8	1	4	7	3	4
0.8a	-6	3	-29	-1	4	-8	3	4	7	6	4
0.7a	-6	4	-28	0	5	-7	5	5	8	9	4
0.6a	-6	5	-28	1	6	-6	7	6	8	12	5
0.5a	-5	6	-27	2	8	-4	8	8	8	13	7
0.4a	-5	7	-25	2	10	-3	8	10	7	11	8
0.3a	-4	8	-21	1	12	-2	4	11	5	5	9
0.2a	-3	7	-14	-1	12	-1	-4	11	2	-7	8
0.1a	-1	5	-5	-8	9	-2	-18	8	-3	-27	5
BOT	0	0	0	-21	0	-4	-43	0	-9	-59	0

**Table 101 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		$M_{zc}$	$M_{yc}$	$M_{yzc}$													
TOP	-3	2	-13	0	5	-26	0	3	-24	0	2	-23	0	1	22-	0	0
0.9a	-6	3	-28	-5	3	-25	-4	3	-23	-3	2	-21	-3	1	20-	-3	0
0.8a	-6	3	-29	-5	3	-25	-5	3	-22	-4	2	-19	-4	1	18-	-4	0
0.7a	-6	4	-28	-5	4	-24	-5	3	-20	-5	2	-17	-4	1	-16	-4	0
0.6a	-6	5	-28	-5	5	-22	-4	4	-18	-4	3	-15	-4	1	12-	-4	0
0.5a	-5	6	-27	-5	6	-20	-4	4	-15	-3	3	-11	-3	1	9-	-3	0
0.4a	-5	7	-25	-4	7	-17	-3	4	-12	-2	3	-8	-1	1	5-	-1	0
0.3a	-4	8	-21	-2	8	-13	-1	4	-8	-1	2	-4	1	1	2-	2	0
0.2a	-3	7	-14	-1	7	-8	1	2	-4	3	1	-1	4	1	1	4	0
0.1a	-1	5	-5	1	5	-2	3	1	-1	4	0	1	4	0	1	5	0
BOT.	0	0	0	2	0	0	1	0	0	0	-1	0	0	-1	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 102 Moment Coefficients along Long Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.8b</b>	<b>0.9b</b>	<b>0.8b</b>	<b>0.9b</b>	<b>0.7b</b>	<b>0.8b</b>	<b>0.9b</b>	<b>0.7b</b>	<b>0.8b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	-1	0	-3	0	0	-4	0	0	3	0	0
0.9a	-3	0	-13	-1	1	-4	0	0	4	1	0
0.8a	-3	0	-15	-1	1	-4	1	1	4	2	0
0.7a	-3	1	-17	0	0	-5	2	0	4	4	0
0.6a	-4	1	-19	0	1	-5	4	1	5	7	1
0.5a	-4	2	-21	1	2	-5	5	2	5	8	2
0.4a	-4	3	-21	1	4	-4	5	4	5	9	3
0.3a	-4	4	-19	1	6	4	5	6	4	7	5
0.2a	-3	4	-14	0	7	-2	1	7	3	2	6
0.1a	-1	3	-6	-3	6	-1	-7	6	0	-10	4
BOT.	0	0	0	-10	0	-2	-23	0	-5	-33	0

**Table 103 Moment Coefficients along Short Side for Rectangular Tanks having Case 3 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
	$M_{zc}$	$M_{yc}$	$M_{zc}$								
TOP	-1	0	-3	0	2	-11	0	1	-10	0	0
0.9a	-3	0	-13	-2	1	-11	-2	1	-10	1	-9
0.8a	-3	0	-15	-3	1	-12	-2	1	-10	-2	1
0.7a	-3	1	-17	-3	1	-13	-2	1	-10	-2	1
0.6a	-4	1	-19	-3	2	-14	-3	2	-9	-2	1
0.5a	-4	2	-21	-3	2	-14	-2	2	-8	-2	1
0.4a	-4	3	-21	-3	3	-13	-2	2	-7	-1	1
0.3a	-4	4	-19	-2	3	-10	-1	2	-5	-1	1
0.2a	-3	4	-14	-1	2	-7	1	1	-2	0	1
0.1a	-1	3	-6	1	0	-2	2	1	0	2	1
BOT.	0	0	0	1	0	0	-1	0	-3	0	-1

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 104 Deflection Coefficients along Long Side, Mid-height ( $y = a/2$ ) for Tanks having Case 4 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

$b/a$	$c/a$	$x$	End	<b>0.1b</b>	<b>0.2b</b>	<b>0.3b</b>	<b>0.4b</b>	<b>0.5b</b>
				<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	
4.0	3.0	0	0	1.20	2.00	2.30	2.30	2.30
4.0	2.0	0	0	1.20	2.00	2.30	2.30	2.30
4.0	1.5	0	0	1.20	2.00	2.30	2.30	2.30
4.0	1.0	0	0	1.20	2.00	2.30	2.30	2.30
4.0	0.5	0	0	1.30	2.10	2.30	2.30	2.30
3.0	2.0	0	0	0.80	1.70	2.10	2.30	2.30
3.0	1.5	0	0	0.80	1.70	2.10	2.30	2.30
3.0	1.0	0	0	0.90	1.70	2.10	2.30	2.30
3.0	0.5	0	0	1.00	1.80	2.10	2.30	2.30
2.0	1.5	0	0	0.50	1.20	1.70	1.90	2.00
2.0	1.0	0	0	0.50	1.20	1.70	2.00	2.10
2.0	0.5	0	0	0.60	1.30	1.80	2.00	2.10
1.5	1.0	0	0	0.30	0.80	1.20	1.50	1.60
1.5	0.5	0	0	0.40	1.00	1.40	1.60	1.70
1.0	0.5	0	0	0.20	0.50	0.70	0.90	0.90

**Table 105 Deflection Coefficients along Short Side, Mid-height ( $y = a/2$ ) for Tanks having Case 4 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

$b/a$	$c/a$	$z$	End	<b>0.1c</b>	<b>0.2c</b>	<b>0.3c</b>	<b>0.4c</b>	<b>0.5c</b>
				<b>0.9c</b>	<b>0.8c</b>	<b>0.7c</b>	<b>0.6c</b>	
4.0	3.0	0	0	0.80	1.70	2.10	2.30	2.30
4.0	2.0	0	0	0.50	1.10	1.70	1.90	2.00
4.0	1.5	0	0	0.30	0.80	1.20	1.50	1.60
4.0	1.0	0	0	0.10	0.30	0.50	0.60	0.70
4.0	0.5	0	0	-0.10	-0.10	-0.10	-0.10	-0.10
3.0	2.0	0	0	0.50	1.10	1.70	1.90	2.00
3.0	1.5	0	0	0.30	0.80	1.20	1.50	1.60
3.0	1.0	0	0	0.10	0.30	0.50	0.60	0.70
3.0	0.5	0	0	-0.10	-0.10	-0.10	-0.10	-0.10
2.0	1.5	0	0	0.30	0.80	1.20	1.50	1.60
2.0	1.0	0	0	0.10	0.30	0.50	0.60	0.70
2.0	0.5	0	0	-0.10	-0.10	-0.10	-0.10	-0.10
1.5	1.0	0	0	0.10	0.30	0.50	0.60	0.70
1.5	0.5	0	0	-0.10	-0.10	-0.10	-0.10	-0.10
1.0	0.5	0	0	0.00	-0.10	-0.10	-0.10	-0.10

**Table 106 Deflection Coefficients along Long Side, Mid-span ( $x = b/2$ ) for Tanks having Case 4 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

$b/a$	$y \backslash c/a$	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	0.30	0.90	1.50	2.00	2.30	2.40	2.10	1.50	0.80	0
4.0	2.0	0	0.30	0.90	1.50	2.00	2.30	2.40	2.10	1.50	0.80	0
4.0	1.5	0	0.30	0.90	1.50	2.00	2.30	2.40	2.10	1.50	0.80	0
4.0	1.0	0	0.30	0.90	1.50	2.00	2.30	2.40	2.10	1.50	0.80	0
4.0	0.5	0	0.30	0.90	1.50	2.00	2.30	2.40	2.10	1.50	0.80	0
3.0	2.0	0	0.30	0.90	1.50	2.00	2.30	2.40	2.00	1.50	0.80	0
3.0	1.5	0	0.30	0.90	1.50	2.00	2.30	2.40	2.00	1.50	0.80	0
3.0	1.0	0	0.30	0.90	1.50	2.00	2.30	2.40	2.00	1.50	0.80	0
3.0	0.5	0	0.30	0.90	1.50	2.00	2.30	2.40	2.00	1.50	0.80	0
2.0	1.5	0	0.20	0.80	1.40	1.80	2.00	2.00	1.80	1.30	0.70	0
2.0	1.0	0	0.30	0.80	1.40	1.80	2.10	2.00	1.80	1.30	0.70	0
2.0	0.5	0	0.30	0.80	1.40	1.90	2.10	2.10	1.80	1.30	0.70	0
1.5	1.0	0	0.20	0.60	1.10	1.40	1.60	1.60	1.40	1.00	0.50	0
1.5	0.5	0	0.20	0.70	1.20	1.50	1.70	1.70	1.40	1.10	0.60	0
1.0	0.5	0	0.10	0.40	0.70	0.80	0.90	0.90	0.70	0.50	0.30	0

**Table 107 Deflection Coefficients along Short Side, Mid-span ( $z = c/2$ ) for Tanks having Case 4 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

$b/a$	$y \backslash c/a$	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	0.30	0.90	1.50	2.00	2.30	2.30	2.00	1.50	0.80	0
4.0	2.0	0	0.20	0.80	1.40	1.80	2.00	2.00	1.80	1.30	0.70	0
4.0	1.5	0	0.20	0.60	1.10	1.40	1.60	1.50	1.30	1.00	0.50	0
4.0	1.0	0	0.10	0.30	0.50	0.60	0.70	0.60	0.50	0.40	0.20	0
4.0	0.5	0	0.00	0.00	0.00	-0.10	-0.10	-0.10	-0.10	-0.10	-0.10	0
3.0	2.0	0	0.20	0.80	1.40	1.80	2.00	2.00	1.80	1.30	0.70	0
3.0	1.5	0	0.20	0.60	1.10	1.40	1.60	1.50	1.30	1.00	0.50	0
3.0	1.0	0	0.10	0.30	0.50	0.60	0.70	0.60	0.50	0.40	0.20	0
3.0	0.5	0	0.00	0.00	0.00	-0.10	-0.10	-0.10	-0.10	-0.10	-0.10	0
2.0	1.5	0	0.20	0.60	1.10	1.40	1.60	1.50	1.30	1.00	0.50	0
2.0	1.0	0	0.10	0.30	0.50	0.60	0.70	0.60	0.50	0.40	0.20	0
2.0	0.5	0	0.00	0.00	0.00	-0.10	-0.10	-0.10	-0.10	-0.10	-0.10	0
1.5	1.0	0	0.10	0.30	0.50	0.60	0.70	0.60	0.60	0.40	0.20	0
1.5	0.5	0	0.00	0.00	0.00	-0.10	-0.10	-0.10	-0.10	-0.10	-0.10	0
1.0	0.5	0	0.00	0.00	0.00	0.00	-0.10	-0.10	-0.10	-0.10	0.00	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 108 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>ye</sub></b>	<b>M<sub>xe</sub></b>	<b>M<sub>ye</sub></b>	<b>M<sub>xe</sub></b>	<b>M<sub>ye</sub></b>	<b>M<sub>xe</sub></b>	<b>M<sub>ye</sub></b>	<b>M<sub>xe</sub></b>	<b>M<sub>yc</sub></b>
TOP	0	1	0	0	9	0	0	4	0	0	0
0.9a	-2	1	-11	4	8	2	8	3	9	2	1
0.8a	-4	1	-21	8	7	4	15	3	18	4	1
0.7a	-6	1	-29	11	5	6	21	2	7	25	0
0.6a	-7	0	-35	14	2	7	25	0	9	29	7
0.5a	-7	0	-37	15	2	8	26	1	9	29	7
0.4a	-7	0	-35	14	4	7	22	2	7	24	6
0.3a	-6	1	-28	10	7	6	13	3	5	13	1
0.2a	-4	1	-18	1	7	2	-3	2	1	-5	1
0.1a	-1	1	-6	-15	5	-2	-27	2	-5	-31	0
BOT.	0	0	0	-41	0	-8	-61	0	-12	-66	-13

**Table 109 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	1	0	0	10	0	0	6	0	0	0
0.9a	-2	1	-11	3	9	1	7	6	3	9	1
0.8a	-4	1	-21	5	8	2	13	5	6	16	2
0.7a	-6	1	-29	7	5	3	18	3	8	23	1
0.6a	-7	0	-35	9	2	3	21	1	9	26	0
0.5a	-7	0	-37	10	1	4	22	1	9	27	1
0.4a	-7	0	-35	10	5	4	19	3	8	23	2
0.3a	-6	1	-28	7	7	4	12	5	6	13	2
0.2a	-4	1	-18	1	8	2	-1	5	2	-4	2
0.1a	-1	1	-6	-11	6	-1	-23	3	-4	-28	1
BOT.	0	0	0	-31	0	-6	-54	0	-11	-63	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 110 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0$ ,  $c/a = 2.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
		$M_{xc}$	$M_{yc}$								
TOP	0	1	0	0	9	0	0	4	0	0	0
0.9a	-2	1	-11	4	8	2	8	3	3	9	1
0.8a	-4	1	-21	8	7	4	15	3	5	18	1
0.7a	-6	1	-29	11	5	6	21	2	7	25	0
0.6a	-7	0	-34	14	2	7	25	0	9	29	0
0.5a	-7	0	-37	15	2	8	26	1	9	29	0
0.4a	-7	0	-35	14	4	7	22	2	7	24	1
0.3a	-6	1	-28	10	7	6	13	3	5	13	1
0.2a	-4	1	-18	1	7	2	-3	2	1	-5	1
0.1a	-1	1	-6	-15	5	-2	-27	2	-5	0	-31
BOT.	0	0	0	-41	0	-8	-61	0	-12	-66	0

**Table 111 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0$ ,  $c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	1	0	0	9	0	0	0	6	0	0
0.9a	-2	1	-11	1	9	-1	4	8	2	6	3
0.8a	-4	1	-21	2	7	-3	8	7	4	12	5
0.7a	-6	1	-29	3	5	3	11	5	6	17	3
0.6a	-7	0	-34	4	2	-3	14	2	7	21	1
0.5a	-7	0	-37	5	1	-3	15	1	8	22	1
0.4a	-7	0	-35	5	4	-2	14	4	7	19	3
0.3a	-6	1	-28	4	7	-1	10	7	6	12	4
0.2a	-4	1	-18	1	8	0	1	7	3	-1	4
0.1a	-1	1	-6	-6	7	-1	-15	5	-2	-22	3
BOT	0	0	0	-19	0	-4	-41	0	-8	-54	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 112 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0$ ,  $c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>vc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>vc</sub></b>	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>vc</sub></b>	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>vc</sub></b>
TOP	0	1	0	0	9	0	0	4	0	0	0
0.9a	-2	1	-11	4	8	2	8	3	3	9	1
0.8a	-4	1	-21	8	7	4	15	3	5	18	1
0.7a	-6	1	-29	12	5	6	21	2	7	25	0
0.6a	-7	0	-35	14	2	7	25	0	9	29	0
0.5a	-7	0	-37	15	2	8	26	1	9	29	0
0.4a	-7	0	-35	14	4	7	22	2	7	24	1
0.3a	-6	1	-28	10	7	6	13	3	5	13	1
0.2a	-4	1	-18	1	7	2	-3	2	1	-5	1
0.1a	-1	1	-6	-15	5	-2	-27	2	-5	0	-31
BOT.	0	0	0	-41	0	-8	-61	0	-12	-66	0

**Table 113 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	1	0	0	7	0	0	0	7	0	0
0.9a	-2	1	-11	0	7	-3	2	8	1	4	6
0.8a	-4	1	-20	0	6	-5	5	7	2	8	5
0.7a	-6	1	-28	1	5	-7	7	5	3	12	4
0.6a	-7	0	-34	1	2	-8	9	2	4	14	1
0.5a	-7	0	-36	1	0	-8	10	1	5	16	1
0.4a	-7	0	-34	2	3	-6	10	4	5	15	3
0.3a	-6	1	-28	2	6	-4	7	7	4	11	5
0.2a	-4	1	-18	0	7	-2	2	8	2	1	6
0.1a	-1	1	-6	-4	6	-1	-10	6	-1	-16	4
BOT	0	0	0	-12	0	-2	-31	0	-6	-44	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 114 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0$ ,  $c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.9b				0.2b				0.7b				0.3b				0.4b				0.6b				0.5b			
		$M_{xc}$	$M_{yc}$																										
TOP	0	3	0	0	9	0	0	3	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
0.9a	-2	2	-9	4	8	2	8	3	3	9	1	2	10	0	2	10	0	2	10	0	0	0	0	0	0	0	0	2	
0.8a	-4	2	-18	9	7	4	16	3	5	18	1	4	19	0	4	10	0	4	10	0	0	0	0	0	0	0	0	4	
0.7a	-5	1	-25	12	4	6	22	2	7	25	0	6	25	0	5	26	0	5	26	0	0	0	0	0	0	0	0	5	
0.6a	-6	0	-30	15	2	7	25	0	9	29	0	7	29	0	6	29	0	6	29	0	0	0	0	0	0	0	0	6	
0.5a	-6	1	-32	16	1	8	26	1	9	29	0	7	29	0	6	29	0	6	29	0	0	0	0	0	0	0	0	6	
0.4a	-6	1	-31	14	4	8	22	2	7	24	1	6	24	0	5	24	0	5	24	0	0	0	0	0	0	0	0	5	
0.3a	-5	2	-26	10	6	6	13	2	5	13	1	3	13	0	3	13	0	3	13	0	0	0	0	0	0	0	0	3	
0.2a	-4	2	-18	1	7	3	-3	2	1	-5	1	-1	-5	0	-1	-5	0	-1	-5	0	0	-1	-5	0	0	-1	-5		
0.1a	-1	1	-6	-16	5	-2	-27	2	-5	-31	0	-6	-31	0	-6	-31	0	-6	-31	0	-6	-31	0	-6	-31	0	-6		
BOT.	0	0	0	-42	0	-8	-62	0	-12	-66	0	-13	-67	0	-13	-67	0	-13	-67	0	-13	-67	0	-13	-67	0	-13		

**Table 115 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$
TOP	0	3	0	0	3	0	0	5	0	0	4
0.9a	-2	2	-9	-1	3	4	0	5	0	1	4
0.8a	-4	2	-18	-2	3	-7	0	4	-1	2	4
0.7a	-6	1	-25	-2	3	-10	1	3	-1	3	5
0.6a	-7	0	-30	-2	2	-12	2	2	0	5	2
0.5a	-7	1	-32	-2	1	-12	3	0	0	7	9
0.4a	-7	1	-31	-1	1	-11	4	2	1	8	2
0.3a	-6	2	-26	0	3	-8	4	4	1	7	4
0.2a	-4	2	-18	0	4	-5	2	6	1	4	5
0.1a	-1	1	-6	-1	4	-2	-3	5	0	-6	4
BOT.	0	0	0	-5	0	-1	-16	0	-3	-25	0
											-7

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 116 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	6	0	0	8	0	0	3	0	0	0
0.9a	-1	6	-6	5	8	3	8	3	10	1	2
0.8a	-2	5	-12	10	6	5	16	2	5	18	1
0.7a	-3	3	-17	14	4	7	22	1	7	25	0
0.6a	-4	1	-20	16	2	8	26	0	8	29	0
0.5a	-4	1	-22	17	1	9	26	1	8	29	0
0.4a	-4	3	-22	16	4	8	22	2	7	24	0
0.3a	-4	4	-20	10	6	6	13	2	5	13	1
0.2a	-3	5	-14	0	7	3	-3	2	0	-5	0
0.1a	-1	4	-6	-17	5	-3	-28	1	-5	-31	0
BOT.	0	0	0	-45	0	-9	-62	0	-12	-66	0

**Table 117 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		<b>0.9c</b>	<b>0.8c</b>	<b>0.7c</b>	<b>0.6c</b>	<b>0.4c</b>	<b>0.3c</b>	<b>0.2c</b>	<b>0.1c</b>	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>zc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>zc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>zc</sub></b>	
TOP	0	6	0	0	3	0	0	2	0	0	1	0	0	0	0	0	0
0.9a	-1	6	-6	-1	3	-4	-1	2	-3	-1	1	-2	-1	0	-1	0	-1
0.8a	-2	5	-12	-2	2	-8	-2	1	-5	-2	1	-4	-2	0	-2	0	-2
0.7a	-3	3	-17	-3	1	-11	-3	1	-7	-3	0	-5	-3	0	-3	0	-2
0.6a	-4	1	-20	-4	0	-14	-3	0	-8	-3	0	-5	-3	0	-3	0	-2
0.5a	-4	1	-22	-4	1	-14	-3	1	-8	-3	1	-4	-2	0	-2	0	-1
0.4a	-4	3	-22	-3	2	-14	-2	2	-7	-2	1	-3	-1	0	0	-1	0
0.3a	-4	4	-20	-2	3	-11	-1	2	-5	0	1	-1	1	0	1	0	2
0.2a	-3	5	-14	-1	2	-7	1	1	-2	2	0	0	3	0	2	3	0
0.1a	-1	4	-6	1	1	-2	2	1	0	2	1	1	3	0	1	3	0
BOT.	0	0	0	1	0	0	-1	0	0	-3	0	-1	-4	0	-1	-5	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 118 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 3.0$ ,  $c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	1	0	0	10	0	0	6	0	0	0
0.9a	-2	1	-11	3	9	1	7	6	3	9	3
0.8a	-4	1	-21	5	8	2	13	5	6	16	2
0.7a	-6	0	-29	7	5	3	18	3	8	23	1
0.6a	-7	0	-35	9	2	3	21	1	9	26	0
0.5a	-7	0	-37	10	1	4	22	1	9	27	1
0.4a	-7	0	-35	10	5	4	19	3	8	23	2
0.3a	-6	0	-29	7	7	4	12	4	6	13	2
0.2a	-4	1	-18	1	8	2	-1	5	2	-4	2
0.1a	-1	1	-6	-11	6	-1	-23	3	-4	-28	1
BOT.	0	0	0	-31	0	-6	-54	0	-11	-63	0

**Table 119 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	1	0	0	9	0	0	0	6	0	0
0.9a	-2	1	-11	1	9	-1	4	8	2	6	3
0.8a	-4	1	-21	2	7	-3	8	7	4	12	5
0.7a	-6	0	-29	3	5	-3	11	5	6	17	3
0.6a	-7	0	-35	4	2	-3	14	2	7	21	1
0.5a	-7	0	-37	5	1	-3	15	1	8	22	1
0.4a	-7	0	-35	5	4	-2	14	4	7	19	3
0.3a	-6	0	-29	4	7	-1	10	7	6	12	4
0.2a	-4	1	-18	1	8	0	1	7	3	-1	4
0.1a	-1	1	-6	-6	7	-1	-15	5	-2	-22	3
BOT	0	0	0	-19	0	-4	-41	0	-8	-54	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 120 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	1	0	0	10	0	0	6	0	0	0
0.9a	-2	1	-11	3	9	1	7	6	3	9	3
0.8a	-4	1	-20	5	8	2	13	5	6	16	2
0.7a	-6	0	-28	8	5	3	18	3	8	23	1
0.6a	-7	0	-34	9	2	3	21	1	9	26	0
0.5a	-7	0	-36	10	1	4	22	1	9	27	1
0.4a	-7	0	-34	10	5	4	19	3	8	23	1
0.3a	-6	1	-28	7	7	4	12	4	6	13	2
0.2a	-4	1	-18	1	8	2	-1	4	2	-4	2
0.1a	-1	1	-6	-11	6	-1	-23	3	-4	-28	1
BOT.	0	0	0	-31	0	-6	-54	0	-11	-63	0

**Table 121 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	1	0	0	7	0	0	0	7	0	0
0.9a	-2	1	-11	0	7	-3	2	8	1	4	6
0.8a	-4	1	-20	0	6	-5	5	7	2	8	5
0.7a	-6	0	-28	1	5	-7	7	5	3	12	4
0.6a	-7	0	-34	1	2	-8	9	2	4	14	1
0.5a	-7	0	-36	1	0	-8	10	1	5	16	1
0.4a	-7	0	-34	2	3	-6	10	4	6	15	3
0.3a	-6	1	-28	2	6	-4	7	7	4	11	5
0.2a	-4	1	-18	0	7	-2	2	8	2	1	6
0.1a	-1	1	-6	-4	6	-1	-10	6	-1	-16	4
BOT	0	0	0	-12	0	-2	-31	0	-6	-44	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 122 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	0	0	2	10	0	0	6	0	0	3	0
0.9a	-2	-9	2	9	1	7	6	3	9	2	3
0.8a	-4	-18	2	8	2	13	5	6	17	2	5
0.7a	-5	-25	1	5	3	18	3	8	23	1	7
0.6a	-6	-30	0	2	4	21	1	9	27	0	8
0.5a	-6	-32	1	1	5	22	1	9	27	1	8
0.4a	-6	-31	1	5	5	20	3	8	23	1	7
0.3a	-5	-27	2	7	4	12	4	6	13	2	4
0.2a	-4	-18	2	8	2	-1	4	2	-4	2	0
0.1a	-1	-6	1	6	-1	-23	3	-4	-29	1	-5
BOT.	0	0	0	0	-7	-55	0	-11	-63	0	-13

**Table 123 Moment Coefficients along Short side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c		
		$M_{xc}$	$M_{yc}$													
TOP	0	2	0	0	3	0	0	5	0	0	4	0	0	3	0	0
0.9a	-2	2	-9	-1	3	-4	0	5	0	1	4	2	2	2	3	2
0.8a	-4	2	-18	-2	3	-7	0	4	-1	2	4	4	3	2	6	4
0.7a	-5	1	-25	-2	3	-10	1	3	-1	3	3	5	5	2	8	6
0.6a	-6	0	-30	-2	2	-12	2	2	0	5	2	6	7	1	10	8
0.5a	-6	1	-32	-2	1	-12	3	0	0	6	0	7	9	0	11	10
0.4a	-6	1	-31	-1	1	-11	4	2	1	8	2	7	10	1	10	11
0.3a	-5	2	-27	-0	3	-8	4	4	1	7	4	6	9	2	9	10
0.2a	-4	2	-18	-0	4	-5	2	6	1	4	5	4	4	3	5	4
0.1a	-1	1	-6	-1	4	-2	-3	4	0	-6	4	0	-8	2	0	5
BOT.	0	0	0	-5	0	-1	-16	0	-3	-25	0	-5	-31	0	-6	-33
																-7

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 124 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	<b>M<sub>xc</sub></b>
TOP	0	6	0	0	9	0	0	5	0	0	M <sub>yc</sub>
0.9a	-1	5	-6	4	9	2	9	5	3	9	M <sub>yc</sub>
0.8a	-2	5	-12	7	7	3	14	4	6	17	M <sub>yc</sub>
0.7a	-3	3	-17	10	5	5	19	3	8	23	M <sub>yc</sub>
0.6a	-4	1	-20	12	2	6	22	1	9	27	M <sub>yc</sub>
0.5a	-4	1	-22	13	1	7	23	1	9	27	M <sub>yc</sub>
0.4a	-4	3	-22	12	5	6	20	3	8	23	M <sub>yc</sub>
0.3a	-4	4	-20	8	7	5	12	4	6	13	M <sub>yc</sub>
0.2a	-3	5	-14	1	8	3	-2	4	1	-4	M <sub>yc</sub>
0.1a	-1	4	-6	-13	6	-2	-24	3	-4	-29	M <sub>yc</sub>
BOT.	0	0	0	-36	0	-7	-57	0	-11	-64	M <sub>yc</sub>

**Table 125 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		<b>0.9c</b>	<b>0.8c</b>	<b>0.7c</b>	<b>0.6c</b>	<b>0.4c</b>	<b>0.3c</b>	<b>0.2c</b>	<b>0.1c</b>	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>zc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>zc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>zc</sub></b>	
TOP	0	6	0	0	3	0	0	2	0	0	1	0	0	0	0	0	0
0.9a	-1	5	-6	-1	3	-4	-1	2	-3	-1	1	-2	-1	0	-1	0	-1
0.8a	-2	5	-12	-2	2	-8	-2	1	-5	-2	1	-4	-2	0	-2	0	-2
0.7a	-3	3	-17	-3	1	-11	-3	1	-7	-3	0	-5	-3	0	-3	0	-2
0.6a	-4	1	-20	-4	0	-14	-3	0	-8	-3	0	-5	-3	0	-3	0	-2
0.5a	-4	1	-22	-4	1	-14	-3	1	-8	-3	1	-4	-2	0	-2	0	-1
0.4a	-4	3	-22	-3	2	-14	-2	2	-7	-2	1	-3	-1	1	0	-1	0
0.3a	-4	4	-20	-2	3	-11	-1	2	-5	0	1	-1	1	0	1	0	2
0.2a	-3	5	-14	-1	2	-7	1	1	-2	2	0	0	3	0	2	3	0
0.1a	-1	4	-6	1	1	-2	2	1	0	2	1	1	3	1	1	3	0
BOT.	0	0	0	1	0	0	-1	0	0	-3	0	-1	-4	0	-1	-5	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 126 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b			
		0.9b				0.8b				0.7b				0.6b							
		$M_{xc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{yc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{yc}$	$M_{xc}$	
TOP	0	1	-0	0	9	0	0	9	0	0	6	0	0	3	0	0	0	0	0	0	0
0.9a	-2	1	-11	1	9	-1	4	8	2	6	5	3	8	3	3	8	0	0	0	0	3
0.8a	-4	1	-20	2	7	-2	8	7	4	12	4	6	15	2	6	16	0	0	0	0	6
0.7a	-6	0	-28	3	5	-3	11	5	6	17	3	8	21	1	8	22	0	0	0	0	8
0.6a	-7	0	-34	4	2	3	14	2	7	21	1	10	24	0	0	10	25	0	0	0	9
0.5a	-7	0	-36	5	1	-3	15	1	8	22	1	10	25	1	10	26	0	0	0	0	9
0.4a	-7	0	-34	5	4	-2	14	4	7	19	3	9	22	1	8	23	0	0	0	0	8
0.3a	-6	0	-28	4	7	-1	10	7	6	12	4	6	13	2	5	13	0	0	0	0	5
0.2a	-4	1	-18	1	8	0	1	7	3	-1	4	2	-2	2	1	-3	0	0	0	1	
0.1a	-1	1	-6	-6	7	-1	-15	5	-2	-22	3	-4	-26	1	-5	-27	0	-5	0	0	
BOT.	0	0	0	-19	0	-4	-41	0	-8	-54	0	-11	-60	0	-12	-62	0	-12	0	-12	

**Table 127 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	-0	1	0	7	0	0	0	7	0	0
0.9a	-2	-11	1	0	7	-3	2	8	1	4	6
0.8a	-4	-20	1	0	6	-5	5	7	2	8	5
0.7a	-6	-28	0	1	5	-7	7	5	3	12	4
0.6a	-7	-34	0	1	2	-8	9	2	4	14	1
0.5a	-7	-36	0	1	0	-8	10	1	5	16	1
0.4a	-7	-34	0	2	3	-6	10	4	5	15	3
0.3a	-6	-28	0	2	6	-4	7	7	4	11	5
0.2a	-4	-18	1	0	7	-2	2	8	2	1	6
0.1a	-1	-6	1	-4	6	1	-10	6	-1	-16	4
BOT	0	0	0	-12	0	-2	-31	0	-6	-44	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 128 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	2	0	0	9	0	0	8	0	0	0
0.9a	-2	2	-9	1	9	-1	4	8	2	7	5
0.8a	-4	2	-18	3	8	-2	8	7	4	13	4
0.7a	-5	1	-25	4	5	-2	12	4	6	18	3
0.6a	-6	0	-30	5	2	-2	15	2	8	21	1
0.5a	-6	1	-32	5	1	-1	16	1	8	22	0
0.4a	-6	1	-31	5	4	-1	14	4	8	20	3
0.3a	-5	2	-27	4	7	0	10	6	12	4	6
0.2a	-4	2	-18	1	8	0	1	7	3	-1	4
0.1a	-1	1	-6	-6	7	-1	-16	5	-2	-23	3
BOT.	0	0	0	-21	0	-4	-42	0	-8	-55	0

**Table 129 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c		
		$M_{xc}$	$M_{yc}$													
TOP	0	2	0	0	3	0	0	5	0	0	4	0	0	3	0	0
0.9a	-2	2	-9	-1	3	-4	0	5	0	1	4	2	2	2	3	2
0.8a	-4	2	-18	-2	3	-7	0	4	-1	2	4	4	3	2	6	4
0.7a	-5	1	-25	-2	3	-10	1	3	-1	3	3	5	5	2	8	6
0.6a	-6	0	-30	-2	2	-12	2	2	0	5	2	6	7	1	10	8
0.5a	-6	1	-32	-2	1	-12	3	0	0	7	0	7	9	0	11	10
0.4a	-6	1	-31	-1	1	-11	4	2	1	8	2	7	10	1	10	11
0.3a	-5	2	-27	0	3	-8	4	4	1	7	4	6	9	2	9	10
0.2a	-4	2	-18	0	4	-5	2	6	1	4	5	4	4	3	5	4
0.1a	-1	1	-6	-1	4	-2	-3	5	0	-6	4	0	-8	2	0	5
BOT.	0	0	0	-5	0	-1	-16	0	-3	-25	0	-5	-31	0	-6	-33
																-7

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 130 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	<b>0.8b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	6	0	0	10	0	0	8	0	0	0
0.9a	-1	5	-6	2	9	0	5	8	3	7	5
0.8a	-2	4	-12	4	8	1	10	6	5	13	4
0.7a	-3	3	-17	6	6	1	13	4	7	19	2
0.6a	-4	1	-20	7	2	1	16	2	8	22	1
0.5a	-4	1	-22	8	1	2	17	1	9	23	1
0.4a	-4	3	-22	7	4	2	16	4	8	20	3
0.3a	-4	4	-20	5	7	2	10	6	6	13	4
0.2a	-3	5	-14	1	9	-1	0	7	3	-1	4
0.1a	-1	3	-6	-8	7	1	-17	5	-3	-24	3
BOT.	0	0	0	-25	0	-5	-45	0	-9	-57	0

**Table 131 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	6	0	0	3	0	0	2	0	0	0
0.9a	-1	5	-6	-1	3	-4	-1	2	-3	-1	-1
0.8a	-2	4	-12	-2	2	-8	-2	1	-5	-2	-2
0.7a	-3	3	-17	-3	1	-11	-3	1	-7	-3	-3
0.6a	-4	1	-20	-4	0	-14	-3	0	-8	-3	-3
0.5a	-4	1	-22	-4	1	-14	-3	1	-8	-3	-2
0.4a	-4	3	-22	-3	2	-14	-2	2	-7	-2	-2
0.3a	-4	4	-20	-2	3	-11	-1	2	-5	0	-1
0.2a	-3	5	-14	-1	2	-7	1	1	-2	0	2
0.1a	-1	3	-6	1	1	-2	2	1	0	2	3
BOT	0	0	0	1	0	0	-1	0	0	-4	0
										-1	-5
										0	-1

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 132 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	0	2	0	0	8	0	0	8	0	0	0
0.9a	-2	2	-9	1	8	-2	3	8	1	4	6
0.8a	-3	1	-17	1	7	-4	5	7	3	9	5
0.7a	-5	1	-24	2	5	-5	8	5	4	12	3
0.6a	-6	0	-29	2	2	-6	9	2	5	15	1
0.5a	-6	0	-32	2	0	-6	11	1	6	17	1
0.4a	-6	1	-31	3	3	-5	10	4	6	15	3
0.3a	5	1	-26	2	6	-3	8	7	5	11	5
0.2a	-4	1	-18	0	8	-2	2	8	3	1	5
0.1a	-1	1	-6	-4	7	-1	-11	6	-1	-16	4
BOT.	0	0	0	-14	0	-3	-32	0	-6	-45	0

**Table 133 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	2	0	0	3	0	0	5	0	0	0
0.9a	-2	2	-9	-1	3	-4	0	5	0	1	4
0.8a	-3	1	-17	-1	3	-7	1	4	0	2	4
0.7a	-5	1	-24	-2	3	-10	1	3	0	4	3
0.6a	-6	0	-29	-2	2	-11	5	2	0	5	2
0.5a	-6	0	-32	-2	1	-12	3	0	0	7	0
0.4a	-6	1	-31	-1	1	-11	4	2	1	8	2
0.3a	5	1	-26	0	3	-8	4	4	2	7	4
0.2a	-4	1	-18	0	4	-5	2	6	1	4	5
0.1a	-1	1	-6	-1	4	-2	-3	5	0	-6	4
BOT	0	0	0	-5	0	-1	-16	0	-3	-26	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 134 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
TOP	0	5	0	0	9	0	0	9	0	0	5
0.9a	-1	5	-6	1	9	-1	3	8	2	5	6
0.8a	-2	4	-11	2	7	-1	7	7	4	10	5
0.7a	-3	3	-16	3	5	-2	9	5	6	14	3
0.6a	-4	1	-20	4	3	-2	12	2	7	17	1
0.5a	-4	1	-22	5	1	-1	13	1	7	18	1
0.4a	-4	3	-22	5	4	-1	12	4	7	17	3
0.3a	-4	4	-20	3	7	0	9	7	6	11	5
0.2a	-3	4	-14	0	8	0	1	7	3	1	5
0.1a	-1	3	-6	-6	7	-1	-12	6	-1	-18	4
BOT.	0	0	0	-18	0	-4	-36	0	-7	-48	0

**Table 135 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		M <sub>xc</sub>	M <sub>yc</sub>	M <sub>zc</sub>													
TOP	0	5	0	0	3	0	0	2	0	0	1	0	0	0	0	0	0
0.9a	-1	5	-6	-1	3	-4	-1	2	-3	-1	1	-2	-1	0	-1	0	-1
0.8a	-2	4	-11	-2	2	-8	-2	1	-5	-2	1	-3	-2	0	-2	0	-2
0.7a	-3	3	-16	-3	1	-11	-3	1	-7	-3	0	-4	-3	0	-3	-2	0
0.6a	-4	1	-20	-4	0	-13	-3	0	-8	-3	0	-5	-3	0	-3	0	-2
0.5a	-4	1	-22	-4	1	-14	-3	1	-8	-3	1	-4	-2	0	-2	0	-1
0.4a	-4	3	-22	-3	2	-13	-2	2	-7	-2	1	-3	-1	1	0	-1	0
0.3a	-4	4	-20	-2	3	-11	-1	2	-5	0	1	-1	1	0	1	0	2
0.2a	-3	4	-14	-1	2	-7	1	1	-2	2	0	0	3	0	2	3	0
0.1a	-1	3	-6	1	1	-2	2	1	0	2	1	1	3	1	1	3	0
BOT.	0	0	0	1	0	0	-1	0	0	-3	0	-1	-4	0	-1	-5	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 136 Moment Coefficients along Long Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	Corner
		$M_{xc}$	$M_{yc}$								
TOP	0	4	0	0	6	0	0	6	0	0	0
0.9a	-1	4	5	0	6	-1	1	6	1	2	5
0.8a	-2	3	9	1	5	-2	3	5	2	4	4
0.7a	-3	2	13	1	4	-3	4	4	3	7	3
0.6a	-3	1	17	1	2	-4	5	2	4	8	2
0.5a	-4	0	19	1	0	-4	6	0	5	10	0
0.4a	-4	2	20	2	2	-4	6	2	5	10	2
0.3a	-4	3	-18	1	5	-3	5	5	4	8	4
0.2a	-3	3	-14	0	6	-2	2	6	3	3	4
0.1a	-1	3	-6	-3	6	-1	-6	6	0	9	4
BOT.	0	0	0	-10	0	-2	-22	0	-4	-31	2

**Table 137 Moment Coefficients along Short Side for Rectangular Tanks having Case 4 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		$M_{zc}$	$M_{yc}$														
TOP	0	4	0	0	2	0	0	1	0	0	1	0	0	0	0	0	0
0.9a	-1	4	5	-1	2	-3	-1	1	-2	-1	0	-1	0	-1	0	0	-1
0.8a	-2	3	9	-2	2	-6	-1	1	-4	-1	0	-2	-1	0	-1	0	-1
0.7a	-3	2	13	-2	1	-9	-2	0	-5	-2	0	-3	-2	0	-1	-2	0
0.6a	-3	1	17	-3	0	-11	-2	0	-6	-2	0	-3	-2	0	-1	-2	0
0.5a	-4	0	19	-3	1	-12	-2	1	-6	-2	1	-2	-1	0	0	-1	0
0.4a	-4	2	20	-3	2	-12	-2	1	-5	-1	1	-1	0	0	1	0	2
0.3a	-4	3	-18	-2	2	-10	-1	1	-4	0	1	0	2	1	0	3	
0.2a	-3	3	-14	-1	1	-6	1	0	-2	2	0	1	3	0	3	0	3
0.1a	-1	3	-6	0	0	-2	1	1	0	2	1	1	2	1	2	0	2
BOT.	0	0	0	0	0	-2	0	0	-4	0	-1	-6	0	-1	-6	0	-1

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 138 Deflection Coefficients along Long side, mid-height ( $y = a/2$ ) for tanks having Case 5 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	x	End	0.1b	0.2b	0.3b	0.4b	0.5b
				0.9b	0.8b	0.7b	0.6b	
4.0	3.0	0	0	4.60	9.30	11.60	12.40	12.70
4.0	2.0	0	0	4.70	9.30	11.60	12.50	12.70
4.0	1.5	0	0	4.80	9.40	11.60	12.50	12.70
4.0	1.0	0	0	5.20	9.60	11.70	12.50	12.70
4.0	0.5	0	0	2.60	9.90	11.80	12.50	12.70
3.0	2.0	0	0	3.20	7.30	10.00	11.30	11.70
3.0	1.5	0	0	3.30	7.40	10.00	11.30	11.70
3.0	1.0	0	0	3.70	7.70	10.20	11.40	11.80
3.0	0.5	0	0	4.10	8.00	10.40	11.60	11.90
2.0	1.5	0	0	1.70	4.40	6.70	8.10	8.50
2.0	1.0	0	0	2.10	4.80	7.00	8.40	8.80
2.0	0.5	0	0	2.50	5.30	7.40	8.70	9.10
1.5	1.0	0	0	1.20	2.90	4.40	5.40	5.70
1.5	0.5	0	0	1.60	3.40	5.00	5.90	6.30
1.5	0.5	0	0	0.60	1.40	2.00	2.50	2.60

**Table 139 Deflection Coefficients along Short Side, Mid-height ( $y = a/2$ ) for Tanks having Case 5 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	z	End	0.1c	0.2c	0.3c	0.4c	0.5c
				0.9c	0.8c	0.7c	0.6c	
4.0	3.0	0	0	3.10	7.20	9.90	11.30	11.70
4.0	2.0	0	0	1.50	4.20	6.50	7.90	8.40
4.0	1.5	0	0	0.70	2.30	3.80	4.80	5.10
4.0	1.0	0	0	-0.10	0.30	0.70	1.10	1.20
4.0	0.5	0	0	-0.40	-0.60	-0.70	-0.80	-0.80
3.0	2.0	0	0	1.50	4.20	6.50	7.90	8.40
3.0	1.5	0	0	0.70	2.30	3.80	4.80	5.10
3.0	1.0	0	0	-0.10	0.30	0.70	1.10	1.20
3.0	0.5	0	0	-0.40	-0.60	-0.70	-0.80	-0.80
2.0	1.5	0	0	0.70	2.30	3.80	4.80	5.20
2.0	1.0	0	0	-1.10	0.30	0.80	1.10	1.20
2.0	0.5	0	0	-0.30	-0.60	-0.70	-0.70	-0.80
1.5	1.0	0	0	0.00	0.50	0.90	1.30	1.40
1.5	0.5	0	0	-0.30	-0.50	-0.60	-0.60	-0.70
1.5	0.5	0	0	-0.20	-0.30	-0.30	-0.30	-0.30

**Table 140 Deflection Coefficients along Long Side, Mid-span ( $x = b/2$ ) for Tanks having Case 5 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a \ y	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	4.00	7.50	10.30	12.10	12.70	12.10	10.30	7.50	4.00	0
4.0	2.0	0	4.00	7.50	10.30	12.10	12.70	12.10	10.30	7.50	4.00	0
4.0	1.5	0	4.00	7.50	10.30	12.10	12.70	12.10	10.30	7.50	4.00	0
4.0	1.0	0	4.00	7.50	10.30	12.10	12.70	12.10	10.30	7.50	4.00	0
4.0	0.5	0	4.00	7.60	10.40	12.10	12.70	12.10	10.40	7.60	4.00	0
3.0	2.0	0	3.70	7.00	9.50	11.10	11.70	11.10	9.50	7.00	3.70	0
3.0	1.5	0	3.70	7.00	9.50	11.20	11.70	11.20	9.50	7.00	3.70	0
3.0	1.0	0	3.70	7.00	9.60	11.20	11.80	11.20	9.60	7.00	3.70	0
3.0	0.5	0	3.70	7.10	9.70	11.40	11.90	11.40	9.70	7.10	3.70	0
2.0	1.5	0	2.70	5.10	7.00	8.10	8.50	8.10	7.00	5.10	2.70	0
2.0	1.0	0	2.80	5.30	7.20	8.40	8.80	8.40	7.20	5.30	2.80	0
2.0	0.5	0	2.90	5.50	7.50	8.70	9.10	8.70	7.50	5.50	2.90	0
1.5	1.0	0	1.80	3.40	4.70	5.50	5.70	5.50	4.70	3.40	1.80	0
1.5	0.5	0	2.00	3.80	5.10	6.00	6.30	6.00	5.10	3.80	2.00	0
1.0	0.5	0	0.90	1.60	2.20	2.50	2.60	2.50	2.20	1.60	0.90	0

**Table 141 Deflection Coefficients along Short Side, Mid-span ( $z = c/2$ ) for Tanks having Case 5 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a \ y	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	3.70	6.90	9.50	11.10	11.70	11.10	9.50	6.90	3.70	0
4.0	2.0	0	2.70	5.00	6.90	8.00	8.40	8.00	6.90	5.00	2.70	0
4.0	1.5	0	1.60	3.10	4.20	4.90	5.10	4.90	4.20	3.10	1.60	0
4.0	1.0	0	0.40	0.80	1.00	1.10	1.20	1.10	1.00	0.80	0.40	0
4.0	0.5	0	-0.20	-0.40	-0.60	-0.80	-0.80	-0.80	-0.60	-0.40	-0.20	0
3.0	2.0	0	2.70	5.00	6.90	8.00	8.40	8.00	6.90	5.00	2.70	0
3.0	1.5	0	1.60	3.10	4.20	4.90	5.10	4.90	4.20	3.10	1.60	0
3.0	1.0	0	0.40	0.80	1.00	1.10	1.20	1.10	1.00	0.80	0.40	0
3.0	0.5	0	-0.20	-0.40	-0.60	-0.80	-0.80	-0.80	-0.60	-0.40	-0.20	0
2.0	1.5	0	1.70	3.10	4.20	4.90	5.20	4.90	4.20	3.10	1.70	0
2.0	1.0	0	0.40	0.80	1.10	1.20	1.20	1.20	1.10	0.80	0.40	0
2.0	0.5	0	-0.20	-0.40	-0.60	-0.70	-0.80	-0.70	-0.60	-0.40	-0.20	0
1.5	1.0	0	0.50	0.90	1.20	1.40	1.40	1.40	1.20	0.90	0.50	0
1.5	0.5	0	-0.20	-0.40	-0.50	-0.60	-0.70	-0.60	-0.50	-0.40	-0.20	0
1.0	0.5	0	-0.10	-0.20	-0.30	-0.30	-0.30	-0.30	-0.30	-0.20	-0.10	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 142 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.4b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.5b</b>
		$M_{xc}$	$M_{yc}$								
TOP	0	4	0	0	37	0	0	21	0	0	0
0.9a	-9	3	-45	20	35	7	35	20	12	41	8
0.8a	-16	2	-80	32	30	12	60	17	21	73	7
0.7a	-21	2	-105	39	22	15	78	12	28	95	5
0.6a	-24	1	-120	43	11	17	88	7	32	108	3
0.5a	-25	0	-125	45	0	18	91	0	34	112	0
0.4a	-24	1	-120	43	11	17	88	7	32	108	3
0.3a	-21	2	-105	39	22	15	78	12	28	95	5
0.2a	-16	2	-80	32	30	12	60	17	21	73	7
0.1a	-9	3	-45	20	35	7	35	20	12	41	8
BOT	0	4	0	0	37	0	0	21	0	0	0

**Table 143 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	4	0	38	0	30	0	0	17	0	0
0.9a	-9	3	-45	14	36	2	28	11	36	16	12
0.8a	-16	2	-80	21	30	3	48	20	64	14	21
0.7a	-21	2	-105	25	22	3	62	17	83	10	28
0.6a	-24	1	-120	27	12	3	69	9	94	5	32
0.5a	-25	0	-125	28	0	3	72	0	31	98	0
0.4a	-24	1	-120	27	12	3	69	9	30	94	5
0.3a	-21	2	-105	25	22	3	62	17	26	83	10
0.2a	-16	2	-80	21	30	3	48	24	20	64	14
0.1a	-9	3	-45	14	36	2	28	11	36	16	12
BOT.	0	4	0	0	38	0	0	30	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 144 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b		0.8b		0.7b		0.6b			
		$M_{xc}$	$M_{yc}$								
TOP	0	5	0	0	37	0	0	20	0	0	0
0.9a	-9	4	-44	20	35	7	35	20	12	41	8
0.8a	-16	3	-78	32	30	12	60	17	21	73	7
0.7a	-20	2	-102	40	22	16	78	12	28	95	5
0.6a	-23	1	-117	44	11	18	88	7	32	108	3
0.5a	-24	0	-122	45	0	18	92	0	34	112	0
0.4a	-23	1	-117	44	11	18	88	7	32	108	3
0.3a	-20	2	-102	40	22	16	78	12	28	95	5
0.2a	-16	3	-78	32	30	12	60	17	21	73	7
0.1a	-9	4	-44	20	35	7	35	20	12	41	8
BOT.	0	5	0	0	37	0	0	20	0	0	0

**Table 145 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	5	0	0	33	0	0	34	0	0	24
0.9a	-9	4	-44	7	31	-5	19	32	8	26	23
0.8a	-16	3	-78	9	26	-11	30	27	13	45	19
0.7a	-20	2	-102	9	18	-16	37	16	17	57	14
0.6a	-23	1	-117	9	9	-20	40	10	19	63	8
0.5a	-24	0	-122	9	0	-21	41	0	20	65	0
0.4a	-23	1	-117	9	9	-20	40	10	19	63	8
0.3a	-20	2	-102	9	18	-16	37	19	17	57	14
0.2a	-16	3	-78	9	26	-11	30	27	13	45	19
0.1a	-9	4	-44	7	31	-5	19	32	8	26	23
BOT	0	5	0	0	33	0	0	34	0	0	24

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 146 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	8	0	0	37	0	0	20	0	0	0
0.9a	-8	7	-42	20	32	7	35	19	12	41	8
0.8a	-15	5	-74	33	30	13	61	16	21	73	7
0.7a	-19	4	-96	41	21	17	79	12	28	95	5
0.6a	-22	2	-110	45	11	19	89	6	32	108	3
0.5a	-23	0	-114	47	0	19	92	0	34	113	0
0.4a	-22	2	-110	45	11	19	89	6	32	108	3
0.3a	-19	4	-96	41	21	17	79	12	28	95	5
0.2a	-15	5	-74	33	30	13	61	16	21	73	7
0.1a	-8	7	-42	20	35	7	35	19	12	41	8
BOT.	0	8	0	0	37	0	0	20	0	0	0

**Table 147 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	8	0	0	24	0	0	28	0	0	22
0.9a	-8	7	-42	3	22	-9	12	27	4	18	21
0.8a	-15	5	-74	2	18	-19	17	22	7	29	18
0.7a	-19	4	-96	0	12	-27	20	16	8	35	13
0.6a	-22	2	-110	-1	6	-32	20	8	8	38	7
0.5a	-23	0	-114	-1	0	-34	21	0	9	38	0
0.4a	-22	2	-110	-1	6	-32	20	8	8	38	7
0.3a	-19	4	-96	0	12	-27	20	16	8	35	13
0.2a	-15	5	-74	2	18	-19	17	22	7	29	18
0.1a	-8	7	-42	3	22	-9	12	27	4	18	21
BOT.	0	8	0	0	24	0	0	28	0	0	22

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 148 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b				
		0.9b				0.8b				0.7b				0.6b								
		$M_{xc}$	$M_{yc}$																			
TOP	0	15	0	0	36	0	0	19	0	0	8	0	0	3	0	0	0	0	0	0	0	0
0.9a	-7	14	-36	21	34	8	36	18	12	41	8	11	44	3	10	44	0	0	0	0	10	0
0.8a	-12	11	-62	35	29	15	62	16	21	73	6	19	77	2	17	78	0	0	0	0	17	0
0.7a	-16	8	-81	44	21	19	80	11	28	96	5	25	101	2	23	103	0	0	0	0	22	0
0.6a	-18	4	-92	49	11	21	91	6	32	109	3	29	116	1	26	117	0	0	0	0	26	0
0.5a	-19	0	-95	50	0	22	94	0	34	114	0	30	1211	0	27	122	0	0	0	0	27	0
0.4a	-18	4	-92	49	11	21	91	6	32	109	3	29	116	1	26	117	0	0	0	0	26	0
0.3a	-16	8	-81	44	21	19	80	11	28	96	5	25	101	2	23	103	0	0	0	0	22	0
0.2a	-12	11	-62	35	29	15	62	16	21	73	6	19	77	2	17	78	0	0	0	0	17	0
0.1a	-7	14	-36	21	34	8	36	18	12	41	8	11	44	3	10	44	0	0	0	0	10	0
BOT.	0	15	0	0	36	0	0	19	0	0	8	0	0	3	0	0	0	0	0	0	0	

**Table 149 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		$M_{zc}$	$M_{yc}$	$M_{vc}$													
TOP	0	15	0	0	7	0	0	13	0	0	12	0	0	7	0	0	0
0.9a	-7	14	-36	-1	6	-13	4	12	-1	7	11	6	9	6	9	10	0
0.8a	-12	11	-62	-5	4	-25	3	9	-3	9	9	13	5	16	14	0	18
0.7a	-16	8	-81	-8	2	-35	1	6	-6	8	6	11	13	4	20	14	0
0.6a	-18	4	-92	-10	1	-41	0	3	-8	7	3	12	12	2	23	14	0
0.5a	-19	0	-95	-10	0	-43	-1	0	-9	7	0	13	12	0	24	14	0
0.4a	-18	4	-92	-10	1	-41	0	3	-8	7	3	12	12	2	23	14	0
0.3a	-16	8	-81	-8	2	-35	1	6	-6	8	6	11	13	4	20	14	0
0.2a	-12	11	-62	-5	4	-25	3	9	-3	9	9	13	5	16	14	0	18
0.1a	-7	14	-36	-1	6	-13	4	12	-1	7	11	6	9	6	9	10	0
BOT.	0	15	0	0	7	0	0	13	0	0	12	0	0	7	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 150 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b			
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>												
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>																			
TOP	0	24	0	0	35	0	0	18	0	0	7	0	0	2	0	0	0	0	0	0	0
0.9a	-6	23	-28	23	34	9	36	17	12	42	7	10	44	2	10	44	0	0	0	0	0
0.8a	-9	19	-47	38	28	17	63	15	21	74	6	19	78	2	17	79	0	0	17	0	0
0.7a	-12	14	-60	48	21	22	82	11	28	97	4	25	102	1	23	103	0	0	22	0	0
0.6a	-14	7	-68	54	11	25	93	6	32	110	2	29	116	1	26	118	0	0	25	0	0
0.5a	-14	0	-70	55	0	26	97	0	33	115	0	30	121	0	27	123	0	0	27	0	0
0.4a	-14	7	-68	54	11	25	93	6	32	110	2	29	116	1	26	118	0	0	25	0	0
0.3a	-12	14	-60	48	21	22	82	11	28	97	4	25	102	1	23	103	0	0	22	0	0
0.2a	-9	19	-47	28	28	17	63	15	21	74	6	19	78	2	17	79	0	0	17	0	0
0.1a	-6	23	-28	23	34	9	36	17	12	42	7	10	44	2	10	44	0	0	9	0	0
BOT	0	24	0	0	35	0	0	18	0	0	7	0	0	2	0	0	0	0	0	0	0

**Table 151 Moment Coefficients along Short side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
TOP	0	24	0	0	13	0	0	7	0	0	0
0.9a	-6	23	-28	-4	13	-17	-3	8	-11	-2	4
0.8a	-9	19	-47	-8	12	-32	-7	8	-22	-6	4
0.7a	-12	14	-60	-11	9	-43	-10	6	-30	-10	4
0.6a	-14	7	-68	-13	5	-49	-13	3	-35	-12	2
0.5a	-14	0	-70	-14	0	-52	-13	0	-37	-13	0
0.4a	-14	7	-68	-13	5	-49	-13	3	-35	-12	2
0.3a	-12	14	-60	-11	9	-43	-10	6	-30	-10	4
0.2a	-9	19	-47	-8	12	-32	-7	8	-22	-6	4
0.1a	-6	23	-28	-4	13	-17	-3	8	-11	-2	4
BOT.	0	24	0	0	13	0	0	7	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 152 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b			0.2b			0.3b			0.4b			0.5b			
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>												
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>															
TOP	0	4	0	0	38	0	0	29	0	0	16	0	0	7	0	0	0
0.9a	-9	3	-44	14	36	3	29	27	11	37	15	12	40	6	11	41	0
0.8a	-16	3	-78	22	31	4	49	23	20	64	13	21	71	5	20	73	0
0.7a	-20	2	-102	26	22	4	62	17	26	83	9	28	93	4	27	96	0
0.6a	-23	1	-117	28	12	3	70	9	30	94	5	32	106	2	31	109	0
0.5a	-24	0	-122	28	0	3	72	0	31	98	0	34	110	0	32	114	0
0.4a	-23	1	-117	28	12	3	70	9	30	94	5	32	106	2	31	106	0
0.3a	-20	2	-102	26	22	4	62	17	26	83	9	28	93	4	27	96	0
0.2a	-16	3	-78	22	31	4	49	23	20	64	13	21	71	5	20	73	0
0.1a	-9	3	-44	14	36	3	29	27	11	37	15	12	40	6	11	41	0
BOT.	0	4	0	0	38	0	0	29	0	0	16	0	0	7	0	0	0

**Table 153 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	4	0	0	33	0	0	34	0	0	24
0.9a	-9	3	-44	7	31	-5	19	32	8	26	23
0.8a	-16	3	-78	9	26	-11	30	27	13	45	19
0.7a	-20	2	-102	9	18	-16	37	19	17	57	14
0.6a	-23	1	-117	9	9	-20	40	10	19	63	8
0.5a	-24	0	-122	9	0	-21	41	0	20	65	0
0.4a	-23	1	-117	9	9	-20	40	10	19	63	8
0.3a	-20	2	-102	9	18	-16	37	19	17	57	14
0.2a	-16	3	-78	9	26	-11	30	27	13	45	19
0.1a	-9	3	-44	7	31	-5	19	32	8	26	23
BOT	0	4	0	0	33	0	0	34	0	0	24

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 154 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b			
		$M_{xc}$	$M_{yc}$																		
TOP	0	7	0	0	38	0	0	28	0	0	16	0	0	7	0	0	0	0	0	0	
0.9a	-8	6	-42	15	36	3	29	27	11	37	15	12	40	6	11	42	0	0	11		
0.8a	-15	5	-74	23	31	5	49	23	20	64	13	21	71	5	20	73	0	0	19		
0.7a	-19	3	-96	27	22	5	63	17	26	83	9	28	93	4	26	96	0	0	26		
0.6a	-22	2	-110	29	12	5	71	9	30	95	5	32	106	2	30	109	0	0	30		
0.5a	-23	0	-114	30	0	5	73	0	32	98	0	34	110	0	32	114	0	0	31		
0.4a	-22	2	-110	29	12	5	71	9	30	95	5	32	106	2	30	109	0	0	30		
0.3a	-19	3	-96	27	22	5	63	17	26	83	9	28	93	4	26	96	0	0	26		
0.2a	-15	5	-74	23	31	5	49	23	20	64	13	21	71	5	20	73	0	0	16		
0.1a	-8	6	-42	12	36	3	29	27	11	37	15	12	40	6	11	42	0	0	11		
BOT.	0	7	0	0	38	0	0	28	0	0	16	0	0	7	0	0	0	0	0		

**Table 155 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	7	0	0	24	0	0	28	0	0	22
0.9a	-8	6	-42	3	22	-9	12	27	4	18	21
0.8a	-15	2	-74	2	18	-19	17	22	7	29	18
0.7a	-19	3	-96	0	12	-27	20	16	8	35	13
0.6a	-22	2	-110	-1	6	-32	20	8	9	38	7
0.5a	-23	0	-114	-1	0	-34	21	0	9	38	0
0.4a	-22	2	-110	-1	6	-32	20	8	9	38	7
0.3a	-19	3	-96	0	12	-27	20	16	8	35	13
0.2a	-15	5	-74	2	18	-19	17	22	7	29	18
0.1a	-8	6	-42	3	22	-9	12	27	4	18	21
BOT.	0	7	0	0	24	0	0	28	0	0	22

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 156 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	0	14	0	0	39	0	0	27	0	0	15
0.9a	-7	13	-36	16	37	5	30	26	11	37	14
0.8a	-12	11	-62	25	31	7	51	22	20	65	12
0.7a	-16	8	-81	31	22	9	65	16	27	85	9
0.6a	-18	4	-92	33	12	10	73	9	31	96	5
0.5a	-19	0	-95	34	0	10	76	0	32	100	0
0.4a	-18	4	-92	33	12	10	73	9	31	96	5
0.3a	-16	8	-81	31	22	9	65	16	27	85	9
0.2a	-12	11	-62	25	31	7	51	22	20	65	12
0.1a	-7	13	-36	16	37	5	30	26	11	37	14
BOT.	0	14	0	0	39	0	0	27	0	0	15

**Table 157 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	14	0	0	7	0	0	13	0	0	12
0.9a	-7	13	-36	-1	6	-13	4	12	-1	7	11
0.8a	-12	11	-62	-5	4	-25	3	9	-3	9	9
0.7a	-16	8	-81	-8	2	-35	1	6	-6	8	6
0.6a	-18	4	-92	-9	1	-41	0	3	-8	7	3
0.5a	-19	0	-95	-10	0	-43	-1	0	-9	7	0
0.4a	-18	4	-92	-9	1	-41	0	3	-8	7	3
0.3a	-16	8	-81	-8	2	-35	1	6	-6	8	6
0.2a	-12	11	-62	-5	4	-25	3	9	-3	9	9
0.1a	-7	13	-36	-1	6	-16	4	12	-1	7	11
BOT	0	14	0	0	7	0	0	13	0	0	12

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 158 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b			
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>																
TOP	0	24	0	0	0	39	0	0	0	26	0	0	0	14	0	0	0	6	0	0	0
0.9a	-6	22	-28	18	37	7	31	25	12	38	13	12	41	5	11	42	0	0	0	0	0
0.8a	-9	19	-47	29	31	11	53	21	21	66	11	21	73	5	20	74	0	0	19	0	0
0.7a	-12	13	-60	35	22	14	68	15	28	86	8	28	95	3	26	97	0	0	25	0	0
0.6a	-14	7	-68	39	12	15	77	8	32	98	4	32	108	2	30	111	0	0	29	0	0
0.5a	-14	0	-70	40	0	16	80	0	33	102	0	33	113	0	31	116	0	0	30	0	0
0.4a	-14	7	-68	39	12	15	77	8	32	98	4	32	108	2	30	111	0	0	29	0	0
0.3a	-12	13	-60	35	22	14	68	15	28	86	8	28	95	3	26	97	0	0	25	0	0
0.2a	-9	19	-47	29	31	11	53	21	21	66	11	21	72	5	20	74	0	0	19	0	0
0.1a	-6	22	-28	18	37	7	31	25	12	38	13	12	41	5	11	42	0	0	11	0	0
BOT.	0	24	0	0	39	0	0	26	0	0	14	0	0	6	0	0	0	0	0	0	0

**Table 159 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	24	0	0	13	0	0	7	0	0	0
0.9a	-6	22	-28	-4	13	-17	-3	8	-11	-2	4
0.8a	-9	19	-47	-8	12	-32	-7	8	-21	-6	4
0.7a	-12	13	-60	-11	9	-43	-10	6	-30	-10	4
0.6a	-14	7	-68	-13	5	-49	-13	3	-35	-12	2
0.5a	-14	0	-70	-14	0	-51	-13	0	-37	-13	0
0.4a	-14	7	-68	-13	5	-49	-13	3	-35	-12	2
0.3a	-12	13	-60	-11	9	-43	-10	6	-30	-10	4
0.2a	-9	19	-47	-8	12	-32	-7	8	-21	-6	4
0.1a	-6	22	-28	-4	13	-17	-3	8	-11	-2	4
BOT	0	24	0	0	13	0	0	7	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 160 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	5	0	0	34	0	0	33	0	0	23
0.9a	-8	4	-41	8	32	-4	19	31	8	27	22
0.8a	-14	3	-72	10	27	-8	31	27	14	46	19
0.7a	-19	2	-94	11	19	-13	38	19	18	58	14
0.6a	-21	1	-107	11	10	-16	42	10	21	65	7
0.5a	-22	0	-112	11	0	-17	43	0	22	67	0
0.4a	-21	1	-107	11	10	-16	42	10	21	65	7
0.3a	-19	2	-94	11	19	-13	38	19	18	58	14
0.2a	14	3	-72	10	27	-8	31	27	14	43	19
0.1a	-8	4	-41	8	32	-4	19	31	8	27	22
BOT.	0	5	0	0	34	0	0	33	0	0	23

**Table 161 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	5	0	0	25	0	0	28	0	0	22
0.9a	-8	4	-41	3	23	-9	12	27	4	18	21
0.8a	-14	3	-72	2	18	-18	18	22	7	29	18
0.7a	-19	2	-94	1	13	-26	20	16	9	35	13
0.6a	-21	1	-107	0	6	-31	21	8	9	38	7
0.5a	-22	0	-112	-1	0	-33	21	0	9	39	0
0.4a	-21	1	-107	0	6	-31	21	8	9	38	7
0.3a	-19	2	-94	1	13	-26	20	16	9	35	13
0.2a	-14	3	-72	2	18	-18	18	22	7	29	18
0.1a	-8	4	-41	3	23	-9	12	27	4	18	21
BOT	0	5	0	0	25	0	0	28	0	0	22

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 162 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
TOP	0	12	0	0	36	0	0	33	0	0	22
0.9a	-7	11	-35	9	34	-1	21	31	9	28	21
0.8a	-12	10	-61	13	28	-4	34	26	16	48	18
0.7a	-16	7	-79	15	20	-7	42	19	20	61	13
0.6a	-18	4	-89	16	10	-9	46	10	23	68	7
0.5a	-19	0	-93	16	0	-9	47	0	24	70	0
0.4a	-18	4	-89	16	10	-9	46	10	23	68	7
0.3a	-16	7	-79	15	20	-7	42	19	20	61	13
0.2a	-12	10	-61	13	28	-4	34	26	16	48	18
0.1a	-7	11	-35	9	34	-1	21	31	9	28	21
BOT.	0	12	0	0	36	0	0	33	0	0	22

**Table 163 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	12	0	0	8	0	0	13	0	0	12
0.9a	-7	11	-35	-1	6	-12	4	12	-1	8	11
0.8a	-12	10	-61	-4	4	-24	3	9	-3	9	10
0.7a	-16	7	-79	-7	2	-34	2	6	-5	9	6
0.6a	-18	4	-89	-9	1	-40	0	3	-7	8	3
0.5a	-19	0	-93	-10	0	-41	0	0	-8	8	0
0.4a	-18	4	-89	-9	1	-40	0	3	-7	8	3
0.3a	-16	7	-79	-7	2	-34	2	6	-5	9	6
0.2a	-12	10	-61	-4	4	-24	3	9	-3	9	10
0.1a	-7	11	-35	-1	6	-12	4	12	-1	8	11
BOT	0	12	0	0	8	0	0	13	0	0	12

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 164 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	22	0	0	38	0	0	32	0	0	21
0.9a	-5	21	-27	11	36	2	22	31	10	29	20
0.8a	-9	18	-46	17	30	2	37	26	18	50	17
0.7a	-12	13	-59	20	21	1	46	19	23	64	13
0.6a	-13	7	-66	21	11	1	51	10	26	72	7
0.5a	-14	0	-68	22	0	0	53	0	28	74	0
0.4a	-13	7	-66	21	11	1	51	10	26	72	7
0.3a	-12	13	-59	20	21	1	46	19	23	64	13
0.2a	-9	18	-46	17	30	2	37	26	18	50	17
0.1a	-5	21	-27	11	36	2	22	31	10	29	20
BOT.	0	22	0	0	38	0	0	32	0	0	21

**Table 165 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
TOP	0	22	0	0	12	0	0	7	0	0	4
0.9a	-5	21	-27	-4	12	-17	-2	7	-10	-1	4
0.8a	-9	18	-46	-8	12	-31	-7	7	-21	-5	4
0.7a	-12	13	-59	-11	9	-41	-10	6	-29	-9	3
0.6a	-13	7	-66	-13	5	-48	-12	3	-34	-12	2
0.5a	-14	0	-68	-13	0	-50	-13	0	-36	-12	0
0.4a	-13	7	-66	-13	5	-48	-12	3	-34	-12	2
0.3a	-12	13	-59	-11	9	-41	-10	6	-29	-9	3
0.2a	-9	18	-46	-8	12	-31	-7	7	-21	-5	4
0.1a	-5	21	-27	-4	12	-17	-2	7	-10	-1	4
BOT.	0	22	0	0	12	0	0	7	0	0	4

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 166 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	9	0	0	29	0	0	29	0	0	22
0.9a	-7	8	-33	5	27	-5	14	28	6	20	21
0.8a	-11	7	-57	6	22	-11	21	23	11	32	17
0.7a	-15	5	-74	6	15	-16	25	16	13	40	13
0.6a	-17	3	-83	6	8	-19	27	9	15	44	7
0.5a	-17	0	-87	6	0	-20	28	0	15	45	0
0.4a	-17	3	-83	6	8	-19	27	9	15	44	7
0.3a	-15	5	-74	6	15	-16	25	16	13	40	13
0.2a	-11	7	-57	6	22	-11	21	23	11	32	17
0.1a	-7	8	-33	2	27	-5	14	28	6	20	21
BOT.	0	9	0	0	29	0	0	29	0	0	22

**Table 167 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
TOP	0	9	0	0	9	0	0	14	0	0	12
0.9a	-7	8	-33	-1	8	-11	5	13	0	8	11
0.8a	-11	7	-57	-3	5	-22	5	10	-1	11	9
0.7a	-15	5	-74	-6	3	-30	3	7	-3	10	6
0.6a	-17	3	-83	-7	1	-36	2	3	-5	10	3
0.5a	-17	0	-87	-8	0	-37	2	0	-5	9	0
0.4a	-17	3	-83	-7	1	-36	2	3	-5	10	3
0.3a	-15	5	-74	-6	3	-30	3	7	-3	10	6
0.2a	-11	7	-57	-3	5	-22	5	10	-1	11	9
0.1a	-7	8	-33	-1	8	-11	5	13	0	8	11
BOT.	0	9	0	0	9	0	0	14	0	0	12

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 168 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b			
		0.9b		0.8b		0.7b		0.6b		0.5b		0.4b		0.3b		0.2b		0.1b			
		$M_{xc}$	$M_{yc}$																		
TOP	0	19	0	0	33	0	0	30	0	0	22	0	0	11	0	0	0	0	0	0	
0.9a	-5	18	-25	7	31	-1	16	29	8	22	21	12	25	10	14	26	0	0	14		
0.8a	-9	15	-43	10	25	-3	25	24	14	36	17	22	42	9	25	44	0	0	26		
0.7a	-11	11	-54	11	15	-5	30	17	18	45	13	29	53	6	33	56	0	0	35		
0.6a	-12	6	-60	12	9	-7	33	9	20	49	7	33	59	3	37	62	0	0	70		
0.5a	-12	0	-62	12	0	-8	34	0	21	51	0	34	61	0	40	64	0	0	72		
0.4a	-12	6	-60	12	9	-7	33	9	20	49	7	33	59	3	38	62	0	0	70		
0.3a	-11	11	-54	11	18	-5	30	17	18	45	13	29	53	6	33	56	0	0	35		
0.2a	-9	15	-43	10	25	-3	25	24	14	36	17	22	42	9	25	44	0	0	26		
0.1a	-5	18	-25	7	31	-1	16	29	8	22	21	12	25	10	14	26	0	0	14		
BOT.	0	19	0	0	33	0	0	30	0	0	22	0	0	11	0	0	0	0	0		

**Table 169 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	19	0	0	10	0	0	5	0	0	0
0.9a	-5	18	-25	-3	11	-15	-2	6	-9	-1	3
0.8a	-9	15	-43	-7	10	-28	-6	6	-18	-4	3
0.7a	-11	11	-54	-10	8	-37	-9	5	-25	-8	3
0.6a	-12	6	-60	-11	4	-43	-11	3	-30	-10	2
0.5a	-12	0	-62	-12	0	-45	-11	0	-31	-11	0
0.4a	-12	6	-60	-11	4	-43	-11	3	-30	-10	2
0.3a	-11	11	-54	-10	8	-37	-9	5	-25	-8	3
0.2a	-9	15	-43	-7	10	-28	-6	6	-18	-4	3
0.1a	-5	18	-25	-3	11	-15	-2	6	-9	-1	3
BOT.	0	19	0	0	10	0	0	5	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 170 Moment Coefficients along Long Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		$M_{xc}$	$M_{yc}$								
TOP	0	12	0	0	21	0	0	20	0	0	0
0.9a	-4	11	-20	3	19	-3	8	18	5	12	14
0.8a	-7	9	-33	3	15	-6	12	15	9	18	11
0.7a	-8	7	-41	3	10	-9	13	10	10	21	8
0.6a	-9	4	-45	3	5	-11	13	5	11	22	4
0.5a	-9	0	-46	3	0	-11	13	0	12	22	0
0.4a	-9	4	-45	3	5	-11	13	5	11	22	4
0.3a	-8	7	-41	3	10	-9	13	10	10	21	8
0.2a	-7	9	-33	3	15	-6	12	15	9	18	11
0.1a	-4	11	-20	3	19	-3	8	19	5	12	14
BOT.	0	12	0	0	21	0	0	20	0	0	0

**Table 171 Moment Coefficients along Short Side for Rectangular Tanks having Case 5 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
TOP	0	12	0	0	5	0	0	2	0	0	0
0.9a	-4	11	-20	-2	6	-11	-1	2	-5	1	-2
0.8a	-7	9	-33	-5	6	-20	-3	3	-11	-2	1
0.7a	-8	7	-41	-7	4	-26	-5	3	-16	-4	2
0.6a	-9	4	-45	-8	2	-30	-6	2	-18	-5	1
0.5a	-9	0	-46	-8	0	-31	-7	0	-19	-6	0
0.4a	-9	4	-45	-8	2	-30	-6	2	-18	-5	1
0.3a	-8	7	-41	-7	4	-26	-5	3	-16	-4	2
0.2a	-7	9	-33	-5	6	-20	-3	3	-11	-2	1
0.1a	-4	11	-20	-2	6	-11	-1	2	-5	1	-2
BOT	0	12	0	0	5	0	0	2	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 172 Deflection Coefficients along Long Side, Mid-height ( $y = a/2$ ) for Tanks having Case 6 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	x	End	0.1b	0.2b	0.3b	0.4b	0.5b
				0.9b	0.8b	0.7b	0.6b	
4.0	3.0		0	40.50	99.80	151.50	185.10	196.60
4.0	2.0		0	50.60	113.90	167.20	201.40	213.10
4.0	1.5		0	54.60	119.60	173.50	207.90	219.60
4.0	1.0		0	56.30	121.80	176.00	210.50	222.20
4.0	0.5		0	51.50	115.10	168.50	202.70	214.30
3.0	2.0		0	20.80	49.20	74.40	91.10	96.90
3.0	1.5		0	24.40	54.60	80.60	97.70	103.60
3.0	1.0		0	26.40	57.60	84.20	101.40	107.40
3.0	0.5		0	24.40	54.60	80.60	97.70	103.60
2.0	1.5		0	6.10	14.70	22.60	27.90	29.80
2.0	1.0		0	8.10	17.90	26.50	32.20	34.20
2.0	0.5		0	8.10	17.80	26.40	32.10	34.10
1.5	1.0		0	3.00	6.80	10.20	12.50	13.30
1.5	0.5		0	3.50	7.60	11.20	13.60	14.50
1.0	0.5		0	0.90	2.00	3.00	3.60	3.80

**Table 173 Deflection Coefficients along Short Side, Mid-height ( $y = a/2$ ) for Tanks having Case 6 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	z	End	0.1c	0.2c	0.3c	0.4c	0.5c
				0.9c	0.8c	0.7c	0.6c	
4.0	3.0		0	3.70	23.30	44.30	59.00	64.30
4.0	2.0		0	-9.10	-10.20	-8.10	-5.80	-4.80
4.0	1.5		0	-10.50	-16.00	-18.60	-19.60	-19.90
4.0	1.0		0	-8.40	-14.20	-18.00	-20.10	-20.80
4.0	0.5		0	-3.60	-6.40	-8.30	-9.50	-9.80
3.0	2.0		0	-2.80	0.20	4.70	8.30	9.60
3.0	1.5		0	-5.60	-7.70	-8.20	-8.00	-7.80
3.0	1.0		0	-5.30	-8.80	-11.00	-12.20	-12.60
3.0	0.5		0	-2.40	-4.30	-5.60	-6.40	-6.60
2.0	1.5		0	-0.90	0.30	2.00	3.40	3.90
2.0	1.0		0	-2.30	-3.60	-4.20	-4.50	-4.60
2.0	0.5		0	-1.30	-2.30	-3.00	-3.40	-3.50
1.5	1.0		0	-0.90	-1.10	-1.00	-0.09	-0.80
1.5	0.5		0	-0.80	-1.30	-1.70	-1.90	-2.00
1.0	0.5		0	-0.30	-0.50	-0.60	-0.70	-0.70

**Table 174 Deflection Coefficients along Long Side, Mid-span ( $x = b/2$ ) for Tanks having Case 6 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a \ y	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	40.4	80.5	119.9	158.7	196.6	233.8	270.2	306.2	341.9	377.8
4.0	2.0	0	43.7	87.1	129.8	171.8	213.1	253.5	293.2	332.5	371.3	410.3
4.0	1.5	0	45.0	89.7	133.8	177.1	219.6	261.3	302.3	242.8	383.1	423.4
4.0	1.0	0	45.6	90.8	135.4	179.2	222.2	264.5	306.0	246.9	387.8	428.8
4.0	0.5	0	44.0	87.6	130.6	172.9	214.3	255.0	295.0	334.4	373.8	412.8
3.0	2.0	0	20.3	40.3	59.8	78.7	96.9	114.4	131.4	148.0	164.4	181.0
3.0	1.5	0	21.7	43.0	63.9	84.1	103.6	122.5	140.7	158.6	176.2	194.1
3.0	1.0	0	22.4	44.6	66.2	87.2	107.4	127.0	146.0	164.5	182.9	201.4
3.0	0.5	0	21.7	43.0	63.9	84.1	103.6	122.4	140.6	158.5	176.1	193.9
2.0	1.5	0	6.6	13.0	19.0	24.6	29.8	34.6	39.0	43.2	47.3	51.5
2.0	1.0	0	7.5	14.8	21.7	28.2	34.2	39.7	44.9	49.9	54.8	59.8
2.0	0.5	0	7.5	14.8	21.6	28.1	34.1	29.6	44.7	49.7	54.5	59.4
1.5	1.0	0	3.1	6.1	8.8	11.2	13.3	15.2	16.8	18.3	19.8	21.4
1.5	0.5	0	3.4	6.6	9.5	12.1	14.5	16.5	18.3	20.0	21.6	23.3
1.0	0.5	0	1.0	1.9	2.7	3.3	3.8	4.2	4.5	4.8	5.1	5.4

**Table 175 Deflection Coefficients along Short Side, Mid-span ( $z = c/2$ ) for Tanks having Case 6 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a \ y	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	13.7	27.1	40.1	52.8	64.3	75.5	86.2	96.6	106.9	117.2
4.0	2.0	0	-0.5	-1.2	-2.1	-3.4	-4.8	-6.5	-8.4	-10.4	-12.3	-14.3
4.0	1.5	0	-3.8	-7.6	-11.6	-15.7	-19.9	-24.0	-28.1	-32.2	-36.2	-40.3
4.0	1.0	0	-4.1	-8.3	-12.5	-16.7	-20.8	-24.8	-28.5	-32.2	-35.8	-39.5
4.0	0.5	0	-2.0	-4.0	-6.0	-7.9	-9.8	-11.7	-13.4	-15.0	-16.6	-18.6
3.0	2.0	0	2.4	4.7	6.7	8.3	9.6	10.6	11.4	12.0	12.6	13.2
3.0	1.5	0	-1.3	-2.7	-4.2	-6.0	-7.8	-9.8	-11.8	-13.8	-15.8	-17.8
3.0	1.0	0	-2.4	-4.9	-7.5	-10.1	-12.6	-15.1	-17.4	-19.7	-21.9	-24.2
3.0	0.5	0	-1.3	-2.7	-4.1	-5.4	-6.6	-7.8	-9.0	-10.0	-11.0	-12.3
2.0	1.5	0	1.2	2.2	3.0	3.5	3.9	4.1	4.1	4.1	4.1	4.1
2.0	1.0	0	-0.8	-1.6	-2.5	-3.5	-4.6	-5.6	-6.5	-7.5	-8.4	-9.3
2.0	0.5	0	-0.7	-1.4	-2.2	-2.8	-3.5	-4.1	-4.6	-5.1	-5.6	-6.2
1.5	1.0	0	0.0	-0.1	-0.2	-0.5	-0.8	-1.2	-1.6	-1.9	-2.3	-2.6
1.5	0.5	0	-0.4	-0.8	-1.3	-1.7	-2.0	-2.3	-2.6	-2.9	-3.1	-3.4
1.0	0.5	0	-0.1	-0.3	-0.4	-0.6	-0.7	-0.8	-0.9	-1.0	-1.1	-1.2

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 176 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-134	34	-668	0	214	-173	0	212	96	0	159	211
0.9a	-165	70	-827	-18	204	-163	15	208	90	30	157	198
0.8a	-142	70	-707	-27	203	-150	27	207	84	53	158	183
0.7a	-122	69	-609	-26	205	-135	37	210	78	70	159	167
0.6a	-105	68	-523	-19	210	-118	45	214	71	81	162	149
0.5a	-89	68	-443	-10	215	-66	50	220	63	86	166	129
0.4a	-73	68	-363	-2	220	-79	52	226	53	84	169	107
0.3a	-56	69	-282	5	225	-58	49	231	42	75	172	83
0.2a	-39	69	-195	9	230	-37	40	235	30	59	175	58
0.1a	-20	70	-102	8	233	-18	24	237	16	34	176	30
BOT.	0	71	0	0	234	0	0	238	0	0	177	0
											91	0
											0	0
											0	0

**Table 177 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c				
		$M_{zc}$	$M_{yc}$															
TOP	-134	34	-668	0	72	-291	0	100	-15	0	85	125	0	48	191	0	0	210
0.9a	-165	70	-827	-34	61	-271	1	94	-14	18	81	117	26	46	179	29	0	197
0.8a	-142	70	-707	-49	61	-249	3	93	-12	31	81	109	46	46	166	51	0	183
0.7a	-122	69	-609	-49	63	-225	8	95	-9	42	83	101	61	47	152	67	0	167
0.6a	-105	68	-523	-41	66	-197	14	100	-6	51	87	91	71	49	136	77	0	149
0.5a	-89	68	-443	-30	68	-166	20	105	-3	55	91	80	75	52	119	82	0	130
0.4a	-73	68	-363	-19	72	-133	25	111	-1	56	96	68	74	54	99	80	0	108
0.3a	-56	69	-282	-9	76	-99	27	116	1	53	100	54	67	56	78	72	0	84
0.2a	-39	69	-195	-2	80	-65	25	120	3	43	103	38	53	58	54	56	0	58
0.1a	-20	70	-102	2	83	-32	16	123	2	26	105	20	26	59	28	33	0	30
BOT.	0	71	0	0	84	0	0	124	0	0	106	0	0	59	0	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 178 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-105	101	-527	0	235	-113	0	222	123	0	164	223
0.9a	-135	124	-672	-11	227	-105	18	218	115	32	162	208
0.8a	-116	124	-578	-15	226	-96	33	218	107	56	162	193
0.7a	-100	124	-500	-12	228	-86	44	221	98	74	164	175
0.6a	-86	124	-432	-6	233	-75	53	225	89	86	167	156
0.5a	-74	125	-368	2	238	-62	58	230	78	90	170	135
0.4a	-61	126	-304	8	244	-49	59	235	66	88	173	112
0.3a	-48	127	-238	13	249	-35	54	240	52	79	176	87
0.2a	-33	128	-166	15	254	-22	44	244	37	61	178	60
0.1a	-17	129	-87	11	258	-10	26	247	19	35	180	31
BOT.	0	131	0	0	259	0	0	247	0	0	180	0
											92	0
											0	0
											0	0

**Table 179 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-105	101	-527	0	34	-349	0	3	-138	0	12
0.9a	-135	124	-672	-47	42	-322	-16	5	-129	-1	8
0.8a	-116	124	-578	-61	40	-296	-23	7	-117	-1	6
0.7a	-100	124	-500	-59	40	-267	-23	5	-105	2	8
0.6a	-86	124	-432	-50	41	-233	-18	2	-91	7	10
0.5a	-74	125	-368	-40	41	-196	-1	1	-75	13	14
0.4a	-61	126	-304	-30	39	-158	-3	4	-59	18	17
0.3a	-48	127	-238	-19	37	-118	4	7	-42	21	20
0.2a	-33	128	-166	-10	33	-78	8	22	-27	20	16
0.1a	-17	129	-87	3	30	-38	7	24	-13	14	17
BOT.	0	131	0	0	29	0	0	25	0	0	17

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 180 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	-96	126	-478	0	244	-88	0	226	134	0	165
0.9a	-123	144	-615	-8	236	-82	20	223	125	32	164
0.8a	-105	144	-527	-10	235	-75	35	222	116	58	164
0.7a	-91	144	-455	-7	238	-67	47	225	107	76	166
0.6a	-79	145	-393	0	242	-58	56	229	96	87	169
0.5a	-67	147	-335	7	248	-47	61	234	84	92	172
0.4a	-55	149	-277	13	254	-36	62	239	71	90	175
0.3a	-43	151	-216	17	259	-25	57	244	56	80	177
0.2a	-30	153	-151	17	264	-15	46	248	39	62	180
0.1a	-16	154	-80	12	267	-7	27	250	21	36	181
BOT.	0	156	0	0	269	0	0	251	0	0	182
											93
											0
											0
											0

**Table 181 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c				
		$M_{zc}$	$M_{yc}$															
TOP	-96	126	-478	0	77	-394	0	36	-230	0	17	-129	0	7	-73	0	0	-55
0.9a	-123	144	-615	-57	80	-362	-28	44	-214	-15	22	-120	-9	9	-67	-7	0	-50
0.8a	-105	144	-527	-70	77	-332	-42	45	-196	-24	24	-109	-15	10	-60	-12	0	-44
0.7a	-91	144	-455	-66	79	-297	-43	44	-176	-26	23	-96	-16	10	-51	12	0	-36
0.6a	-79	145	-393	-57	82	-25	-38	44	-153	-23	22	-82	-13	9	-42	-10	0	-29
0.5a	-67	147	-335	-47	84	-218	-30	44	-128	-16	21	-67	-7	8	-33	-4	0	-22
0.4a	-55	149	-277	-36	85	-175	-20	44	-102	-8	20	-52	0	7	-24	2	0	-15
0.3a	-43	151	-216	-26	84	-132	-11	42	-75	-1	19	-37	6	7	-16	8	0	-9
0.2a	-30	153	-151	-15	82	-88	-3	40	-49	5	17	-23	10	6	-9	11	0	-4
0.1a	-16	154	-80	-6	80	-43	1	38	-24	6	16	-11	8	5	-4	9	0	-1
BOT.	0	156	0	0	78	0	0	38	0	0	15	0	0	5	0	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 182 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	-92	135	-461	0	248	-78	0	228	138	0	166
0.9a	-120	149	-598	-7	240	-73	20	225	129	33	165
0.8a	-102	149	-509	-8	239	-66	36	224	120	58	165
0.7a	-87	150	-436	-4	242	-59	49	227	110	77	167
0.6a	-75	152	-373	3	247	-50	58	231	99	88	169
0.5a	-63	155	-315	10	252	-41	63	236	87	93	172
0.4a	-52	158	-260	16	257	-31	63	241	73	91	175
0.3a	-40	162	-202	20	263	-21	58	245	57	81	178
0.2a	-28	164	-141	19	268	-13	47	249	40	63	180
0.1a	-15	166	-75	13	271	-5	28	251	21	36	181
BOT.	0	168	0	0	272	0	0	252	0	0	182

**Table 183 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
	$\mathbf{M}_z$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$	$\mathbf{M}_{yzc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$	$\mathbf{M}_{yzc}$	$\mathbf{M}_{zc}$	$\mathbf{M}_{yzc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$
TOP	-92	135	-461	0	106	-479	0	63	-368	0	37
0.9a	-120	149	-598	-76	100	-437	-49	67	-341	-36	41
0.8a	-102	149	-509	-83	95	-398	-67	65	-312	-55	41
0.7a	-87	150	-436	-76	99	-352	-67	67	-280	-59	42
0.6a	-75	152	-373	-66	105	-303	-60	70	-244	-55	43
0.5a	-63	155	-315	-56	109	-255	-50	74	-205	-46	46
0.4a	-52	158	-260	-45	113	-206	-39	77	-164	-34	47
0.3a	-40	162	-202	-33	114	-156	-27	78	-123	-22	48
0.2a	-28	164	-141	-21	114	-105	-15	77	-81	-11	48
0.1a	-15	166	-75	-10	113	-52	-5	76	-40	-3	47
BOT	0	168	0	0	112	0	0	75	0	0	46

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 184 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	-101	112	-504	0	237	-108	0	223	125	0	164
0.9a	-135	123	-675	-10	229	-101	19	219	117	32	163
0.8a	-114	122	-572	-14	228	-92	34	219	109	57	163
0.7a	-98	123	-488	-11	231	-82	45	222	100	75	165
0.6a	-83	125	-417	-3	235	-71	54	226	90	86	167
0.5a	-70	127	-351	5	241	-58	59	231	79	91	170
0.4a	-57	130	-287	11	246	-45	60	236	67	89	173
0.3a	-44	133	-222	16	251	-32	56	241	53	79	176
0.2a	-31	136	-154	17	256	-20	45	245	37	61	178
0.1a	-16	138	-81	12	259	-9	27	247	19	35	180
BOT.	0	140	0	0	260	0	0	248	0	0	180
											92
											0
											0
											0

**Table 185 Moment Coefficients along Short side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c				0.2c				0.3c				0.4c				0.5c			
		<b>0.9c</b>	<b>0.8c</b>	<b>0.7c</b>	<b>0.6c</b>	<b>0.5c</b>	<b>0.4c</b>	<b>0.3c</b>	<b>0.2c</b>	<b>0.1c</b>	<b>0.9c</b>	<b>0.8c</b>	<b>0.7c</b>	<b>0.6c</b>	<b>0.5c</b>	<b>0.4c</b>	<b>0.3c</b>	<b>0.2c</b>	<b>0.1c</b>		
	<b>M<sub>zc</sub></b>	<b>M<sub>yc</sub></b>																			
TOP	-101	112	-504	0	126	-656	0	79	-605	0	48	-570	0	23	-550	0	0	0	-543		
0.9a	-135	123	-675	-115	87	-600	-94	66	-553	-80	43	-525	-73	22	-509	-70	0	0	-504		
0.8a	-114	122	-572	-109	84	-536	-105	59	-504	-101	38	-481	-98	19	-467	-97	0	0	-463		
0.7a	-98	123	-488	-96	89	-467	-95	63	-447	-95	41	-431	-95	20	-421	-95	0	0	-418		
0.6a	-83	125	-417	-82	94	-401	-82	68	-387	-83	45	-375	-83	22	-368	-83	0	0	-366		
0.5a	-70	127	-351	-69	97	-337	-69	72	-325	-69	48	-316	-69	24	-310	-69	0	0	-308		
0.4a	-57	130	-287	-56	100	-273	-55	75	-262	-55	50	-254	-54	25	-249	-54	0	0	-248		
0.3a	-44	133	-222	-43	102	-209	-42	76	-198	-41	51	-191	-40	26	-187	-40	0	0	-185		
0.2a	-31	136	-154	-29	104	-141	-27	77	-133	-26	51	-127	-25	26	-124	-25	0	0	-122		
0.1a	-16	138	-81	-14	104	-72	-13	76	-66	-11	50	-63	-11	25	-61	-10	0	0	-60		
BOT	0	140	0	0	103	0	0	75	0	0	50	0	0	25	0	0	0	0	0		

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 186 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	-74	38	-369	0	130	-130	0	130	69	0	99
0.9a	-100	60	-502	-14	122	-121	11	125	65	24	97
0.8a	-88	60	-438	-19	121	-111	20	124	61	43	97
0.7a	-77	60	-386	-17	124	-100	28	127	57	56	98
0.6a	-68	61	-339	-11	127	-88	35	131	52	66	102
0.5a	-59	62	-294	-4	132	-73	41	137	47	70	105
0.4a	-49	62	-246	2	137	-58	43	143	41	70	109
0.3a	-39	63	-195	7	143	-42	41	148	33	63	113
0.2a	-28	64	-138	9	148	-27	35	152	24	50	116
0.1a	-15	65	-73	8	152	-13	21	155	13	30	118
BOT.	0	66	0	0	154	0	0	156	0	0	118

**Table 187 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-74	38	-369	0	1	-241	0	24	-68	0	25
0.9a	-100	60	-502	-32	6	-223	-7	17	-63	5	20
0.8a	-88	60	-438	-42	5	-206	-10	16	-57	10	20
0.7a	-77	60	-386	-40	4	-186	-8	17	-50	15	21
0.6a	-68	61	-339	-33	4	-163	-3	20	-42	20	24
0.5a	-59	62	-294	-26	2	-138	3	24	-34	25	27
0.4a	-49	62	-246	-18	1	-112	9	28	-25	29	31
0.3a	-39	63	-195	-11	4	-84	13	33	-17	30	34
0.2a	-28	64	-138	-4	8	-55	14	36	-10	26	37
0.1a	-15	65	-73	0	12	-27	10	39	-4	17	39
BOT	0	66	0	0	14	0	0	40	0	0	40

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 188 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-64	65	-3.9	0	141	-97	0	136	87	0	102	182
0.9a	-88	82	-440	-10	133	-90	13	132	81	25	100	170
0.8a	-77	82	-384	-13	133	-83	24	131	76	45	100	158
0.7a	-68	82	-338	10	135	-75	33	134	71	60	102	144
0.6a	-60	84	-298	-4	139	-65	40	138	64	69	105	130
0.5a	-52	85	-259	2	144	-54	45	143	57	74	109	113
0.4a	-44	87	-218	7	150	-42	47	149	49	73	112	94
0.3a	-35	89	-173	11	156	-30	45	154	39	66	116	74
0.2a	-25	90	-123	12	162	-19	37	158	28	52	119	51
0.1a	-13	92	-66	9	166	-8	23	161	15	31	121	27
BOT.	0	92	0	0	167	0	0	162	0	0	121	0
											63	0
											0	0
											0	0

**Table 189 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-64	65	-319	0	39	-266	0	13	-136	0	3
0.9a	-88	82	-440	-39	43	-245	-17	20	-127	-6	8
0.8a	-77	82	-384	-48	41	-226	-24	21	-116	-10	9
0.7a	-68	82	-338	-44	41	-204	-24	20	-104	-9	8
0.6a	-60	84	-298	-39	43	-179	-20	19	-90	-6	7
0.5a	-52	85	-259	-32	43	-152	-14	18	-75	0	5
0.4a	-44	87	-218	-24	42	-124	-8	16	-59	5	3
0.3a	-35	89	-173	-17	40	-94	-2	13	-43	10	1
0.2a	-25	90	-123	-9	38	-62	3	10	-27	12	2
0.1a	-13	92	-66	-3	35	-31	5	7	-13	9	3
BOT	0	92	0	0	33	0	0	6	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 190 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	-59	78	-294	0	147	-79	0	139	97	0	104
0.9a	-82	91	-410	-8	140	-74	14	135	91	26	102
0.8a	-71	91	-355	-10	140	-67	26	135	85	46	102
0.7a	-62	92	-310	-5	142	-60	36	138	78	61	104
0.6a	-54	95	-271	1	146	-51	44	142	71	71	107
0.5a	-47	98	-234	7	152	-42	49	147	63	76	111
0.4a	-39	101	-196	12	157	-32	50	153	54	75	114
0.3a	-31	104	-156	14	163	-22	47	158	43	68	118
0.2a	-22	106	-111	15	169	-13	39	162	31	53	120
0.1a	-12	108	-60	11	173	-6	23	162	16	31	122
BOT.	0	109	0	0	175	0	0	166	0	0	123

**Table 191 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		$M_{zc}$	$M_{yc}$	$M_{yzc}$													
TOP	-59	78	-294	0	66	-319	0	38	-236	0	22	-182	0	10	-152	0	0
0.9a	-82	91	-410	-51	62	-292	-31	42	-219	-22	25	-170	-18	12	-142	-17	0
0.8a	-71	91	-355	-56	59	-268	-43	41	-201	-34	25	-155	-29	12	-129	-27	0
0.7a	-61	92	-310	-52	62	-239	-43	42	-181	-37	26	-139	-32	12	-115	-31	0
0.6a	-54	95	-271	-46	66	-209	-39	44	-158	-34	27	-121	-30	13	-99	-29	0
0.5a	-47	98	-234	-39	69	-177	-32	46	-133	-27	28	-101	-24	13	-82	-23	0
0.4a	-39	101	-196	-31	71	-145	-25	47	-107	-20	28	-80	-16	13	-64	-15	0
0.3a	-31	104	-156	-23	71	-111	-16	47	-79	-11	28	-59	-8	13	-47	-7	0
0.2a	-22	106	-111	-15	71	-75	-8	45	-52	-4	27	-38	-1	12	-30	0	0
0.1a	-12	108	-60	-6	69	-37	-2	44	-25	1	25	-18	3	12	-14	3	0
BOT	0	109	0	0	68	0	0	43	0	0	25	0	0	12	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 192 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b		0.8b		0.7b		0.6b			
		$M_{xc}$	$M_{yc}$								
TOP	-63	66	-314	0	141	-99	0	136	87	0	102
0.9a	-91	77	-453	-11	133	-91	13	132	81	25	100
0.8a	-78	76	-388	-13	133	-83	24	131	76	45	100
0.7a	-67	77	-336	-9	136	-74	34	134	71	60	102
0.6a	-58	80	-291	-2	140	-64	41	138	64	70	105
0.5a	-50	86	-249	4	145	-53	46	144	57	74	109
0.4a	-41	86	-207	10	150	-40	48	149	49	73	112
0.3a	-33	90	-163	13	156	-29	46	154	39	66	116
0.2a	-23	93	-115	14	161	-17	38	158	28	53	118
0.1a	-12	95	-61	10	165	-8	23	161	15	31	120
BOT.	0	96	0	0	167	0	0	162	0	0	121

**Table 193 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$								
TOP	-63	66	-314	0	82	-435	0	51	-401	0	31
0.9a	-91	77	-453	-76	56	-401	-62	42	-368	-53	28
0.8a	-78	76	-388	-74	53	-361	-70	38	-337	-67	24
0.7a	-67	77	-336	-66	57	-318	-65	41	-301	-64	26
0.6a	-58	80	-291	-57	61	-276	-57	45	-262	-57	29
0.5a	-50	83	-249	-49	64	-234	-48	48	-222	-48	32
0.4a	-41	86	-207	-40	67	-192	-39	50	-181	-39	33
0.3a	-33	90	-163	-31	69	-148	-30	52	-137	-29	34
0.2a	-23	93	-115	-21	71	-101	-20	52	-92	-18	34
0.1a	-12	95	-61	-10	71	-52	-9	51	-46	-8	34
BOT	0	96	0	0	70	0	0	51	0	0	33

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 194 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-35	11	-177	0	49	-92	0	52	30	0	41	106
0.9a	-54	24	-272	-12	43	-86	5	47	29	14	38	100
0.8a	-49	24	-245	-15	44	-80	10	46	28	25	37	94
0.7a	-45	25	-224	-12	45	-73	15	48	27	33	39	87
0.6a	-41	25	-204	-8	48	-65	19	52	25	40	42	80
0.5a	-36	26	-182	-4	52	-56	23	57	24	44	46	71
0.4a	-32	27	-158	-1	57	-45	26	62	22	45	49	61
0.3a	-26	28	-129	3	62	-34	26	67	19	43	53	49
0.2a	-19	29	-94	5	68	-22	23	72	14	35	56	34
0.1a	-10	30	-51	5	72	-10	15	75	8	22	58	18
BOT.	0	30	0	0	74	0	0	76	0	0	59	0

**Table 195 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-35	11	-177	0	3	-143	0	9	-45	0	10
0.9a	-54	24	-272	-21	7	-132	-5	4	-42	2	7
0.8a	-49	24	-245	-25	6	-124	-7	3	-38	5	6
0.7a	-45	25	-224	-24	5	-114	-6	4	-33	8	6
0.6a	-41	25	-204	-20	5	-102	-2	6	-28	11	8
0.5a	-36	26	-182	-16	3	-88	1	8	-22	15	11
0.4a	-32	27	-158	-12	1	-72	5	12	-16	19	14
0.3a	-26	28	-129	-8	2	-55	8	16	-11	20	17
0.2a	-19	29	-94	-3	6	-37	10	20	-5	19	20
0.1a	-10	30	-51	0	9	-18	8	23	-2	13	22
BOT	0	30	0	0	11	0	0	24	0	0	23

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 196 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	-29	28	-147	0	59	-62	0	58	51	0	45
0.9a	-46	38	-229	-8	54	-58	7	54	48	16	42
0.8a	-41	38	-206	-9	54	-53	14	53	46	28	42
0.7a	-37	39	-187	-6	56	-49	20	55	43	38	43
0.6a	-34	41	-170	-2	59	-43	25	59	40	45	46
0.5a	-30	43	-152	2	63	-36	29	64	37	49	50
0.4a	-27	45	-133	5	68	-29	31	69	32	49	54
0.3a	-22	48	-109	7	74	-21	30	74	27	46	57
0.2a	-16	50	-80	8	80	-13	26	79	20	38	60
0.1a	-9	51	-44	6	85	-6	17	83	11	23	63
BOT.	0	52	0	0	86	0	0	84	0	0	63

**Table 197 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c			
		$M_{zc}$	$M_{yc}$	$M_{yzc}$													
TOP	-29	28	-147	0	27	-164	0	14	-108	0	7	-70	0	3	-48	0	0
0.9a	-46	38	-229	-26	26	-151	-14	17	-100	-9	10	-65	-6	4	-44	-5	0
0.8a	-41	38	-206	-30	25	-141	-20	17	-92	-13	10	-59	-10	5	-39	-8	0
0.7a	-37	39	-187	-28	26	-129	-20	17	-83	-14	10	-52	-10	5	-33	-9	0
0.6a	-34	41	-170	-25	28	-115	-18	18	-73	-12	10	-44	-9	5	-27	-7	0
0.5a	-30	43	-152	-22	29	-101	-15	18	-62	-9	10	-35	-5	5	-20	-4	0
0.4a	-27	45	-133	-18	29	-84	-10	18	-50	-4	9	-27	-1	4	-13	1	0
0.3a	-22	48	-109	-13	29	-66	-6	16	-37	0	8	-18	4	3	-8	5	0
0.2a	-16	50	-80	-8	28	-45	-1	14	-24	4	6	-11	7	2	-3	8	0
0.1a	-9	51	-44	-3	26	-23	2	12	-11	5	5	-4	7	1	-1	7	0
BOT	0	52	0	0	24	0	0	11	0	0	4	0	0	1	0	0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 198 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b		0.8b		0.7b		0.6b			
		$M_{xc}$	$M_{yc}$								
TOP	-29	27	-147	0	58	-65	0	58	50	0	45
0.9a	-48	35	-238	-9	53	-60	7	54	48	16	42
0.8a	-42	34	-210	-9	53	-55	14	53	45	28	42
0.7a	-38	35	-188	-6	55	-49	20	55	43	38	43
0.6a	-33	38	-167	-1	58	-43	26	59	40	45	46
0.5a	-30	41	-148	3	63	-35	30	64	37	49	50
0.4a	-25	44	-126	6	68	-28	32	69	33	50	53
0.3a	-20	48	-102	8	74	-20	31	74	29	47	54
0.2a	-15	51	-74	9	80	-12	27	79	20	38	60
0.1a	-8	53	-41	7	84	-5	17	82	11	23	62
BOT.	0	54	0	0	86	0	0	83	0	0	63
										33	0
										0	0
										0	0

**Table 199 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-29	27	-147	0	40	-223	0	25	-204	0	15
0.9a	-48	35	-238	-39	26	-208	-31	20	-188	-26	14
0.8a	-42	34	-210	-39	25	-191	-36	18	-175	-34	12
0.7a	-38	35	-188	-36	27	-172	-35	19	-158	-34	13
0.6a	-33	39	-167	-32	29	-153	-31	22	-140	-31	14
0.5a	-30	41	-148	-28	32	-133	-27	24	-121	-27	16
0.4a	-25	44	-126	-24	35	-111	-23	26	-100	-22	17
0.3a	-20	48	-102	-19	37	-88	-18	27	-77	-17	18
0.2a	-15	51	-74	-13	38	-61	-11	28	-52	-10	18
0.1a	-8	53	-41	-6	38	-32	-5	27	-26	-4	17
BOT.	0	54	0	0	38	0	0	26	0	0	17

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 200 Moment Coefficients along Long Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-18	9	-89	0	25	-50	0	26	26	0	21	76
0.9a	-30	16	-149	-8	21	-46	3	22	25	9	18	72
0.8a	-28	16	-138	-8	21	-44	7	22	24	16	17	69
0.7a	-26	16	-130	-6	23	-41	10	23	23	22	18	65
0.6a	-24	17	-122	-4	25	-37	13	25	22	26	20	60
0.5a	-22	19	-112	-2	28	-33	16	29	20	30	23	54
0.4a	-20	20	-101	0	32	-28	18	33	19	31	27	47
0.3a	-17	22	-85	2	37	-21	18	38	16	30	38	38
0.2a	-13	23	-64	3	41	-14	17	43	13	26	33	28
0.1a	-7	24	-36	4	46	-6	12	46	7	17	36	15
BOT.	0	25	0	0	47	0	0	47	0	0	36	0

**Table 201 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.4c	0.3c	0.2c	0.1c	0.9c	0.8c
	$\mathbf{M}_{xc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$								
TOP	-18	9	-89	0	10	-95	0	3	-50	0	0
0.9a	-30	16	-149	-16	10	-88	-7	6	-46	-3	-18
0.8a	-28	16	-138	-18	10	-84	-9	6	-43	-4	-17
0.7a	-26	16	-130	-17	10	-78	-9	6	-39	-4	-14
0.6a	-24	17	-122	-15	11	-72	-8	6	-34	-2	-11
0.5a	-22	19	-112	-14	11	-64	-6	6	-29	0	-2
0.4a	-20	20	-101	-11	11	-55	-3	4	-23	3	-1
0.3a	-17	22	-85	-8	9	-44	0	2	-16	6	-2
0.2a	-13	23	-64	-5	7	-30	3	1	-10	8	3
0.1a	-7	24	-36	-1	5	-15	4	3	-4	7	5
BOT.	0	25	0	0	4	0	0	0	6	0	4

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 202 Moment Coefficients along Long Side for Rectangular Tanks Having Case 6 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-16	13	-82	0	28	-41	0	28	33	0	22	83
0.9a	-28	17	-142	-7	24	-38	4	24	32	10	19	79
0.8a	-26	17	-129	-6	24	-35	8	24	31	18	19	74
0.7a	-24	18	-118	-4	25	-32	12	25	30	24	20	70
0.6a	-22	20	-109	-1	27	-29	16	28	28	29	22	65
0.5a	-20	22	-98	2	31	-24	19	32	26	32	25	58
0.4a	-17	25	-87	4	36	-20	21	36	24	34	28	51
0.3a	-14	28	-72	5	41	-14	21	41	20	33	32	41
0.2a	-11	31	-54	6	46	-9	19	45	15	28	35	30
0.1a	-6	33	-31	5	50	-4	13	49	9	18	37	20
BOT.	0	34	0	0	52	0	0	50	0	38	0	0

**Table 203 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-16	13	-82	0	21	129	0	13	-115	0	8
0.9a	-28	17	-142	-23	13	121	-18	11	-107	-14	7
0.8a	-26	17	-129	-23	12	113	-21	9	-100	-19	6
0.7a	-24	18	-118	-22	14	104	-20	10	-92	-19	7
0.6a	-22	20	-109	-20	15	94	-19	12	-83	-18	8
0.5a	-20	22	-98	-18	18	84	-17	13	-73	-16	9
0.4a	-17	25	-87	-16	20	72	-15	15	-61	-14	10
0.3a	-14	28	-72	-13	22	58	-11	16	-47	-10	10
0.2a	-11	31	-54	-9	23	41	-7	16	-32	-6	10
0.1a	-6	33	-31	-4	23	22	-3	15	-16	-1	9
BOT	0	34	0	0	22	0	0	15	0	0	9
											0
											0
											0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 204 Moment Coefficients along Long Sde for Rectangular Tanks having Case 6 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-7	4	-36	0	9	-19	0	9	17	0	7	42
0.9a	-13	5	-64	-4	6	-18	1	6	17	4	5	41
0.8a	-12	5	-61	-4	6	-17	3	6	16	8	4	39
0.7a	-12	5	-58	-2	6	-16	5	6	16	10	5	38
0.6a	-11	6	-56	-1	7	-15	7	7	15	13	6	36
0.5a	-11	7	-54	0	9	-14	8	9	14	15	7	33
0.4a	-10	9	-50	0	12	-13	9	12	13	16	9	30
0.3a	-9	11	-44	1	15	-10	10	15	12	17	12	25
0.2a	-7	13	-35	2	19	7	10	19	9	15	15	19
0.1a	-4	14	-21	2	22	-3	7	22	6	11	17	11
BOT.	0	15	0	0	24	0	0	23	0	0	17	0

**Table 205 Moment Coefficients along Short Side for Rectangular Tanks having Case 6 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-7	4	-36	0	7	-53	0	4	-43	0	2
0.9a	-13	5	-64	-9	4	-50	-6	3	-40	-5	2
0.8a	-12	5	-61	-10	4	-48	-8	3	-38	-6	2
0.7a	-12	5	-58	-10	4	-46	-8	3	-36	-7	2
0.6a	-11	6	-56	-9	5	-44	-8	4	-34	-7	3
0.5a	-11	7	-54	-9	6	-40	-7	5	-30	-6	3
0.4a	-10	9	-50	-8	7	-36	-7	5	-26	-5	3
0.3a	-9	11	-44	-7	8	-30	-5	6	-21	4	4
0.2a	-7	13	-35	-5	9	-23	-3	6	-14	-2	3
0.1a	-4	14	-21	-2	8	-12	-1	5	-7	1	2
BOT	0	15	0	0	8	0	0	4	0	2	0
										1	0
										0	0
										0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 206 Deflection Coefficients along Long Side, Mid-height ( $y = a/2$ ) for Tanks having Case 7 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

$b/a$	$c/a$	$x$	End	<b>0.1b</b>	<b>0.2b</b>	<b>0.3b</b>	<b>0.4b</b>	<b>0.5b</b>
				<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	
4.0	3.0		0	8.20	20.50	29.50	34.40	35.90
4.0	2.0		0	9.20	21.40	30.10	34.80	36.30
4.0	1.5		0	10.20	22.30	30.80	35.30	36.70
4.0	1.0		0	11.30	23.40	30.80	35.80	37.20
4.0	0.5		0	11.60	23.60	31.50	35.90	37.30
3.0	2.0		0	5.60	14.40	21.70	26.20	27.70
3.0	1.5		0	6.60	15.50	22.70	27.10	28.50
3.0	1.0		0	7.70	16.70	23.80	28.00	29.40
3.0	0.5		0	8.00	17.00	24.00	28.20	29.60
2.0	1.5		0	2.70	7.00	10.90	13.50	14.40
2.0	1.0		0	3.70	8.30	12.40	15.00	15.90
2.0	0.5		0	4.10	8.80	12.90	15.60	16.50
1.5	1.0		0	1.70	4.10	6.20	7.60	8.10
1.5	0.5		0	2.20	4.70	7.00	8.50	9.00
1.0	0.5		0	0.70	1.60	2.30	2.80	3.00

**Table 207 Deflection Coefficients along Short Side, Mid-height ( $y = a/2$ ) for Tanks having Case 7 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

$b/a$	$c/a$	$z$	End	<b>0.1c</b>	<b>0.2c</b>	<b>0.3c</b>	<b>0.4c</b>	<b>0.5c</b>
				<b>0.6c</b>	<b>0.7c</b>	<b>0.8c</b>	<b>0.9c</b>	
4.0	3.0		0	4.60	13.10	20.50	25.20	26.80
4.0	2.0		0	1.10	4.50	8.10	10.60	11.50
4.0	1.5		0	-0.40	0.60	1.90	3.00	3.30
4.0	1.0		0	-1.20	-1.80	-2.00	-2.00	-2.00
4.0	0.5		0	-0.80	-1.40	-1.90	-2.10	-2.20
3.0	2.0		0	1.30	4.80	8.40	11.00	11.90
3.0	1.5		0	-0.30	0.80	2.20	3.30	3.70
3.0	1.0		0	-1.10	-1.60	-1.80	-1.80	-1.80
3.0	0.5		0	-0.80	-1.40	-1.80	-2.00	-2.10
2.0	1.5		0	0.30	1.70	3.40	4.50	5.00
2.0	1.0		0	-0.80	-1.00	-0.90	-0.80	-0.80
2.0	0.5		0	-0.60	-1.10	-1.40	-1.60	-1.70
1.5	1.0		0	-0.30	-0.20	0.10	0.30	0.40
1.5	0.5		0	-0.50	-0.80	-1.00	-1.10	-1.20
1.0	0.5		0	-0.20	-0.40	-0.40	-0.50	-0.50

**Table 208 Deflection Coefficients along Long Side, Mid-span ( $x = b/2$ ) for Tanks having Case 7 Arrangements for Various Length/Height and Width/Height Ratios**  
*(Table 1, Clauses 3.1 and 3.1.4)*

$b/a$	$c/a$	$y$	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	2.00	7.40	15.30	25.00	35.90	47.70	59.80	72.10	84.50	96.80	
4.0	2.0	0	2.00	7.40	15.40	25.20	36.30	48.20	60.50	73.00	85.50	98.10	
4.0	1.5	0	2.00	7.50	15.60	25.50	36.70	48.70	61.20	73.90	86.60	99.40	
4.0	1.0	0	2.10	7.60	15.70	25.80	37.20	49.40	62.00	74.90	87.80	100.80	
4.0	0.5	0	2.10	7.60	15.80	25.80	37.30	49.50	62.20	75.10	88.00	101.00	
3.0	2.0	0	1.60	5.90	12.10	19.50	27.70	36.30	45.10	53.90	62.60	71.40	
3.0	1.5	0	1.70	6.10	12.40	20.10	28.50	37.40	46.50	55.60	64.70	73.80	
3.0	1.0	0	1.70	6.20	12.80	20.70	29.40	38.70	48.10	57.50	67.00	76.40	
3.0	0.5	0	1.70	6.30	12.80	20.80	29.60	38.90	48.40	57.90	67.40	77.00	
2.0	1.5	0	1.00	3.40	6.70	10.50	14.40	18.30	22.20	25.90	29.50	33.20	
2.0	1.0	0	1.10	3.70	7.30	11.50	15.90	20.40	24.70	29.00	33.10	37.30	
2.0	0.5	0	1.10	3.80	7.60	11.90	16.50	21.10	25.60	30.00	34.30	38.70	
1.5	1.0	0	0.60	2.10	4.00	6.10	8.10	10.00	11.80	13.50	15.10	16.70	
1.5	0.5	0	0.70	2.30	4.40	6.70	9.00	11.10	13.20	15.10	16.90	18.80	
1.0	0.5	0	0.30	0.90	1.70	2.40	3.00	3.50	3.90	4.30	4.70	5.00	

**Table 209 Deflection Coefficients along Short Side, Mid-span ( $z = c/2$ ) for Tanks having Case 7 Arrangements for Various Length/Height and Width/Height Ratios**  
*(Table 1, Clauses 3.1 and 3.1.4)*

$b/a$	$c/a$	$y$	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	1.60	5.70	11.70	18.90	26.80	35.00	43.40	51.80	60.10	68.50	
4.0	2.0	0	0.80	2.80	5.50	8.50	11.50	14.50	17.30	20.00	22.60	25.30	
4.0	1.5	0	0.30	1.10	1.90	2.70	3.30	3.80	4.10	4.30	4.40	4.60	
4.0	1.0	0	0.00	-0.20	-0.60	-1.30	-2.00	-2.90	-3.90	-4.80	-5.80	-6.70	
4.0	0.5	0	-0.10	-0.50	-1.00	-1.50	-2.20	-2.90	-3.50	-4.20	-4.80	-5.50	
3.0	2.0	0	0.80	2.90	5.60	8.70	11.90	14.90	17.90	20.70	23.40	26.20	
3.0	1.5	0	0.40	1.20	2.10	2.90	3.70	4.20	4.60	4.90	5.20	5.50	
3.0	1.0	0	0.00	-0.20	-0.50	-1.10	-1.80	-2.60	-3.50	-4.30	-5.20	-6.00	
3.0	0.5	0	-0.10	-0.50	-0.90	-1.50	-2.10	-2.70	-3.30	-3.90	-4.50	-5.10	
2.0	1.5	0	0.40	1.40	2.60	3.90	5.00	5.90	6.80	7.50	8.20	8.90	
2.0	1.0	0	0.00	0.00	-0.10	-0.40	-0.80	-1.30	-1.80	-2.40	-2.90	-3.40	
2.0	0.5	0	-0.10	-0.40	-0.70	-1.20	-1.70	-2.10	-2.60	-3.00	-3.40	-3.90	
1.5	1.0	0	0.10	0.30	0.40	0.50	0.40	0.20	0.00	-0.20	-0.50	-0.70	
1.5	0.5	0	-0.10	-0.30	-0.50	-0.80	-1.20	-1.50	-1.80	-2.10	-2.30	-2.60	
1.0	0.5	0	0.00	-0.10	-0.20	-0.40	-0.50	-0.60	-0.70	-0.80	-0.90	-1.00	

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 210 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$	$M_{yc}$	$M_{xc}$
TOP	-68	4	-338	0	83	-41	0	74	51	0	50
0.9a	-75	10	-373	-6	79	-38	7	74	47	9	50
0.8a	-61	9	-303	-9	79	-34	7	74	41	8	50
0.7a	-49	8	-247	-11	79	-29	1	73	35	-2	50
0.6a	-39	8	-197	-13	79	-24	-11	72	27	-21	48
0.5a	-30	7	-150	-18	76	-20	-30	69	17	-50	45
0.4a	-21	6	-105	-26	71	17	-56	64	5	-89	41
0.3a	-13	5	-64	-38	62	-14	-91	55	-7	-139	34
0.2a	-6	4	-28	-55	49	-14	-137	42	-22	202	25
0.1a	-1	2	-5	-78	29	-16	-194	24	-37	-277	14
BOT.	0	0	0	-108	0	-22	-265	0	-53	-367	0

**Table 211 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-68	4	-338	0	67	-88	0	71	31	0	54
0.9a	-75	10	-373	-12	62	-80	5	68	28	11	53
0.8a	-61	9	-303	-16	62	-71	6	68	26	15	53
0.7a	-49	8	-247	-15	62	-62	4	69	22	12	53
0.6a	-39	8	-197	-14	62	-51	-1	69	18	1	53
0.5a	-30	7	-150	-13	61	-40	-12	68	12	-18	52
0.4a	-21	6	-105	-16	57	-30	-28	64	5	-46	48
0.3a	-13	5	-64	-22	51	-21	-52	57	-3	-84	42
0.2a	-6	4	-28	-32	41	-15	-84	45	13	-134	32
0.1a	-1	2	-5	-45	25	-11	-126	27	-24	-197	19
BOT.	0	0	0	-61	0	-12	-180	0	-36	-275	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 212 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b		0.8b		0.7b		0.6b			
		$M_{xc}$	$M_{yc}$								
TOP	-56	15	-281	0	84	-28	0	73	53	0	49
0.9a	-65	25	-323	-4	81	-26	7	73	49	8	49
0.8a	-53	24	-267	-7	80	-23	7	73	43	7	49
0.7a	-44	23	-221	-9	80	-20	1	72	36	-3	48
0.6a	-36	21	-180	-13	80	-17	-12	71	28	-23	47
0.5a	-28	19	-140	-18	77	-14	-31	68	17	-52	44
0.4a	-20	17	-100	-28	72	13	-59	63	5	-92	39
0.3a	-13	14	-63	-42	63	-12	-96	54	-8	-143	33
0.2a	-6	10	-29	-61	50	-14	-143	41	-23	-207	24
0.1a	-1	5	-5	-87	30	-18	-202	23	-39	-283	13
BOT.	0	0	0	-120	0	-24	-276	0	-55	-374	0

**Table 213 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c		
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c	
M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	
TOP	-56	15	-281	0	28	-126	0	39	-7	0	33	58
0.9a	-65	25	-323	-18	23	-115	0	35	-6	9	31	54
0.8a	-53	24	-267	-21	24	-102	2	35	-5	15	31	49
0.7a	-44	23	-221	-17	25	-88	4	37	-3	18	32	44
0.6a	-36	21	-180	-12	26	-72	6	39	-2	18	34	37
0.5a	-28	19	-140	-7	27	-55	5	40	-1	13	35	29
0.4a	-20	17	-100	5	27	-40	1	40	-1	2	35	20
0.3a	-13	14	-63	-5	27	-26	-8	38	-2	-16	32	10
0.2a	-6	10	-29	-8	23	-14	-24	32	-5	-44	27	-2
0.1a	-1	5	-5	-14	15	-7	-47	20	-9	-83	17	-15
BOT	0	0	0	-19	0	4	-79	0	-16	-137	0	-27

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 214 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b		0.8b		0.7b		0.6b			
		$M_{xc}$	$M_{yc}$								
TOP	-47	31	-235	0	85	-14	0	72	56	0	48
0.9a	-55	38	-276	-2	82	-13	7	72	51	8	48
0.8a	-46	37	-230	-4	82	-11	8	72	45	7	48
0.7a	-38	36	-192	-7	82	-10	1	71	38	-4	47
0.6a	-32	34	-158	-11	82	-9	-12	70	29	-24	45
0.5a	-25	32	-125	-18	79	-8	-33	67	18	-54	42
0.4a	-18	28	-92	-30	74	-8	-62	61	5	-95	38
0.3a	-12	23	-59	-46	65	-10	-101	52	-9	-147	31
0.2a	-6	17	-28	-68	51	-14	-150	40	-24	-212	23
0.1a	-1	9	-6	-97	30	-19	211	23	-41	-289	13
BOT.	0	0	0	-134	0	-27	-287	0	-57	-381	0

**Table 215 Moment Coefficients along Short side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c				
		$M_x$	$M_{yc}$	$M_{zc}$	$M_{yec}$													
TOP	-47	31	-235	0	1	-139	0	12	-39	0	13	22	0	8	54	0	0	65
0.9a	-55	38	-276	-21	5	-125	-5	8	-35	4	10	21	8	6	51	9	0	61
0.8a	-46	37	-230	-23	4	-111	-5	8	-30	7	10	20	14	6	48	16	0	57
0.7a	-38	36	-192	-18	3	-95	-1	9	-25	11	11	20	19	7	44	21	0	52
0.6a	-32	34	-158	-12	2	-78	3	11	-19	15	13	19	22	8	40	24	0	46
0.5a	-25	32	-125	-6	0	-60	7	14	-13	17	15	17	23	9	34	25	0	39
0.4a	-18	28	-92	-2	3	-42	9	16	-8	16	17	14	20	10	26	21	0	30
0.3a	-12	23	-59	1	6	-27	8	17	-4	10	17	10	11	10	17	11	0	19
0.2a	-6	17	-28	2	7	-14	2	16	-2	2	16	4	-6	9	7	-7	0	8
0.1a	-1	9	-6	1	6	-4	-9	12	-2	-23	11	-3	-34	6	-4	-38	0	-5
BOT	0	0	0	0	0	-27	0	-5	-57	0	-11	-78	0	-16	-86	0	-17	

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 216 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.9b				0.2b				0.7b				0.3b				0.4b				0.6b				0.5b			
		$M_{xc}$	$M_{yc}$	$M_{xe}$	$M_{ye}$	$M_{xyc}$	$M_{yec}$	$M_{xce}$	$M_{yce}$																				
TOP	-39	45	-194	0	87	1	0	71	59	0	46	61	0	22	52	0	0	0	0	47									
0.9a	-45	50	-227	0	85	1	8	71	54	8	46	55	6	22	46	6	6	0	0	42									
0.8a	-38	50	-188	-1	84	1	8	71	48	6	46	47	3	22	38	1	0	0	0	34									
0.7a	-31	49	-157	-4	84	1	1	70	40	-5	45	37	-12	21	28	-15	0	0	25										
0.6a	-26	48	-129	-9	84	0	-13	69	30	-26	44	25	-37	20	17	-41	0	0	13										
0.5a	-21	46	-103	-18	81	-1	-35	65	18	-57	41	12	-73	19	3	-78	0	0	0										
0.4a	-15	42	-76	-31	75	-4	-65	60	5	-99	36	-4	-120	16	-12	-127	0	-15											
0.3a	-10	36	-50	-49	66	-8	-106	51	-9	152	30	-21	-179	13	-29	-188	0	-32											
0.2a	-5	27	-25	-75	51	-13	-157	38	-26	-217	22	-39	-251	9	-47	-261	0	-49											
0.1a	-1	15	-6	-108	31	-21	-221	22	-43	-296	12	-58	-335	5	-66	-346	0	-69											
BOT.	0	0	0	-151	0	-30	-300	0	-60	-388	0	-78	-431	0	-86	-444	0	-89											

**Table 217 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-39	45	-194	0	27	-156	0	12	-90	0	6
0.9a	-45	50	-227	-26	27	-139	-14	16	-81	-7	8
0.8a	-38	50	-188	-26	27	-122	-16	16	-71	-9	9
0.7a	-31	49	-157	-21	28	-103	-12	16	-60	-6	8
0.6a	-26	48	-129	-15	28	-84	-7	15	-47	-1	8
0.5a	-21	46	-103	-9	26	-64	-1	14	-35	6	6
0.4a	-15	42	-76	-3	22	-46	6	11	23	12	5
0.3a	-10	36	-50	2	17	-28	11	7	-12	17	2
0.2a	-5	27	-25	7	11	-14	14	4	-4	19	0
0.1a	-1	15	-6	10	5	-3	15	0	1	17	1
BOT	0	0	0	13	0	3	13	0	3	0	2

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 218 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b		0.8b		0.7b		0.6b			
		$M_{xc}$	$M_{yc}$								
TOP	-38	47	-191	0	88	4	0	71	60	0	46
0.9a	-45	49	-225	0	85	4	8	71	55	8	46
0.8a	-36	49	-182	0	85	4	8	71	48	6	46
0.7a	-30	49	-149	-3	85	3	2	70	40	-5	45
0.6a	-24	48	-119	-8	84	2	-13	69	30	-26	43
0.5a	-18	47	-92	-17	81	1	-35	65	18	-57	40
0.4a	-13	44	-66	-30	75	-2	-66	59	-5	-99	36
0.3a	-8	39	-42	-49	66	-7	-107	50	-10	-153	30
0.2a	-4	31	-20	-76	51	-13	-158	38	-26	-218	22
0.1a	-1	18	-4	-111	30	-21	-223	21	-43	-297	12
BOT.	0	0	0	-156	0	-31	-302	0	-60	-390	0

**Table 219 Moment Coefficients along Short Side for Rectangular Tanks Having Case 7 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c		
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c	
	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$									
TOP	-38	47	-191	0	43	-215	0	26	-186	0	16	-167
0.9a	-45	49	-225	-37	33	-191	-30	23	-166	-25	15	-151
0.8a	-36	49	-182	-33	33	-163	-31	23	-146	-29	14	-133
0.7a	-30	49	-149	-27	35	-135	-26	25	-123	-25	16	-113
0.6a	-24	48	-119	-21	36	-108	-20	26	-99	-19	17	-92
0.5a	-18	47	-92	-15	35	-83	-13	25	-75	-12	17	-69
0.4a	-13	44	-66	-10	33	-58	-7	24	-52	-5	16	-48
0.3a	-8	39	-42	4	29	-36	0	21	-32	2	14	-29
0.2a	-4	31	-20	2	22	-17	6	16	-15	9	11	-13
0.1a	-1	18	-4	7	14	-4	12	10	-2	16	6	-1
BOT	0	0	0	0	0	2	21	0	4	26	0	5
												29
												0
												6

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 220 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-52	6	-259	0	72	-65	0	70	39	0	52	75
0.9a	-62	19	-311	-9	67	-60	6	68	35	11	51	69
0.8a	-52	18	-258	-12	67	-53	7	68	32	15	51	61
0.7a	-43	18	-215	-12	68	-46	5	69	27	11	52	51
0.6a	-35	17	-176	-12	68	-38	-2	69	22	-1	51	39
0.5a	-28	15	-138	-14	66	-31	-14	68	15	-22	50	26
0.4a	-20	13	-100	-18	62	-23	-32	64	7	-51	46	12
0.3a	-13	11	-63	-26	56	-18	-58	56	-3	91	40	-4
0.2a	-6	8	-29	-38	44	-14	-93	44	-14	-143	31	-22
0.1a	-1	4	-6	-55	27	-13	-138	26	-26	-208	18	-40
BOT.	0	0	0	-75	0	-15	-196	0	-39	-288	0	-58

**Table 221 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c		
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c	
M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	
TOP	-52	6	-259	0	30	-120	0	40	-4	0	33	60
0.9a	-62	19	-311	17	25	-109	1	36	-3	10	31	55
0.8a	-52	18	-258	20	25	-98	2	36	-2	16	31	50
0.7a	-43	18	-215	16	26	-84	4	38	-1	18	33	45
0.6a	-35	17	-176	12	27	-69	6	40	0	18	34	38
0.5a	-28	15	-138	8	29	-53	5	41	0	12	35	30
0.4a	-20	13	-100	5	29	-38	0	41	0	1	35	20
0.3a	-13	11	-63	6	28	-25	10	38	-1	18	33	10
0.2a	-6	8	-29	9	24	-14	26	32	-5	46	27	-2
0.1a	-1	4	-6	15	16	-7	49	21	-10	85	17	-15
BOT	0	0	0	21	0	-4	82	0	-16	140	0	-28

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 222 Moment Coefficients along Long Side for Rectangular Tanks 8 having Case 7 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	-43	23	-214	0	75	-46	0	70	45	0	51
0.9a	-53	33	-264	-6	71	-43	7	69	41	11	51
0.8a	-44	32	-222	-9	71	-38	8	69	37	15	51
0.7a	-37	31	-187	-10	71	-33	5	69	31	10	51
0.6a	-31	30	-156	-11	71	-28	-2	69	25	-3	50
0.5a	-25	28	-124	-14	70	-23	-16	68	17	-24	49
0.4a	-18	25	-92	-20	66	-18	-35	64	8	-55	45
0.3a	-12	21	-59	-30	58	-14	-63	56	-3	-96	39
0.2a	-6	15	-29	-44	47	-13	-100	44	-15	-150	30
0.1a	-1	8	-6	-63	28	-14	-148	26	-28	-217	17
BOT.	0	0	0	-88	0	-18	-210	0	-42	-299	0

**Table 223 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c		
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c	
	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zc}$									
TOP	-43	23	-214	0	1	-132	0	13	-35	0	13	24
0.9a	-53	33	-264	-20	3	-119	-4	9	-31	4	11	23
0.8a	-44	32	-222	-22	2	-106	-4	9	-27	8	10	23
0.7a	-37	31	-187	-17	1	-91	-1	10	-22	12	12	22
0.6a	-31	30	-156	-12	0	-75	4	13	-17	15	14	20
0.5a	-25	28	-124	-7	2	-58	7	15	-11	17	16	18
0.4a	-18	25	-92	-2	5	-41	9	17	-7	15	17	15
0.3a	-12	21	-59	1	8	-26	7	18	-4	9	18	10
0.2a	-6	15	-29	1	9	-14	1	17	-2	-4	16	-4
0.1a	-1	8	-6	0	7	-4	-11	12	-3	-26	11	-4
BOT.	0	0	0	-2	0	0	-30	0	-6	-61	0	-12

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 224 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-35	39	-175	0	79	-26	0	71	52	0	51	77
0.9a	-43	45	-216	-3	75	-23	8	70	48	11	50	70
0.8a	-36	45	-181	-5	75	-21	10	70	42	14	50	61
0.7a	-30	45	-152	-6	75	-18	7	70	36	9	50	51
0.6a	-25	44	-127	-8	75	-15	-2	70	29	-4	50	39
0.5a	-20	42	-102	-12	74	-13	-17	68	20	-27	48	25
0.4a	-15	39	-76	-20	69	-11	-39	63	9	-59	44	10
0.3a	-10	33	-50	-33	62	-10	-69	55	-3	-102	38	-7
0.2a	-5	25	-26	-50	49	-12	-108	43	-16	-158	29	-25
0.1a	-1	14	-6	-74	30	-15	-160	25	-30	-227	16	-44
BOT.	0	0	0	-105	0	-21	-226	0	-45	-311	0	-62

**Table 225 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-35	39	-175	0	25	11	0	11	-84	0	5
0.9a	-43	45	-216	-25	25	14	-13	14	-76	-6	7
0.8a	-36	45	-181	-25	25	14	-15	14	-67	-8	8
0.7a	-30	45	-152	-20	26	14	-12	14	-56	-5	7
0.6a	-25	44	-127	-15	25	14	-6	14	-44	0	7
0.5a	-20	42	-102	-9	24	12	-1	12	-33	6	6
0.4a	-15	39	-76	-4	20	10	5	10	-21	12	4
0.3a	-10	33	-50	2	16	6	10	6	-12	16	2
0.2a	-5	25	-26	6	10	3	13	3	-4	18	1
0.1a	-1	14	-6	9	5	0	14	0	1	15	2
BOT	0	0	0	12	0	0	10	0	2	5	0
										1	0
										0	0
										-2	0
										0	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 226 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b			
		0.9b				0.8b				0.7b				0.6b							
		$M_{xc}$	$M_{yc}$																		
TOP	-34	41	-171	0	79	-22	0	71	54	0	51	77	0	26	81	0	0	0	0	81	0
0.9a	-43	45	-213	-3	76	-20	8	70	49	11	50	70	12	26	74	13	0	0	73	0	0
0.8a	-35	44	-174	-4	76	-17	10	70	44	15	50	61	15	26	64	15	0	0	63	0	0
0.7a	-29	45	-143	-4	77	-14	7	71	37	9	50	51	8	25	52	7	0	0	51	0	0
0.6a	-23	45	-116	-6	76	-12	-1	70	29	-4	50	39	-9	25	38	-11	0	0	37	0	0
0.5a	-18	44	-90	-11	74	-10	-16	68	20	-27	48	25	-37	24	23	-40	0	0	21	0	0
0.4a	-13	42	-65	-19	70	-8	-39	63	9	-60	44	10	-75	21	6	-81	0	0	4	0	0
0.3a	--8	37	-42	-32	62	-9	-69	55	-3	-104	37	-7	-126	18	-13	-134	0	0	-15	0	0
0.2a	-4	29	-20	-51	49	-11	-110	43	-16	-159	28	-25	-190	14	-32	-201	0	0	-34	0	0
0.1a	-1	18	-5	-77	30	-15	-163	25	-31	-229	16	-44	-268	8	-52	-281	0	0	-55	0	0
BOT.	0	0	0	-111	0	-22	-230	0	-46	-314	0	-63	-362	0	-72	-377	0	0	-75	0	0

**Table 227 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
	$\mathbf{M}_z$	$\mathbf{M}_{yz}$	$\mathbf{M}_y$	$\mathbf{M}_{zy}$	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_{zy}$	$\mathbf{M}_{zc}$	$\mathbf{M}_{yc}$	$\mathbf{M}_z$	$\mathbf{M}_{yz}$
TOP	-34	41	-171	0	40	-202	0	24	-175	0	15
0.9a	-43	45	-213	-35	30	-180	-28	22	-157	14	-142
0.8a	-35	44	-174	-32	31	-155	-30	21	-138	-28	13
0.7a	-29	45	-143	-26	32	-129	-25	23	-117	-24	15
0.6a	-23	45	-116	-21	33	-104	-19	24	-94	-18	16
0.5a	-18	44	-90	-15	33	-80	-13	24	-72	-12	16
0.4a	-13	42	-65	-10	31	-57	-7	23	-51	-5	15
0.3a	--8	37	-42	-4	27	-36	-1	20	-31	2	13
0.2a	-4	29	-20	1	22	-17	6	15	-14	9	10
0.1a	-1	18	-5	6	13	-4	12	9	-2	16	6
BOT	0	0	0	12	0	2	20	0	4	25	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 228 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
		$M_{xc}$	$M_{yc}$								
TOP	-33	5	-164	0	43	-73	0	45	20	0	35
0.9a	-45	16	-223	-10	38	-66	4	42	19	11	33
0.8a	-38	16	-192	-12	39	-60	6	42	17	17	34
0.7a	-33	15	-166	-10	40	-53	8	44	16	19	35
0.6a	-28	15	-142	-8	41	-44	7	45	13	16	36
0.5a	-23	14	-116	-7	42	-35	3	47	10	8	37
0.4a	-18	13	-88	-8	42	-26	-5	46	7	-7	36
0.3a	-12	1	-59	-11	39	-18	-19	43	2	-30	34
0.2a	-6	9	-30	-18	33	-12	-40	36	-5	63	27
0.1a	-1	5	-7	-28	21	-8	-70	22	-13	-108	17
BOT.	0	0	0	-41	0	-8	-110	0	-22	-170	0

**Table 229 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c				
		$M_{zc}$	$M_{yc}$															
TOP	-33	5	-164	0	9	-105	0	17	-18	0	16	35	0	9	64	0	0	73
0.9a	-45	16	-223	-16	5	-95	2	13	-16	5	13	33	9	8	60	10	0	69
0.8a	-38	16	-192	-18	6	-86	1	13	-14	10	13	31	16	8	56	18	0	64
0.7a	-33	15	-166	-14	7	-75	1	15	-11	13	14	29	20	9	51	22	0	58
0.6a	-28	15	-142	-10	8	-63	4	17	-8	15	16	26	22	10	45	24	0	51
0.5a	-23	14	-116	-7	10	-49	6	19	-5	16	18	23	21	11	37	23	0	42
0.4a	-18	13	-88	-4	12	-36	6	21	-3	12	20	18	16	12	28	17	0	32
0.3a	-12	1	-59	-2	14	-24	3	22	-1	4	20	11	4	12	18	4	0	19
0.2a	-6	9	-30	-2	13	-13	-5	20	-2	-11	18	4	-17	10	6	-18	0	6
0.1a	-1	5	-7	-5	10	-5	-20	14	-4	-37	12	-6	-49	7	-7	-54	0	-8
BOT	0	0	0	-9	0	-2	-42	0	-8	-76	0	-15	-98	0	-20	-106	0	-21

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 230 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b								
		0.9b		0.8b		0.7b		0.6b										
		$M_{xc}$	$M_{yc}$															
TOP	-26	22	-128	0	50	-45	0	49	35	0	37	78	0	19	99	0	0	106
0.9a	-35	29	-176	-6	46	-42	6	46	32	12	35	72	15	19	91	16	0	97
0.8a	-30	29	-152	-7	46	-38	9	46	29	19	36	65	24	19	82	25	0	87
0.7a	-27	30	133	-5	48	-33	10	48	26	20	37	57	26	20	71	27	0	75
0.6a	-23	30	-114	-5	49	-28	9	49	22	16	38	47	20	20	58	22	0	61
0.5a	-19	29	-95	-5	50	-22	3	50	17	7	38	36	8	20	44	8	0	46
0.4a	-15	28	-74	-8	49	-17	-8	49	11	-11	38	23	-14	20	28	-15	0	29
0.3a	-10	24	-51	-14	45	-13	-24	45	4	-36	34	9	-46	18	10	-49	0	10
0.2a	-5	19	-27	-23	38	-10	-49	37	-5	-73	28	-6	-90	14	-8	-96	0	-9
0.1a	-1	11	-7	-37	24	-9	-83	23	-15	-123	17	-22	-149	9	-27	-158	0	-29
BOT.	0	0	0	-55	0	-11	-129	0	-26	-189	0	-38	-226	0	-45	-238	0	-48

**Table 231 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-26	22	-128	0	16	-114	0	6	-60	0	2
0.9a	-35	29	-176	-19	17	-103	-9	9	-54	-4	4
0.8a	-30	29	-152	-20	16	-93	-11	9	-48	-5	5
0.7a	-27	30	-133	-17	17	-81	-9	9	-41	-2	4
0.6a	-23	30	-114	-13	17	-68	-5	8	-33	1	3
0.5a	-19	29	-95	-9	15	-54	0	7	-24	6	2
0.4a	-15	28	-74	-4	13	-40	4	4	-16	10	0
0.3a	-10	24	-51	0	9	-26	8	1	-9	13	2
0.2a	-5	19	-27	4	5	-13	9	1	-3	13	3
0.1a	-1	11	-7	6	1	-3	8	3	0	7	4
BOT.	0	0	0	7	0	1	1	0	-7	0	-1

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 232 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b				
		0.9b				0.8b				0.7b				0.6b								
		$M_{xc}$	$M_{yc}$																			
TOP	-24	26	-120	0	52	-38	0	50	40	0	38	81	0	20	100	0	0	0	100	0	0	106
0.9a	-33	31	-167	-5	48	-34	7	48	37	13	36	74	16	19	92	17	0	0	97			
0.8a	-28	31	-140	-5	49	-30	10	48	33	20	37	67	24	19	83	26	0	0	87			
0.7a	-24	32	-119	-3	50	-26	12	49	30	21	38	58	26	20	71	27	0	0	75			
0.6a	-20	33	-99	-2	51	-21	10	51	25	17	39	48	20	20	58	21	0	0	61			
0.5a	-16	33	-80	-3	52	-16	4	51	19	7	39	36	7	21	44	7	0	0	45			
0.4a	-12	33	-61	-6	51	-12	-7	50	12	-11	38	23	-15	20	27	-17	0	0	28			
0.3a	-8	30	-40	-13	48	-9	-25	46	4	-39	34	9	-48	18	9	-52	0	0	9			
0.2a	-4	25	-21	-24	39	-8	-51	37	-5	-77	28	-7	-94	14	-9	-100	0	0	-10			
0.1a	-1	15	-5	-41	25	-9	-88	23	-16	-128	17	-23	-154	8	-28	-163	0	0	-30			
BOT.	0	0	0	-64	0	-13	-137	0	-27	-196	0	-39	-232	0	-46	-245	0	0	-49			

**Table 233 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c		
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c	
M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	M <sub>zc</sub>	M <sub>yc</sub>	
TOP	-24	26	-120	0	29	-155	0	18	-134	0	11	-119
0.9a	-33	31	-167	-27	22	-140	-22	16	-121	-18	10	-109
0.8a	-28	31	-140	-25	22	-123	-23	15	-108	-22	10	-97
0.7a	-24	32	-119	-22	24	-104	-20	17	-93	-19	11	-84
0.6a	-20	33	-99	-18	25	-87	-16	18	-76	-15	12	-69
0.5a	-16	33	-80	-14	25	-69	-12	18	-59	-10	12	-53
0.4a	-12	33	-61	-9	25	-50	-7	18	-43	-5	12	-37
0.3a	-8	30	-40	-4	22	-33	-1	16	-27	1	10	-23
0.2a	-4	25	-21	1	18	-16	4	12	-13	7	8	-10
0.1a	-1	15	-5	5	11	-4	10	7	-2	13	5	-1
BOT	0	0	0	10	0	2	16	0	3	20	0	4

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 234 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b		0.8b		0.7b		0.6b			
		$M_{xc}$	$M_{yc}$								
TOP	-18	9	-89	0	26	-45	0	27	20	0	21
0.9a	-27	15	-135	-7	23	-42	3	24	18	9	19
0.8a	-24	15	-121	-7	23	-39	6	24	17	15	19
0.7a	-22	16	-110	-5	25	-35	8	26	16	18	20
0.6a	-20	16	-98	4	26	-30	9	28	14	18	22
0.5a	-17	16	-85	-3	28	-25	8	30	12	15	24
0.4a	-14	16	-68	-4	30	-19	3	31	9	7	25
0.3a	-10	14	-49	-6	29	-14	-5	31	5	-7	24
0.2a	-5	11	-27	-10	26	-9	-20	27	-1	-30	21
0.1a	-1	7	-7	-18	17	-6	-42	18	-7	-64	14
BOT.	0	0	0	-30	0	-6	-75	0	-15	-113	0

**Table 235 Moment Coefficients along Short side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-18	9	-81	0	7	-81	0	0	-35	0	2
0.9a	-27	15	-74	-14	8	-74	-5	3	-31	1	1
0.8a	-24	15	-68	-14	8	-68	-6	4	-28	1	1
0.7a	-22	16	-61	-13	8	-61	-5	3	-24	1	1
0.6a	-20	16	-53	-10	7	-53	-2	2	-19	4	0
0.5a	-17	16	-43	-7	6	-43	1	1	-14	7	2
0.4a	-14	16	-33	-4	4	-33	4	2	-9	9	3
0.3a	-10	14	-22	-1	2	-22	5	4	-5	10	5
0.2a	-5	11	-12	1	1	-12	5	6	-2	7	6
0.1a	-1	7	-4	2	2	-4	1	6	-1	-2	5
BOT	0	0	0	1	0	0	-10	0	-2	-22	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 236 Moment Coefficients along Long Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b		
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>									
TOP	-16	15	-78	0	30	33	0	30	29	0	23	68
0.9a	-24	19	-119	-5	27	29	5	27	10	21	63	13
0.8a	-21	19	-104	-4	27	26	8	27	17	21	58	21
0.7a	-18	20	-92	-2	29	23	11	29	23	20	22	52
0.6a	-16	21	-80	-0	31	19	12	31	21	20	24	45
0.5a	-13	23	-67	-0	33	-15	10	33	17	16	26	36
0.4a	-11	23	-53	-2	34	-11	4	34	13	7	26	8
0.3a	-8	22	-38	-5	34	-8	-6	33	7	-9	25	15
0.2a	-4	9	-21	-12	30	-6	-23	29	0	-34	22	2
0.1a	-1	12	-6	-23	20	-6	-49	19	8	-72	14	12
BOT.	0	0	0	-40	0	-8	-87	0	17	-125	0	25

**Table 237 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c				0.2c				0.3c				0.4c				0.5c			
		$M_{zc}$	$M_{yc}$																		
TOP	-16	-78	15	0	-108	19	0	-92	11	0	-80	7	0	-74	3	0	-72	0	-72	0	
0.9a	-24	-119	19	-19	-98	14	-15	-83	10	-12	-74	7	-10	-68	3	-10	-66	0	-66	0	
0.8a	-21	-104	19	-18	-88	14	-16	-76	10	-15	-66	6	-14	-61	3	-14	-59	0	-59	0	
0.7a	-18	-92	20	-16	-78	15	-15	-66	11	-14	-58	7	-13	-53	3	-13	-51	0	-51	0	
0.6a	-16	-80	21	-14	-66	16	-13	-56	12	-12	-48	8	-11	-44	4	-11	-42	0	-42	0	
0.5a	-13	-67	23	-11	-54	17	-10	-45	13	-8	-38	8	-8	-34	4	-7	-32	0	-32	0	
0.4a	-11	-53	23	-8	-42	17	-6	-33	12	-4	-27	8	-3	-23	4	-3	-22	0	-22	0	
0.3a	-8	-38	22	-4	-28	16	-2	-21	11	0	-16	7	1	-13	3	2	-12	0	-12	0	
0.2a	-4	-21	19	0	-15	13	3	-10	9	5	-7	5	7	-5	3	7	-4	0	-4	0	
0.1a	-1	-6	12	4	-4	8	7	-2	5	10	0	3	11	1	1	12	1	0	0	0	
BOT.	0	0	0	0	8	2	0	12	2	0	13	3	0	14	3	0	14	3	0	0	

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 238 Moment Coefficients along Long side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b		0.8b		0.7b		0.6b			
		$M_{xc}$	$M_{yc}$								
TOP	-7	5	-37	0	10	-19	0	10	16	0	40
0.9a	-12	6	-62	-4	8	-17	2	8	15	5	6
0.8a	-11	6	-57	-3	8	-16	4	8	15	9	6
0.7a	-11	7	-54	-2	9	-15	6	8	14	11	7
0.6a	-10	8	-50	-1	10	-14	7	10	13	13	8
0.5a	-9	9	-46	0	12	-12	7	12	11	13	10
0.4a	-8	11	-39	-0	14	-10	6	14	10	11	11
0.3a	6	11	-31	-1	16	-7	3	16	7	6	13
0.2a	-4	10	-20	-3	16	-5	-4	16	3	-5	12
0.1a	-1	7	-7	-8	12	-3	-17	12	-2	-25	9
BOT.	0	0	0	-17	0	-3	-40	0	-8	-59	0

**Table 239 Moment Coefficients along Short Side for Rectangular Tanks having Case 7 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	-7	5	-37	0	7	-51	0	4	-40	0	2
0.9a	-12	6	-62	-9	5	-47	-6	4	-37	-4	2
0.8a	-11	6	-57	-9	5	-44	-7	3	-34	-6	2
0.7a	-11	7	-54	-9	5	-41	-7	4	-31	-6	3
0.6a	-10	8	-50	-8	6	-37	-7	5	-27	-6	3
0.5a	-9	9	-46	-7	7	-33	-6	5	-23	-4	3
0.4a	-8	11	-39	-6	8	-27	-4	5	-17	-2	3
0.3a	6	11	-31	-4	8	-20	-1	5	-12	0	3
0.2a	-4	10	-20	-1	6	-11	-1	3	-6	3	2
0.1a	-1	7	-7	2	3	-4	4	1	-1	5	0
BOT	0	0	0	4	0	1	4	0	1	3	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 240 Deflection Coefficients along Long Side, Mid-height ( $y = a/2$ ) for Tanks having Case 8 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	x c/a	End	0.1b	0.2b	0.3b	0.4b	0.5b
			0.9b	0.8b	0.7b	0.6b	
4.0	3.0	0	2.50	4.40	5.10	5.10	5.20
4.0	2.0	0	2.50	4.40	5.10	5.10	5.20
4.0	1.5	0	2.50	4.40	5.10	5.10	5.20
4.0	1.0	0	2.60	4.50	5.10	5.10	5.20
4.0	0.5	0	2.90	4.60	5.10	5.10	5.20
3.0	2.0	0	1.80	3.70	4.70	5.00	5.10
3.0	1.5	0	1.80	3.70	4.70	5.00	5.10
3.0	1.0	0	1.90	3.80	4.70	5.10	5.10
3.0	0.5	0	2.20	4.00	4.80	5.10	5.20
2.0	1.5	0	1.00	2.50	3.70	4.30	4.50
2.0	1.0	0	1.10	2.60	3.70	4.30	4.50
2.0	0.5	0	1.40	2.90	3.90	4.50	4.60
1.5	1.0	0	0.70	1.80	2.70	3.30	3.50
1.5	0.5	0	1.00	2.10	3.00	3.50	3.70
1.5	0.5	0	0.50	1.00	1.50	1.80	2.00

**Table 241 Deflection Coefficients along Short Side, Mid-height ( $y = a/2$ ) for Tanks having Case 8 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	z c/a	End	0.1c	0.2c	0.3c	0.4c	0.5c
			0.9c	0.8c	0.7c	0.6c	
4.0	3.0	0	1.80	3.70	4.70	5.00	5.10
4.0	2.0	0	1.00	2.50	3.60	4.60	4.50
4.0	1.5	0	0.60	1.60	2.60	3.20	3.40
4.0	1.0	0	0.10	0.50	1.00	1.30	1.40
4.0	0.5	0	-0.20	-0.20	-0.30	-0.30	-0.30
3.0	2.0	0	1.00	2.50	3.60	4.30	4.50
3.0	1.5	0	0.60	1.60	2.60	3.20	3.40
3.0	1.0	0	0.10	0.50	1.00	1.30	1.40
3.0	0.5	0	-0.20	-0.20	-0.30	-0.30	-0.30
2.0	1.5	0	0.60	1.60	2.60	3.20	3.40
2.0	1.0	0	0.10	0.50	1.00	1.30	1.40
2.0	0.5	0	-0.20	-0.20	-0.30	-0.30	-0.30
1.5	1.0	0	1.10	0.60	1.00	1.30	1.40
1.5	0.5	0	-0.20	-0.20	-0.30	-0.30	-0.30
1.5	0.5	0	-0.10	-0.20	-0.20	-0.20	-0.20

**Table 242 Deflection Coefficients along Long Side, Mid-span ( $x = b/2$ ) for Tanks having Case 8 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	y	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	0.50	1.70	3.20	4.40	5.20	5.40	4.90	3.70	2.00	0	
4.0	2.0	0	0.50	1.70	3.20	4.40	5.20	5.40	4.90	3.70	2.00	0	
4.0	1.5	0	0.50	1.70	3.20	4.40	5.20	5.40	4.90	3.70	2.00	0	
4.0	1.0	0	0.50	1.70	3.20	4.40	5.20	5.40	4.90	3.70	2.00	0	
4.0	0.5	0	0.50	1.70	3.20	4.40	5.20	5.40	4.90	3.70	2.00	0	
3.0	2.0	0	0.50	1.70	3.10	4.40	5.20	5.30	4.80	3.70	2.00	0	
3.0	1.5	0	0.50	1.70	3.10	4.30	5.10	5.30	4.80	3.70	2.00	0	
3.0	1.0	0	0.50	1.70	3.10	4.30	5.10	5.30	4.80	3.70	2.00	0	
3.0	0.5	0	0.50	1.70	3.10	4.40	5.20	5.30	4.80	3.70	2.00	0	
2.0	1.5	0	0.50	1.50	2.80	3.80	4.50	4.60	4.20	3.20	1.70	0	
2.0	1.0	0	0.50	1.60	2.80	3.90	4.50	4.70	4.20	3.20	1.70	0	
2.0	0.5	0	0.50	1.60	2.80	3.90	4.60	4.80	4.30	3.30	1.80	0	
1.5	1.0	0	0.40	1.20	2.20	3.00	3.50	3.60	3.20	2.50	1.30	0	
1.5	0.5	0	0.40	1.30	2.30	3.20	3.70	3.80	3.50	2.60	1.40	0	
1.0	0.5	0	0.20	0.80	1.30	1.70	2.00	2.00	1.80	1.40	0.70	0	

**Table 243 Deflection Coefficients along Short Side, Mid-span ( $z = c/2$ ) for Tanks having Case 8 Arrangements for Various Length/Height and Width/Height Ratios**

(Table 1, Clauses 3.1 and 3.1.4)

b/a	c/a	y	0	0.1a	0.2a	0.3a	0.4a	0.5a	0.6a	0.7a	0.8a	0.9a	1.0a
4.0	3.0	0	0.50	1.70	3.10	4.30	5.10	5.30	4.80	3.70	2.00	0	
4.0	2.0	0	0.50	1.50	2.80	3.80	4.50	4.60	4.20	3.20	1.70	0	
4.0	1.5	0	0.40	1.20	2.10	2.90	3.40	3.50	3.10	2.40	1.30	0	
4.0	1.0	0	0.20	0.60	1.00	1.20	1.40	1.40	1.30	1.00	0.50	0	
4.0	0.5	0	0.00	-0.10	-0.20	-0.20	-0.30	-0.30	-0.30	-0.20	-0.10	0	
3.0	2.0	0	0.50	1.50	2.80	3.80	4.50	4.60	4.20	3.20	1.70	0	
3.0	1.5	0	0.40	1.20	2.10	2.90	3.40	3.50	3.10	2.40	1.30	0	
3.0	1.0	0	0.20	0.60	1.00	1.20	1.40	1.40	1.30	1.00	0.50	0	
3.0	0.5	0	0.00	-0.10	-0.20	-0.20	-0.30	-0.30	-0.30	-0.20	-0.10	0	
2.0	1.5	0	0.40	1.20	2.10	2.90	3.40	3.50	3.10	2.40	1.30	0	
2.0	1.0	0	0.20	0.60	1.00	1.20	1.40	1.40	1.30	1.00	0.50	0	
2.0	0.5	0	0.00	-0.10	-0.20	-0.20	-0.30	-0.30	-0.30	-0.20	-0.10	0	
1.5	1.0	0	0.20	0.60	1.00	1.30	1.40	1.40	1.30	1.00	0.50	0	
1.5	0.5	0	0.00	-0.10	-0.10	-0.20	-0.30	-0.30	-0.30	-0.20	-0.10	0	
1.0	0.5	0	0.00	0.00	-0.10	-0.10	-0.20	-0.20	-0.20	-0.20	-0.10	0.00	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 244 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	3	0	0	22	0	0	8	0	0	0
0.9a	-7	2	-35	18	20	7	28	8	9	32	2
0.8a	-12	1	-60	28	16	13	47	6	15	53	2
0.7a	-15	1	-75	33	10	16	58	4	19	66	1
0.6a	-16	0	-81	34	2	17	60	1	20	68	0
0.5a	-16	0	-78	31	5	16	55	2	19	61	1
0.4a	-14	1	-68	24	11	13	41	5	15	44	1
0.3a	-10	1	-50	12	15	9	18	6	8	18	1
0.2a	-6	2	-29	-6	15	3	-14	6	0	-19	1
0.1a	-2	1	-8	-32	11	-5	-57	4	-11	-65	1
BOT.	0	0	0	0	0	0	0	0	0	0	0

**Table 245 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 3.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	3	0	0	25	0	0	15	0	0	0
0.9a	-7	2	-35	13	23	4	24	14	9	30	6
0.8a	-12	1	-60	20	18	7	40	11	16	50	5
0.7a	-15	1	-75	23	11	8	49	7	20	61	3
0.6a	-16	0	-81	23	2	8	50	1	21	63	0
0.5a	-16	0	-78	21	5	8	46	4	20	57	2
0.4a	-14	1	-68	16	12	7	35	8	17	42	4
0.3a	-10	1	-50	9	16	5	16	10	10	18	4
0.2a	-6	2	-29	-4	17	1	-10	10	2	-16	4
0.1a	-2	1	-8	-22	13	-4	-48	7	-8	-61	3
BOT	0	0	0	-51	0	-10	-98	0	-20	-117	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 246 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b				
		0.9b				0.8b				0.7b				0.6b								
		$M_{xc}$	$M_{yc}$																			
TOP	0	3	0	0	22	0	0	8	0	0	2	0	0	0	0	0	0	0	0	0	0	0
0.9a	-7	2	-35	18	20	7	28	8	9	32	2	7	32	0	7	32	0	7	32	0	7	7
0.8a	-12	2	-59	28	16	13	47	6	15	53	2	13	55	0	11	55	0	11	55	0	11	11
0.7a	-15	1	-75	33	10	16	58	4	19	66	1	16	67	0	14	67	0	14	67	0	14	14
0.6a	-16	0	-81	34	2	17	60	1	20	68	0	16	70	0	15	70	0	15	70	0	14	14
0.5a	-16	1	-78	31	5	16	55	2	19	61	1	15	62	0	13	63	0	13	63	0	13	13
0.4a	-14	1	-68	24	11	13	41	5	15	44	1	11	45	0	9	45	0	9	45	0	9	9
0.3a	-10	1	-50	12	15	9	18	6	8	18	1	5	18	0	4	18	0	4	18	0	4	4
0.2a	-6	2	-29	-6	15	3	-14	6	0	-19	1	-3	-20	0	-4	-20	0	-4	-20	0	-4	-4
0.1a	-2	1	-8	-32	11	-5	-57	4	-11	-65	1	-13	-67	0	-13	-67	0	-13	-67	0	-13	-13
BOT.	0	0	0	-70	0	-14	-112	0	-22	-123	0	-25	-125	0	-25	-125	0	-25	-125	0	-25	-25

**Table 247 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 2.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	3	0	0	24	0	0	22	0	0	14
0.9a	-7	2	-35	7	22	-1	18	20	7	24	13
0.8a	-12	2	-59	10	17	-3	28	16	13	40	10
0.7a	-15	1	-75	10	10	-6	33	10	16	48	6
0.6a	-16	0	-81	10	2	-7	34	2	17	50	1
0.5a	-16	1	-78	9	5	-7	31	5	16	45	3
0.4a	-14	1	-68	7	11	-6	24	11	14	35	7
0.3a	-10	1	-50	4	15	-4	12	15	9	17	10
0.2a	-6	2	-29	-2	16	-3	-5	15	3	-10	10
0.1a	-2	1	-8	-13	12	-3	-32	11	-5	-47	7
BOT.	0	0	0	-29	0	-6	-70	0	-14	-97	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 248 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	0	4	0	0	22	0	0	0	0	0	0
0.9a	-7	3	-34	18	20	7	28	8	9	32	2
0.8a	-12	2	-58	28	16	13	48	6	15	53	2
0.7a	-15	1	-73	34	10	16	58	4	19	66	1
0.6a	-16	0	-79	34	2	17	60	1	20	68	0
0.5a	-15	1	-77	31	5	16	55	2	19	61	1
0.4a	-13	1	-67	24	11	14	41	5	15	44	1
0.3a	-10	2	-50	12	15	9	18	6	8	18	1
0.2a	-6	2	-29	-6	15	3	-14	5	0	-19	1
0.1a	-2	1	-8	-32	11	-5	-58	4	-11	-66	1
BOT.	0	0	0	-70	0	-14	-113	0	-23	-123	0

**Table 249 Moment Coefficients along Short side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c				0.2c				0.3c				0.4c				0.5c			
		$M_{zc}$	$M_{yc}$																		
TOP	0	4	0	0	21	0	0	22	0	0	16	0	0	9	0	0	0	0	0	0	
0.9a	-7	3	-34	4	19	-5	12	20	5	18	15	9	22	5	11	23	0	0	11		
0.8a	-12	2	-58	4	14	-11	19	16	9	29	12	16	35	6	19	37	0	0	20		
0.7a	-15	1	-73	4	8	-15	21	10	10	34	7	21	42	4	24	45	0	0	25		
0.6a	-16	0	-79	3	2	-18	21	2	11	35	2	22	44	1	26	47	0	0	27		
0.5a	-15	1	-77	2	4	-17	20	5	10	33	4	22	41	2	25	43	0	0	26		
0.4a	-13	1	-67	2	9	-15	16	11	9	26	8	18	32	4	21	34	0	0	22		
0.3a	-10	2	-50	1	13	-11	9	15	6	14	11	12	17	6	14	18	0	0	14		
0.2a	-6	2	-29	-2	14	-7	-2	16	2	-4	12	5	-6	6	5	-7	0	0	4		
0.1a	-2	1	-8	-8	11	-4	-21	12	-3	-33	8	-5	-41	4	-6	-44	0	-7			
BOT	0	0	0	-17	0	-3	-49	0	-10	-75	0	-15	-90	0	-18	-94	0	-19			

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 250 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b				
		0.9b				0.8b				0.7b				0.6b								
		$M_{xc}$	$M_{yc}$																			
TOP	0	7	0	0	21	0	0	8	29	8	9	32	2	0	0	0	0	0	0	0	0	0
0.9a	-6	6	-30	19	20	8	29	8	9	32	2	7	32	0	7	32	0	7	32	0	7	7
0.8a	-10	4	-52	30	15	13	48	6	15	53	1	12	55	0	11	55	0	11	55	0	11	11
0.7a	-13	2	-65	35	9	16	58	3	19	66	1	15	67	0	14	67	0	14	67	0	14	14
0.6a	-14	0	-70	36	2	18	61	1	20	68	0	16	70	0	15	70	0	15	70	0	14	14
0.5a	-14	2	-69	33	5	17	55	2	19	61	1	15	62	0	13	63	0	13	63	0	13	13
0.4a	-12	3	-60	25	11	14	41	4	15	45	1	11	45	0	9	45	0	9	45	0	9	9
0.3a	-9	4	-46	13	14	10	18	6	8	18	1	5	18	0	4	18	0	4	18	0	4	4
0.2a	-5	4	-27	-6	15	3	-15	5	0	-19	1	-3	-20	0	-4	-20	0	-4	-20	0	-4	-4
0.1a	-2	3	-8	-33	10	-5	-58	3	-11	-66	1	-13	-67	0	-13	-67	0	-13	-67	0	-13	-13
BOT.	0	0	0	-73	0	-15	-113	0	-23	-123	0	-25	-125	0	-25	-125	0	-25	-125	0	-25	-25

**Table 251 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	7	0	0	11	0	0	14	0	0	12
0.9a	-6	6	-30	0	10	-9	5	13	1	9	11
0.8a	-10	4	-52	-2	7	-18	6	10	1	13	9
0.7a	-13	2	-65	-4	4	-24	6	6	0	13	5
0.6a	-14	0	-70	-4	1	-27	5	2	0	13	2
0.5a	-14	2	-69	-4	1	-26	5	2	0	13	2
0.4a	-12	3	-60	-3	4	-23	5	6	0	12	5
0.3a	-9	4	-46	-2	6	-17	4	9	1	9	8
0.2a	-5	4	-27	-1	7	-10	1	10	0	2	9
0.1a	-2	3	-8	-2	6	-4	-7	9	-1	-12	7
BOT	0	0	0	-6	0	-1	-22	0	-4	-37	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 252 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	15	0	0	20	0	0	7	0	0	0
0.9a	-4	14	-22	20	19	8	29	7	8	32	2
0.8a	-7	11	-37	32	15	14	49	5	15	54	1
0.7a	-9	6	-45	38	9	18	60	3	18	66	1
0.6a	-10	1	-48	39	2	20	62	0	20	69	0
0.5a	-9	3	-47	36	5	19	56	2	18	61	1
0.4a	-8	7	-42	28	10	16	42	4	14	45	1
0.3a	-7	10	-33	14	14	10	18	5	8	18	1
0.2a	-4	10	-20	-7	14	3	-15	5	-1	-19	1
0.1a	-1	7	-7	-37	10	-6	-59	3	-11	-66	1
BOT.	0	0	0	-79	0	-16	-115	0	-23	-124	0

**Table 253 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 4.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	15	0	0	6	0	0	2	0	0	0
0.9a	-4	14	-22	-3	6	-12	-1	3	-6	0	1
0.8a	-7	11	-37	-6	6	-23	-4	3	-13	-3	1
0.7a	-9	6	-45	-8	4	-29	-7	2	-17	-6	1
0.6a	-10	1	-48	-9	1	-32	-8	1	-19	-7	0
0.5a	-9	3	-47	-8	2	-31	-7	1	-19	-6	1
0.4a	-8	7	-42	-7	4	-27	-5	3	-16	-4	1
0.3a	-7	10	-33	-4	6	-20	-3	3	-11	-1	2
0.2a	-4	10	-20	-1	5	-12	1	2	-6	2	1
0.1a	-1	7	-7	1	3	-4	3	1	-1	4	0
BOT.	0	0	0	3	0	1	3	0	1	2	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 254 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	0	2	0	0	24	0	0	15	0	0	0
0.9a	-7	2	-35	13	23	4	24	14	9	30	6
0.8a	-12	1	-60	20	18	7	40	11	16	50	5
0.7a	-15	1	-75	23	11	8	49	6	20	61	3
0.6a	-16	0	-81	23	2	8	50	1	21	63	0
0.5a	-16	0	-78	21	5	8	46	4	20	57	2
0.4a	-14	1	-68	16	12	7	35	8	17	42	3
0.3a	-10	1	-50	9	16	5	16	10	10	18	4
0.2a	-6	1	-29	-4	17	1	-10	10	2	-16	4
0.1a	-2	1	-8	-22	12	-4	-48	7	-8	-61	3
BOT.	0	0	0	-51	0	-10	-98	0	-20	-117	0

**Table 255 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 3.0, c/a = 2.0$**

( Table 1, Clause 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	2	0	0	24	0	0	22	0	0	14
0.9a	-7	2	-35	7	22	-1	18	20	7	24	13
0.8a	-12	1	-60	10	17	-3	28	16	13	40	10
0.7a	-15	1	-75	10	10	-6	33	10	16	48	6
0.6a	-16	0	-81	10	2	-7	34	2	17	50	1
0.5a	-16	0	-78	9	5	-7	31	5	16	45	3
0.4a	-14	1	-68	7	11	-6	24	11	14	35	7
0.3a	-10	1	-50	4	15	-4	12	15	9	17	10
0.2a	-6	1	-29	-2	16	-3	-5	15	3	-10	10
0.1a	-2	1	-8	-13	12	-3	-32	11	-5	-47	7
BOT.	0	0	0	-29	0	-6	-70	0	-14	-97	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 256 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		0.9b	0.8b	0.7b	0.6b	0.5b	0.4b	0.3b	0.2b	0.1b	0.9b
	$M_{xc}$	$M_{yc}$	$M_{xc}$								
TOP	0	3	0	0	24	0	0	15	0	0	0
0.9a	-7	2	-34	13	23	5	25	14	9	30	6
0.8a	-12	2	-58	20	18	7	40	11	16	50	5
0.7a	-15	1	-72	23	11	8	49	6	20	61	3
0.6a	-16	0	-80	23	2	9	51	1	21	63	0
0.5a	-15	1	-77	21	5	8	46	4	20	57	2
0.4a	-13	1	-68	17	12	7	35	8	17	42	3
0.3a	-10	2	-50	9	16	5	16	10	10	18	4
0.2a	-6	2	-29	-4	17	1	-10	10	2	-16	4
0.1a	-2	1	-8	-23	12	-4	-48	7	-8	-61	3
BOT.	0	0	0	-51	0	-10	-98	0	-20	-117	0

**Table 257 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 3.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	3	0	0	21	0	0	22	0	0	16
0.9a	-7	2	-34	4	18	-5	12	20	5	18	15
0.8a	-12	2	-58	4	14	-11	19	16	9	29	12
0.7a	-15	1	-73	4	8	-15	21	10	10	34	7
0.6a	-16	0	-80	3	2	-18	21	2	11	35	2
0.5a	-15	1	-77	2	4	-18	20	5	10	33	4
0.4a	-13	1	-67	2	9	-15	16	11	9	26	8
0.3a	-10	2	-50	1	13	-11	9	15	6	14	11
0.2a	-6	2	-29	-2	14	-7	-2	16	2	-4	12
0.1a	-2	1	-8	-8	11	-4	-21	12	-3	-33	8
BOT.	0	0	0	-17	0	-3	-49	0	-10	-75	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 258 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	6	0	0	24	0	0	14	0	0	0
0.9a	-6	5	-31	14	22	5	25	13	9	30	6
0.8a	-10	4	-52	21	17	8	41	10	16	50	4
0.7a	-13	2	-65	25	10	10	50	6	20	61	2
0.6a	-14	0	-71	25	2	10	52	1	21	64	0
0.5a	-14	2	-69	23	5	10	47	4	20	58	2
0.4a	-12	3	-60	18	12	8	35	7	17	42	3
0.3a	-9	4	-46	9	16	6	17	10	10	18	4
0.2a	-5	4	-27	-4	17	2	-11	9	2	-16	4
0.1a	-2	3	-8	-24	12	-4	-49	6	-9	-61	2
BOT.	0	0	0	-54	0	-11	-99	0	-20	-117	0

**Table 259 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 3.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	6	0	0	11	0	0	14	0	0	0
0.9a	-6	5	-31	0	10	-9	5	13	1	9	11
0.8a	-10	4	-52	-2	7	-18	6	10	1	13	9
0.7a	-13	2	-65	-4	4	-24	6	6	0	13	5
0.6a	-14	0	-71	-4	1	-27	5	2	0	13	2
0.5a	-14	2	-69	-4	1	-26	5	2	0	13	2
0.4a	-12	3	-60	-3	4	-23	5	6	0	12	5
0.3a	-9	4	-46	-2	6	-17	4	9	1	9	8
0.2a	-5	4	-27	-1	7	-10	1	10	0	2	9
0.1a	-2	3	-8	-2	6	-4	-7	9	-1	-12	7
BOT	0	0	0	-6	0	-1	-22	0	-4	-37	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 260 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b				
		0.9b				0.8b				0.7b				0.6b								
		$M_{xc}$	$M_{yc}$																			
TOP	0	15	0	0	24	0	0	13	0	0	5	0	0	2	0	0	0	0	0	0	0	0
0.9a	-4	13	-22	16	22	7	26	12	9	30	5	8	32	2	7	32	0	7	32	0	7	0
0.8a	-7	10	-37	25	17	11	43	9	16	51	4	14	54	1	12	54	0	0	54	0	0	12
0.7a	-9	6	-45	29	10	14	52	6	20	62	2	18	66	1	15	68	0	0	68	0	0	15
0.6a	-10	1	-48	29	2	14	54	1	22	65	0	19	68	0	16	69	0	0	69	0	0	15
0.5a	-9	3	-47	27	5	14	49	3	20	58	2	17	61	1	15	62	0	0	62	0	0	14
0.4a	-8	7	-42	21	12	37	7	16	43	3	13	45	1	11	45	0	0	0	0	0	0	10
0.3a	-7	10	-33	11	16	8	17	9	10	18	4	7	18	1	5	18	0	0	18	0	0	4
0.2a	-4	10	-20	-5	16	3	-12	9	1	-17	3	-2	-19	1	-3	-19	0	0	-19	0	0	-4
0.1a	-1	7	-7	-28	12	-4	-51	6	-9	-62	2	-12	-66	1	-13	-67	0	0	-67	0	0	-13
BOT.	0	0	0	-62	0	-12	-103	0	-21	-119	0	-21	-124	0	-25	-125	0	0	-25	0	0	-25

**Table 261 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 3.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	15	0	0	6	0	0	2	0	0	0
0.9a	-4	13	-22	-3	6	-12	-1	3	-6	0	1
0.8a	-7	10	-37	-6	6	-23	-4	3	-13	-3	1
0.7a	-9	6	-45	-8	4	-29	-7	2	-17	-6	1
0.6a	-10	1	-48	-9	1	-32	-8	1	-19	-7	0
0.5a	-9	3	-47	-8	2	-31	-7	1	-19	-6	1
0.4a	-8	7	-42	-7	4	-27	-5	3	-16	-4	1
0.3a	-7	10	-33	-4	6	-20	-3	3	-11	-1	2
0.2a	-4	10	-20	-1	5	-12	1	2	-6	2	1
0.1a	-1	7	-7	1	3	-4	3	1	-1	4	0
BOT	0	0	0	3	0	1	3	0	1	2	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 262 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	2	0	0	24	0	0	21	0	0	14
0.9a	-7	2	-34	8	22	-1	18	20	8	24	13
0.8a	-12	1	-58	10	17	-3	28	16	13	40	10
0.7a	-15	1	-73	11	10	-5	33	9	16	48	6
0.6a	-16	0	-79	10	2	-7	34	2	17	50	1
0.5a	-15	0	-77	9	5	-7	31	5	17	46	3
0.4a	-13	1	-67	7	11	-6	24	11	14	35	7
0.3a	-10	1	-50	4	16	-4	13	15	9	17	9
0.2a	-6	1	-29	-3	17	-3	-5	15	3	-10	9
0.1a	-2	1	-8	-13	13	-3	-32	11	-5	-47	6
BOT.	0	0	0	-29	0	-6	-70	0	-14	-7	0

**Table 263 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 2.0, c/a = 1.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	2	0	0	21	0	0	22	0	0	16
0.9a	-7	2	-34	4	19	-5	12	20	5	18	15
0.8a	-12	1	-58	4	14	-11	19	16	9	29	12
0.7a	-15	1	-73	4	8	-15	21	10	10	34	7
0.6a	-16	0	-79	3	2	-18	21	2	11	35	2
0.5a	-15	0	-77	2	4	-17	20	5	10	33	4
0.4a	-13	1	-67	2	9	-15	16	11	9	26	8
0.3a	-10	1	-50	1	13	-11	9	15	6	14	11
0.2a	-6	1	-29	-2	14	-7	-2	16	2	-4	12
0.1a	-2	1	-8	-8	11	-4	-21	12	-3	-33	8
BOT.	0	0	0	-17	0	-3	-49	0	-10	-75	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 264 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b				0.2b				0.3b				0.4b				0.5b				
		0.9b				0.8b				0.7b				0.6b								
		$M_{xc}$	$M_{yc}$																			
TOP	0	6	0	0	25	0	0	21	0	0	13	0	0	6	0	0	0	0	0	0	0	0
0.9a	-6	5	-31	8	23	0	18	19	8	25	12	9	28	6	9	29	0	0	0	0	9	0
0.8a	-10	4	-52	12	17	-1	29	15	13	40	10	16	46	4	16	48	0	0	0	0	16	0
0.7a	-13	2	-65	13	10	-3	35	9	17	49	6	21	57	3	21	59	0	0	0	0	20	0
0.6a	-14	0	-70	12	2	-4	36	2	18	51	1	23	59	1	22	62	0	0	0	0	22	0
0.5a	-14	1	-69	11	5	-4	32	5	17	46	3	21	54	2	21	56	0	0	0	0	20	0
0.4a	-12	3	-60	9	12	-3	25	11	15	35	7	17	40	3	17	42	0	0	0	0	16	0
0.3a	-9	4	-46	4	16	-2	13	14	10	17	9	11	18	4	10	19	0	0	0	0	9	0
0.2a	-5	3	-27	-3	17	-2	-6	15	3	-10	9	2	-13	4	1	-14	0	0	0	0	0	0
0.1a	-2	2	-8	-14	13	-3	-33	10	-5	-48	6	-8	-56	3	-10	-59	0	0	0	-11	0	0
BOT.	0	0	0	-32	0	-6	-73	0	-15	-99	0	-20	-112	0	-22	-115	0	-23	0	-23	0	0

**Table 265 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 2.0, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	6	0	0	11	0	0	14	0	0	0
0.9a	-6	5	-31	0	10	-9	5	13	1	9	11
0.8a	-10	4	-52	-2	7	-18	6	10	1	13	9
0.7a	-13	2	-65	-4	4	-24	6	6	0	13	5
0.6a	-14	0	-70	-4	1	-27	5	2	0	13	2
0.5a	-14	1	-69	-4	1	-26	5	2	0	13	2
0.4a	-12	3	-60	-3	4	-23	5	6	0	12	5
0.3a	-9	4	-46	-2	6	-17	4	9	1	9	8
0.2a	-5	3	-27	-1	7	-10	1	10	0	2	9
0.1a	-2	2	-8	-2	6	-4	-7	9	-1	-12	7
BOT	0	0	0	-6	0	-1	-22	0	-4	-37	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 266 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>	<b>0.8b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	14	0	0	26	0	0	20	0	0	0
0.9a	-4	13	-22	10	24	3	20	18	9	25	11
0.8a	-7	10	-37	15	18	4	32	15	15	42	9
0.7a	-9	6	-45	17	11	4	38	9	19	51	5
0.6a	-10	1	-48	17	2	4	39	2	20	53	1
0.5a	-9	3	-47	16	5	4	36	5	19	49	3
0.4a	-8	7	-42	12	12	3	28	10	16	37	6
0.3a	-7	10	-33	6	17	2	14	14	11	17	8
0.2a	-4	10	-20	-3	18	0	-7	14	3	-11	8
0.1a	-1	7	-7	-17	13	-3	-37	10	-6	-50	5
BOT.	0	0	0	-40	0	-8	-79	0	-16	-102	0

**Table 267 Moment Coefficients along Short Side for Rectangular Tanks Having Case 8 Arrangements for  $b/a = 2.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	14	0	0	6	0	0	2	0	0	0
0.9a	-4	13	-22	-3	6	-12	-1	3	-6	0	1
0.8a	-7	10	-37	-6	6	-23	-4	3	-13	-3	1
0.7a	-9	9	-45	-8	4	-29	-7	2	-17	-6	-1
0.6a	-10	1	-48	-9	1	-32	-8	1	-19	-7	0
0.5a	-9	3	-47	-8	2	-31	-7	1	-19	-6	1
0.4a	-8	7	-42	-7	4	-27	-5	3	-16	-4	1
0.3a	-7	10	-33	-4	6	-20	-3	3	-11	-1	2
0.2a	-4	10	-20	-1	5	-12	1	2	-6	2	1
0.1a	-1	7	-7	1	3	-4	3	1	-1	4	0
BOT	0	0	0	3	0	1	3	0	1	2	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 268 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( *Table 1, Clauses 3.1 and 3.1.4* )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	5	0	0	22	0	0	22	0	0	0
0.9a	-6	4	-30	5	20	-4	13	20	6	19	15
0.8a	-10	3	-51	6	15	-8	20	16	10	30	12
0.7a	-13	2	-64	6	9	-11	23	10	12	36	7
0.6a	-14	0	-69	5	2	-13	24	2	12	37	2
0.5a	-14	1	-68	5	4	-13	22	5	12	34	3
0.4a	-12	2	-59	4	10	-11	17	11	10	27	8
0.3a	-9	3	-45	2	14	-8	10	15	7	15	11
0.2a	-5	3	-27	-2	15	-5	15	3	-5	11	5
0.1a	-2	2	-8	-9	12	-3	-22	11	-3	-34	8
BOT.	0	0	0	-20	0	-4	-53	0	-11	-77	0

**Table 269 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 1.5, c/a = 1.0$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	5	0	0	11	0	0	15	0	0	0
0.9a	-6	4	-30	0	10	9	6	13	1	9	11
0.8a	-10	3	-51	-2	7	-17	6	10	1	13	9
0.7a	-13	2	-64	-3	4	-23	6	6	1	14	5
0.6a	-14	0	-69	-4	1	-26	6	2	0	13	2
0.5a	-14	1	-68	-4	1	-26	5	2	0	13	2
0.4a	-12	2	-59	-3	4	-22	5	6	1	12	5
0.3a	-9	3	-45	-2	6	-16	4	9	1	9	8
0.2a	-5	3	-27	-1	8	-10	1	10	0	2	9
0.1a	-2	2	-8	-3	7	-4	-7	9	-1	-12	7
BOT	0	0	0	-6	0	-1	-22	0	-4	-38	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 270 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	13	0	0	24	0	0	22	0	0	15
0.9a	-4	12	-22	7	22	0	15	20	7	20	14
0.8a	-7	10	-36	10	17	-1	23	16	12	33	11
0.7a	-9	6	-44	11	10	-3	27	9	15	40	7
0.6a	-9	1	-47	11	2	-3	28	2	16	41	2
0.5a	-9	3	-46	10	5	-4	26	5	16	38	3
0.4a	-8	7	-41	8	11	-3	21	11	13	30	8
0.3a	-6	9	-32	4	16	-2	11	15	9	16	10
0.2a	-4	9	-20	-2	17	-2	-4	15	4	-6	11
0.1a	-1	7	-7	-12	13	-3	-26	11	-4	-38	7
BOT.	0	0	0	-28	0	-6	-61	0	-12	-84	0

**Table 271 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 1.5, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c		0.2c		0.3c		0.4c		0.5c	
		0.9c	0.8c	0.7c	0.6c	0.5c	0.4c	0.3c	0.2c	0.1c	0.9c
		$M_{zc}$	$M_{yc}$								
TOP	0	13	0	0	6	0	0	2	0	0	0
0.9a	-4	12	-22	-3	6	-12	-1	3	-6	0	1
0.8a	-7	10	-36	-6	6	-22	-4	3	-12	-3	1
0.7a	-9	6	-44	-8	4	-28	-6	2	-17	-5	1
0.6a	-9	1	-47	-8	1	-31	-7	1	-19	-6	0
0.5a	-9	3	-46	-8	2	-30	-7	1	-18	-6	1
0.4a	-8	7	-41	-7	4	-26	-5	3	-15	-4	1
0.3a	-6	9	-32	-4	5	-20	-3	3	-11	-1	-1
0.2a	-4	9	-20	-1	5	-12	1	2	-5	2	1
0.1a	-1	7	-7	1	3	-4	3	1	-1	4	0
BOT	0	0	0	3	0	1	3	0	1	1	0

**IS 3370 (Part 4/Sec 2) : 2021**

**Table 272 Moment Coefficients along Long Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1b		0.2b		0.3b		0.4b		0.5b	
		<b>0.9b</b>	<b>0.8b</b>	<b>0.7b</b>	<b>0.6b</b>	<b>0.5b</b>	<b>0.4b</b>	<b>0.3b</b>	<b>0.2b</b>	<b>0.1b</b>	<b>0.9b</b>
	<b>M<sub>xc</sub></b>	<b>M<sub>yc</sub></b>	<b>M<sub>xc</sub></b>								
TOP	0	10	0	0	18	0	0	17	0	0	13
0.9a	-4	9	-19	3	16	-3	8	16	5	12	9
0.8a	-6	7	-31	3	12	-6	12	12	8	18	9
0.7a	-8	4	-38	3	7	-8	13	7	9	21	6
0.6a	-8	1	-40	3	2	-9	13	2	10	21	2
0.5a	-8	2	-40	3	3	-9	13	3	10	20	2
0.4a	-7	5	-36	2	7	-8	11	8	9	17	6
0.3a	-6	7	-29	1	11	-6	7	11	6	11	9
0.2a	-4	7	-19	-1	12	-4	0	12	3	0	9
0.1a	-1	5	-7	-6	10	-3	-12	10	-1	-19	7
BOT.	0	0	0	-15	0	-3	-35	0	-7	-51	0

**Table 273 Moment Coefficients along Short Side for Rectangular Tanks having Case 8 Arrangements for  $b/a = 1.0, c/a = 0.5$**

( Table 1, Clauses 3.1 and 3.1.4 )

Moment Coefficients	Corner	0.1c			0.2c			0.3c			0.4c			0.5c				
		$M_{zc}$	$M_{yc}$															
TOP	0	10	0	0	3	0	0	-10	0	0	0	1	0	0	1	0	0	0
0.9a	-4	9	-19	-2	4	-10	0	1	-4	1	0	-1	2	0	1	2	0	2
0.8a	-6	7	-31	-4	4	-18	-3	2	-9	-1	1	-3	0	0	0	0	0	2
0.7a	-8	4	-38	-6	3	-23	-4	1	-12	-3	1	-5	-3	0	-1	-2	0	1
0.6a	-8	1	-40	-7	1	-25	-5	0	-14	-4	0	-6	-4	0	-1	-3	0	0
0.5a	-8	2	-40	-6	1	-25	-5	1	-14	-4	0	-6	-3	0	-1	-3	0	0
0.4a	-7	5	-36	-6	3	-22	-4	2	-12	-3	1	-4	-2	0	0	-2	0	1
0.3a	-6	7	-29	-4	4	-17	-2	2	-8	0	1	-2	0	0	1	1	0	2
0.2a	-4	7	-19	-1	3	-10	1	1	-4	2	0	0	3	0	2	3	0	3
0.1a	-1	5	-7	1	1	-3	2	0	-1	3	1	1	4	1	2	4	0	2
BOT	0	0	0	2	0	0	0	0	-1	0	0	-3	0	-1	-4	0	-1	-1

**IS 3370 (Part 4/Sec 2) : 2021**

**ANNEX A**

(Foreword)

**COMMITTEE COMPOSITION**

Cement and Concrete Sectional Committee, CED 02

<i>Organization</i>	<i>Representative(s)</i>
In Personal Capacity ( <i>Grace Villa, Kadamankulam P.O., Thiruvalla 689583</i> )	SHRI JOSE KURIAN ( <b>Chairman</b> )
ACC Ltd, Mumbai	SHRI RAJESH J. MODI DR MANISH V. KARANDIKAR ( <i>Alternate</i> )
Ambuja Cements Limited, Ahmedabad	SHRI UMESH P. SONI SHRI SUKURU RAMARAO ( <i>Alternate</i> )
Atomic Energy Regulatory Board, Mumbai	SHRI L. R. BISHNOI SHRI SOURAV ACHARYA ( <i>Alternate</i> )
Builders' Association of India, Mumbai	SHRI SUSHANTA KUMAR BASU SHRI D. R. SEKOR ( <i>Alternate</i> )
Building Materials & Technology Promotion Council, New Delhi	SHRI C. N. JHA
Cement Manufacturers' Association, Noida	DR V. RAMACHANDRA Ms SHASHWATI GHOSE ( <i>Alternate</i> )
Central Public Works Department, New Delhi	SHRI D. K. GARG SHRI NAVEEN KUMAR BANSAL ( <i>Alternate</i> )
Central Soil and Materials Research Station, New Delhi	DIRECTOR SHRI U. S. VIDYARTHİ ( <i>Alternate</i> )
Central Water Commission, New Delhi	DIRECTOR (CMDD) (N&W) DEPUTY DIRECTOR (CMDD) (NW&S) ( <i>Alternate</i> )
Commat Technolgies Pvt Ltd, Kolkata	DR A. K. CHATTERJEE DR SUBRATO CHOWDHURY ( <i>Alternate</i> )
Construction Chemical Manufacturers' Association, Mumbai	SHRI SAMIR SURLAKER SHRI NILOTPOL KAR ( <i>Alternate</i> )
CSIR – Central Building Research Institute, Roorkee	SHRI S. K. SINGH SHRI SUBHASH GURRAM ( <i>Alternate</i> )
CSIR – Central Road Research Institute, New Delhi	DR RAKESH KUMAR DR V. V. L. KANTA RAO ( <i>Alternate</i> )
CSIR – Structural Engineering Research Centre, Chennai	DR K. RAMANJANEYULU DR P. SRINIVASAN ( <i>Alternate</i> )
Delhi Development Authority, New Delhi	SHRI LAXMAN SINGH SHRI VIJAY SHANKAR ( <i>Alternate</i> )
Department of Science and Technology, Ministry of Science and Technology, New Delhi	SHRI S. S. KOHLI
Engineers India Limited, New Delhi	SHRI RAJANJI SRIVASTAVA SHRI ANURAG SINHA ( <i>Alternate</i> )
Gammon India Limited, Mumbai	SHRI SHRIRAM B. KULKARNI SHRI RAHUL BIRADAR ( <i>Alternate</i> )
Hindustan Construction Company Limited, Mumbai	SHRI SATISH KUMAR SHARMA SHRI MUKESH VALECHA ( <i>Alternate</i> )

<i>Organization</i>	<i>Representative(s)</i>
Housing and Urban Development Corporation Limited, New Delhi	REPRESENTATIVE
Indian Association of Structural Engineers, New Delhi	SHRI MAHESH TANDON SHRI GANESH JUNEJA ( <i>Alternate</i> )
Indian Concrete Institute, Chennai	SHRI VIVEK NAIK SECRETARY GENERAL ( <i>Alternate</i> )
Indian Institute of Technology Delhi, New Delhi	DR SHASHANK BISHNOI DR DIPTI RANJAN SAHOO ( <i>Alternate</i> )
Indian Institute of Technology Madras, Chennai	DR DEVADAS MENON DR MANU SANTHANAM ( <i>Alternate</i> )
Indian Institute of Technology Roorkee, Roorkee	DR V. K. GUPTA DR BHUPINDER SINGH ( <i>Alternate</i> )
Indian Roads Congress, New Delhi	SHRI S. K. NIRMAL SHRI R. V. PATIL ( <i>Alternate</i> )
Military Engineer Services, Engineer-in-Chief's Branch, Army HQ, New Delhi	MAJ GEN S. K. SRIVASTAV SHRI MAN SINGH ( <i>Alternate</i> )
Ministry of Road Transport and Highways, New Delhi	SHRI Y. BALAKRISHNA SHRI SANJEEV KUMAR ( <i>Alternate</i> )
National Council for Cement and Building Materials, Ballabgarh	SHRI V. V. ARORA DR S. K. CHATURVEDI ( <i>Alternate</i> )
National Test House, Kolkata	SHRI D. V. S. PRASAD DR SOMIT NEOGI ( <i>Alternate</i> )
Nuclear Power Corporation of India Ltd, Mumbai	SHRI ARVIND SHRIVASTAVA SHRI RAGHUPATI ROY ( <i>Alternate</i> )
Nuvoco Vistas Corporation Limited, Mumbai	SHRI PRANAV DESAI SHRI RAVINDRA KHAMPARIA ( <i>Alternate</i> )
Public Works Department, Govt of Tamil Nadu, Chennai	SUPERINTENDING ENGINEER EXECUTIVE ENGINEER ( <i>Alternate</i> )
The India Cements Limited, Chennai	REPRESENTATIVE
The Indian Hume Pipe Company Limited, Mumbai	SHRI P. R. BHAT SHRI S. J. SHAH ( <i>Alternate</i> )
The Institution of Engineers (India), Kolkata	DR H. C. VISVESVARAYA SHRI S. H. JAIN ( <i>Alternate</i> )
The Rameo Cements Limited, Chennai	SHRI BALAJI K. MOORTHY SHRI ANIL KUMAR PILLAI ( <i>Alternate</i> )
Ultra Tech Cement Ltd, Mumbai	SHRI SURYA VALLURI DR M. R. KALGAL ( <i>Alternate</i> )
Voluntary Organization in Interest of Consumer Education, New Delhi	SHRI M. A. U. KHAN SHRI B. MUKHOPADHYAY ( <i>Alternate</i> )
In personal capacity [B-803, Oberoi Exquisite, Oberoi Garden City, Goregaon (East), Mumbai]	SHRI A. K. JAIN
In personal capacity (36, Old Sneh Nagar, Wardha Road, Nagpur)	SHRI L. K. JAIN
In personal capacity (EA-92, Maya Enclave, Hari Nagar, New Delhi)	SHRI R. C. WASON

**IS 3370 (Part 4/Sec 2) : 2021**

<i>Organization</i>	<i>Representative(s)</i>
BIS Directorate General	SHRI SANJAY PANT, SCIENTIST 'F' AND HEAD (CIVIL ENGINEERING) [ REPRESENTING DIRECTOR GENERAL ( <i>Ex-officio</i> ) ]

*Member Secretaries*  
SHRI S. ARUN KUMAR  
SCIENTIST 'E' (CIVIL ENGINEERING), BIS

AND

SHRI MILIND GUPTA  
SCIENTIST 'C' (CIVIL ENGINEERING), BIS

Concrete Subcommittee, CED 2:2

<i>Organization</i>	<i>Representative(s)</i>
In personal capacity ( <i>Grace Villa, Kadamankulam P.O., Thiruvalla 689583</i> )	SHRI JOSE KURIAN ( <b>Convener</b> )
ACC Limited, Mumbai	SHRI PRAHLAD MUJUMDAR SHRI ANIL KULKARNI ( <i>Alternate</i> )
Ambuja Cement Limited, Ahmedabad	SHRI UMESH P. SONI SHIR SUKURU RAMARAO ( <i>Alternate</i> )
AFCONS Infrastructure Limited, Mumbai	SHRI MANISH MOKAL
Association of Consulting Civil Engineers (India), Bengaluru	SHRI AVINASH D. SHIRODE SHRI K. K. MEGHASHYAM ( <i>Alternate</i> )
Atomic Energy Regulatory Board, Mumbai	SHRI L. R. BISHNOI SHRI SOURAV ACHARYA ( <i>Alternate</i> )
Building Materials and Technology Promotion Council, New Delhi	SHRI PANKAJ GUPTA
Bureau of Design for Hydel and Irrigation Project, Bhopal	SHRI S. K. KHARE SHRI BHAGWATI PRASAD GUPTA ( <i>Alternate</i> )
Bureau Veritas India Ltd, Mumbai	REPRESENTATIVE
Central Public Works Department, New Delhi	SHRI D. K. GARG SHRI RAJESH KHARE ( <i>Alternate</i> )
Central Soil and Materials Research Station, New Delhi	SHRI RAJEEV KUMAR SHRI RAJ KUMAR ( <i>Alternate</i> )
Creative Design Consultants Engineers Pvt Ltd, Ghaziabad	SHRI AMAN DEEP GARG SHRI MANIK CHATTERJEE ( <i>Alternate</i> )
CSIR – Central Building Research Institute, Roorkee	DR RAJESH DEOLIA SHRI H. C. ARORA ( <i>Alternate</i> )
CSIR – Central Road Research Institute, New Delhi	SHRI J. B. SENGUPTA SHRI SATISH PANDEY ( <i>Alternate</i> )
CSIR – Structural Engineering Research Centre, Chennai	DR B. H. BHARATHKUMAR DR P. SRINIVASAN ( <i>Alternate</i> )

<i>Organization</i>	<i>Representative(s)</i>
Department of Science and Technology Ministry of Science and Technology, New Delhi	SHRI S. S. KOHLI
Elkem South Asia Pvt Ltd, Navi Mumbai	SHRI BRAJESH MALVIYA SHRI SURENDRA SHARMA ( <i>Alternate</i> )
Engineers India Limited, New Delhi	SHRI RAJANJI SRIVASTAVA SHRI ANURAG SINHA ( <i>Alternate</i> )
Gammon India Limited, Mumbai	SHRI SUDEESH RAJENDRAN
Hindustan Construction Company Ltd, Mumbai	SHRI SATISH KUMAR SHARMA SHRI KHATARBATCHA JIMMETAIN ( <i>Alternate</i> )
Indian Concrete Institute, Chennai	SHRI K. C. TAYADE SECRETARY GENERAL ( <i>Alternate</i> )
Indian Institute of Technology Delhi, New Delhi	DR B. BHATTACHARJEE DR SHASHANK BISHNOI ( <i>Alternate</i> )
Indian Institute of Technology Kanpur, Kanpur	DR SUDHIR MISHRA
Indian Institute of Technology Madras, Chennai	DR MANU SAN THANAM DR RADHAKRISHNA G. PILLAI ( <i>Alternate</i> )
Indian Institute of Technology Roorkee, Roorkee	REPRESENTATIVE
Indian Society of Structural Engineers, Mumbai	SHRI UMESH JOSHI SHRI HEMANT VADALKAR ( <i>Alternate</i> )
Irrigation and Power Research Institute, Amritsar	CHIEF ENGINEER (RESEARCH) RESEARCH OFFICER ( <i>Alternate</i> )
Larsen and Toubro Limited, ECC Division, Chennai	DR B. SIVARAMA SARMA SHRI S. MANOHAR ( <i>Alternate</i> )
Military Engineer Services, Engineer-in- Chief's Branch, Integrated HQ of MoD (Army), New Delhi	MAJ GEN S. K. SRIVASTAV SHRI MAN SINGH ( <i>Alternate</i> )
Ministry of Road Transport and Highways, New Delhi	SHRI A. P. PATHAK SHRI A. K. PANDEY ( <i>Alternate</i> )
NBCC (India) Limited, New Delhi	SHRI H. S. YADAV SHRI ARUN KUMAR SHARMA ( <i>Alternate</i> )
National Council for Cement & Building Materials, Ballabgarh	SHRI V. V. ARORA SHRI P. N. OJHA ( <i>Alternate</i> )
National Institute of Technology Warangal, Warangal	DR C. B. KAMESWARA RAO DR D. RAMA SESU ( <i>Alternate</i> )
Nuclear Power Corporation of India Limited, Mumbai	SHRI ARVIND SRIVASTAVA SHRI N. M. RAO ( <i>Alternate</i> )
Oberoi Reality Limited, Mumbai	SHRI R. GURU SHANKAR
Pidilite Industries Limited, Mumbai	DR SUGUNA NAIK
Ready Mixed Concrete Manufacturers' Association, Mumbai	SHRI VIJAYKUMAR R. KULKARNI SHRI SRIRANG SONDUR ( <i>Alternate</i> )
Research, Design & Standards Organisation (Ministry of Railways), Lucknow	JT DIRECTOR STDRS (B&S)/CB-I JT DIRECTOR STDRS (B&S)/CB-II ( <i>Alternate</i> )
RDC Concrete (India) Pvt Ltd, Thane	SHRI ANIL BANCHHOR SHRI SIMRANJIT SINGH ( <i>Alternate</i> )
Shapoorji Pallonji and company private limited, Mumbai	SHRI GIRISH BONDE SHRI D. N. VISHWANATH ( <i>Alternate</i> )
Tandon Consultants Pvt Limited, New Delhi	SHRI MAHESH TANDON SHRI VINAY GUPTA ( <i>Alternate</i> )

**IS 3370 (Part 4/Sec 2) : 2021**

<i>Organization</i>	<i>Representative(s)</i>
Tata Consulting Engineers Limited, Mumbai	SHRI S. N. DIWAKAR SHRI MANOS KUMAR DE ( <i>Alternate</i> )
Ultra Tech Cement Ltd, Mumbai	DR V. RAMACHANDRA DR A. K. SINGH ( <i>Alternate</i> )
Water Resource Department, Govt. of Madhya Pradesh, Mumbai	SHRI S. K. KHARE SHRI B. P. GUPTA ( <i>Alternate</i> )
In personal capacity ( <i>452 Sector 14, Sonipat, Haryana</i> )	SHRI R. K. JAIN
In personal capacity ( <i>36, Old Sneh Nagar, Wardha Road, Nagpur</i> )	SHRI L. K. JAIN
In personal capacity [ <i>B-803, Oberoi Exquisite, Oberoi Garden City, Goregaon (East), Mumbai</i> ]	SHRI A. K. JAIN
In personal capacity ( <i>EA-92, Maya Enclave, Hari Nagar, New Delhi</i> )	SHRI R. C. WASON
In personal capacity ( <i>M1 F1 VGN Minerva Apartments, Guruswamy Road, Nolambur, Chennai</i> )	DR C. RAJKUMAR

Panel for Review/Revision of IS 3370, CED 2:2/P1

<i>Organization</i>	<i>Representative(s)</i>
In Personal Capacity ( <i>36, Old Sneh Nagar, Wardha Road, Nagpur</i> )	SHRI L. K. JAIN ( <b>Convener</b> )
Creative Design Consultants & Engineers Pvt Ltd, Ghaziabad	SHRI AMAN DEEP GARG SHRI MANIK CHATTERJEE ( <i>Alternate</i> )
CSIR-Central Road Research Institute, New Delhi	DIRECTOR
CSIR-Structural Engineering Research Centre, Chennai	DR B. H. BHARATHKUMAR DR P. SRINIVASAN ( <i>Alternate</i> )
Gammon Engineers & Contractors Pvt Ltd, Mumbai	SHRI S. W. DESHPANDE SHRI MUKUND C. BUTALA ( <i>Alternate</i> )
Government College of Engineering, Pune	DR NAMDEO A. HEDAOO
Hindustan Construction Company Ltd, Mumbai	SHRI SATISH KUMAR SHARMA SHRI MUKESH VALECHA ( <i>Alternate</i> )
Indian Concrete Institute, Chennai	REPRESENTATIVE
Indian Institute of Technology Delhi, New Delhi	DR DIPTI RANJAN SAHOO DR SHASHANK BISHNOI ( <i>Alternate</i> )
Indian Institute of Technology Roorkee, Roorkee	DR ASHOK K. JAIN
Military Engineer Services, Engineer-in-Chief's Branch, Integrated HQ of MoD (Army), New Delhi	SHRI J. B. SHARMA SHRI YOGESH K. SINGHAL ( <i>Alternate</i> )
National Council for Cement & Building Materials, Ballabgarh	SHRI V. V. ARORA SHRI T. V. G. REDDY ( <i>Alternate</i> )
Tata Consulting Engineers Limited, Mumbai	SHRI S. M. PALEKAR SHRI S. KRISHNA ( <i>Alternate</i> )
In Personal Capacity ( <i>Grace Villa, Kadamkulam P.O., Thiruvalla 689 583</i> )	SHRI JOSE KURIAN

<i>Organization</i>	<i>Representative(s)</i>
In personal capacity ( <i>A2B/37A, Ekta Apartment, Paschim Vihar, New Delhi 110 063</i> )	SHRI ARVIND KUMAR
In personal capacity ( <i>Flat No. 220, Ankur Apartments, Mother Dairy Road, Patparganj, Delhi 110 092</i> )	DR V. THIRUVENGADAM
In personal capacity ( <i>K-L/2, Kavi Nagar, Ghaziabad 201 002</i> )	DR A. K. MITTAL
In personal capacity ( <i>House No. 2103 Sector 7D, Faridabad 121 006</i> )	SHRI HARISH KUMAR JULKA
In personal capacity ( <i>EA-92, Maya Enclave, Hari Nagar, New Delhi</i> )	SHRI R. C. WASON



(Continued from second cover)

- b) Deflection coefficients have been included for rectangular tanks.
- c) Moment coefficients for rectangular tanks have been revised and enlarged to cover wider range of loading configurations, end-restraint conditions, and width/height ratios.
- d) A clause on the ‘ulti-cell tanks’ has been included providing information on how to modify single-cell coefficients for use in the design of multi-cell tanks.

The Committee responsible for the formulation of this standard has taken into consideration the views of engineers and technologists and has related the standard to the practices followed in the country in this field. Due weightage has also been given to the need for international coordination among the standards prevailing in different countries of the world. These considerations led the Sectional Committee to derive assistance from published materials of British Standards Institution and Portland Cement Association, Illinois, USA. Tables have been reproduced from the following publications of Portland Cement Association, Illinois, USA: Rectangular Concrete Tanks (*revised fifth edition*) and the same is thankfully acknowledge.

The composition of the Committee responsible for the formulation of this standard is given at Annex A.

For the purpose of deciding whether a particular requirement of this standard is complied with the final value, observed or calculated, expressing the result of a test or analysis shall be rounded off in accordance with IS 2 : 1960 ‘Rules for rounding off numerical values (*revised*)’. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

## Bureau of Indian Standards

BIS is a statutory institution established under the *Bureau of Indian Standards Act*, 2016 to promote harmonious development of the activities of standardization, marking and quality certification of goods and attending to connected matters in the country.

### Copyright

BIS has the copyright of all its publications. No part of these publications may be reproduced in any form without the prior permission in writing of BIS. This does not preclude the free use, in the course of implementing the standard, of necessary details, such as symbols and sizes, type or grade designations. Enquiries relating to copyright be addressed to the Director (Publications), BIS.

### Review of Indian Standards

Amendments are issued to standards as the need arises on the basis of comments. Standards are also reviewed periodically; a standard along with amendments is reaffirmed when such review indicates that no changes are needed; if the review indicates that changes are needed, it is taken up for revision. Users of Indian Standards should ascertain that they are in possession of the latest amendments or edition by referring to the latest issue of 'BIS Catalogue' and 'Standards: Monthly Additions'.

This Indian Standard has been developed from Doc No.: CED 02 (13704).

### Amendments Issued Since Publication

Amend No.	Date of Issue	Text Affected

## BUREAU OF INDIAN STANDARDS

### Headquarters:

Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 110002  
*Telephones:* 2323 0131, 2323 3375, 2323 9402

*Website:* [www.bis.gov.in](http://www.bis.gov.in)

### Regional Offices:

Central	: Manak Bhavan, 9 Bahadur Shah Zafar Marg NEW DELHI 110002	<i>Telephones</i> $\begin{cases} 2323\ 7617 \\ 2323\ 3841 \end{cases}$
---------	---	---

Eastern	: 1/14 C.I.T. Scheme VII M, V.I.P. Road, Kankurgachi KOLKATA 700054	<i>Telephones</i> $\begin{cases} 2337\ 8499, 2337\ 8561 \\ 2337\ 8626, 2337\ 9120 \end{cases}$
---------	--	---

Northern	: Plot No. 4-A, Sector 27-B, Madhya Marg CHANDIGARH 160019	<i>Telephones</i> $\begin{cases} 265\ 0206 \\ 265\ 0290 \end{cases}$
----------	---	---

Southern	: C.I.T. Campus, IV Cross Road, CHENNAI 600113	<i>Telephones</i> $\begin{cases} 2254\ 1216, 2254\ 1442 \\ 2254\ 2519, 2254\ 2315 \end{cases}$
----------	--	---

Western	: Manakalaya, E9 MIDC, Marol, Andheri (East) MUMBAI 400093	<i>Telephones</i> $\begin{cases} 2832\ 9295, 2832\ 7858 \\ 2832\ 7891, 2832\ 7892 \end{cases}$
---------	---	---

<b>Branches</b>	AHMEDABAD. BENGALURU. BHOPAL. BHUBANESHWAR. COIMBATORE. DEHRADUN. DURGAPUR. FARIDABAD. GHAZIABAD. GUWAHATI. HYDERABAD. JAIPUR. JAMMU. JAMSHEDPUR. KOCHI. LUCKNOW. NAGPUR. PARWANOO. PATNA. PUNE. RAIPUR. RAJKOT. VISAKHAPATNAM.
-----------------	--