

Building Energy Retrofits Under Capital Constraints[☆]

Matthew Dahlhausen, Mohammad Heidarinejad, Jelena Srebric

University of Maryland

Abstract

Write the abstract last. 4 sentences. State the problem. Say why it's an interesting problem. Say what your solution achieves. Say what follows from your solution.

Keywords: Office building; energy retrofit; energy efficiency measures; simple payback; staging; integrative design; measure bundles; measure packages; energy simulation

1. Introduction

Governments and institutions are focusing on building energy efficiency as an area for sizable, cost-effective energy use reduction and greenhouse gas mitigation [1, 2]. Commercial buildings are important to consider, as they are capital
5 intensive and long-lasting, with a median lifetime of 70 years [3]. Without considerable efforts to retrofit the current building stock for energy efficiency, as much as 80% of 2005 thermal energy consumption can remain past 2050 [4]. Currently, while 86% of construction costs go to building renovation, little of that goes to improving the energy efficiency of buildings [5]. Renovation rates
10 are around 2.2%, with an 11% average energy savings [6]. This rate needs to grow several-fold, with average savings around 55%, to approach modest emission reduction targets and Architecture 2030 goals [6]. Few renovation projects in the U.S. have achieved this savings level, with one recent study identifying only 50 such projects, known as deep or advanced energy retrofits [7, 8].

[☆]Fully documented methods available here.

15 Lack of access to capital, insufficient payback, and saving uncertainty are
top barriers to making energy retrofits more prevalent [9, 10]. Most projects
are funded with limited internal capital, sometimes with assistance from grants,
rebates, and other incentives. These projects have tended towards individual
lighting, controls, and HVAC equipment measures with reliable savings, as it
20 can be very expensive to go through an extensive energy audit that may not
significantly reduce the savings uncertainty. While the practice of single measure
ranking by simple-payback results in good financial payback on a per-measure
basis, it doesn't take advantage of measure integration that can yield greater
energy savings. Most notably, heating and cooling load reduction measures
25 enable downsizing central mechanical equipment for significant replacement cost
savings. This means that choosing measure with optimal payback individually
may not yield the best retrofit decision overall. Uncertainty and capital budgets
make energy retrofits an economic problem, not just a physical one.

Several studies have investigated and established methodologies for choosing
30 energy retrofits, summarized by [11]. A subset of the retrofit literature considers
the integrative aspect of measure selection. [12] show performance of measure
packages under different decision criteria and the impact of uncertainty. This
approach captures the interaction between retrofit measures. However, it is
not always possible to implement all measures at once, largely depending on
35 available capital. [13] demonstrate a process to implement measures in order
depending on capital availability. This reduces financial risk exposure of a large
retrofit project, and stays within an internal budget, but does not consider what
measure package would result in the best savings. Both approaches are needed.
Extending the project timeline incorporates major equipment replacements that
40 are already embedded in capital plans into a comprehensive retrofit package.
This allows targeted load reductions to precede equipment replacement, and to
account for the cost of waiting. There is a trade-off between sacrificing expected
life of equipment by replacing it now with other measures, or waiting until end-
of-life and forgoing possible energy savings from implementing measures sooner.

45 This paper establishes a methodology for evaluating energy retrofit packages

under capital constraints, demonstrates it through a case-study of an office building in Philadelphia, PA, and discusses the significance of the difference in capital availability to the optimal retrofit decisions.

2. Methods

50 **2 pages describing method, 5 pages details**

Energy retrofit measure selection is dependent on capital availability, financial criteria, and uncertainties in energy savings and energy costs. Including measure interaction and savings uncertainties is necessary to properly account for a measure's impact on building performance. This increases the number of options to consider, and requires energy simulation to handle the complexity of measure interaction. Installing measures longitudinally based on a fixed capital budget adds further complexity, as the order in which measures are installed becomes significant. Load reduction measures allow equipment downsizing, and there is a performance difference for different size systems with the same energy efficiency measures. This greatly increases the number of energy simulation options to consider. This study constructs all the possible retrofit path-options, including this downsizing difference, to measure the impact of capital constraints on the best retrofit measure option. Figure 1 shows the process of building path options to consider for a building retrofit under capital constraints.



Figure 1: Flowchart

65 2.1. Case Study

The case study is a commercial office building at the Philadelphia Navy Yard, shown in Figures 2,3. It was originally built as a barracks, and underwent

major renovation in 1999 to become an office building. The building is about 75,000 ft² (6,968 m²), of which about 60,000 ft² (5,574 m²) is conditioned space,
 70 about 40,000ft² (3,716 m²) of that office, spread over 3 stories and a conditioned basement. The Energy Utilization Index (EUI) in this study is referenced to conditioned floor area. The building exterior wall is 1.5ft (0.46m) thick brick, and has a window-to-wall ratio of 17%. Three Variable Air Volume (VAV) units with DX cooling serve the building. A gas boiler serves heating coils at each air
 75 handler and provides reheat for terminal boxes in each thermal zone. Gas hot water heaters provide service hot water.



Figure 2: Figure caption




Figure 3: Figure caption

The building energy model uses the Openstudio[**REF**] modeling platform. The simplifications on the model are to assume an identical floor plan on each story, which is nearly the case in the building. The fenestration is modeled
 80 with a set window-to-wall ratio on each exterior wall, rather than modeling each window individually, to improve simulation speed with little accuracy loss on load calculations [14]. Mechanical equipment and lighting specifications are detailed from design drawings. Plug load is modeled with a set area density for office, conference, and lobby areas from sub-meter data, and equipment
 85 schedules were then adjusted to match the hourly plug load profile[15, 16]. Air infiltration is assumed to be a uniform, constant 0.2 ACHnat across the exterior enclosure [REF? used 189]. The model uses AMY weather data from the

Philadelphia International Airport, located a few miles from the building site. A detailed summary of building instrumentation and calibration are available in [17, 18]. The model calibrates to 10-month hourly sub-metered energy data for heating, cooling, service hot water, fan, lighting, total building electric, and total building gas energy use. Plug load and miscellaneous electric use, including water systems pumps and elevators use, is assumed equal to the total building electrical energy use less all other metered electrical loads cooling, fans, and lighting. January 2012 data are not available, as sub-meter data was not installed until late January, and HVAC sub-meter data in December 2012 are not comparable, as the building underwent a major controls upgrade. The lack of data for these periods increases the uncertainty in heating energy use for model calibration, as nearly a fourth of annual heating degree days occurred in January. The calibration disregards anomalous service hot water use data in April and May, when water use spiked, coinciding with a construction period on the second floor. Table 1 shows coefficient of variation of the root square mean error (CVRSME) and normalized mean bias error (NMBE) calibration statistics for each end use following ASHRAE Guideline 14 [19]. The calibrated setpoint temperature was around 72°F (22°C) with some variation to match observed VAV temperature control.

	CVRSME	NMBE	Months
Calibration Target	15%	5%	All
All Electricity	6.1%	-0.6%	All
Plug Loads	5.9%	-2.1%	All
Lighting	4.9%	2.6%	All
Fans	9.3%	-1.2%	Omit December
Cooling	12.6%	3.6%	Omit December
All Gas	12.0%	2.3%	Omit December
Heating	12.6%	1.7%	Omit December
Service Hot Water	9.5%	2.3%	Omit April and May

Table 1: Building 101 Energy End Use Calibration Metrics

2.1.1. Energy Efficiency Measures

This study considers seven energy efficiency measures, shown in Table 2,. The selected measures were commonly recommended in energy audits of the building. Costs, shown in Table 3, are from RSMeans [20].

EEM	Description	Source
Exterior Wall Insulation and Finish System	Add an exterior insulation and finish system, with 4" (0.1 m) EPS board, R-16, reduce infiltration by 30%	-
Lighting Power Density Reduction	Reduce conference and office lighting power density from 1.15 to 0.9 W/ft ² (12.38 to 9.69 W/m ²)	-
Occupancy Sensors	Reduce lighting fraction from 0.2 to 0.05 during unoccupied hours on weekdays, and 0.15 to 0.05 on weekends	-
Reduce Infiltration by 15%	-	-
Window Film	Reduce SHGC from 0.764 to 0.38	-
Condensing Boiler Replacement	Replace boiler with 90% efficient condensing boiler, auto-size capacity and flow rates for loop, lower supply temperature to 140 °F (60 °C)	-
Condensing Unit Replacement	Replace condensing units with auto-sized unit with high speed EER 11.5 and low speed EER 16.2	-

Table 2: Building 101 Energy Efficiency Measures

2.2. Results

Show the difference in the solution depending on the capital availability.

3. Discussion

2 pages comparison to related work

compare to [12]

EEM	Cost/Unit	Cost
Exterior Wall Insulation and Finish System	\$4.78/ft ² wall area	\$927,930
Lighting Power Density Reduction	\$4.78/ft ² floor area	\$202,886
Occupancy Sensors	\$1.06/ft ² floor area	\$44,991
Reduce Infiltration by 15%	\$-/ft ² wall area	\$00,000
Window Film	\$18.93/ft ² glazing	\$182,311
Condensing Boiler Replacement	\$20,706 + \$4.05/kW	variable
Condensing Unit Replacement	\$7,909 + \$2693.91/kW	variable

Table 3: Building 101 Energy Efficiency Measures

4. Conclusions

0.5 pages

5. L^AT_EX templates

5.1. Lists

- Bullet point one
- Bullet point two
- 1. Numbered list item one
- 2. Numbered list item two

5.2. Equations

$$e = mc^2 \tag{1}$$

Acknowledgements

This material is based upon work supported by the Energy Efficient Build-ings Hub (EEB Hub), an energy innovation hub sponsored by the U.S. Depart-ment of Energy under Award Number DE-EE0004261. The author would like to thank Richard Sweetser for sharing his valuable experience, Payam Delgoshaei for sharing the sub metered energy data for 2012.

References

- [1] G. Choi, J. Creyts, A. Derkach, P. Farese, S. Nyquist, K. Ostrowski, Unlocking energy efficiency in the u.s. economy, Tech. rep., McKinsey&Company (2009).
- 135 [2] R. H. P. Farese, R. Gelman, A tool to prioritize energy efficiency investments, Tech. rep., National Renewable Energy Laboratory (2012).
URL <http://www.nrel.gov/docs/fy12osti/54799.pdf>
- [3] 2011 Buildings Energy Data Book. Table 3.2.7., U.S. Department of Energy, 2011.
140 URL http://buildingsdatabook.eren.doe.gov/docs/5CDataBooks/5C2010_BEDB.pdf
- [4] D. Urge-Vorsatz, K. Petrichenko, M. Staniec, J. Eom, Energy use in buildings in a long-term perspective, Current Opinion in Environmental Sustainability 5 (2) (2013) 141–151, cited By 2.
145 URL <http://www.scopus.com/inward/record.url?eid=2-s2.0-84879409618&partnerID=40&md5=b5d7bb1da2127c81d17641dab47fbd35>
- [5] N. Wang, C. Taylor, M. J. McCabe, DOE Commercial Building Energy Asset Rating: Market Research and Program Direction, 2012.
- 150 [6] V. Olgyay, C. Seruto, Whole-building retrofits: A gateway to climate stabilization, Vol. 116, 2010, pp. 244–251, cited By 6.
URL <http://www.scopus.com/inward/record.url?eid=2-s2.0-79952663556&partnerID=40&md5=986853b607769b4fef15e7e15b629061>
- 155 [7] Neea study: Examples of deep energy savings in existing buildings, Tech. rep., New Buildings Institute (2011).
URL http://www.betterbricks.com/sites/default/files/nbi_neea_deep_savings_search_phase_1_final.pdf

- [8] G. Liu, Advanced energy retrofit guide for office buildings, Tech. rep., Pacific Northwest National Laboratory, Richland, WA (2011).
160
- [9] Energy efficiency indicator, Tech. rep., Johnson Controls (2014).
- [10] L. M. Abadie, R. A. Ortiz, I. Galarraga, Determinants of energy efficiency investments in the {US}, Energy Policy 45 (0) (2012) 551 – 566. doi:<http://dx.doi.org/10.1016/j.enpol.2012.03.002>.
165 URL <http://www.sciencedirect.com/science/article/pii/S0301421512002078>
- [11] Z. Ma, P. Cooper, D. Daly, L. Ledo, Existing building retrofits: Methodology and state-of-the-art, Energy and Buildings 55 (0) (2012) 889 – 902, cool Roofs, Cool Pavements, Cool Cities, and Cool World. doi:<http://dx.doi.org/10.1016/j.enbuild.2012.08.018>.
170 URL <http://www.sciencedirect.com/science/article/pii/S0378778812004227>
- [12] A. Rysanek, R. Choudhary, Optimum building energy retrofits under technical and economic uncertainty, Energy and Buildings 57 (0) (2013) 324 – 337. doi:<http://dx.doi.org/10.1016/j.enbuild.2012.10.027>.
175 URL <http://www.sciencedirect.com/science/article/pii/S0378778812005361>
- [13] G. Kumbaroglu, R. Madlener, Evaluation of economically optimal retrofit investment options for energy savings in buildings, Energy and Buildings 49 (0) (2012) 327 – 334. doi:<http://dx.doi.org/10.1016/j.enbuild.2012.02.022>.
180 URL <http://www.sciencedirect.com/science/article/pii/S0378778812000990>
- [14] G. Liu, M. Liu, A rapid calibration procedure and case study for simplified simulation models of commonly used {HVAC} systems, Building and Environment 46 (2) (2011) 409 – 420.
185

doi:<http://dx.doi.org/10.1016/j.buildenv.2010.08.002>.

URL <http://www.sciencedirect.com/science/article/pii/S0360132310002453>

- 190 [15] P. Delgoshaei, K. Xu, S. Wagner, R. Sweetser, J. Freihaut, Hourly
Plug Load Measurements and Profiles for a Medium Office Building -
a Case Study, AEI 2013, American Society of Civil Engineers, 2013,
Ch. 81, pp. 827–836. arXiv:<http://ascelibrary.org/doi/pdf/10.1061/9780784412909.081>, doi:10.1061/9780784412909.081.
- 195 URL <http://ascelibrary.org/doi/abs/10.1061/9780784412909.081>
- [16] K. Xu, Assessing the minimum instrumentation to well tune existing
medium sized office building energy models, Ph.D. thesis, Architectural
Engineering, The Pennsylvania State University (2012).
- [17] A. Dasgupta, H. Henderson, R. Sweetser, T. Wagner, Building monitoring
200 system and preliminary results for a retrofitted office building, in: Interna-
tional High Performance Buildings Conference, Purdue University, Purdue
University, 2012.
- [18] M. Dahlhausen, Staging building energy retrofits, Ph.D. thesis, Architec-
tural Engineering, The Pennsylvania State University (2014).
- 205 [19] Ashrae guideline 14-2002: Measurement of energy and demand savings
(2012).
- [20] R. C. D. Inc., Rsmeansonline version 5.0.3 (2014).
URL <http://rsmeansonline.com>