

SCHEDULE OF REINFORCEMENT (PER SPAN)

| SL NO | LOCATION            | BAR MKQ | SHAPE | DIA (mm) | SPACING (mm) | LENGTH (mm) | NOS. | TOTAL LENGTH (m) | WEIGHT (kg) |
|-------|---------------------|---------|-------|----------|--------------|-------------|------|------------------|-------------|
| 1     | SLAB-BOTTOM ALONG-X | a1      |       | 25       | 125          | 11150       | 96   | 1070.40          | 4121        |
| 2     | SLAB-BOTTOM ALONG-Y | a2      |       | 12       | 115          | 12430       | 91   | 1131.13          | 1004        |
| 3     | SLAB-SIDE ALONG-Y   | a3      |       | 10       | —            | 11900       | 2    | 23.80            | 15          |
| 4     | SLAB-TOP ALONG-X    | a4      |       | 25       | 125          | 11240       | 89   | 1000.36          | 617         |
| 5     | SLAB-TOP ALONG-Y    | a5      |       | 12       | 125          | 11600       | 84   | 974.40           | 601         |
| 6     | KERB-BOTTOM         | b1      |       | 25       | —            | 11500       | 8    | 92.00            | 82          |
| 7     | KERB-TOP            | b2      |       | 25       | —            | 11530       | 8    | 92.24            | 82          |
| 8     | KERB-SIDES          | b3      |       | 10       | —            | 10840       | 8    | 86.72            | 54          |
| 9     | KERB-STIRRUPS       | b4      |       | 10       | 280          | 2870        | 76   | 218.12           | 135         |

© DOES NOT INCLUDE THE ADDITIONAL STIRRUPS AT LAPS OF LONGITUDINAL BARS-REFER DRG. NO SD/103

REFERENCE DRAWINGS

| DRAWING NO.     | TITLE                                          |
|-----------------|------------------------------------------------|
| SD/101          | GENERAL NOTES                                  |
| SD/102          | GENERAL ARRANGEMENT                            |
| SD/103 & SD/104 | MISCELLANEOUS DETAILS                          |
| SD/105          | DETAILS OF R.C.C. RAILINGS (WITHOUT FOOTPATHS) |

Dead load of the superstructure per span including R.C.C. railings  
@ 3 kN / m and wearing coat @ 2 kN / sq m = 28.63 kN


QUANTITIES (PER SPAN)

| EFFECTIVE SPAN (m)                                 | 10.0   |
|----------------------------------------------------|--------|
| CONCRETE (cu m)                                    | 136.40 |
| STEEL INCLUDING 5% EXTRA FOR LAPS AND WASTAGE (kg) | 7047   |
| ASPHALTIC WEARING COAT (sq m)                      | 113.36 |

NOTES:-

- All dimensions are in millimetres unless otherwise mentioned.
- On the reinforcement drawings, the reinforcement is shown in accordance with the IS: 456-1978 code of practice for concrete and IS: 1786-1978 code of practice for reinforcement steel.
- The reinforcement of railing posts shall be incorporated before casting of the deck slab.
- The railings shall conform to drawing no SD/105 or any other approved type.
- Dimensions in schedule of reinforcement are given as per IS: 2502.
- Reinforcement of adjacent span superstructure, approach slab not shown.

DRAINAGE SPOUT (TP)  
REFER NOTE NO 2 OF  
DRG. NO. SD/102  
REINFORCEMENT TO BE  
CUT AND ADJUSTED TO  
ACCOMMODATE THE  
DRAINAGE SPOUT.



PLAN SHOWING REINFORCEMENT DETAILS OF DECK SLAB \*

|                                    |                     |        |
|------------------------------------|---------------------|--------|
| DATE                               | DESCRIPTION         | BY     |
|                                    |                     |        |
| REVISION                           |                     |        |
| GOVERNMENT OF INDIA                |                     |        |
| MINISTRY OF SURFACE TRANSPORT      |                     |        |
| (ROADS WING), NEW DELHI            |                     |        |
| STANDARD DRAWINGS FOR ROAD BRIDGES |                     |        |
| R.C.C. SOLID SLAB                  |                     |        |
| SUPERSTRUCTURE (RIGHT) SPAN 100m   |                     |        |
| (WITHOUT FOOTPATHS)                |                     |        |
| RECOMMENDED BY                     | APPROVED BY         | 1990   |
| (S.S. REDDY) E.E.                  | (S.K. KAISTHA) S.E. | DRG NO |
|                                    |                     | SD/114 |