

ACDC-OpFlow Manual V0.1.3

Haixiao Li Azadeh Kermansaravi Aleksandra Lekić

September 3, 2026

Contents

1 Overview **2**
1.1 Motivation . . . 2
1.2 Configuration . . . 2
1.2.1 Dependencies . . . 2
1.2.2 Installation steps . . . 3
1.2.3 Code structure . . . 4

2 OPF Formulation **5**
2.1 Nomenclature . . . 5
2.2 Original nonlinear formulation . . . 7
2.3 Convex relaxed formulation . . . 10

3 Code Implementation **13**
3.1 Data preparation . . . 13
3.2 Parameter processing . . . 19
3.3 Variable definition . . . 19
3.4 Constraint construction . . . 22

4 Examples **25**
4.1 Running a case . . . 25
4.2 Benchmark . . . 26
4.2.1 Performance comparison . . . 26
4.2.2 Discussion . . . 27

A Additional Discussion **30**
A.1 Power flow accuracy . . . 30

1 Overview

1.1 Motivation

AC/VSC-MTDC (Voltage Source Converter-based Multi-terminal DC) grids play a crucial role in modern power systems by enhancing grid stability, flexibility, and grid-friendly interconnection. VSC-MTDC allows independent active and reactive power control, enabling seamless connection of AC grids in different regions. The scheduling of a power system consisting of multiple interconnected AC grids and a VSC-MTDC grid is significant [1], [2], [3]. As depicted in Fig. 1.1, we need a technique to help enhance the rationality and optimality of scheduling, which involves solving the problems known as the AC/DC optimal power flow (OPF).




Figure 1.1: Overview of the AC/DC OPF problem

This section provides a concise guide on environment configuration, core code structure, running the code, and accessing results. It serves as a basic introduction to help users to get started with **ACDC-OpFlow**.

1.2 Configuration

1.2.1 Dependencies

ACDC-OpFlow is developed using languages: Matlab, Julia, Python, Cpp. For each programming environment, we provide recommendations on the dependency versions used in our implementation. While users may install later versions of these dependencies, it is advised to verify compatibility.

- Matlab r2021b: Yalmip 20230622.
- Julia v1.10: CSV 0.10.15 | DataFrames 1.7.0 | JuMP 1.23.3 | Gurobi 1.0.0 | Graphs 1.12.1 | GraphPlot 0.6.1 | GLMakie 0.11.4 | ColorSchemes 3.29.0 | Colors 0.12.11.
- Python v3.12 : numpy 2.2.1 | pandas 2.2.3 | scipy 1.15.1 | pyomo 6.8.2 | networkx 3.4.2 | matplotlib 3.10.0 | gurobipy 11.0.1.
- Cpp : Gurobi C++ API | Eigen3 3.4.0 | matplotplusplus 3.4.0.

- Gurobi GUROBI OPTIMIZATION : Gurobi 9.5.2.
- Matpower MATPOWER : Matpower 7.1.

1.2.2 Installation steps

To install required toolboxes in Matlab environment, users can download the toolbox directly from the official website. Then, users can add the toolbox folders to Matlab path, using the following commands:

```
>> addpath(genpath('path/to/YALMIP'))
>> ...
>> savepath
```

To install required packages in Julia environment, users can use the following commands:

```
>> using Pkg
>> Pkg.add("JuMP")
>> Pkg.add("CSV")
>> ...
```

Alternatively, users may use the package mode (triggered by pressing the `]` key in the Julia REPL):

```
>> (@v1.10) pkg> add JuMP
>> (@v1.10) pkg> add CSV
>> ...
```

To install required packages in Python environment, users can use the following commands if with Anaconda[1], installing packages into isolated environments:

```
>> conda create -n acdcOpflow-env python=3.12
>> conda activate acdcOpflow-env
>> conda install numpy pandas matplotlib ...
```

Also, users can install packages either globally or within virtual environments:

```
>> pip install numpy pandas matplotlib ...
```

To install required libraries in Cpp, we recommend using vcpkg[2] to simplifies the process of acquiring and managing Cpp dependencies. The commands are:

```
>> ./vcpkg install eigen3 boost
>> ./vcpkg install matplotplusplus
>> ...
```

[1] https://www.anaconda.com/
[2] https://vcpkg.io/en/

1.2.3 Code structure

As presented in Fig. A.2, under the framework of **ACDC-OpFlow**, every coding language follows a unified workflow: First, we prepare input data related to AC and DC grids, which are all saved in structured comma-separated value (CSV) files. Secondly, extracting key parameter information from .csv data files and handling them to form the specific parameter vectors (matrices). Third, based on predefined parameter vectors (matrices), the AC/DC OPF model is constructed and subsequently solved using the Gurobi solver. Lastly, the optimal power flow results are organized and output in text format, accompanied by a visual presentation to facilitate the observation of the results. For each coding language, the included main functions are listed as Fig. 1.3.




Figure 1.2: Unified workflow in **ACDC-OpFlow**

Core functions

- `create_ac`: AC system data loading
- `create_dc`: DC system data loading
- `params_ac`: AC system parameter extraction
- `params_dc`: DC system parameter extraction
- `solve_opf`: AC/DC OPF implementation
- `viz_opf`: AC/DC OPF result visulization

Figure 1.3: Main functions in **ACDC-OpFlow**

2 OPF Formulation

2.1 Nomenclature

This section introduces the mathematical formulation of the AC/DC OPF used in **ACDC-OpFlow**. The fundamental constraint and objective functions to describe the optimal steady-state behavior for the AC/DC power system are introduced. Symbols appearing in subsequent formulas can be found below.

Indexes, Sets, super/subscript

$(\bar{\cdot})/(\underline{\cdot})$ -The upper/lower bound of the corresponding optimization variables and parameters

$|\cdot|$ -Magnitude

$\mathcal{L}$ -Branch set

$\mathcal{N}$ -Node set

AC -Alternating current

$cost$ -Generation cost

$droop$ -Droop parameters

gen -Generator

$h,\ i,\ j$ -System node

ij -System branch

$load$ -Load

$loss$ -Power loss

$mppt$ -Maximum Power Point Tracking

$MTDC$ -Multi-terminal direct current

ref -Reference value

res -Renewable energy source

VSC -Voltage source converter

Variables and Parameters Related to the AC Grid

θ_{ij}^{AC} -Phase difference for AC branch ij

$c_{i,2}^{AC}/c_{i,1}^{AC}/c_{i,0}^{AC}$ -Quadratic/Linear/Constant generator generation coefficient at AC bus i

c_{ij}^{AC}/s_{ij}^{AC} -Optimization variables linked with the AC nodal voltage

$e_{i,2}^{AC}/e_{i,1}^{AC}/e_{i,0}^{AC}$ -Quadratic/Linear/Constant REs generation coefficient at AC bus i

G_{ij}^{AC}/B_{ij}^{AC} -Real/Imaginary part of AC bus admittance matrix

g_{ij}^{AC}/b_{ij}^{AC} -Conductance/Susceptance of AC branch ij

p_{ij}^{AC}/q_{ij}^{AC} -Real/Reactive power for AC branch ij

$p_{i,A2V}^{AC}/q_{i,A2V}^{AC}$ -Real/Reactive power delivered from the AC grid to the VSC station at AC bus i

$p_{i,gen}^{AC}/q_{i,gen}^{AC}$ -Real/Reactive power outputs of generator at AC bus i

$p_{i,load}^{AC}/q_{i,load}^{AC}$ -Real/Reactive power loads at AC bus i

$p_{i,res}^{AC}/q_{i,res}^{AC}$ -Real/Reactive power of RESs at AC bus i

p_{i}^{AC}/q_{i}^{AC} -Real/Reactive power injection at AC bus i

$s_{i,res}^{AC}$ -Apparent power of RES at AC bus i

v_{i}^{AC} -AC bus i voltage

Variables and Parameters Related to the MTDC Grid

$k_{i,droop}^{MTDC}$ -Droop slope at MTDC bus i

l_{jh}^{MTDC} -Squared current of MTDC branch jh

$p_{i,ref}^{MTDC}$ -Power reference of DC power control/DC droop control at MTDC bus i

p_{jh}^{MTDC} -Power of MTDC branch jh

u_{j}^{MTDC} -Squared MTDC bus j voltage

v_{j}^{MTDC} -MTDC bus j voltage

$V_{i,ref}^{MTDC}$ -Voltage reference of DC voltage control/DC droop control at MTDC bus i

Variables and Parameters Related to the VSC Station

$\theta_{s}^{VSC}/\theta_{f}^{VSC}/\theta_{c}^{VSC}$ -VSC bus $s/f/c$ phase

$a_{loss}^{VSC}/b_{loss}^{VSC}/c_{loss}^{VSC}$ -Constant/Linear/Quadratic coefficient of VSC cpower loss function

b_{f}^{VSC} -Susceptance for VSC bus f to ground

$b_{sf}^{VSC}/b_{fc}^{VSC}$ -Susceptance for VSC branch sf/fc

$c_{sf}^{VSC}/s_{sf}^{VSC}/c_{cf}^{VSC}/s_{cf}^{VSC}$ -Optimization variables linked with the VSC nodal voltage

$g_{sf}^{VSC}/g_{fc}^{VSC}$ -Conductance for VSC branch sf/fc

I_{c}^{VSC} -Phase current at VSC bus c




Figure 2.1: Equivalent impedance model of VSC

l_c^{VSC} -Squared phase current at VSC bus c

p_{loss}^{VSC} -VSC power loss

$q_{s,ref}^{VSC}$ -Power reference of reactive power control at VSC bus s

$v_s^{VSC}/v_f^{VSC}/v_c^{VSC}$ -VSC bus $s/f/c$ voltage

$v_{s,ref}^{VSC}$ -Voltage reference of AC voltage control at VSC bus s

2.2 Original nonlinear formulation

The original AC/DC OPF formulation contains is formulated as a nonlinear programming (NLP) problem due to the presence of several nonlinear constraints, such as nonlinear power flow constraints and quadratic converter loss constraints. Fig. 2.1 is provided to help understanding power flow formulation at the AC/DC coupling points. The explicit formulation of the original AC/DC OPF model is prsented as below.

Original AC/MTDC OPF Formulation [NLP]

Variables:

$p_i^{AC}, q_i^{AC}, p_{i,gen}^{AC}, q_{i,gen}^{AC}, p_{i,res}^{AC}, q_{i,res}^{AC}, s_{i,res}^{AC}, p_{i,A2V}^{AC}, q_{i,A2V}^{AC}, \theta_i^{AC}, v_i^{AC}$	$i \in \mathcal{N}^{AC}$
p_{ij}^{AC}, q_{ij}^{AC}	$(i,j) \in \mathcal{L}^{AC}$
p_j^{MTDC}, v_j^{MTDC}	$j \in \mathcal{N}^{MTDC}$
p_{jh}^{MTDC}	$(j,h) \in \mathcal{L}^{MTDC}$
$p_s^{VSC}, q_s^{VSC}, \theta_s^{VSC}, v_s^{VSC}$	$s \in \mathcal{N}^{VSC}$
$p_c^{VSC}, q_c^{VSC}, \theta_c^{VSC}, v_c^{VSC}, I_c^{VSC}$	$c \in \mathcal{N}^{VSC}$
$q_f^{VSC}, \theta_f^{VSC}, v_f^{VSC}$	$f \in \mathcal{N}^{VSC}$

AC Constraints:

$$p_{ij}^{AC} = g_{ij}^{AC} \left|v_i^{AC}\right|^2 - \left|v_i^{AC}\right| \left|v_j^{AC}\right| \left(g_{ij}^{AC} \cos\theta_{ij}^{AC} + b_{ij}^{AC} \sin\theta_{ij}^{AC}\right), \quad i,j \in \mathcal{N}^{AC}, \quad (i,j) \in \mathcal{L}^{AC} \tag{2.1a}$$

$$q_{ij}^{AC} = -b_{ij}^{AC} \left|v_i^{AC}\right|^2 + \left|v_i^{AC}\right| \left|v_j^{AC}\right| \left(b_{ij}^{AC} \cos\theta_{ij}^{AC} - g_{ij}^{AC} \sin\theta_{ij}^{AC}\right), \quad i,j \in \mathcal{N}^{AC}, \quad (i,j) \in \mathcal{L}^{AC} \tag{2.1b}$$

$$p_i^{AC} = \sum_{(i,j)} p_{ij}^{AC} + \left(\sum_j G_{ij}^{AC}\right) (v_i^{AC})^2, \quad i,j \in \mathcal{N}^{AC}, \quad (i,j) \in \mathcal{L}^{AC} \tag{2.1c}$$

$$q_i^{AC} = \sum_{(i,j)} q_{ij}^{AC} + \left(\sum_j -B_{ij}^{AC}\right) (v_i^{AC})^2, \quad i,j \in \mathcal{N}^{AC}, \quad (i,j) \in \mathcal{L}^{AC} \tag{2.1d}$$

$$p_i^{AC} = p_{i,gen}^{AC} - p_{i,load}^{AC} - p_{i,A2V}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.2a}$$

$$q_i^{AC} = q_{i,gen}^{AC} - q_{i,load}^{AC} - q_{i,A2V}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.2b}$$

$$\underline{p}_{i,gen}^{AC} \le p_{i,gen}^{AC} \le \overline{p}_{i,gen}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.3a}$$

$$\underline{q}_{i,gen}^{AC} \le q_{i,gen}^{AC} \le \overline{q}_{i,gen}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.3b}$$

$$\underline{\left|v_i^{AC}\right|} \le \left|v_i^{AC}\right| \le \overline{\left|v_i^{AC}\right|}, \quad i \in \mathcal{N}^{AC} \tag{2.4}$$

$$0 \le p_{i,res}^{AC} \le \bar{p}_{i,res}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.5a}$$

$$\left(p_{i,res}^{AC}\right)^2 + \left(q_{i,res}^{AC}\right)^2 \le \left(\bar{s}_{i,res}^{AC}\right)^2 \tag{2.5b}$$

MTDC Constraints:

$$p_{jh}^{MTDC} = \rho^{MTDC} \cdot v_j^{MTDC} \left(v_j^{MTDC} - v_h^{MTDC}\right) y_{jh}^{MTDC}, \quad j,h \in \mathcal{N}^{MTDC}, \quad (j,h) \in \mathcal{L}^{MTDC} \tag{2.6a}$$

$$p_j^{MTDC} = \sum_{(j,h)} p_{jh}^{MTDC}, \quad j,h \in \mathcal{N}^{MTDC}, \quad (j,h) \in \mathcal{L}^{MTDC} \tag{2.6b}$$

$$\underline{v}_j^{MTDC} \le v_j^{MTDC} \le \overline{v}_j^{MTDC}, \quad j \in \mathcal{N}^{MTDC} \tag{2.7}$$

$$p_j^{MTDC} = p_{j,ref}^{MTDC}, \quad j \in \mathcal{N}^{MTDC} \tag{2.8a}$$

$$v_j^{MTDC} = v_{j,ref}^{MTDC}, \quad j \in \mathcal{N}^{MTDC} \tag{2.8b}$$

$$p_j^{MTDC} = p_{j,ref}^{MTDC} - \frac{1}{k_{j,droop}^{MTDC}} \left(v_j^{MTDC} - v_{j,ref}^{MTDC}\right), \quad j \in \mathcal{N}^{MTDC} \tag{2.8c}$$

VSC Constraints:

$$p_s^{VSC} = p_{i,A2V}^{AC}, \quad s \in \mathcal{N}^{VSC}, \quad i \in \mathcal{N}^{AC} \tag{2.9a}$$

$$q_s^{VSC} = q_{i,A2V}^{AC}, \quad s \in \mathcal{N}^{VSC}, \quad i \in \mathcal{N}^{AC} \tag{2.9b}$$

$$\begin{aligned} p_s^{VSC} = \left|v_s^{VSC}\right|^2 g_{sf}^{VSC} - \left|v_s^{VSC}\right| \left|v_f^{VSC}\right| \left[g_{sf}^{VSC} \cos\left(\theta_s^{VSC} - \theta_f^{VSC}\right)\right. \\ \left. + b_{sf}^{VSC} \sin\left(\theta_s^{VSC} - \theta_f^{VSC}\right)\right], \quad s, f \in \mathcal{N}^{VSC} \end{aligned} \tag{2.10a}$$

$$\begin{aligned} q_s^{VSC} = -\left|v_s^{VSC}\right|^2 b_{sf}^{VSC} - \left|v_s^{VSC}\right| \left|v_f^{VSC}\right| \left[g_{sf}^{VSC} \cos\left(\theta_s^{VSC} - \theta_f^{VSC}\right)\right. \\ \left. - b_{sf}^{VSC} \sin\left(\theta_s^{VSC} - \theta_f^{VSC}\right)\right], \quad s, f \in \mathcal{N}^{VSC} \end{aligned} \tag{2.10b}$$

$$\begin{aligned} p_c^{VSC} = \left|v_c^{VSC}\right|^2 g_{fc}^{VSC} + \left|v_f^{VSC}\right| \left|v_c^{VSC}\right| \left[g_{fc}^{VSC} \cos\left(\theta_f^{VSC} - \theta_c^{VSC}\right)\right. \\ \left. - b_{fc}^{VSC} \sin\left(\theta_f^{VSC} - \theta_c^{VSC}\right)\right], \quad f, c \in \mathcal{N}^{VSC} \end{aligned} \tag{2.11a}$$

$$\begin{aligned} q_c^{VSC} = -\left|v_c^{VSC}\right|^2 b_{fc}^{VSC} + \left|v_f^{VSC}\right| \left|v_c^{VSC}\right| \left[g_{fc}^{VSC} \sin\left(\theta_f^{VSC} - \theta_c^{VSC}\right)\right. \\ \left. + b_{fc}^{VSC} \cos\left(\theta_f^{VSC} - \theta_c^{VSC}\right)\right], \quad f, c \in \mathcal{N}^{VSC} \end{aligned} \tag{2.11b}$$

$$q_f^{VSC} = -\left|v_f^{VSC}\right|^2 b_f^{VSC}, \quad f \in \mathcal{N}^{VSC} \tag{2.12}$$

$$p_c^{VSC} + p_{loss}^{VSC} + p_j^{MTDC} = 0, \quad j \in \mathcal{N}^{MTDC}, \quad c \in \mathcal{N}^{VSC} \tag{2.13}$$

$$p_{loss}^{VSC} = a_{loss}^{VSC} + b_{loss}^{\mathrm{VSC}} \left|I_c^{VSC}\right| + c_{loss}^{VSC} \left|I_c^{VSC}\right|^2, \quad c \in \mathcal{N}^{VSC} \tag{2.14a}$$

$$0 \le \left|I_c^{VSC}\right| \le \left|\overline{I_c^{VSC}}\right|, \quad c \in \mathcal{N}^{VSC} \tag{2.14b}$$

$$(v_c^{VSC})^2 \cdot \left|I_c^{VSC}\right|^2 = (p_c^{VSC})^2 + (q_c^{VSC})^2 \quad c \in \mathcal{N}^{VSC} \tag{2.15}$$

$$v_s^{VSC} = v_{s,ref}^{VSC}, \quad s \in \mathcal{N}^{VSC} \tag{2.16a}$$

$$q_s^{VSC} = q_{s,ref}^{VSC}, \quad s \in \mathcal{N}^{VSC} \tag{2.16b}$$

Goal:

$$\min \sum_i \left\{ c_{i,2}^{AC} \left(p_{i,gen}^{AC}\right)^2 + c_{i,1}^{AC} p_{i,gen}^{AC} + c_{i,0}^{AC} + e_{i,2}^{AC} \left(p_{i,res}^{AC}\right)^2 + e_{i,1}^{AC} p_{i,res}^{AC} + e_{i,0}^{AC} \right\}, \quad i \in \mathcal{N}^{AC} \tag{2.17}$$

- **AC Constraints**: ✓(2.1a)-(2.1d) are power flow constraints. ✓(2.2a)-(2.2b) are nodal power balance equations. ✓(2.3a)-(2.3b) are generator power output limits. ✓(2.4) is the voltage magnitude limit. ✓(2.4) is the voltage magnitude limit. ✓(2.5a)-(2.5b) regulates the power output constraint of RESs.

- **MTDC Constraints**: ✓(2.6a)-(2.6b) are power flow constraints. ✓(2.7) is the voltage magnitude limit. ✓(2.8a)-(2.8c) represents the VSC control mode at DC terminal. Note that only one of them is hold depending on the chosen control model.

- **VSC Constraint**: ✓(2.9a)-(2.9b) are the active and reactive power couplings between the AC grid and VSC. ✓(2.10a)-(2.10b) are the active and reactive power injections from the view of node s.✓(2.11a)-(2.11b) are the active and reactive power injections from the view of node c. ✓(2.12) is the reactive power injection from the view of node f. If we consider the latest converters with the MMC topology, the filter is not required to install at node f and $b_f^{vsc} = 0$.✓(2.13) is the active power coupling between the MTDC grid and VSC.✓(2.14a)-(2.14b) are related to the converter loss function. ✓(2.15) denote the voltage and current relationship from the view of node c. ✓(2.16a)-(2.16b) represent the VSC control mode at AC PCC. Note that only one of them holds depending on the chosen control model.

- **Goal**: ✓(2.17) represent minimizing power generation costs.

2.3 Convex relaxed formulation

The original AC/DC OPF problem is NLP. Such a problem is not favored due to their limited scalability and computational challenges. Give these reasons, we formulate a convex relaxed version of the original AC/DC OPF problem. Our demo code is based on the convex relaxed version as below.

Convex Relaxed AC/MTDC OPF Formulation [SOCP]

Variables:

$p_i^{AC}, q_i^{AC}, p_{i,gen}^{AC}, q_{i,gen}^{AC}, p_{i,A2V}^{AC}, q_{i,A2V}^{AC}, p_{i,res}^{AC}, q_{i,res}^{AC}, s_{i,res}^{AC}$	$i \in \mathcal{N}^{AC}$	
$p_{ij}^{AC}, q_{ij}^{AC}, s_{ij}^{AC}, c_{ij}^{AC}$	$(i,j) \in \mathcal{L}^{AC}$	
p_j^{MTDC}, v_j^{MTDC}	$j \in \mathcal{N}^{MTDC}$	
$p_{jh}^{MTDC}, l_{jh}^{MTDC}$	$(j,h) \in \mathcal{L}^{MTDC}$	
p_s^{VSC}, q_s^{VSC}	$s \in \mathcal{N}^{MTDC}$	
$p_c^{VSC}, q_c^{VSC}, I_c^{VSC}, l_c^{VSC}$	$c \in \mathcal{N}^{MTDC}$	
q_f^{VSC}	$f \in \mathcal{N}^{MTDC}$	
$c_{mn}^{VSC}, c_{mn}^{VSC}$	$m,n \in \{s,f,c\}$	$s,f,c \in \mathcal{N}^{MTDC}$

AC Constraints:

$$p_{ij}^{AC} = G_{ij}\left(c_{ii}^{AC} - c_{ij}^{AC}\right) + B_{ij}s_{ij}^{AC}, \quad i,j \in \mathcal{N}^{AC}, \quad (i,j) \in \mathcal{L}^{AC} \tag{2.17a}$$

$$q_{ij}^{AC} = -B_{ij}\left(c_{ii}^{AC} - c_{ij}^{AC}\right) + G_{ij}s_{ij}^{AC}, \quad i,j \in \mathcal{N}^{AC}, \quad (i,j) \in \mathcal{L}^{AC} \tag{2.17b}$$

$$p_i^{AC} = c_{ii}^{AC}G_{ii} + \sum_j \left(c_{ij}^{AC}G_{ij} - s_{ij}^{AC}B_{ij}\right), \quad i,j \in \mathcal{N}^{AC} \tag{2.17c}$$

$$q_i^{AC} = -c_{ii}^{AC}B_{ii} - \sum_j \left(c_{ij}^{AC}B_{ij} + s_{ij}^{AC}G_{ij}\right), \quad i,j \in \mathcal{N}^{AC} \tag{2.17d}$$

$$c_{ij}^{AC} = c_{ji}^{AC}, \quad i,j \in \mathcal{N}^{AC} \tag{2.17e}$$

$$s_{ij}^{AC} = -s_{ji}^{AC}, \quad i,j \in \mathcal{N}^{AC} \tag{2.17f}$$

$$(c_{ij}^{AC})^2 + (s_{ij}^{AC})^2 \leq c_{ii}^{AC}c_{jj}^{AC}, \quad i,j \in \mathcal{N}^{AC} \tag{2.17g}$$

$$p_i^{AC} = p_{i,gen}^{AC} - p_{i,load}^{AC} - p_{i,A2V}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.18a}$$

$$q_i^{AC} = q_{i,gen}^{AC} - q_{i,load}^{AC} - q_{i,A2V}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.18b}$$

$$\underline{p}_{i,gen}^{AC} \leq p_{i,gen}^{AC} \leq \overline{p}_{i,gen}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.19a}$$

$$\underline{q}_{i,gen}^{AC} \leq q_{i,gen}^{AC} \leq \overline{q}_{i,gen}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.19b}$$

$$\underline{\left|v_i^{AC}\right|}^2 \leq c_{ii}^{AC} \leq \overline{\left|v_i^{AC}\right|}^2, \quad i \in \mathcal{N}^{AC} \tag{2.20}$$

$$0 \leq p_{i,res}^{AC} \leq \bar{p}_{i,res}^{AC}, \quad i \in \mathcal{N}^{AC} \tag{2.21a}$$

$$-\bar{s}_{i,res}^{AC} \leq \cos\left(\frac{k}{N}\pi\right)p_{i,res}^{AC} + \sin\left(\frac{k}{N}\pi\right)q_{i,res}^{AC} \leq \bar{s}_{i,res}^{AC}, \quad \forall k \in \{1,2,\cdots N\}, \quad i \in \mathcal{N}^{AC} \tag{2.21b}$$

MTDC Constraints:

$$p_j^{MTDC} = \sum_{(j,h)} p_{jh}^{MTDC}, \quad j \in \mathcal{N}^{MTDC}, \quad (j,h) \in \mathcal{L}^{MTDC} \tag{2.22a}$$

$$p_{jh}^{MTDC} + p_{hj}^{MTDC} = r_{jh}^{MTDC}l_{jh}^{MTDC}, \quad (j,h) \in \mathcal{L}^{MTDC} \tag{2.22b}$$

$$u_j^{MTDC} - u_h^{MTDC} = r_{jh}^{MTDC}\left(p_{jh}^{MTDC} - p_{hj}^{MTDC}\right), \quad j,h \in \mathcal{N}^{MTDC}, \quad (j,h) \in \mathcal{L}^{MTDC} \tag{2.22c}$$

$$p_{jh}^{MTDC} \leq l_{jh}^{MTDC}u_j^{MTDC} \quad j \in \mathcal{N}^{MTDC}, \quad (j,h) \in \mathcal{L}^{MTDC} \tag{2.22d}$$

$$\underline{u}_j^{MTDC} \leq u_j^{MTDC} \leq \overline{u}_j^{MTDC}, \quad j \in \mathcal{N}^{MTDC} \tag{2.23}$$

$$p_j^{MTDC} = p_{j,ref}^{MTDC}, \quad j \in \mathcal{N}^{MTDC} \tag{2.24a}$$

$$u_j^{MTDC} = \left(v_{j,ref}^{MTDC}\right)^2, \quad j \in \mathcal{N}^{MTDC} \tag{2.24b}$$

$$p_j^{MTDC} = p_{j,ref}^{MTDC} - \frac{1}{k_{j,droop}^{MTDC}}\left(\frac{1}{2} + \frac{1}{2}u_j^{MTDC} - v_{j,ref}^{MTDC}\right), \quad j \in \mathcal{N}^{MTDC} \tag{2.24c}$$

VSC constraints:

$$p_s^{VSC} = p_{i,A2V}^{AC}, \quad s \in \mathcal{N}^{VSC} \tag{2.25a}$$
$$q_s^{VSC} = q_{i,A2V}^{AC}, \quad s \in \mathcal{N}^{VSC} \tag{2.25b}$$
$$p_s^{VSC} = c_{ss}^{VSC} g_{sf}^{VSC} - c_{sf}^{VSC} g_{sf}^{VSC} + s_{sf}^{VSC} b_{sf}^{VSC}, \quad s, f \in \mathcal{N}^{MTDC} \tag{2.26a}$$
$$q_s^{VSC} = -c_{ss}^{VSC} b_{sf}^{VSC} + c_{sf}^{VSC} b_{sf}^{VSC} + s_{sf}^{VSC} g_{sf}^{VSC}, \quad s, f \in \mathcal{N}^{MTDC} \tag{2.26b}$$
$$c_{sf}^{VSC} = c_{fs}^{VSC}, \quad s, f \in \mathcal{N}^{AC} \tag{2.26c}$$
$$s_{sf}^{VSC} = -s_{fs}^{VSC}, \quad s, f \in \mathcal{N}^{VSC} \tag{2.26d}$$
$$(c_{sf}^{VSC})^2 + (s_{sf}^{VSC})^2 \leq c_{ss}^{VSC} c_{ff}^{VSC}, \quad s, f \in \mathcal{N}^{AC} \tag{2.26e}$$
$$p_c^{VSC} = c_{cc}^{VSC} g_{cf}^{VSC} - c_{cf}^{VSC} g_{cf}^{VSC} + s_{cf}^{VSC} b_{cf}^{VSC}, \quad c, f \in \mathcal{N}^{MTDC} \tag{2.27a}$$
$$q_c^{VSC} = -c_{cc}^{VSC} b_{cf}^{VSC} + c_{cf}^{VSC} b_{cf}^{VSC} + s_{cf}^{VSC} g_{cf}^{VSC}, \quad c, f \in \mathcal{N}^{MTDC} \tag{2.27b}$$
$$c_{cf}^{VSC} = c_{fc}^{VSC}, \quad c, f \in \mathcal{N}^{VSC} \tag{2.27c}$$
$$s_{cf}^{VSC} = -s_{fc}^{VSC}, \quad c, f \in \mathcal{N}^{VSC} \tag{2.27d}$$
$$(c_{cf}^{VSC})^2 + (s_{cf}^{VSC})^2 \leq c_{cc}^{VSC} c_{ff}^{VSC}, \quad c, f \in \mathcal{N}^{VSC} \tag{2.27e}$$
$$q_f^{VSC} = -c_{ff}^{VSC} b_f^{VSC}, \quad f \in \mathcal{N}^{VSC} \tag{2.28}$$
$$p_c^{VSC} + p_{loss}^{VSC} + p_j^{MTDC} = 0, \quad j \in \mathcal{N}^{MTDC}, \quad c \in \mathcal{N}^{VSC} \tag{2.29}$$
$$p_{loss}^{VSC} = a_{loss}^{VSC} + b_{loss}^{\mathrm{V\,S\,C}} \left| I_c^{VSC} \right| + c_{loss}^{VSC} l_c^{VSC}, \quad c \in \mathcal{N}^{VSC} \tag{2.30a}$$
$$0 \leq \left| I_c^{VSC} \right| \leq \left| \overline{I_c^{VSC}} \right|, \quad c \in \mathcal{N}^{VSC} \tag{2.30b}$$
$$0 \leq l_c^{VSC} \leq \left| \overline{I_c^{VSC}} \right|^2, \quad c \in \mathcal{N}^{VSC} \tag{2.30c}$$
$$\left| I_c^{VSC} \right|^2 \leq l_c^{VSC}, \quad c \in \mathcal{N}^{VSC} \tag{2.31a}$$
$$(p_c^{VSC})^2 + (q_c^{VSC})^2 \leq c_{cc}^{VSC} \cdot l_c^{VSC} \quad c \in \mathcal{N}^{VSC} \tag{2.31b}$$
$$c_{ss}^{VSC} = (v_{s,ref}^{VSC})^2, \quad s \in \mathcal{N}^{VSC} \tag{2.32a}$$
$$q_s^{VSC} = q_{s,ref}^{VSC}, \quad s \in \mathcal{N}^{VSC} \tag{2.32b}$$

Goal:

$$\min \sum_i \left\{ c_{i,2}^{AC} \left(p_{i,gen}^{AC} \right)^2 + c_{i,1}^{AC} p_{i,gen}^{AC} + c_{i,0}^{AC} + e_{i,2}^{AC} \left(p_{i,res}^{AC} \right)^2 + e_{i,1}^{AC} p_{i,res}^{AC} + e_{i,0}^{AC} \right\}, \quad i \in \mathcal{N}^{AC} \tag{2.33}$$

- **AC Constraints**: ✓(2.17a)-(2.17g) consist of the second-order cone (SOC) relaxed power flow constraints [4]. ✓(2.18a)-(2.18b) are nodal power balance equations. ✓(2.19a)-(2.19b) are generator power output limits. (2.20) is the squared voltage magnitude limit. ✓(2.21a)-(2.21b) consists of the approximated power output constraint of RESs. Specifically, (2.21b) depicts the use of polygonal approxmiation to represent the originally circular feasible power region.

- **MTDC Constraints**: ✓(2.22a)-(2.22d) consist of the SOC relaxed power flow constraints [5]. ✓(2.23) is the squared voltage magnitude limit. ✓(2.24a)-(2.24c) represents the VSC control mode at DC terminal. Especially, the term v_{ij}^{MTDC} is replaced by the expression with respect to u_{ij}^{MTDC} in (2.24c), through Talyor expansion. Note that for (2.24a)-(2.24c), only one of them holds depending on the chosen control model.

- **VSC Constraint**: ✓(2.25a)-(2.25b) are the active and reactive power couplings between the AC grid and VSC. ✓(2.26a)-(2.26e) consist of the SOC relaxed active and reactive power injections from the view of node s.✓(2.27a)-(2.27e) consist of the SOC relaxed active and reactive power injections from the view of node c. ✓(2.28) is the reactive power injection from the view of node f. ✓(2.29) is the active power coupling between the MTDC grid and VSC. ✓(2.30a)-(2.30c) are related to the converter loss function. ✓(2.31a)-(2.31b) consist of the SOC relaxed voltage and current relationship from the view of node c. ✓(2.32a)-(2.32b) represent the VSC control mode at AC PCC. Note that only one of them is hold depending on the chosen control model.

- **Goal**: ✓(2.33) represent minimizing power generation costs.

3 Code Implementation

3.1 Data preparation

The data required for AC/DC OPF includes the fundamental data of the interconnected AC grids and the fundamental data of the MTDC grid, which are listed and shown in Fig. 3.1. All data are stored in .CSV files due to its compatibility with various language environments.

Users can manually fill in power grid parameters into respective .CSV files based on their specific needs. Below we present the details regarding the respective .CSV. The style of the saved data in .CSV is basically consistent with mpc structure used in Matpower[3] and MatACDC[4].




Figure 3.1: Required power grid data sheet

For the DC grid, the required fundamental data files includes `baseMW_dc.csv`, `pol_dc.csv`, `bus_dc.csv`, `branch_dc.csv`, `branch_dc.csv`. In the file, each column of the data corresponds to a parameter item. A specific rule needs to be followed when saving data into these files. The details about parameter items and descriptions of DC grid data files can be found in Table 1, 2, 3, 4, 5. Note that in `bus_dc.csv` and `branch_dc.csv` files, some parameter items may appear to be meaningless but serve as placeholders to maintain the same format style with the well-known Matpower.

For the AC grid, the required fundamental data files includes `baseMVA_ac.csv`, `bus_ac.csv`, `branch_ac.csv`, `gen_ac.csv`, `gencost_ac.csv`, `res_ac.csv`. The details about parameter items

[3]MATPOWER Manual
[4]MatACDC Manual

and descriptions of AC grid data files can be found in Table 6, 7, 8, 27, 28, 29. Matpower provides various AC grid case files. Sometimes, users may want to directly select and integrate multiple AC grids without manually modifying data files. To facilitate this process, we provide auxiliary functions `merge_ac` and `save_csv`. User can build up Matlab script as below.

```
mpc_merged = merge_ac('case9','case14'); % merge_ac('case_a','case_b','...')
% If no path is provided, saved in the current path.
save_csv(mpc_merged, directory);
```

After running the script, users can name the prefix of the series of .CSV filenames related to ac grids and directly type it. Finally, save information is shown in command window, like blow.

```
>> Reordered bus IDs for case9
>> Reordered bus IDs for case14
>> Enter a prefix for the CSV filenames: ac9ac14
>> Merged AC grid data has already been saved to:
>> D:\acdcopf\Tests\ac9ac14_baseMVA_ac.csv
>> D:\acdcopf\Tests\ac9ac14_bus_ac.csv
>> D:\acdcopf\Tests\ac9ac14_gen_ac.csv
>> D:\acdcopf\Tests\ac9ac14_branch_ac.csv
>> D:\acdcopf\Tests\ac9ac14_gencost_ac.csv
```

Column	Parameters	Description [Unit]
1	baseMW	Base power capacity [MW].

Table 1: baseMW_dc.csv file

Column	Parameters	Description [Unit]
1	pol	Number of poles (1=monopolar grid, 2=bipolar grid) [-].

Table 2: pol_dc.csv file

Column	Parameters	Description [Unit]
1	bus_i	Bus number [-].
2	—	N/A.
3	Pd	Active power loads [MW].
4	—	N/A.
5	—	N/A.
6	—	N/A.
7	—	N/A.
8	—	N/A.
9	—	N/A.
10	baseKV	Bus voltage level [kV].
11	—	N/A.
12	Vmax	Maximum bus voltage magnitude [p.u.].
13	Vmin	Minimum bus voltage magnitude [p.u.].

Table 3: bus_dc.csv file

Column	Parameters	Description [Unit]
1	fbus	From bus index [-].
2	tbus	To bus index [-].
3	r	Branch resistance [p.u.].
4	—	N/A.
5	—	N/A.
6	—	N/A.
7	—	N/A.
8	—	N/A.
9	—	N/A.
10	—	N/A.
11	—	N/A.
12	—	N/A.
13	—	N/A.

Table 4: branch_dc.csv file

Column	Parameters	Description [Unit]
1	busdc_i	Converter-connected DC bus index [-].
2	busac_i	Converter-connected AC bus index [-].
3	gridac	AC grid number of which converter belongs [-].
4	type_dc	Converter DC-side control modes (1=Constant DC power control, 2=Constant DC voltage control, 3=DC droop control) [-].
5	type_ac	Converter AC-side control modes (1=Constant AC voltage control, 2=Constant reactive power control) [-].
6	P_g	Setting of the active power output of converter DC terminal (applicable to the constant DC power control) [MW].
7	Q_g	Setting of the reactive power output of converter PCC bus (applicable to the constant reactive power control [MVAr].
8	Vtar	Setting of the voltage amplitude of converter DC terminal (applicable to the constant DC voltage control) [p.u.].
9	rtf	Resistance of the converter transformer [p.u.].
10	xtf	Reactance of the converter transformer [p.u.].
11	bf	Conductance of the converter filter [p.u.].
12	rc	Resistance of the converter Phase reactor [p.u.].
13	xc	reactance of the converter Phase reactor [p.u.].
14	basekVac	Base voltage of the converter AC side [p.u.].
15	Vmmax	Maximum voltage magnitude of the converter AC side [p.u.].
16	Vmmin	Minimum voltage magnitude of the converter AC side [p.u.].
17	Imax	Maximum current magnitude of the converter [p.u.].
18	status	Converter status (1=in service, 0=out of service) [p.u.].
19	LossA	Constant loss coefficient [MW].
20	LossB	Linear loss coefficient [kV].
21	LossCR	Rectifier quadratic loss coefficient [Ω].
22	LossCI	Inverter quadratic loss coefficient [Ω].

Table 5: conv_dc.csv file

Column	Parameters	Description [Unit]
1	baseMVA	Base power capacity [MVA].

Table 6: baseMVA_ac.csv file

Column	Parameters	Description [Unit]
1	bus_i	Bus number [-].
2	type	Bus type (3=Slack, 2=PV, 1=PQ) [-]
3	Pd	Active power loads [MW].
4	Qd	Reactive power loads [MVAr].
5	Gs	Shunt conductance (at V=1.0 p.u.) [MW].
6	Bs	Shunt susceptance (at V=1.0 p.u.) [MVAr].
7	area	Area number [-].
8	Vm	Reactive power loads [p.u.].
9	Va	Reactive power loads [drgrees].
10	baseKV	Bus voltage level [kV].
11	zone	Loss zone [-].
12	Vmax	Maximum bus voltage magnitude [p.u.].
13	Vmin	Minimum bus voltage magnitude [p.u.].

Table 7: bus_ac.csv file

Column	Parameters	Description [Unit]
1	fbus	From bus index [-].
2	tbus	To bus index [-].
3	r	Branch resistance [p.u.].
4	x	Branch reactance [p.u.].
5	b	Line charging susceptance [p.u.].
6	rateA	Rate A (MVA limit for normal operation) [MVA].
7	rateB	Rate B (MVA limit for short-term) [MVA].
8	rateC	Rate C (MVA limit for emergency) [MVA].
9	ratio	Transformer tap ratio (if applicable) [-].
10	angle	Transformer phase shift angle [degrees].
11	status	Line status (1=active, 0=out-of-service) [-].
12	angmin	Minimum voltage angle difference [degrees].
13	angmax	Maximum voltage angle difference [degrees].

Table 8: branch_ac.csv file

Column	Parameters	Description [Unit]
1	bus	Generator's bus number [-].
2	Pg	Active power output [MW].
3	Qg	Reactive power output [MVAr].
4	Qmax	Maximum reactive power output [MVar].
5	Qmin	Minimum reactive power output [MVar].
6	Vg	Voltage magnitude setpoint [p.u.].
7	mBase	Total MVA base of generator [MVA].
8	status	Generator status (1=in service, 0=out of service) [-].
9	Pmax	Maximum active power output [MW].
10	Pmin	Minimum active power output [MW].
11	Pc1	lower real power output of PQ capability curve [MW].
12	Pc2	upper real power output of PQ capability curve [MW].
13	Qc1min	Minimum reactive power output at Pc1 [MVar].
14	Qc1max	Maximum reactive power at Pc1 [MVar].
15	Qc2min	Minimum reactive power at Pc2 [MVar].
16	Qc2max	Maximum reactive power at Pc2 [MVar].
17	ramp_agc	Ramp rate for automatic generation control [MW/min].
18	ramp_10	Ramp rate for 10-minute reserves [MW].
19	ramp_30	Ramp rate for 30-minute reserves [MW].
20	ramp_q	Ramp rate for reactive power [MVar/min].
21	apf	Area participation factor [-].

Table 9: gen_ac.csv file

Column	Parameters	Description [Unit]
1	bus	Cost function type(1=piecewise, 2=polynomial) [-].
2	startup	Startup cost [$].
3	shuntdown	Shutdown cost [$].
4	n	Number of data points (if piecewise linear) or order of polynomial [$].
5	cost	Coefficients of polynomial (from hgithest to lowest order) or piecewise data points.

Table 10: gencost_ac.csv file

Column	Parameters	Description [Unit]
1	bus	Generator's bus number [-].
2	Presmax	Maximum available active power [MW].
3	Sresmax	Maximum apparent power [MVA].
4	bus	Cost function type (1=piecewise, 2=polynomial) [-].
5	startup	Startup cost [$].
6	shuntdown	Shutdown cost [$].
7	n	Number of data points (if piecewise linear) or order of polynomial [$].
8	cost	Coefficients of polynomial (from highest to lowest order) or piecewise data points.

Table 11: res_ac.csv file

3.2 Parameter processing

Language-specific functions `create_ac` and `create_dc` reads .csv file data related to the interconnected AC grids and the MTDC grid. Depending on the programming environment, different handling approaches are used to read and organize these .csv files, as listed in Table 12.

Table 12: .CSV File Data Handling Approaches Across Programming Languages

Language	Read .csv Files	Transformed Data Structure
Matlab	`readmatrix` (built-in)	Uses a `struct` where each field name maps to a numeric matrix or a scalar.
Python	`pandas.read_csv`	Uses a `dict` where each string key maps to a `NumPy` array or a scalar.
Julia	`CSV.File` + `DataFrame`	Uses a `Dict{String, Any}` where each string key maps to a numeric array or a scalar.
Cpp	`ifstream` + `csv_reader` (custom)	Uses an `unordered_map<std::string, Eigen::MatrixXd>` where each string key maps to an `Eigen` matrix.

Subsequently, language-specific functions `params_ac` and `params_dc` are further utilized to extract the essential and critical parameters required for constructing the AC/DC OPF model. During this process, different language-specific conventions are adopted to define one-dimensional, two-dimensional, and three-dimensional parameters, which are listed in Table 13.

Table 13: Parameter Defining Across Programming Languages

Language	1D Parameter (`fbus_dc`, `nbuses_ac`, etc.)	2D Parameter (`bus_dc`, `pd_ac`, etc.)	3D Parameter (`bus_entire_ac`, etc.)
Matlab	`vector`/`x(i)`, `cell`/`x{n}`	`matrix`/`x(i, j)`, `cell`/`x{n}(i)`	`cell`/`x{n}(i, j)`
Python	`np.ndarray`/`x[i]`, `list`/`x[n]`	`np.ndarray`/`x[i, j]`, `list`/`x[n][i]`	`list`/`x[n][i, j]`
Julia	`Vector`/`x[i](x[n])`	`Matrix`/`x[i, j]`, `Vector`/`x[n][i]`	`Vector`/`x[n][i, j]`
Cpp	`Eigen::Vector`/`x(i)`, `std::vector`/`x[i]`	`Eigen::Matrix`/`x(i, j)`, `std::vector`/`x[n](i)`	`std::vector`/`x[n](i, j)`

★ The mark means `type`/`syntax`

3.3 Variable definition

The core OPF solver can be found in `solve_opf`, where the AC/DC OPF model is formulated and solved. **ACDC-OpFlow** formulates AC/DC OPF model as a SOCP problem, which has been presented in Section 2.3.

In implementations across Matlab, Python, Julia, and Cpp, **ACDC-OpFlow** utilizes Gurobi, a powerful convex optimization solver that supports SOCP solving and offers academic licenses free of charge for research and educational use[5], as the unified solver backend. To facilitate AC/DC OPF modelling and solver invocation, **ACDC-OpFlow** integrates each language with a widely adopted modelling framework and corresponding solver interface. Table 14 summarizes the dependencies used for optimization in each programming environment.

Table 14: Optimization Modeling Dependencies Across Programming Languages

Language	**Dependencies (functionalities)**
Matlab	YALMIP[6] (modeling interface + solver bridge)
Python	Pyomo[7] (modeling interface) + gurobipy (solver bridge)
Julia	JuMP[8] (modeling interface) + Gurobi.jl (solver bridge)
Cpp	Gurobi C++ API[9] (modeling interface + solver interface)

To further support the optimization modeling, each implementation explicitly defines optimization decision variables in compatible formats with each modeling framework, as shown in Table 15.

Table 15: Optimization Variable Definition Across Languages

Language	**Define Variables**
Matlab	`sdpvar(...)`
Python	`Var(..., domain = Reals)`
Julia	`@variable(model, ...)`
Cpp	`model.addVar(..., GRB_CONTINUOUS)`

Similar to parameter definition, optimization variable definition also conforms to language-specific conventions, and the summary of representative expressions for defining one-dimensional, two-dimensional, and three-dimensional variables in each language environment are listed below:

```
%% Variable Defining in Matlab via YALMIP

% 1D Variable (e.g., vn2_dc)
  vn2_dc = sdpvar(nbuses_dc, 1);
% 2D Variable (e.g., pij_dc)
  pij_dc = sdpvar(nconvs_dc, nconvs_dc, 'full');
% 2D Variable (e.g., vn2_ac)
  vn2_ac = cell(ngrids, 1);
  for ng = 1:ngrids
```

[5] https://www.gurobi.com/academia/academic-program-and-licenses/
[6] https://yalmip.github.io/
[7] https://www.pyomo.org/
[8] https://jump.dev/
[9] https://docs.gurobi.com/projects/optimizer/en/current/reference/cpp.html

```
      vn2_ac{ng} = sdpvar(nbuses_ac{ng}, 1);
end
% 3D Variable (e.g., pij_ac)
  pij_ac = cell(ngrids, 1);
  for ng = 1:ngrids
      pij_ac{ng} = sdpvar(nbuses_ac{ng}, nbuses_ac{ng}, 'full');
end
```

```
# Variable definition in Python via Pyomo

# 1D variable (e.g., vn2_dc)
  model.vn2_dc = Var(range(nbuses_dc), domain=Reals)
# 2D variable (e.g., pij_dc)
  model.pij_dc = Var(range(nbuses_dc), range(nbuses_dc), domain=Reals)
# 2D variable (e.g., vn2_ac)
  model.vn2_ac = Var(
      [(ng, i) for ng in range(ngrids) for i in range(nbuses[ng])],
      domain=Reals)
# 3D variable (e.g., pij_ac)
  model.pij_ac = Var(
      [(ng, i, j) for ng in range(ngrids) for i in range(nbuses[ng]) for j in
      ↪  range(nbuses[ng])],
      domain=Reals)
```

```
# Variable Definition in Julia via JuMP

# 1D Variable (e.g., vn2_dc)
  vn2_dc = @variable(model, [1:nbuses_dc])
# 2D Variable (e.g., pij_dc)
  @variable(model, pij_dc[1:nbuses_dc, 1:nbuses_dc])
# 2D Variable (e.g., vn2_ac)
  vn2_ac = Vector{Vector{JuMP.VariableRef}}(undef, ngrids)
  for ng in 1:ngrids
      vn2_ac[ng] = @variable(model, [1:nbuses_ac[ng]])
  end
# 3D Variable (e.g., pij_ac)
  pij_ac = Vector{Matrix{JuMP.VariableRef}}(undef, ngrids)
  for ng in 1:ngrids
      pij_ac[ng] = @variable(model, [1:nbuses_ac[ng], 1:nbuses_ac[ng]])
  end
```

```
// Variable Definition in Cpp via Gurobi Cpp API

// 1D Variable (e.g., vn2_dc)
  Eigen::Matrix<GRBVar, Eigen::Dynamic, 1> vn2_dc(nbuses_dc);
  for (int i = 0; i < nbuses_dc; ++i) {
```

```
      vn2_dc(i) = model.addVar(-GRB_INFINITY, GRB_INFINITY, 0.0, GRB_CONTINUOUS);
  }
// 2D Variable (e.g., pij_dc)
  Eigen::Matrix<GRBVar, Eigen::Dynamic, Eigen::Dynamic> pij_dc(nbuses_dc, nbuses_dc);
  for (int i = 0; i < nbuses_dc; ++i) {
      for (int j = 0; j < nbuses_dc; ++j) {
          pij_dc(i, j) = model.addVar(-GRB_INFINITY, GRB_INFINITY, 0.0,
          ↪ GRB_CONTINUOUS);
      }
  }
// 2D Variable (e.g., vn2_ac)
  std::vector<Eigen::Matrix<GRBVar, Eigen::Dynamic, 1>> vn2_ac(ngrids);
  vn2_ac[ng].resize(nbuses_ac[ng]);
  for (int i = 0; i < nbuses_ac[ng]; ++i) {
      vn2_ac[ng](i) = model.addVar(-GRB_INFINITY,  GRB_INFINITY, 0.0, GRB_CONTINUOUS);
  }
// 3D Variable (e.g., pij_ac)
  std::vector<Eigen::Matrix<GRBVar, Eigen::Dynamic, Eigen::Dynamic>> pij_ac(ngrids);
  pij_ac[ng] = Eigen::Matrix<GRBVar, Eigen::Dynamic, Eigen::Dynamic>(nbuses_ac[ng],
  ↪ nbuses_ac[ng]);
  for (int i = 0; i < nbuses_ac[ng]; ++i) {
      for (int j = 0; j < nbuses_ac[ng]; ++j) {
          pij_ac[ng](i, j) = model.addVar(-GRB_INFINITY, GRB_INFINITY, 0.0,
          ↪ GRB_CONTINUOUS);
      }
  }
```

3.4 Constraint construction

Each implementation explicitly adds operational constraints in compatible formats with each modeling framework, as shown in Table 16. Next, we will take the addition of SOC-based DC power flow constraints as an example to present code snippets under different implementations more specifically.

Table 16: Constraint Construcution Across Languages

Language	Constraints Construction
Matlab	`Cons = [Cons; expr]`
Python	`model.Constraint = Constraint(expr)`
Julia	`@constraint(model, expr)`
Cpp	`model.addConstr(expr)` (for linear constraints), `model.addQConstr(expr)` (for SOC constraints)

```m
%% Constraint Construction in Matlab via YALMIP, with vectorized formulation.

% --- DC Power Flow Constraints (Second-Order Cone Relaxation) ---
zij_dc = 1./abs(ybus_dc);
zij_dc = zij_dc-diag(diag(zij_dc));
zij_dc(isinf(zij_dc)) = 1e4;

con_dc = [con_dc;
    pn_dc == sum(pij_dc, 2) * pol_dc;
    pij_dc + pij_dc' == zij_dc .* lij_dc;
    repmat(vn2_dc, 1, nbuses_dc) - repmat(vn2_dc', nbuses_dc, 1) == zij_dc .* (pij_dc - pij_dc');
    pij_dc.^2 <= lij_dc .* repmat(vn2_dc, 1, nbuses_dc);
    vn2_dc >= 0;
    lij_dc >= 0];
```

```python
# Constraint Construction in Python via Pyomo, with for-loop formulation.

model.addconstraints = ConstraintList()
# ------------------------------
# DC Power Flow Constraints (Second-Order Cone Relaxation)
# ------------------------------
zij_dc = 1.0 / np.abs(ybus_dc.toarray())
zij_dc = zij_dc - np.diag(np.diag(zij_dc))
zij_dc[np.isinf(zij_dc)] = 1e4

for i in range(nbuses_dc):
    model.addconstraints.add(model.pn_dc[i]  == pol_dc * sum(model.pij_dc[i, j] for j in range(nbuses_dc)))
    model.addconstraints.add(model.vn2_dc[i] >= 0)
    for j in range(nbuses_dc):
        model.addconstraints.add(model.pij_dc[i, j] + model.pij_dc[j, i] == zij_dc[i, j] * model.lij_dc[i, j])
        model.addconstraints.add(model.vn2_dc[i] - model.vn2_dc[j] == zij_dc[i, j] * (model.pij_dc[i, j] - model.pij_dc[j, i]))
        model.addconstraints.add(model.pij_dc[i, j]**2 <= model.lij_dc[i, j] * model.vn2_dc[i])
        model.addconstraints.add(model.lij_dc[i, j] >= 0)
```

```julia
# Constraint Construction in Julia via JuMP, with vectorized formulation.

# ------------------------------
# DC Power Flow Constraints (Second-Order Cone Relaxation)
# ------------------------------
zij_dc = 1.0 ./ abs.(ybus_dc)
zij_dc = zij_dc .- Diagonal(diag(zij_dc))
zij_dc[isinf.(zij_dc)] .= 1e4
```

```julia
@constraint(model, pn_dc .== pol_dc * sum(pij_dc, dims=2))
@constraint(model, pij_dc .+ pij_dc' .== zij_dc .* lij_dc)
@constraint(model, vn2_dc .- vn2_dc' .== zij_dc .* (pij_dc .- pij_dc'))
@constraint(model, pij_dc.^2 .<= lij_dc .* repeat(vn2_dc, 1, nbuses_dc))
@constraint(model, vn2_dc .>= 0)
@constraint(model, lij_dc .>= 0)
```

```cpp
// Constraint Construction in Cpp via Gurobi Cpp API, with for-loop formulation.

// 1. Constrains for dc power flow - second-order cone relaxation
Eigen::MatrixXd y_dc_dense = Eigen::MatrixXd(y_dc);
Eigen::MatrixXd zij_dc = y_dc_dense.array().abs().cwiseInverse().matrix();
zij_dc -= zij_dc.diagonal().asDiagonal();
for (int i = 0; i < zij_dc.rows(); ++i) {
    for (int j = 0; j < zij_dc.cols(); ++j) {
        if (std::isinf(zij_dc(i, j))) {
            zij_dc(i, j) = 1e4;
        }
    }
}

for (int i = 0; i < nbuses_dc; ++i) {
    GRBLinExpr power_flow_sum = 0.0;
    for (int j = 0; j < nbuses_dc; ++j) {
        power_flow_sum += pij_dc(i, j);
    }
    model.addConstr(pn_dc(i) == power_flow_sum * pol_dc);
}

for (int i = 0; i < nbuses_dc; ++i) {
    for (int j = 0; j < nbuses_dc; ++j) {
        model.addConstr(pij_dc(i, j) + pij_dc(j, i) == zij_dc(i, j) * lij_dc(i, j));
        model.addQConstr(pij_dc(i, j) * pij_dc(i, j) <= lij_dc(i, j) * vn2_dc(i));
        model.addConstr(vn2_dc(i) - vn2_dc(j) == zij_dc(i, j) * (pij_dc(i, j) -
        ↪  pij_dc(j, i)));
    }
}

for (int i = 0; i < nbuses_dc; ++i) {
    model.addConstr(vn2_dc(i) >= 0.0);
    for (int j = 0; j < nbuses_dc; ++j) {
        model.addConstr(lij_dc(i, j) >= 0.0);
        }
}
```

4 Examples

4.1 Running a case

Matlab, Python, Julia, and Cpp follows a unified running process. As mentioned earlier, before running the AC/DC OPF, we need to prepare the required .CSV files to save the parameter data related to interconnected AC grids and the MTDC grid. In each programming language, users can execute AC/DC OPF through the code snippet as below.

```
solve_opf('mtdc3slack_a', 'ac9ac14',
          'vscControl', true,
          'writeTxt', false,
          'plotResult', true)
```

Noted that in `solve_opf()`, besides attributes `'matdc3slack_a'` and `'ac9ac14'`, which respectively represent the case name of MTDC grid and interconnected AC grids, there are three additional attributes: `'vscControl'`, `'writeTxt'`, and `'plotResult'` need to be set:

- `'vscControl'` is used to determine if the VSC control constraints formulated as (2.24a)-(2.24c) and (2.32a)-(2.32b) are activated. Its default setting is `true` means the VSC control constraints need to be added into the formed AC/DC OPF model, and the control settings are pre-defined in the imported `conv_dc.csv` file. When the VSC control mode is considered to be optimized, it should not be pre-specified. `'vscControl'` should be set to `false`, which means that (2.24a)-(2.24c) and (2.32a)-(2.32b) are excluded from the formed AC/DC OPF model.

- `'writeTxt'` is used to determine whether the printed AC/DC OPF results shown in Fig. 4.1 should be saved as a text file. By default, it is set to `false`, and no .txt file will be generated. If set to `true`, a .txt file named `opf_result.txt` will be produced in the current working directory. Regardless of whether `'writeTxt'` is set to `true` or `false`, the textual results shown in Fig. 4.1 will always be printed to the terminal window.

Figure 4.1: Printed AC/DC OPF text.

```
================================================================================================
|     AC Grid Bus Data                                                                         |
================================================================================================
 Area   Branch  Voltage        Generation              Load                    RES
 #      #       Mag [pu]    Pg [MW]   Qg [MVAr]   Pd [MW]   Qd [MVAr]   Pres [MW]  Qres [MVAr]
-----  -------  --------   --------   ---------   -------   ---------   ---------  -----------
   1       1     1.046*    87.560     118.622      0.000       0.000        -           -
   1       2     1.094    134.532     299.997      0.000       0.000        -           -
   1       3     1.037     93.126      91.777      0.000       0.000        -           -
   1       4     1.009        -           -        0.000       0.000        -           -
   1       5     1.000        -           -       90.000      30.000     40.000       -8.082
   1       6     1.016        -           -        0.000       0.000        -           -
   1       7     1.002        -           -      100.000      35.000        -           -
   1       8     1.015        -           -        0.000       0.000        -           -
   1       9     0.983        -           -      125.000      50.000        -           -
   2       1     1.053*   168.897       5.726      0.000       0.000     35.000        8.989
   2       2     1.027     32.396      26.193     21.700      12.700        -           -
   2       3     0.990      0.000      25.297     94.200      19.000        -           -
   2       4     0.997        -           -       47.800      -3.900        -           -
   2       5     1.000        -           -        7.600       1.600        -           -
   2       6     1.042      0.000      21.712     11.200       7.500        -           -
   2       7     1.034        -           -        0.000       0.000        -           -
```

```
  2      8     1.060      0.000     15.435      0.000       0.000        -          -
  2      9     1.028        -         -        29.500      16.600       -          -
  2     10     1.023        -         -         9.000       5.800       -          -
  2     11     1.029        -         -         3.500       1.800       -          -
  2     12     1.027        -         -         6.100       1.600       -          -
  2     13     1.022        -         -        13.500       5.800       -          -
  2     14     1.007        -         -        14.900       5.000       -          -
-----   -----   --------   --------   ---------   -------   ---------   ---------  -----------
The total generation cost is $10815.00/MWh(€10013.89/MWh)

... ... (omitted)

================================================================
|     MTDC Branch Data                                         |
================================================================
Branch  From   To     From Branch    To Branch      Branch Loss
#       Bus#   Bus#   Flow Pij [MW]  Flow Pij [MW]  Pij_loss [MW]
------  -----  -----   ---------      ---------      --------
    1      1      2      31.986        -31.724         0.262
    2      2      3       7.281         -7.268         0.014
    3      1      3      28.014        -27.732         0.282
------  -----  -----   ---------      ---------      --------
The totoal DC network losses is 0.557 MW .

Execution time is 5.295s .
```

- `'plotResult'` is used to determine whether the visualization of AC/DC OPF results, as shown in Fig. 4.2, is enabled. By default, it is set to `true`, and the corresponding plots will be generated automatically. Such visualizations provide intuitive insights into system-wide power flow. In some cases, the system size is relatively large, and the visualization may become cluttered due to the excessive amount of information displayed. Fortunately, the plotting tools used in each programming languages are interactive and support zooming, allowing users to focus on specific regions of interest. Of course, if the user is not interested in visualization, setting `'plotResult'` to `false` will disable plotting outputs.

4.2 Benchmark

4.2.1 Performance comparison

To compare programming languages, benchmark scripts were developed. The test cases consistently used the same three-terminal MTDC grid case `'mtdc3slack'` a combined with four representative interconnected AC grid cases from small to large scales that are: `'ac9ac14'`, `'ac14ac57'`, `'ac57ac118'`, and `'ac118ac300'`. For all experiments, each was executed five times per test case and with three warmup trial runs to avoid the effect of just-in-time (JIT) compilation and delayed code execution due to memory caching.

Execution time and memory allocation were stored for each execution, and a post-execution process was carried out to compute median values from the results. In the case of Julia, run time was recorded using the `@elapsed` macro provided in the `BenchmarkTools.jl` package, while memory allocations were tracked at the systems level by observing process monitoring. Julia utilized a separate, although framework-based dictionary, dependent on grid modeling but also leveraged modular, very high-performance versions of the algorithms. For Python runtime, `time.time()` was used and memory by using the `psutil` library to return the resident set size (RSS). The Python benchmark script was made to accommodate missing input files, should there be a case of non-completion.

Cpp performance benchmarks used the high-resolution `std::chrono` clock for timing, while memory measurements came from `GetProcessMemoryInfo()` on Windows. Cpp was also in an




Figure 4.2: Visualization of AC/DC OPF results across programming languages. The size of ● is proportional to the AC load level. The size of ● is proportional to the AC generator power level. The size of ● is proportional to the AC RES power level. The color intensity of ▭ indicates the branch power level.

object-oriented context with custom memory stuff to reduce dynamic allocations. Matlab used `tic` and `toc` to measure execution time and had a custom `et_memory_usage()` method to track memory and invoke garbage collection every run. To make sure memory use was consistent every run, the benchmark had to invoke a pause for a few seconds to get consistent memory states. All implementations run in the same benchmarking environment to give a fair and consistent comparison across languages. The statistics collected, therefore, included median run time, run time variation (min-max), peak memory usage, and relative memory use normalized against the smallest test case as the baseline for each language.

The benchmarking results are summarized in Table 17. For each case, we report the median execution time, run-time range, peak memory usage, and relative memory usage normalized to the smallest test case within each language.

4.2.2 Discussion

The results indicate striking variations in execution time and memory consumption between implementations.

Runtime:

- Across the benchmarked cases, Julia consistently had the fastest execution times. For example, in the largest case, `'ac118ac300'`, Julia was the only language to return a solution in seconds (4.446 s), outperforming Cpp (38.431 s), Python (35.976 s), and especially Matlab (not computed successfully within an hour). Julia's position was also aided by the use

Table 17: Benchmark Results Summary Across Programming Languages

Case	Language	Time (s)	Time Range (s)	Memory (MB)	Rel. Mem.
ac9ac14 +mtdc3slack_a	Matlab	7.673	7.611–7.732	0.1	1.0x
	Cpp	0.139	0.133–0.142	0.0	0x
	Julia	0.055	0.052–0.072	0.1	1.0x
	Python	0.138	0.127–0.182	1.7	17.0x
ac14ac57 +mtdc3slack_a	Matlab	157.353	154.715–166.027	5.3	0.14x
	Cpp	1.780	1.478–2.365	0.5	0.013x
	Julia	0.233	0.202–0.940	36.8	1.0x
	Python	1.014	0.997–1.054	2.4	0.07x
ac57ac118 +mtdc3slack_a	Matlab	177.273	92.259–245.281	14.9	0.12x
	Cpp	3.464	3.299–4.056	0.8	0.006x
	Julia	0.799	0.783–0.821	129.4	1.0x
	Python	5.063	4.977–5.240	2.6	0.02x
ac118ac300 +mtdc3slack_a	Matlab	-	-	-	-
	Cpp	38.431	37.126–38.924	0.5	0x
	Julia	4.446	4.353–5.343	537.7	1.0x
	Python	35.976	28.344–96.248	1.9	0.003x

★ The case ac118ac300+mtdc3slack_a is not computed successfully in MATLAB

of JIT compilation, type stability, and fast numerical computing libraries that are heavily optimized.

- Cpp had particularly strong and consistent performance, as it was often ranked second in execution time to Julia with sometimes very small margins. For example, Cpp solved `'ac14ac57'` in 1.780 s and `'ac57ac118'` in 3.464 s, indicating an ability to scale with the larger case. While Cpp may not be capable of the peak performance that Julia demonstrated, it still represented a large improvement over Matlab and Python, in particular, the larger cases.

- Python had more mixed performance. For some of the smaller cases like `'ac9ac14'`, it performed reasonably well (0.138 s, similar to Cpp) but for larger problems like `'ac57ac118'`, its performance suffered 5.063 s but still much better than Matlab). Overall, this suggests that Python could return competitive performance when appropriately optimized but also suffers from the overheads of being interpreted and dynamically typed languages.

- Matlab consistently had the slowest execution times, taking 7.673 s for `'ac9ac14'` and up to 177.273 s for `'ac57ac118'`. Although Matlab offers a high-level and user-friendly interface for numerical computing, it is not optimized for large-scale, real-time OPF problems, compared to compiled or JIT-compiled languages.

Memory Usage:

- Cpp had the lowest memory use in the benchmarks, achieving 0.0MB on `'ac9ac14'` and only 0.8 MB on `'ac57ac118'`. Cpp's efficiency in memory usage can be attributed to its manual control and low overhead, making it a great option for embedded or constrained environments.

- Matlab also achieved low memory usage of 0.1 MB or small cases, and up to 14.9 MB for `'ac57ac118'`. These values show that, while executing slowly, Matlab uses in-place operations and other efficient numerical operations to limit memory usage.

- Python had reasonable and moderate memory usage, between 1.7 MB on `'ac9ac14'` and 2.6 MB on `'ac57ac118'`. However, for the small case calls, its relative memory use was at the high end due likely to either run-time overhead from Python itself or memory overhead to include references to external libraries (i.e. `numpy`, or, `pandas` etc.).

- In the larger cases, Julia consumed the most memory during execution. For example, the largest call (`'ac57ac118'`) was finished using 129.4 MB, and the second largest (`'ac118ac300'`) finished with 537.7 MB. This likely reflects its design choice to have more memory used to enable faster execution speed and array "fusion". This is generally fine in high-performance computing, as long as the overall needs of memory consumption remain low and adequate overall.

Scalability:

- The scalability of Julia was noted to be very impressive since execution times increased sub-linearly, from 0.055 s for `'ac9ac14'` to 0.799 s for `'ac57ac118'`, and 4.446 s for `'ac118ac300'`, the largest case. This shows that Julia is very robust and is quite appropriate for large-scale AC/DC OPF problems or even for real-time applications.

- The scalability of Cpp was also very strong. Times grew from 0.139 s for `'ac9ac14'` to 3.464 s for `'ac57ac118'`, and 38.431 s for `'ac118ac300'`. This projection is enhanced because of the compile-time optimizations and low-level control Cpp enables to increase speed. However, with this comes a higher level of complexity to develop.

- The scalability for Python was reasonable. However, there was too much variability in run time as the size of the system increased—the largest case,`'ac57ac118'`, had running times range from 28.344 s to 96.248 s, which influenced background overhead and behaviour of the number of libraries.

- Beyond time, Matlab did not scale significantly. It was not able to complete the largest case `'ac118ac300'`, and the response time for the mid-size cases `'ac14ac57'` (157.353 s) and `'ac57ac118'` (177.273 s) had large increases in execution time. This demonstrates that Matlab is not suitable for large-scale optimization still making it a better alternative in prototyping scenarios and for educational purposes.

A Additional Discussion

A.1 Power flow accuracy

ACDC-OpFlow takes the convex relaxed power flow constraints for future model expansion. One major advantage is that it preserves the convexity of the OPF model, enabling the potential integration of DC topology reconfiguration as a tractable mixed-integer convex optimization problem. Naturally, the downside is a potential loss in power flow calculation accuracy. Taking Fig. A.1 as an example, we provide an intuitive comparison between the power flow results obtained using the standard power flow calculation method (from MATACDC) and those derived from the convex-scaled approach (from **ACDC-OpFlow**).

The comparison results are listed in Tables 18-26. We can observe that in SOC relaxed power flow models, the calculation of nodal voltage is generally more accurate than that of branch power flows. This is because SOC relaxations directly approximate the quadratic voltage magnitude relationships using convex constraints, which tend to preserve voltage-related variables more reliably. In contrast, branch power flows involve nonlinear combinations of voltages and angles, and their SOC-relaxed representations often introduce greater approximation errors [6],[7].




Figure A.1: Simple test system from MATACDC. The AC system is from `"case5_stagg"` and MTDC system is from `"case5_stagg_MTDCslack"`.

Table 18: Comparison of AC Node Voltage

AC Node	Node Voltage [p.u.]		Aboslute Error [p.u.]
	ACDC-OpFlow	MATACDC	
#1	1.06	1.06	0
#2	1	1	0
#3	1	1	0
#4	0.996	0.996	0
#5	0.99	0.991	0.001

Table 19: Comparison of DC Node Voltage

DC Node	Node Voltage [p.u.]		Aboslute Error [p.u.]
	ACDC-OpFlow	MATACDC	
#1	1.008	1.008	0
#2	1	1	0
#3	0.998	0.998	0

Table 20: Comparison of AC Branch Power

AC Branch	Branch Power [MW]		Aboslute Error [MW]
	ACDC-OpFlow	MATACDC	
#1	98.848	98.38	0.468
#2	34.699	35.26	0.561
#3	12.471	13.25	0.779
#4	16.504	17.08	0.576
#5	25.825	25.33	0.495
#6	24.339	23.09	1.249
#7	0.612	-0.07	0.682

Table 21: Comparison of DC Branch Power

DC Branch	Branch Power [MW]		Aboslute Error [MW]
	ACDC-OpFlow	MATACDC	
#1	31.986	30.66	1.326
#2	7.281	8.52	1.239
#3	28.014	27.96	0.054

Table 22: Comparison of AC Branch Power Loss

AC Branch	Branch Loss [MW]		Aboslute Error [MW]
	ACDC-OpFlow	MATACDC	
#1	2.730	2.717	0.013
#2	1.038	1.062	0.024
#3	0.103	0.116	0.013
#4	0.169	0.181	0.012
#5	0.267	0.257	0.01
#6	0.062	0.057	0.005
#7	0.004	0.004	0

Table 23: Comparison of DC Branch Power Loss

DC Branch	Branch Loss [MW]		Aboslute Error [MW]
	ACDC-OpFlow	MATACDC	
#1	0.262	0.24	0.022
#2	0.014	0.02	0.006
#3	0.282	0.28	0.002

Table 24: Comparison of VSC Converter Loss

VSC	Converter Loss [MW]		Aboslute Error [MW]
	ACDC-OpFlow	MATACDC	
#1	1.233	1.29	0.057
#2	1.124	1.14	0.016
#3	1.147	1.17	0.023

Table 25: Comparison of Generator Active Power

Generator	Active Power Generation [MW]		Aboslute Error [MW]
	ACDC-OpFlow	MATACDC	
#1	133.547	133.64	0.093
#2	40	40	0

Table 26: Comparison of Generator Reactive Power

Generator	Reactive Power Generation [Mvar]		Aboslute Error [Mvar]
	ACDC-OpFlow	MATACDC	
#1	84.333	84.32	0.013
#2	-32.11	-32.84	0.73

To further assess its applicability to OPF problems of different scales, three additional test systems are constructed, as shown in Fig. A.2, by integrating different MATPOWER AC test cases with the same customized MTDC grid, VSC stations, and RES plants. Since the objective is to minimize the generation cost, we mainly focus on the active power outputs of the generators to evaluate the applicability of the SOCP relaxation. According to the corresponding optimization results shown in Tables 27, 28, 29, we can conclude that the accuracy of the SOCP relaxation is considered satisfactory.

Table 27: Comparison Between OPF-NLP and OPF-SOCP (MATPOWER `case9` is used as the AC grid.)

Item	**OPF-NLP**	**OPF-SOCP**	**Relative Err. (OPF-NLP is Benchmark) [%]**
Generation Cost [$]	2529.74	2518.07	0.4163
P_{G1} [MW]	43.63	43.38	0.5730
P_{G2} [MW]	77.09	76.77	0.4151
P_{G3} [MW]	54.59	54.35	0.4396




Figure A.2: Additional AC/DC test systems constructed by integrating different MATPOWER AC test cases with the consistent customized MTDC grids, VSC stations, and RES plants.

Table 28: Comparison Between OPF-NLP and OPF-SOCP (MATPOWER `case57` is used as the AC grid.)

Item	**OPF-NLP**	**OPF-SOCP**	**Relative Err. (OPF-NLP is Benchmark) [%]**
Generation Cost [$]	35724.53	35617.81	0.2987
P_{G1} [MW]	137.22	136.54	0.4956
P_{G2} [MW]	52.95	49.52	6.4778
P_{G3} [MW]	42.80	42.71	0.2103
P_{G4} [MW]	44.80	45.88	2.4107
P_{G5} [MW]	444.31	445.53	0.2746
P_{G6} [MW]	55.13	55.31	0.3265
P_{G7} [MW]	344.97	344.15	0.2377

Table 29: Comparison Between OPF-NLP and OPF-SOCP (MATPOWER `case89pegase` is used as the AC grid.)

Item	**OPF-NLP**	**OPF-SOCP**	**Relative Err. (OPF-NLP is Benchmark) [%]**
Generation Cost [$]	5674.86	5665.97	0.1567
P_{G913} [MW]	1642.30	1572.70	4.2381
P_{G2107} [MW]	1153.49	1109.22	3.8378
P_{G2267} [MW]	166.67	166.67	0.0000
P_{G3659} [MW]	666.67	666.67	0.0000
P_{G4586} [MW]	44.13	100.00	126.6128
P_{G5097} [MW]	21.23	21.23	0.0000
P_{G6233} [MW]	529.73	595.89	12.4898
P_{G6798} [MW]	333.33	333.33	0.0000
P_{G7279} [MW]	100.00	100.00	0.0000
P_{G7960} [MW]	208.66	200.13	4.0864
P_{G8605} [MW]	600.00	600.00	0.0000
P_{G9239} [MW]	208.65	200.12	4.0882

References

[1] J. Beerten, S. Cole, and R. Belmans, "Generalized steady-state vsc mtdc model for sequential ac/dc power flow algorithms," *IEEE Transactions on Power Systems*, vol. 27, no. 2, pp. 821–829, 2012.

[2] H. Ergun, J. Dave, D. Van Hertem, and F. Geth, "Optimal power flow for ac–dc grids: Formulation, convex relaxation, linear approximation, and implementation," *IEEE Transactions on Power Systems*, vol. 34, no. 4, pp. 2980–2990, 2019.

[3] D. Van Hertem, O. Gomis-Bellmunt, and J. Liang, *HVDC grids: for offshore and supergrid of the future*. John Wiley & Sons, 2016.

[4] B. Kocuk, S. S. Dey, and X. A. Sun, "Strong socp relaxations for the optimal power flow problem," *Operations Research*, vol. 64, no. 6, pp. 1177–1196, 2016.

[5] L. Gan and S. H. Low, "Optimal power flow in direct current networks," in *52nd IEEE Conference on Decision and Control*, 2013, pp. 5614–5619.

[6] M. Farivar and S. H. Low, "Branch flow model: Relaxations and convexification—part i," *IEEE Transactions on Power Systems*, vol. 28, no. 3, pp. 2554–2564, 2013.

[7] L. Gan, N. Li, U. Topcu, and S. H. Low, "Exact convex relaxation of optimal power flow in radial networks," *IEEE transactions on automatic control*, vol. 60, no. 1, pp. 72–87, 2014.