

ENTERPRISE PILOT BRIEFING

Predictive battery operations, measured before control.

Forecast consumption and PV, schedule storage every 30 minutes, and prove value in shadow mode before enabling physical dispatch.

READY FOR ENTERPRISE SHADOW PILOT

One operational layer from telemetry to a safe battery setpoint.

Operational Flow

- Timestamped consumption and PV ingestion.
- Hybrid consumption and photovoltaic forecasting.
- Net-load and tariff-aware scheduling.
- Battery capacity, power, efficiency, SoC, and reserve constraints.
- Time-limited command with safety interlocks.

Available Now

- FastAPI operational service and typed web client.
- 30-minute plans and automatic dry-run control cycles.
- Dashboard for forecast, grid, battery power, SoC, and actions.
- Backtesting, benchmark evidence, and reproducible tests.
- Adapter boundary for an authenticated inverter/BMS integration.

Production boundary: physical actuation remains disabled until the site-specific adapter, command acknowledgement, cybersecurity review, hardware-in-the-loop testing, and commissioning are accepted.

REPRODUCIBLE EVIDENCE

21,936 real observations across 15 months.

30 min

DATA CADENCE

15

CALENDAR MONTHS

90.25%

ROUND-TRIP EFFICIENCY
ASSUMPTION

Dataset period: 2010-10-01 to 2011-12-31. Tariff and degradation assumptions are documented in the evidence package.

Annualized Net Scenario Value

Pilot 60Kwh		EUR 1,085/yr
Commercial 120Kwh		EUR 1,853/yr
Commercial 240Kwh		EUR 2,182/yr

Scenario	Import reduction	Solar self-consumption	Equivalent cycles
pilot_60kwh	10,479 kWh	87.67% to 94.65%	174.7
commercial_120kwh	16,285 kWh	87.67% to 98.52%	135.7
commercial_240kwh	18,525 kWh	87.67% to 99.99%	77.2

Honest result: the current dispatch policy did not reduce the maximum monthly peak in this dataset. The measured value came from solar capture and energy shifting, not a demand-charge claim.

REFERENCE SCENARIO

120 kWh / 40 kW commercial battery.

EUR

2,321

NET VALUE OVER
BENCHMARK

16.3

MWh

GRID IMPORT REDUCTION

98.52%

OPTIMIZED SOLAR SELF-
CONSUMPTION

Included Corrections

- Continuous SoC over the full period.
- Terminal SoC value adjustment.
- EUR 0.04/kWh discharged degradation allowance.
- Charge/discharge efficiency and reserve.

Not Yet Proven by This Benchmark

- Customer-specific forecast accuracy.
- Live telemetry availability and latency.
- Hardware command success.
- Customer tariff and operational savings.

This is a dispatch-potential benchmark using historical actuals. The enterprise pilot converts potential into measured, customer-specific evidence.

Progressive risk reduction with explicit gates.

0. Qualification - 3 to 5 days

Data sample, tariff, topology, equipment, value estimate, integration gaps, go/no-go.

1. Data and Baseline - 1 to 2 weeks

Read-only ingestion, data quality, bill reconstruction, KPI freeze, baseline acceptance.

2. Shadow Operations - 4 to 6 weeks

Forecast and schedule every 30 minutes without hardware control. Measure forecast error, hypothetical value, availability, throughput, and exceptions.

3. Controlled Dispatch - 2 to 4 weeks

Authenticated adapter, restricted envelope, command acknowledgement, telemetry confirmation, fallback, emergency stop, reviewed expansion.

4. Production Decision

Accept, extend, remediate, or stop based on jointly agreed technical, safety, security, and economic gates.

Closed-loop control is an acceptance milestone, not a demo feature.

Required Controls

- TLS, workload identity, RBAC, and rotated secrets.
- Immutable schedule, command, acknowledgement, and override audit.
- Fresh telemetry and device-health validation.
- Power, SoC, reserve, time-validity, and emergency-stop interlocks.
- Local-controller fallback and tested rollback.

Current Production Blockers

- No customer-specific device adapter.
- No customer-device command acknowledgement loop.
- No production identity/authorization deployment.
- No external immutable production audit destination.
- No hardware-in-the-loop or site commissioning evidence.
- No completed customer security assessment.

These blockers do not prevent read-only integration or shadow mode. They deliberately prevent unsupported unattended physical control.

COMMERCIAL STRUCTURE

Qualify first. Price integration and fleet value, not hype.

Stage	Indicative band	Purpose
Data and value assessment	EUR 5k-10k	Baseline, opportunity, integration and go/no-go.
Shadow-mode pilot	EUR 15k-30k	Live read-only operation and measured KPI report.
Controlled hardware pilot	+ EUR 20k-50k	Adapter, security, commissioning and controlled dispatch.
Production	After pilot	Per-site, fleet, managed service, or verified-value model.

Qualification gate: expected three-year value should exceed implementation and operating cost by at least 3x, unless the buyer documents strategic fleet or resilience value.

Indicative bands are an internal scoping framework, not a public price list or binding offer.

THE ASK

Select one site and prove the value together.

Customer Provides

- 6-12 months of interval consumption and PV.
- Tariff, export compensation, and bill data.
- Battery, inverter, BMS, and meter specifications.
- Technical, cybersecurity, commercial, and site-safety owners.
- Read-only connectivity for shadow mode.

Enerwise Delivers

- Data quality and baseline report.
- Live forecast and battery schedules.
- Dashboard, evidence store, and weekly review.
- Measured technical and economic KPIs.
- Production go/no-go recommendation and rollout design.

No guaranteed savings.
Measured evidence, then control.