

# Determination of Hardness Factors for Various Proton Beams

C. Simpson-Allsop, L. Ram, K. Nikolopoulos, T. Price, I. Mateu

University of Birmingham,

October 16, 2018



# Outline

- ① Introduction
- ② Other Studies and Current Values
- ③ I-V Measurements
- ④ C-V Measurements
- ⑤ Irradiations using the MC40 Cyclotron
- ⑥ Determination of Hardness Factors
- ⑦ Conclusion and Outlook

# Introduction

Utilizing the **I–V** and **C–V** characteristics of **BPW34F photodiodes**, the **Hardness Factors**,  $\kappa$ , of three different proton beams have been measured.

- The **MC40 Cyclotron** at the **University of Birmingham** (25 MeV).
- The **IRRAD Proton Facility** at **CERN** (24 GeV).
- The **Irradiations Facility** at the **Karlsruhe Institute of Technology** (24 MeV).


For **IRRAD**, the Results were compared to a similar study undertaken by **I. Mateu** this year.

## Other Studies and Current Values

- Current MC40 cyclotron value: **2.2** for **25 MeV protons** [1].
- KIT:  **$2.05 \pm 0.61$**  for **24 MeV protons**, with a previous assumption of **1.85** for **26 MeV protons** [2].
- **Tabulated values** from RD50:  $\sim 2.56$  for **25 MeV protons** [3].
- Studies at the IRRAD facility: **0.56** (2015), and **0.60** (2016) for **24 GeV protons** [4].

# I-V Measurements


## Setup



Experimental setup for I-V measurements.

# I-V Measurements

## Setup



Aluminium shielding box.

# C–V Measurements

Current – Voltage Relation and Maximum Depletion Voltage.


- The **capacitance** of a photodiode is related to the **reverse bias** by [5]:

$$C = \frac{f\sqrt{\epsilon_S i \epsilon_0}}{\sqrt{V}}$$

- At **maximum depletion voltage**, capacitance becomes independent of voltage.
- Plotting **capacitance vs voltage** on a log plot should therefore show a straight line, with a **deviation** at maximum depletion.

# C-V Measurements

## Setup




Experimental setup for C-V measurements.

# C-V Measurements

## Calculating Maximum Depletion Voltage

- By calculating the **intersect** of the two fits, the point at which the trend deviates from a straight line could be calculated.
- Applying this method, a maximum depletion voltage value of  $V_{dep} = -90.8 \pm 5.1 \text{ V}$  was inferred.



# Proton Irradiations

## ATLAS Chamber




The isolation box within the ATLAS chamber, the box was used to cool the photodiodes to  $-27^{\circ}\text{C}$ .

# Proton Irradiations

## Mounting the Photodiodes

⊗ Beam direction.



Aluminium mount. The nickel foils were used to measure the incident fluence.

# Computing Hardness Factors

## Leakage Current Variation with Fluence

- Post irradiation, all photodiodes were annealed for 80 minutes at 60°C.
- The **change in leakage current** before and after irradiation is related to **proton fluence** by [6]:

$$\Delta I = \alpha L^2 w \phi$$


- The **hardness factor** can be written as:

$$\kappa = \frac{\alpha}{\alpha_{neq}} \quad \text{since} \quad \kappa = \frac{\phi_{neq}}{\phi}$$

Where  $\alpha_{neq} = (3.99 \pm 0.03) \times 10^{-17} \text{ Acm}^{-1}$  [6].

# Results


## Hardness Factor of the MC40 Cyclotron



From this, a value of  $\kappa_{MC40} = 2.198 \pm 0.084$  for 25 MeV protons was inferred.

# Results


## Hardness Factor of the IRRAD Proton Facility



Using the same method as for the MC40 Cyclotron, a value of  $\kappa_{IRRAD} = 0.622 \pm 0.019$  for 24 GeV protons was inferred.

# Results

## Hardness Factor of the IRRAD Proton Facility - Comparison with I. Mateu's Data




Analysis of I. Mateu's data yields a value of

$\kappa_{\text{Mateu}} = 0.616 \pm 0.017$ , which is in agreement with his own analysis (0.632) and our result.

# Results


## Hardness Factor of the IRRAD Proton Facility - Comparison with I. Mateu's Data

For Isidre's data, the maximum depletion voltage was calculated for each sensor, and so was not kept constant across all data points.



Example  $\frac{1}{C^2} - V$  curve for I. Mateu's data analysis.

# Hardness Factor of the KIT Irradiations Facility



The highest fluence point was ignored to omit the non-linearity region ( $\sim 10^{13} \text{ n}_{\text{eq}}/\text{cm}^2$  [7]). This gave a value of  $\kappa_{\text{KIT}} = 2.199 \pm 0.282$  for 24 MeV protons.

# Conclusion and Outlook

- The I-V and C-V characteristics of BPW34F photodiodes have been analysed.
- Using these characteristics, hardness factors for various proton beams have been determined.
- The results are in good agreement with other studies.
- In the future, it is suggested that studies are done to determine the current related damage rate for neutrons (This study assumed a value of  $\alpha_{neq} = (3.99 \pm 0.03) \times 10^{-17}$  Acm<sup>-1</sup> [6]), and therefore, determine independent hardness factor values.

# References I

-  T. Price. *Experimental Determination of the Hardness Factor for the Birmingham Irradiation Facility.* 30th RD50 Workshop (Krakow). June 2017. URL: <https://indico.cern.ch/event/637212/contributions/2608664/>.
-  A. Dierlamm. *Proton Irradiation in Karlsruhe.* 16th RD50 Workshop. 2010. URL: [https://indico.cern.ch/event/86625/contributions/2103519/attachments/1080676/1541436/Irradiations\\_Ka.pdf](https://indico.cern.ch/event/86625/contributions/2103519/attachments/1080676/1541436/Irradiations_Ka.pdf).
-  RD50. Mar. 2018. URL: <http://rd50.web.cern.ch/rd50/>.

## References II

-  Isidre Mateu et al. *NIEL hardness factor determination for the new proton irradiation facility at CERN*. 28th RD50 Workshop. June 2016. URL:  
<http://cds.cern.ch/record/2162852/files/AIDA-2020-SLIDE-2016-002.pdf?version=1>.
-  G. Casse. "The effect of hadron irradiation on the electrical properties of particle detectors made from various silicon materials". PhD thesis. Universite Joseph Fourier-Grenoble, 1998.
-  M. Moll. "Radiation Damage in Silicon Particle Detectors". PhD thesis. University of Hamburg, 1999.


## References III



F. Ravotti et al. "BPW34 commercial p-i-n diodes for high-level 1-MeV neutron equivalent fluence monitoring". In: *2007 9th European Conference on Radiation and Its Effects on Components and Systems*. 2007, pp. 1–8. DOI: 10.1109/RADECS.2007.5205483.

# Extra Slides

## Fluence Determination




Schematic diagram of germanium counter.

- The **irradiated nickel foils** were analyzed using a **germanium counter**.
- Due to the weak activity of the foils, they had to be placed directly on top of the counter.
- A **ratio of counts** was taken between this position and the calibrated position.
- The measured counts from the foils were then converted into **proton fluences**.

# Extra Slides

## Beam Energy Determination



Geant4 simulation revealing the incident beam energy, the energy at the nickel foils, and the energy at the sample (Courtesy of Dr. T. Price).