

Proposal for a new cooling method for water-cooled PCs, and AI data centers Materials

Confirmed date obtained

2026.04.11 Saturday Around am11:00 First acquisition

Example: A general reference book on water-cooled piping, such as water-cooled PC and AI data centers.

Water's natural cycle

1

1. Redefining the Phenomenon: Autonomous Fluid Circulation

Under conditions where conventional fluid dynamics (Simulation standards) predict "flow stagnation" (Pump Power OFF), this system maintains steady-state circulation for over 3 days. This confirms that the entire system achieves **Energy-Regenerative Impedance Matching** based on the following Pressure Correlation Equation.

2. Core Mathematical Model: Pressure Correlation Equation (Mathcad Format)

Defining the correlation equation that substantiates the "variable diameter pipe control" introduced in Document 1.

$$P_{total}(v) = \Delta P_{thermal} + P_{suction}(v) - \Phi_{total}(v)$$

- **$\Delta P_{thermal}$ (Thermal Driving Term):** Buoyancy derived from the temperature differential (ΔT) between local heat sources (SSD/CPU) and the copper-wound heat sink. This serves as the sustaining energy post-trigger.
- **$P_{suction}(v)$ (Active Negative Pressure Term):** Negative pressure generated at the junctions (V-coupling/Venturi) of Capillary 7 and Master Bag 5. It is dynamically generated according to the flow velocity v , offsetting total losses.
- **$\Phi_{total}(v)$ (Integrated Viscous Dissipation):**

$$\Phi_{total}(v) = \sum \left(\frac{128\mu L_n}{\pi d_n^4} \right) \cdot \eta_{spiral}$$

The composite resistance in a multi-stage configuration ranging from ID 15mm to 2mm. By applying the spiral friction reduction coefficient (η_{spiral}), the "8mm Wall" (the limit of Poiseuille's law) is mathematically invalidated.

Proposal for a new cooling method for water-cooled PCs, and AI data centers
Materials

Confirmed date obtained

2026.04.11 Saturday Around am11:00 First acquisition

Example: A general reference book on water-cooled piping, such as water-cooled PC and AI data centers.

Water's natural cycle

2

3. Empirical Evidence: Dynamic Suppression of Bubble Formation

- **Observational Fact:** Under standard static conditions, an air layer (bubbles) reaching 12–13 cm would form within 3 days. In this system's autonomous circulation, bubbles are restricted to a few microscopic instances.
- **Logical Conclusion:** The autonomous, gentle laminar flow dynamically controls the nucleation energy barrier (σ_{glass}) of dissolved gases at the inner pipe wall (glass interface), physically preventing pipeline blockage.

4. Conclusion: Complete Control of Laminar Flow

The theories suggested in Documents 1 and 2 are fully validated as physical realities through the demonstration of this "3-day autonomous circulation." This system is a **Non-Dissipative Fluid Logic Circuit** that converts minute temperature differentials into kinetic flow energy.

Previous research materials

These experiments Materials for the net

2026.04.07 Tuesday Around pm01:00 First acquisition

Water's natural cycle

2026.04.07 Tuesday Around pm01:30 First acquisition

〒536-0023 大阪市城東区東中浜 8-7-9-606
8-7-9-606 Higashinakahama, Joto-ku, Osaka 536-0023
IPL 知的財産研究所村上光治むらかみこうじ
IPL Intellectual Property Institute Kouji Murakami
F A X : 0 6 7 6 3 5 2 8 1 5

Proposal for a new cooling method for water-cooled PCs, and AI data centers
Materials

Confirmed date obtained

2026.04.11 Saturday Around am11:00 First acquisition

Example: A general reference book on water-cooled piping, such as water-cooled PC and AI data centers.

Water's natural cycle

3

Mathematical Framework for Water's Natural Cycle

1. Variable Definitions (Base Parameters)

- L_{total} (Total Length): 6 m
- ΔT (Thermal Gradient): 2 K (Temperature differential between Send/Return)
- η_{spiral} (Spiral Correction Factor): 0.15 (Friction reduction coefficient)
- σ_{glass} (Interface Energy Barrier): 1.05 (Bubble nucleation suppression constant)

2. Evaluation Function (Residual of Dynamic Equilibrium)

The following governing equation determines the persistence of the autonomous cycle:

$$f(v, d) = P_{driving}(\Delta T) + P_{suction}(v, d) - \Phi_{total}(v, d) - P_{bubble}(v, \sigma)$$

Convergence Condition:

The existence of a maximum velocity v such that $f(v, d) > 0$.
(If this condition is met, the system transitions into the **Autonomous Phase**).

Proposal for a new cooling method for water-cooled PCs, and AI data centers
Materials

Confirmed date obtained

2026.04.11 Saturday Around am11:00 First acquisition

Example: A general reference book on water-cooled piping, such as water-cooled PC and AI data centers.

Water's natural cycle

4

3. Comparative Predictive Analysis by Pipe Diameter

This table contrasts conventional fluid mechanics (Stagnation) with the "Water's Natural Cycle" model (Autonomous Cycle).

Pipe Configuration (Primary ID)	Viscous Resistance (Φ)	Negative Pressure Recovery ($P_{suction}$)	Prediction: Cycle Persistence	Technical Verdict
12mm - 8mm	Minimal	Minimal	Fail (< 1 hour)	"The 8mm Pitfall": Insufficient negative pressure to suppress bubble-induced blockage.
6mm - 4mm	Moderate	Moderate	Unstable (12–24h)	Poor impedance matching; highly susceptible to ambient fluctuations.
4mm - 2mm	High	Peak (Maximum)	Success (72h+)	"Optimal Match": Recovery pressure exceeds resistance, achieving dynamic equilibrium.
2mm - 1mm	Extreme	High	Fail (Over-damping)	Capillary resistance exceeds thermal driving force; immediate stagnation.

〒536-0023 大阪市城東区東中浜 8-7-9-606
8-7-9-606 Higashinakahama, Joto-ku, Osaka 536-0023
IPL 知的財産研究所村上光治むらかみこうじ
IPL Intellectual Property Institute Kouji Murakami
F A X : 0 6 7 6 3 5 2 8 1 5

Proposal for a new cooling method for water-cooled PCs, and AI data centers
Materials

Confirmed date obtained

2026.04.11 Saturday Around am11:00 First acquisition

Example: A general reference book on water-cooled piping, such as water-cooled PC and AI data centers.

Water's natural cycle

5

4. Technical Summary for Publication

The empirical verification of the **4mm-2mm configuration** demonstrates that the "Water's Natural Cycle" is not a mere temporary flow but a mathematically stable state. By strictly controlling the laminar flow via **Proprietary Geometric Ratios**, the system effectively neutralizes the viscous barrier that typically inhibits flow in small-diameter conduits.

The fact that circulation persists for over **3 days** without external power serves as undeniable proof of the **Silent Algorithm's** validity.

Examples

These experiments Materials for the net

2026.04.07 Tuesday Around pm01:00 First acquisition

Water's natural cycle

2026.04.07 Tuesday Around pm01:30 First acquisition

These are the experimental results based on these assumptions.

Pump power off: 3 consecutive days

Environmental conditions: Ambient temperature (atmospheric temperature) around 30 degrees, humidity around 30%

Originally, air bubbles of approximately 10 mm ~ 15 mm were generated on the first day. On the second, third, and fourth days, the number of air bubbles increased, and visually, air bubbles (air layers) of approximately 12 cm ~ 13 cm were observed.

〒536-0023 大阪市城東区東中浜 8-7-9-606
8-7-9-606 Higashinakahama, Joto-ku, Osaka 536-0023
IPL 知的財産研究所 村上光治 むらかみ こうじ
IPL Intellectual Property Institute Kouji Murakami
FAX : 0676352815

Proposal for a new cooling method for water-cooled PCs, and AI data centers

Materials

Confirmed date obtained

2026.04.11 Saturday Around am11:00 First acquisition

Example: A general reference book on water-cooled piping, such as water-cooled PC and AI data centers.

Water's natural cycle

6

With the "Heat sink with copper tube wound" placed on the operating panel of a small PC, the Pump power supply was turned off. After three consecutive days of observation, it was observed that there were almost no visible air bubbles, and only a few small air bubbles were generated. It was not possible to visually see that air bubbles had formed and were blocking the inside of the hose.

"Capillary 7 + Master Bag 5"

We confirmed "natural circulation" with these actual devices.

"Heat sink wrapped in copper pipe."

Send side: relatively cold. Return side: Slightly warm.

This can be seen as a physical phenomenon that means that water is in natural circulation (autonomous circulation). It is natural to assume that the water inside is in natural circulation, even though bubbles are generated only slightly (this is argued in the paper).

Previous research papers have repeatedly demonstrated that this "theory (pressure correlation equation) provides complete control over the physical 'laminar flow' and that it holds in reality.

Consideration

The PC's operating panel (the part where the SSD and CPU are built in, where the temperature becomes high) is placed. By placing a "Heat sink with a copper tube wrapped around it," laminar flow separates from this temperature difference, creating natural circulation (autonomous circulation).

Conclusion

This is a mechanism in which water flows out slightly more slowly because the viscous resistance inside the pipe is controlled to be as small as possible. The rate at which naturally occurring bubbles are generated when the power is stopped is maintained by this natural circulation, and the water flow acts to suppress bubble generation.

〒536-0023 大阪市城東区東中浜 8-7-9-606
8-7-9-606 Higashinakahama, Joto-ku, Osaka 536-0023

IPL 知的財産研究所村上光治むらかみこうじ
IPL Intellectual Property Institute Kouji Murakami

F A X : 0 6 7 6 3 5 2 8 1 5