



**NATIONAL
FIRE CODES®**

Copyright by National Fire Protection Association (NFPA). NFPA 13 is licensed, by agreement for individual use. No other reproduction or transmission in any form permitted without written permission of NFPA. For inquires or to report unauthorized use, contact licensing@nfpa.org.

32.1 * General.

A sprinkler system installed in accordance with this standard shall be inspected, tested, and maintained by the property owner or their authorized representative in accordance with NFPA 25 to ensure the system continues to provide a reasonable degree of protection for life and property from fire.